



November 7, 1989

Donald F. Schnell
Senior Vice President
Nuclear

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-137
Washington, D.C. 20555

Gentlemen:

ULNRC-2101

DOCKET NUMBER 50-483
CALLAWAY PLANT
NONCONFORMING MOLDED-CASE
CIRCUIT BREAKERS

- References:
- 1) NRC Bulletin No. 88-10, dated November 22, 1988
 - 2) ULNRC-1959, dated March 31, 1989
 - 3) NRC Bulletin No. 88-10, Supplement 1, dated August 3, 1989

Reference 1 required licensees to identify and trace to the circuit breaker manufacturer (CBM), all molded-case circuit breakers (MCCBs) stored for use in safety-related applications. Union Electric provided the results of this review to the NRC as Reference 2.

Based on a preliminary review of responses to Bulletin 88-10, the NRC staff issued Reference 3 which requested licensees to:

1. Review written reports submitted to the NRC in accordance with Bulletin 88-10 and verify that the responses meet the bulletin provisions as clarified by the bulletin supplement, and;
2. Prepare and retain documentation for possible audit that indicates that the review has been performed as requested.

Union Electric has reviewed the Bulletin 88-10 response (Reference 2) against the clarifications contained in the bulletin supplement. As a result the review of breaker traceability was expanded to include original spares purchased under the construction program which were received after August 1, 1983. The traceability of all safety-related MCCBs stored at


TE2-1
110

Callaway Plant as of September 1, 1989 was established to a Certificate of Conformance (C of C) to either the CBM or a 10CFR50, Appendix B qualified supplier. Surveillances were performed to establish traceability to the CBM in cases where the C of C was traceable to the qualified supplier.

Therefore, Union Electric has reviewed the bulletin supplement and verified that the bulletin provisions as clarified by the supplement have been met as described in this letter and in Reference 2. Documentation associated with this review is being maintained at Callaway Plant and is available for review by the NRC staff.

If you have any questions concerning this letter, please contact me.

Very truly yours,


Donald F. Schnell

WEK/kea

STATE OF MISSOURI)
) S S
CITY OF ST. LOUIS)

Donald F. Schnell, of lawful age, being first duly sworn upon oath says that he is Senior Vice President-Nuclear and an officer of Union Electric Company; that he has read the foregoing document and knows the content thereof; that he has executed the same for and on behalf of said company with full power and authority to do so; and that the facts therein stated are true and correct to the best of his knowledge, information and belief.

By *Donald F. Schnell*
Donald F. Schnell
Senior Vice President
Nuclear

SUBSCRIBED and sworn to before me this 7th day of November, 1989

Barbara J. Pfaff
BARBARA J. PFAFF
NOTARY PUBLIC, STATE OF MISSOURI
MY COMMISSION EXPIRES APRIL 22, 1993
ST. LOUIS COUNTY

cc: Gerald Charnoff, Esq.
Shaw, Pittman, Potts & Trowbridge
2300 N. Street, N.W.
Washington, D.C. 20037

Dr. J. O. Cermak
CFA, Inc.
4 Professional Drive (Suite 110)
Gaithersburg, MD 20879

R. C. Knop
Chief, Reactor Project Branch 1
U.S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Bruce Little
Callaway Resident Office
U.S. Nuclear Regulatory Commission
RR#1
Steedman, Missouri 65077

Tom Alexion (2)
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
1 White Flint, North, Mail Stop 13E21
11555 Rockville Pike
Rockville, MD 20852

Manager, Electric Department
Missouri Public Service Commission
P.O. Box 360
Jefferson City, MO 65102