



Public Service®

December 4, 1989
Fort St. Vrain
Unit No. 1
P-89468

**Public Service
Company of Colorado**
P.O. Box 840
Denver CO 80201-0840

A. Clegg Crawford
Vice President
Nuclear Operations

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555

ATTN: Seymour H. Weiss, Director
Non-Power Reactor, Decommissioning
and Environmental Project Directorate

Docket No. 50-267

SUBJECT: Supplement to Proposed Technical
Specification Change - Sections 4.7
and 5.7 - Fuel Handling and Storage

REFERENCE: PSC Letter, Crawford to Weiss,
dated September 14, 1989
(P-89344)

Dear Mr. Weiss:

In accordance with telephone conversations between Mr. Peter Erickson, Nuclear Regulatory Commission (NRC) Project Manager for Fort St. Vrain, and Mr. M. H. Holmes, Nuclear Licensing Manager for Public Service Company of Colorado (PSC), enclosed is a supplement to the Proposed Technical Specification Change submitted September 14, 1989 (Reference 1). This supplement includes a listing of page deletions and page substitutions from the previous submittal as well as the revised pages.

This supplement is being made to delete some of the changes previously requested. Please do not make the changes addressing the demonstration of a calculated $K(\text{eff})$ of less than or equal to 0.95 with all rods withdrawn. This condition is expected to be reached later in the defueling and need not be addressed at this time. Also, please do not make the change to the applicability statement of LCO 4.7.3 reading "and stored fuel element surface temperatures can exceed 750 degrees F". This change is also not required at this time.


8912140306 891204
FDR ADOCK 05000267
P PDC

A001
1/1

December 4, 1989

If you have any questions regarding this submittal, please contact Mr. M. H. Holmes at (303) 480-6960.

Sincerely,


A. Clegg Crawford
Vice President
Nuclear Operations

Enclosure

ACC/JMW/km

cc: Regional Administrator, Region IV
ATTN: Mr. T. F. Westerman, Chief
Projects Section B

Mr. Robert E. Farrell
Senior Resident Inspector
Fort St. Vrain

Robert M. Quillen, Director
Radiation Control Division
Colorado Department of Health

