



Commonwealth Edison
Dresden Nuclear Power Station
R.R. #1
Morris, Illinois 60450
Telephone 815/942-2920

May 5, 1983

DJS Ltr #83-436

James G. Keppler, Regional Director
Directorate of Regulatory Operations - Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Reportable Occurrence Report #83-27/03L-0, Docket #050-237 is being submitted to your office in accordance with Dresden Nuclear Power Station Technical Specification 6.6.P.2.(c), observed inadequacies in the implementation of administrative or procedural controls which threaten to cause reduction of degree of redundancy provided in reactor protection systems or engineered safety feature systems.

D.J. Scott
Station Superintendent
Dresden Nuclear Power Station

DJS/kjl

Enclosure

cc: Director of Inspection & Enforcement
Director of Management Information & Program Control
U.S. NRC, Document Management Branch
File/NRC

8305170159 830505
PDR ADOCK 05000237
S PDR

MAY 9 1983

IER2



Commonwealth Edison

DEVIATION REPORT

DVR NO. 12 - 2 - 83 - 59
STA UNIT YEAR NO.

PART 1 TITLE OF DEVIATION Local Leak Rate Test Failure
Due to Foreign Substance on Valves OCCURRED 4-8-83 0800
DATE TIME

SYSTEM AFFECTED 1600 PLANT STATUS AT TIME OF EVENT TESTING
Primary Containment MODE Shutdown, PWR(MWT) 0, LOAD(MWE) 0 YES NO

DESCRIPTION OF EVENT While performing an inspection of valves A0-2-203-1B, 1C, and 1D,
A0-2-1601-61 and 2-220-58A and 58B, a foreign substance was discovered on each
valve seat and disc. Local leak rate tests (LLRT) were performed on each valve
after foreign substance was removed. Valves A0-2-203-1C, 1D, 1601-61 and
2-220-58B failed LLRT.

26776, 27096, 27098, 27057, 27055, and 27056 10 CFR50.72 NRC RED PHONE NOTIFICATION MADE YES NO

EQUIPMENT FAILURE See Above WORK REQUEST NO. RESPONSIBLE SUPERVISOR Rob Stachnick DATE 4-15-83

PART 2 OPERATING ENGINEER'S COMMENTS None

EVENT OF PUBLIC INTEREST
TECH. SPEC. VIOLATION
NON REPORTABLE OCCURRENCE
14 DAY REPORTABLE/T.S.
30 DAY REPORTABLE/T.S. 6, 6, B, 2, C
ANNUAL/SPECL REPORT REQ'D
24-HOUR NRC NOTIFICATION REQ'D
TELEPH N/A REG. ON III DATE TIME
TELEGM/TELECOPY N/A REGION III DATE TIME
CECO CORPORATE NOTIFICATION MADE IF ABOVE NOTIFICATION IS PER 10CFR21
5-DAY WRITTEN REPORT REQ'D PER 10CFR21
Telecopy Dennis P. Galle 4-15-83 1320
CECO CORPORATE OFFICER DATE TIME

PRELIMINARY REPORT COMPLETED AND REVIEWED John M. Almer 4-15-83
OPERATING ENGINEER DATE

INVESTIGATED REPORT & RESOLUTION ACCEPTED BY STATION REVIEW J. Almer for J.P.B. M. Almer 5/6/83

RESOLUTION APPROVED AND AUTHORIZED FOR DISTRIBUTION Douglas Scott 5/4/83
STATION SUPERINTENDENT DATE