

Georgia Power Company
Post Office Box 439
Baxley, Georgia 31513
Telephone 912 367-7781
912 537-9444

USNRC REGION II
ATLANTA GEORGIA
Georgia Power
89 SEP 1 48:07

Edwin I. Hatch Nuclear Plant


PM-83-715
July 27, 1983

PLANT E. I. HATCH
Special Report
50-366

United States Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II
Suite 3100
101 Marietta Street
Atlanta, Georgia 30303

ATTENTION: Mr. James P. O'Reilly

Pursuant to Section 6.9.2 and 3.5.1 action: c. of Hatch Unit 2
Technical Specifications, please find attached Special Report.


H. C. Nix
General Manager

HCN/SXB/fp

xc: G. F. Head
J. T. Beckham, Jr.
T. V. Greene
C. T. Jones
R. Rogers
S. X. Baxley
Control Room
File M-58
Document Control
J. A. Betsill

8309070028 830727
PDR ADOCK 05000366
S PDR

OFFICIAL COPY

1122

111

Special Report
Georgia Power Company
Plant E. I. Hatch
Docket No. 50-366

HPCI INJECTION INTO REACTOR

On 7-22-83 at 14:47, HPCI auto initiated and injected into the reactor to restore and maintain level following a loss of feedwater transient. The transient was initiated when RFPT 2B tripped for unknown reasons. RFPT 2A was out of service due to an insulation fire earlier in the day.

As of the date of this report, there have been twenty-five (25) incidents with HPCI injection into the reactor vessel.