

Duke Power Company
P.O. Box 33188
Charlotte, N.C. 28224

Hal B. Tucker
Vice President
Nuclear Production
(704)373-4531



DUKE POWER

June 13, 1990

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Subject: Catawba Nuclear Station, Units 1 and 2
Docket Nos. 50-413 and 50-414
Proposed Technical Specification Amendment Withdrawal
Technical Specification 4.6.1.8

Gentlemen:

My letter dated April 23, 1990 submitted a proposed amendment to Technical Specification 4.6.1.8. This proposed amendment required that the laboratory test of the carbon samples from the Annulus Ventilation System be listed at 95% relative humidity and 30°C, for a methyl iodide penetration of 0.71%.

Upon further review, Duke Power has determined that this change is not necessary, and is withdrawing the proposed amendment described above.

Very truly yours,

A handwritten signature in cursive script that reads 'Hal B. Tucker'.

Hal B. Tucker

MHH/45/lcs

9006200286 900613
PDR ADLOCK 05000413
PDC

F001
1/0

U. S. Nuclear Regulatory Commission

June 13, 1990

Page 2

xc: Mr. S. D. Ebnetter, Acting Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Mr. Heyward Shealy, Chief
Bureau of Radiological Health
South Carolina Department of Health &
Environmental Control
2600 Bull Street
Columbia, South Carolina 29201

American Nuclear Insurers
Dottie Sherman, ANI Library
The Exchange, Suite 245
270 Farmington Avenue
Farmington, CT 06032

M & M Nuclear Consultants
1221 Avenue of the Americas
New York, New York 10020

INPO Records Center
Suite 1500
1100 Circle 75 Parkway
Atlanta, Georgia 30339

Mr. W. T. Orders
NRC Resident Inspector
Catawba Nuclear Station

Dr. K. N. Jabbour
Office of Nuclear Regulation
U. S. Nuclear Regulatory Commission
One White Flint North
Mail Stop 14H25
Washington, D.C. 20555