

# Duquesne Light Company

Beaver Valley Power Station  
PO Box 4  
Shippingport, PA 15077-0004

JOHN D. SIEBER  
Vice President - Nuclear Group

(412) 393-6266

June 14, 1990

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

Reference: Beaver Valley Power Station, Unit No. 1 and No. 2  
BV-1 Docket No. 50-334, License No. DPR-66  
BV-2 Docket No. 50-412, License No. NPF-73  
Proposed Operating License Change Request No. 179/42  
(TAC Nos. 76891 and 76892)

Gentlemen:


Enclosed are:

1. An Application for Amendment to the above operating licenses to revise the Electrical Power System Shutdown, the A.C. Distribution - Shutdown, and the D.C. Distribution - Shutdown Specifications to more closely resemble the wording contained in the Standard Technical Specifications. This proposed change includes the addition of the requirement that an operable 120 volt A.C. Vital Bus must be energized from an inverter connected to a D.C. Bus. The Applicability Statements would be revised to include the period when all fuel is removed from the reactor vessel and movement of irradiated fuel or movement of loads over irradiated fuel is occurring.

This proposed change was reviewed by the OSC and ORC and determined to be safe and does not involve an unreviewed safety question.

2. Documents designated Attachments A, B and C which set forth the change in the Technical Specifications, the safety analysis and the no significant hazards evaluation.

Very truly yours,

  
J. D. Sieber  
Vice President  
Nuclear Group

cc: Mr. J. Beall, Sr. Resident Inspector  
Mr. T. T. Martin, NRC Region I Administrator  
Mr. A. W. DeAgazio, Project Manager  
Mr. R. Saunders (VEPCO)

9006210001 900614  
PDR ADOCK 05000334  
P FDC

*Adol*  
11/1