

REACTOR VESSEL MATERIAL SURVEILLANCE PROGRAM WITHDRAWAL SCHEDULE

TABLE 4.4.6.1.3-1

<u>SPECIMEN HOLDER</u>	<u>VESSEL LOCATION</u>	<u>LEAD FACTOR</u>	<u>WITHDRAWAL TIME (EFPY)</u>
117C4936G010	300°	0.6	10
117C4936G011	120°	0.6	30
117C4936G012	30°	0.6	Spare
Neutron Dusimeter	30°		1st Refuel Outage

3850N