



Commonwealth Edison

DEVIATION REPORT

DVR NO. 12 - 2 - 82 - 16
STA UNIT YEAR NO.

PART 1 TITLE OF DEVIATION Failure to Take Unit 2 and 3 Battery Pilot Cell Voltages OCCURRED 3/25/82 1200
DATE TIME

EM AFFECTED 8300 PLANT STATUS AT TIME OF EVENT 2500 (2) 800 (2) TESTING
DC Systems MODE U-2 Run U-3 S/D PWR(MWT) 0 (3) LOAD(MWE) 0 (3) YES NO

DESCRIPTION OF EVENT Pilot cell voltage readings were not taken for the Unit 2 or Unit 3 24/48 VDC, 125 VDC or 250 VDC batteries as required by Tech. Spec. Surveillance Requirement 4.9.B.1.

EQUIPMENT FAILURE 10 CFR50.72 NRC RED PHONE NOTIFICATION MADE YES NO
Michael Wright DATE 3/25/82

PART 2 OPERATING ENGINEER'S COMMENTS A notation was made on the surveillance procedure stating that the fluke voltmeter used for voltage reading was broken. This event will be reviewed with the shift supervisors to prevent recurrence.

EVENT OF PUBLIC INTEREST TECH. SPEC. VIOLATION NON REPORTABLE OCCURRENCE 14 DAY REPORTABLE/T.S. 30 DAY REPORTABLE/T.S. 6.6.B.2.c. ANNUAL/SPECL REPORT REQ'D
24-HOUR NRC NOTIFICATION REQ'D TELEPH Tom Tongue (courtesy) 3/25/82 1300 REGION III DATE TIME
TELEGM/TELECOPY REGION III DATE TIME
CECO CORPORATE NOTIFICATION MADE IF ABOVE NOTIFICATION IS PER 10CFR21
5-DAY WRITTEN REPORT REQ'D PER 10CFR21
TELEPH F. A. Palmer 3/25/82 1457 CECO CORPORATE OFFICER DATE TIME

PRELIMINARY REPORT COMPLETED AND REVIEWED Michael Wright 3/25/82 OPERATING ENGINEER DATE

INVESTIGATED REPORT & RESOLUTION ACCEPTED BY STATION REVIEW Jack Brunner 4/22/82 Michael Wright 4-22-82

RESOLUTION APPROVED AND AUTHORIZED FOR DISTRIBUTION Douglas Scott 4/22/82 STATION SUPERINTENDENT DATE
8205180-574 I E 22 11