NRC FORM 366 (7-77)

U.S. NUCLEAR REGULATORY COMMISSION

Unit 2

LICENSEE EVENT REPORT

Report No. 82-08-01X-1

CONTROL BLOCK: | | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | P A P B S 2 (2) | 0 0 - 0 0 0 0 0 0 0 0 (3) | 4 1 1 1 1 (4) | | (5)
LICENSEE CODE | LICENSE NUMBER | LICENSE TYPE | CAT

CON'T 01 | REPORT SOURCE L (6) | 0 5 0 - 0 2 7 7 (7) | 0 3 2 8 8 2 (8) | 0 4 1 5 8 2 (9)
DOCKET NUMBER | EVENT DATE | REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 With Unit 2 in refuel mode and Unit 3 at full power, problems with aux
03 boilers resulted in operating one boiler on #2 diesel fuel instead of #6
04 fuel oil. Diesel fuel tank inventory decreased below Tech Spec limit of
05 104,000 gallons by approximately 3,000 gallons. Fuel level was below
06 limit for maximum of 12 hours. Additional fuel was available in Unit 1
07 diesel fuel oil storage tank and 18,000 gallons of diesel fuel were
08 delivered within nine hours after identification of problem.

	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
09	E E (11)	A (12)	B (13)	Z Z Z Z Z Z (14)	Z (15)	Z (16)

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	8 2	—	0 0 8	/	0 1	X	—	1

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
X (18)	Z (19)	Z (20)	Z (21)	0 0 0 0	Y (23)	N (24)	Z (25)	Z Z Z Z (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Diesel fuel tank inventory was not properly monitored during period when
11 auxiliary boiler was using diesel fuel oil. Steps were immediately taken
12 to obtain additional oil deliveries. Aux boiler fuel oil supply was
13 transferred to #6 oil within 7 hours. Data sheet was added to ST 9.1 to
14 calculate inventory once per day and to reorder at 122,000 gallons.

	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
15	H (28)	0 0 0 (29)	U/3-Full Power	A (31)	Operator Observation

	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
16	Z (33)	Z (34)	N/A	N/A

PERSONNEL EXPOSURES

	NUMBER	TYPE	DESCRIPTION (39)
17	0 0 0 (37)	(38)	N/A

PERSONNEL INJURIES

	NUMBER	DESCRIPTION (41)
18	0 0 0 (40)	N/A

LOSS OF OR DAMAGE TO FACILITY (43)

	TYPE	DESCRIPTION
19	Z (42)	N/A

PUBLICITY

	ISSUED	DESCRIPTION (45)	NRC USE ONLY
20	N (44)	N/A	

8204260 122

NAME OF PREPARER M. J. Cooney PHONE (215) 841-5020