

Duke Power Company
P.O. Box 33198
Charlotte, N.C. 28242

Hal B. Tucker
Vice President
Nuclear Production
(704)373-4531



DUKE POWER

June 29, 1990

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Subject: Catawba Nuclear Station, Units 1 and 2
Docket Nos. 50-413 and 50-414
NRC Inspection Report Nos. 50-413 and 50-414/89-13
Supplemental Response to Violation 50-413/89-13-04

Gentlemen:

In my July 27, 1989 response to Violation 50-413/89-13-04 (Example 5), concerning Crisis Management Center (CMC) drawings not reflecting current "As Built" station conditions, I committed to revise the existing drawing control program to provide essential "As Built" drawings in the CMC. I also committed to provide training for personnel responsible for implementation of this program. These corrective actions were to be completed by July 1, 1990.

Revisions to the drawing control program have been made to provide essential drawings for the CMC that reflect completed and partially completed station modifications. Drawings used at the CMC include flow diagrams, electrical elementaries and one-line electrical drawings. Personnel responsible for maintaining CMC drawings have been trained.

Based upon further review of this issue, I believe the previous CMC drawings were appropriate to the circumstances. CMC personnel do not directly supervise reactor operations nor the manipulation of controls. When supporting the station, the CMC communicates directly with station personnel who have access to the appropriate "As Built" drawings.

9007060294 900629
PDR ADOCK 05000413
D FDC

IKD
1/0


U. S. Nuclear Regulatory Commission

June 29, 1990

Page 2

During the next twelve months, Duke Power will continue to evaluate the benefits of the changes made to the CMC drawing control program and decide if continued implementation is warranted.

Very truly yours,



Hal B. Tucker

WRC/166/lcs

xc: Mr. Stewart D. Ebnetter
Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Mr. W. T. Orders
NRC Resident Inspector
Catawba Nuclear Station