

BEFORE THE UNITED STATES  
NUCLEAR REGULATORY COMMISSION

In the matter of )  
NEW YORK POWER AUTHORITY ) Docket No. 50-333  
James A. FitzPatrick Nuclear Power Plant )


APPLICATION FOR AMENDMENT TO OPERATING LICENSE

The New York Power Authority requests an amendment to the Technical Specifications contained in Appendix A to Facility Operating License DPR-59 for the James A. FitzPatrick Nuclear Power Plant. This application is filed in accordance with Section 10 CFR 50.90 of the Nuclear Regulatory Commission's regulations.

This application proposes to eliminate the reactor scram and Main Steam Line Isolation Valve closure requirements associated with the Main Steam Line Radiation Monitors. The proposed changes conform with NRC approved Licensing Topical Report NEDO-31400.


The proposed change to the Technical Specifications is Attachment I to this Application for Amendment to the Operating License. The Safety Evaluation for the proposed change is included as Attachment II. A markup of the affected Technical Specification pages are provided in Attachment III.

New York Power Authority

  
Ralph E. Beedle  
Executive Vice President  
Nuclear Generation

STATE OF NEW YORK  
COUNTY OF WESTCHESTER

Subscribed and sworn to before me  
this 15 day of July 1993.

  
Notary Public

KATHLEEN M. FITZGERALD  
Notary Public, State of New York  
No 4990017  
Qualified in Westchester County  
Commission Expires Dec. 23, 1993

9307220055 930715  
PDR ADOCK 05000333  
P PDR