



Commonwealth Edison


Dresden Nuclear Power Station
R.R. #1
Morris, Illinois 60450
Telephone 815/942-2920

July 21, 1982

DJS LTR: #82/806

James G. Keppler, Regional Administrator
Directorate of Regulatory Operations Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Reportable Occurrence Report #82-25/03L-0, Docket #050-237 is being submitted to your office in accordance with Dresden Nuclear Power Station Technical Specification 6.6.B.2.(b), conditions leading to operation in a degraded mode permitted by a limiting condition for operation or plant shutdown required by a limiting condition for operation.


D. J. Scott
Station Superintendent
Dresden Nuclear Power Station

DJS:mb

Enclosure

cc: Director of Inspection & Enforcement
Director of Management Information & Program Control
U. S. NRC, Document Management Branch
File/NRC



Commonwealth Edison

DEVIATION REPORT

DVR NO. 12 STA 2 UNTT 82 YEAR 41 NO.

PART 1 TITLE OF DEVIATION LPCI Suction Valve (MO2-1501-5D) Failure To Open OCCURRED 7/1/82 1915 DATE TIME

SYSTEM AFFECTED 1500 LPCI PLANT STATUS AT TIME OF EVENT MODE RUN, PWR(MWT) 2330, LOAD(MWE) 761 TESTING YES NO

DESCRIPTION OF EVENT During LPCI Valve Operability Testing, LPCI suction valve MO2-1501-5D failed to reopen following closure. Breaker racked out and racked back in. Valve manually moved off seat and electrically would still not open. Manually reopened suction valve and EM's notified to investigate.

10 CFR50.72 NRC RED PHONE NOTIFICATION MADE YES NO

EQUIPMENT FAILURE D21387 WORK REQUEST NO. RESPONSIBLE SUPERVISOR Bob Herbert DATE 7/1/82

PART 2 OPERATING ENGINEER'S COMMENTS

Electricians cleaned aux. contacts in breaker, and valve operated properly.

EVENT OF PUBLIC INTEREST, TECH. SPEC. VIOLATION, NON REPORTABLE OCCURRENCE, 14 DAY REPORTABLE/T.S., 30 DAY REPORTABLE/T.S. 6.6.B.2.b, ANNUAL/SPECL REPORT REQ'D, 24-HOUR NRC NOTIFICATION REQ'D, TELEPH N/A, TELEGM/TELECOPY N/A, CECO CORPORATE NOTIFICATION MADE, 5-DAY WRITTEN REPORT REQ'D PER 10CFR21, TELEPH F. A. Palmer, CECO CORPORATE OFFICER, 7/2/82 1543 DATE TIME

PRELIMINARY REPORT COMPLETED AND REVIEWED John M. Almer OPERATING ENGINEER 7/2/82 DATE

INVESTIGATED REPORT & RESOLUTION ACCEPTED BY STATION REVIEW J Brunner 7/29/82 John M. Almer 7/29/82

RESOLUTION APPROVED AND AUTHORIZED FOR DISTRIBUTION E.W. Pagan Jr STATION SUPERINTENDENT 7/29/82 DATE