



Commonwealth Edison

Dresden Nuclear Power Station
R.R. #1
Morris, Illinois 60450
Telephone 815/942-2920

June 29, 1982

DJS Ltr. #82-728

James G. Keppler, Regional Administrator
Directorate of Regulatory Operations - Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Reportable Occurrence Report #82-20/03L-0, Docket #050-237 is being submitted to your office in accordance with Dresden Nuclear Power Station Technical Specification 6.6.B.2.(d), abnormal degradation of systems other than those specified in item B.l.e. above designed to contain radioactive material resulting from the fission process.

D. J. Scott
Station Superintendent
Dresden Nuclear Power Station

DJS/nh

Enclosure

cc/ Director of Inspection & Enforcement
Director of Management Information & Program Control
U.S. NRC, Document Management Branch
File/NRC

8207130342 820629
PDR ADOCK 05000237
S PDR

JUL 6 1982
IE 22



Commonwealth Edison

DEVIATION REPORT

DVR NO. 12 - 2 - 82 - 35
STA UNIT YEAR NO.

PART 1 TITLE OF DEVIATION 2/3 Radwaste Concentrated Waste Spill
OCCURRED 6/9/82 0500
DATE TIME

SYSTEM AFFECTED 2000 PLANT STATUS AT TIME OF EVENT
Radwaste MODE Run, PWR(MWT) 2465, LOAD(MWE) 783 TESTING YES NO

DESCRIPTION OF EVENT During the process of dumping "B" Max Recycle Concentrator for a concentrated waste sample, the A.O. dump valve for "B" Concentrator developed a leak. Upon further investigation, it was found to be a bad diaphragm on A.O. Dump Valve 2/3-2012-217B. One to two hundred gallons of concentrated waste were spilled on the first floor of the Max Recycle Building.

EQUIPMENT FAILURE D 21030
10 CFR50.72 NRC RED PHONE NOTIFICATION MADE YES NO
RESponsible SUPERVISOR Edward F. Iddings DATE 6/9/82

PART 2 OPERATING ENGINEER'S COMMENTS Operations and Technical Staff are investigating the possibility of using an upgraded type of diaphragm. There was no release of radioactive material to the environs and all of the evaporator bottoms were contained within the Max Recycle Building.

EVENT OF PUBLIC INTEREST
TECH. SPEC. VIOLATION
NON REPORTABLE OCCURRENCE
14 DAY REPORTABLE/T.S.
30 DAY REPORTABLE/T.S. 6.6.B.2.d
ANNUAL/SPECL REPORT REQ'D
24-HOUR NRC NOTIFICATION REQ'D
TELEPH REGION III DATE TIME
TELEGM/TELECOPY REGION III DATE TIME
CECO CORPORATE NOTIFICATION MADE IF ABOVE NOTIFICATION IS PER 10CFR21
5-DAY WRITTEN REPORT REQ'D PER 10CFR21
F. A. Palmer 6/11/82 0740
TELEPH CECO CORPORATE OFFICER DATE TIME

PRELIMINARY REPORT COMPLETED AND REVIEWED D. E. Sharper 6/9/82
OPERATING ENGINEER DATE

INVESTIGATED REPORT & RESOLUTION ACCEPTED BY STATION REVIEW
J. Brunner 7/1/82
John M. Almon 7/2/82

RESOLUTION APPROVED AND AUTHORIZED FOR DISTRIBUTION
Douglas P. West 7/2/82
STATION SUPERINTENDENT DATE