



A Centeror Energy Company

DONALD C. SHELTON
Vice President - Nuclear
(419) 249-2300

Docket Number 50-346

License Number NPF-3

Serial Number 1-927

August 9, 1990

United States Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

Subject: Supplemental Response to Inspection Report Number 50-346/89021

Gentlemen:

Toledo Edison (TE) received Inspection Report Number 89021 (Log Number 1-2195) and provided its response to a Notice of Violation identified in the inspection report (Violation 89021-01) concerning pressure testing performed at Davis-Besse Nuclear Power Station (DBNPS) in lieu of ASME Code required hydrostatic pressure testing. In the response, dated February 6, 1990 (Serial Number 1-908), Toledo Edison denied the alleged violation.

On July 31, 1990, members of the Toledo Edison staff met with the NRC staff at the Region III office to discuss issues relating to the alleged violation. Based upon these discussions, Toledo Edison hereby rescinds its denial and accepts the alleged violation.

On July 17, 1990, Toledo Edison submitted a request for relief from the requirements of Section XI of the ASME Code concerning hydrostatic testing requirements (Serial Number 1829). Relief from the requirements of IWA-5212 and IWA-5213 for certain systems where the IIT was used during the first ten-year in-service inspection (ISI) interval was requested. Also, by letter dated July 17, 1990 (Serial Number 1823), Toledo Edison proposed to perform hydrostatic tests, in accordance with the ASME Code, on affected systems during the first period of the second ten-year ISI interval. The second ten-year ISI interval begins on September 21, 1990. Therefore, based on the above submittals, no further corrective actions are necessary.

9008160161 900809
PDR ADOCK 03000346
Q PDC

TEOL
1/0

Docket Number 50-346


License Number NPF-3

Serial Number 1-927

Page 2

Should you require any additional information concerning this matter, please contact Mr. R. W. Schrauder, Manager - Nuclear Licensing, at (419) 249-2366.

Very truly yours,



RKP/mmb

cc: P. M. Byron, DB-1 NRC Senior Resident Inspector
A. B. Davis, Regional Administrator, NRC Region III
M. D. Lynch, DB-1 NRC Senior Project Manager
Utility Radiological Safety Board of Ohio