



February 23, 1994

2CAN029407

U. S. Nuclear Regulatory Commission
Document Control Desk
Mail Station P1-137
Washington, DC 20555

Subject: Arkansas Nuclear One - Unit 2
Docket No. 50-368
License No. NPF-6
1993 Annual Report Of Steam Generator Tube Inservice Inspections

Gentlemen:

The Arkansas Nuclear One, Unit 2 (ANO-2) Technical Specifications 4.4.5.5.b and 6.9.1.5.b require that complete results of all ANO-2 steam generator tube inservice inspections (ISI) performed during the report period be submitted to the NRC on an annual basis. Except for the inspection of two tubes which were not examined during the last refueling outage conducted in 1992 (2R9), no inservice inspections of the steam generators were conducted in 1993. However, a non-ISI inspection of the steam generator tubes was conducted during our 1993 planned outage (2P93-1). Results of this non-ISI inspection were voluntarily transmitted by letter dated June 17, 1993 (2CAN069302).

ANO-2 Technical Specification Amendment 143, dated February 23, 1993 (2CNA029302), added a note to Table 4.4-2 of the Technical Specifications granting a one time exemption to the C-3 inspection requirements for the 2R9 inspection of "B" steam generator tubes 38-66 and 37-67 for the period of November 27, 1992, through May 30, 1993. Inspection of these two tubes was not completed as part of the 100% C-3 sample inspection performed during 2R9 (see Entergy Operations letter dated November 27, 1992 (2CAN119205)). The inservice inspection of these tubes was completed in conjunction with the non-ISI examinations conducted during 2P93-1. No indications were identified in these tubes as a result of this inspection.


This submittal completes the reporting requirements of ANO-2 Technical Specifications 4.4.5.5.b and 6.9.1.5.b for 1993. Should you have any questions regarding this issue, please contact me.

170037

9403170201 940223
PDR ADOCK 0500036B
R PDR

ACT 7/10

Very truly yours,


Dwight C. Mims
Director, Licensing

DCM/jjd

cc: Mr. Leonard J. Callan
Regional Administrator
U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

NRC Senior Resident Inspector
Arkansas Nuclear One - ANO-1 & 2
Number 1, Nuclear Plant Road
Russellville, AR 72801

Mr. George Kalman
NRR Project Manager Region IV/ANO-1
U. S. Nuclear Regulatory Commission
NRR Mail Stop 13-H-3
One White Flint North
11555 Rockville Pike
Rockville, MD 20852

Mr. Thomas W. Alexion
NRR Project Manager, Region IV/ANO-2
U. S. Nuclear Regulatory Commission
NRR Mail Stop 13-H-3
One White Flint North
11555 Rockville Pike
Rockville, MD 20852