



**ENTERGY**

Entergy Operations, Inc.

Route 3 Box 137G

Russellville, AR 72801

Tel 501-964-8888

**Jerry W. Yelverton**

Vice President

Operations ANO

June 22, 1994

ICAN069401

U. S. Nuclear Regulatory Commission  
Document Control Desk  
Mail Station P1-137  
Washington, DC 20555

Subject: Arkansas Nuclear One - Unit 1  
Docket No. 50-313  
License No. DPR-51  
Technical Specification Change Request Concerning The Arkansas  
Nuclear One - Unit 1 Emergency Feedwater System

Gentlemen:

Attached for your review and approval are proposed Technical Specification (TS) changes revising the Limiting Conditions For Operation, Surveillance Requirements, and Bases for the Arkansas Nuclear One - Unit 1 (ANO-1) Emergency Feedwater (EFW) System. The proposed changes extend the allowable outage time for one inoperable train of EFW from 36 hours to 72 hours, clarify the specifications and their associated Bases, and relocate information to more appropriate sections. The changes are in accordance with the requirements for EFW set forth in NUREG 1430 "Restructured Standard Technical Specifications for B & W Plants" Revision 0 issued September 1992, and have been modified to correspond to the existing ANO-1 TS format and plant specific construction.

The proposed changes have been evaluated in accordance with 10CFR50.91(a)(1) using criteria in 10CFR50.92(c) and it has been determined that these changes involve no significant hazards considerations. The bases for this determination are included in the attached submittal.

Entergy Operations requests that the effective date for this change be within 30 days following NRC approval to allow sufficient time to implement procedure revisions required as a result of the amendment. Although this request is neither exigent nor emergency, your prompt review is requested.

000000

9406280172 940622  
PDR ADOCK 05000313  
P PDR

*Aool*  
*11*

Very truly yours,

*Jerry W. Yelverton*

JWY/cws  
Attachments

To the best of my knowledge and belief, the statements contained in this submittal are true.

SUBSCRIBED AND SWORN TO before me, a Notary Public in and for Logan  
County and the State of Arkansas, this 22nd day of June, 1994.

*Sandy Sichenmorgen*  
Notary Public  
My Commission Expires May 11, 2000

cc: Mr. Leonard J. Callan  
Regional Administrator  
U. S. Nuclear Regulatory Commission  
Region IV  
611 Ryan Plaza Drive, Suite 400  
Arlington, TX 76011-8064

NRC Senior Resident Inspector  
Arkansas Nuclear One - ANO-1 & 2  
Number 1, Nuclear Plant Road  
Russellville, AR 72801

Mr. George Kalman  
NRR Project Manager Region IV/ANO-1 & 2  
U. S. Nuclear Regulatory Commission  
NRR Mail Stop 13-H-3  
One White Flint North  
11555 Rockville Pike  
Rockville, MD 20852

Ms. Greta Dicus  
Arkansas Department of Health  
Division of Radiation Control  
and Emergency Management  
4815 West Markham Street  
Little Rock, AR 72205