



July 15, 1994

2CAN079403

U. S. Nuclear Regulatory Commission
Document Control Desk
Mail Station P1-137
Washington, DC 20555

Subject: Arkansas Nuclear One - Unit 2
Docket No. 50-368
License No. NPF-6
Inservice Inspection Outage Summary Report

Gentlemen:

Article IWA-6230 in Section XI of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code requires the Owner to submit an inservice inspection (ISI) summary report within 90 days of the completion of the ISI conducted during a refueling outage. As the operator for Arkansas Nuclear One, Unit 2 (ANO-2), Entergy Operations is submitting this report on behalf of the Owner, Arkansas Power & Light Company (AP&L). The scope of the report is to provide the inspection results of the Class 1 and 2 pressure retaining components and their supports.

Included in the attached report are the Form NIS-1 "Owner's Report for Inservice Inspections" and a summary of the ISI component examinations. The ISI was performed before and during the tenth refueling outage (2R10) for ANO-2. The outage was completed on April 24, 1994. This form was prepared in accordance with the 1989 Edition of Section XI of the Code.

The NIS-2 forms, "Owner's Report for Repairs and Replacements" are included in the attachment and address repairs and/or replacements since the completion of the ninth refueling outage (2R9), October 20, 1992, through the completion of 2R10. Six NIS-2 forms that were not included in the 2R9 ISI Outage Summary Report dated January 18, 1993 (2CAN019302), are also attached.


200000

9407200317 940715
PDR ADOCK 05000368
PDR

A047
1/1

Should you have any questions regarding this submittal, please contact me.

Very truly yours,



Dwight C. Mims
Director, Licensing

DCM/jjd

Attachments

cc: Mr. Leonard J. Callan
Regional Administrator
U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

NRC Senior Resident Inspector
Arkansas Nuclear One - ANO-1 & 2
Number 1, Nuclear Plant Road
Russellville, AR 72801

Mr. George Kalman
NRR Project Manager Region IV/ANO-1 & 2
U. S. Nuclear Regulatory Commission
NRR Mail Stop 13-H-3
One White Flint North
11555 Rockville Pike
Rockville, MD 20852