



**Commonwealth Edison**

Dresden Nuclear Power Station

R.R. #1

Morris, Illinois 60450

Telephone 815/942-2920

March 24, 1983

DJS Ltr. # 83-317

James G. Keeper, Regional Administrator  
Region III  
U.S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, IL 60137

Reportable Occurrence Report #83-16/03L-0, Docket #050-237 is being submitted to your office in accordance with Dresden Nuclear Power Station Technical Specification 6.6.B.2(b), conditions leading to operation in a degraded mode permitted by a limiting condition for operation or plant shutdown required by a limiting condition for operation.

D.J. Scott  
Station Superintendent  
Dresden Nuclear Power Station

DJS/jmt

Enclosure

cc: Director of Inspection & Enforcement  
Director of Management Information & Program Control  
U.S. NRC, Document Management Branch  
File/NRC



Commonwealth Edison

DEVIATION REPORT

DVR NO. 12 - 2 - 83 - 30  
STA UNIT YEAR NO.

PART 1 TITLE OF DEVIATION  
Pipe Brackets For Snubbers 43 and 52 Are Loose  
OCCURRED 2-24-83 1400  
DATE TIME

SYSTEM AFFECTED 203 PLANT STATUS AT TIME OF EVENT TESTING  
D-Main Steam Line MODE Refuel, PWR(MWT) 0, LOAD(MWE) 0 YES NO

DESCRIPTION OF EVENT  
While stroke testing snubbers 43 and 52 in the D2 Drywell, the snubber to pipe brackets were found to be loose (nuts were only hand tight)

10 CFR50.72 NRC RED PHONE NOTIFICATION MADE YES NO

EQUIPMENT FAILURE 26169 WORK REQUEST NO. RESPONSIBLE SUPERVISOR Donald C. Maxwell DATE 2-28-83

PART 2 OPERATING ENGINEER'S COMMENTS  
Unit 2 is shutdown for refueling, and no fuel was in the reactor vessel.

EVENT OF PUBLIC INTEREST  
TECH. SPEC. VIOLATION  
NON REPORTABLE OCCURRENCE  
14 DAY REPORTABLE/T.S.  
30 DAY REPORTABLE/T.S. 6.6.B.2.b  
ANNUAL/SPECL REPORT REQ'D  
24-HOUR NRC NOTIFICATION REQ'D  
TELEPH NA REGION III DATE TIME  
TELEGM/TELECOPY NA REGION III DATE TIME  
CECO CORPORATE NOTIFICATION MADE IF ABOVE NOTIFICATION IS PER 10CFR21  
5-DAY WRITTEN REPORT REQ'D PER 10CFR21  
A.I.R. #  
L.E.R. # 83-16/03L-0  
Telecopy D. P. Galle 2-28-83 15:15  
CECO CORPORATE OFFICER DATE TIME

PRELIMINARY REPORT COMPLETED AND REVIEWED John M. Almer 2/28/83 OPERATING ENGINEER DATE

INVESTIGATED REPORT & RESOLUTION ACCEPTED BY STATION REVIEW  
Jack Brunner 3/25/83  
John M. Almer 3/25/83

RESOLUTION APPROVED AND AUTHORIZED FOR DISTRIBUTION  
Douglas Kent 3/25/83  
STATION SUPERINTENDENT DATE