

POWER AUTHORITY OF THE STATE OF NEW YORK
JAMES A. FITZPATRICK NUCLEAR POWER PLANT

50-333



CORBIN A. McNEILL, JR.
Resident Manager

P.O. BOX 41
Lycoming, New York 13093

315-342-3840

May 28, 1982
SERIAL: JAFP 82-0577

Ronald C. Haynes, Director
United States Nuclear Regulatory Commission
Region 1
631 Park Avenue
King of Prussia, Pennsylvania 19406

Subject: I.E. Bulletin 81-01 "Surveillance of
Mechanical Snubbers"

- References:
- (1) I.E. Bulletin No. 81-01 "Surveillance of Mechanical Snubbers"
 - (2) PASNY Letter PASNY 81-0232 dated March 11, 1981 from R. J. Pasternak (PASNY) to Boyce H. Grier (NRC), subject "I.E. Bulletin No. 81-01 Surveillance of Mechanical Snubbers"
 - (3) PASNY Letter JPN-81-51 dated July 13, 1981 from J. P. Bayne to Director of Nuclear Reactor Regulation, subject "James A. FitzPatrick Nuclear Power Plant, Docket No. 50-333, Proposed Change to the Technical Specifications Related to Snubber Surveillance"

- Enclosures:
- (1) Summary of Visual Exam Results
 - (2) Functional Test Results

Dear Mr. Haynes:


As required by reference (1) and committed to by reference (2), a visual and functional test of safety-related mechanical snubbers was performed during FitzPatrick's recent refueling outage in accordance with the proposed technical specifications submitted by reference (3). Enclosure (1) summarizes the results of the satisfactory visual exams and enclosure (2) are copies of the satisfactory functional test results performed by Wyle Laboratories.

8206080205 820528
PDR ADOCK 05000333
Q PDR

IE11

The list of mechanical snubbers in enclosure (1) differs slightly from the table provided in reference (3) due to the addition of one additional unit and a renumbering of existing units for clarity. A change to reference (3) to update the table of mechanical snubbers will be submitted by August 1, 1982.

Very truly yours,



Corbin A. McNeill, Jr.
Resident Manager

CAM:WF:nvw
Enclosures

cc: USNRC, Director, Office
of Inspection and Enforcement
Resident NRC Inspector
Internal Distribution
J. Glauser, Pacific Scientific

ENCLOSURE 1

SUMMARY OF VISUAL EXAM RESULTS

<u>MECHANICAL SNUBBER TESTED</u>	<u>OVERALL VISUAL EXAM</u>	<u>IN PLACE STROKE TEST</u>	<u>CLEVIS PIN & ROD BUSHING</u>
10-7B-MS-3	SAT.	SAT.	SAT.
10-9A-MS-40A	SAT.	SAT.	SAT.
10-13A-MS-112	SAT.	SAT.	SAT.
10-15B-MS-124A	SAT.	SAT.	SAT.
10-15B-MS-124B	SAT.	SAT.	SAT.
10-15B-MS-125A	SAT.	SAT.	SAT.
10-15B-MS-125B	SAT.	SAT.	SAT.
10-3B-MS-153	SAT.	SAT.	SAT.
10-35-MS-22 1A	SAT.	SAT.	SAT.
10-9A-MS-254	SAT.	SAT.	SAT.
10-9B-MS-286	SAT.	SAT.	SAT.
10-15A-MS-304	SAT.	SAT.	SAT.
10-15A-MS-303	SAT.	SAT.	SAT.
10-15A-MS-307	SAT.	SAT.	SAT.
10-15A-MS-308	SAT.	SAT.	SAT.
10-15B-MS-119A	SAT.	SAT.	SAT.