

WISCONSIN PUBLIC SERVICE CORPORATION

P.O. Box 1200, Green Bay, Wisconsin 54305

April 25, 1984

Mr. J. G. Keppler, Regional Administrator Region III U.S. Nuclear Regulatory Commission 799 Roosevelt Road Glen Ellyn, IL 60137

Dear Mr. Keppler:

Docket 50-305 **Operating License DPR-43** Kewaunee Nuclear Power Plant I.E. Bulletin 84-02: Failures of General Electric Type HFA Relays In Use in Class 1E Safety Systems

In response to the "Actions for All Holders of Operating Licenses or Construction Permits" in the referenced I.E. Bulletin:

A review of relays used in Class 1E safety systems has verified that there are no General Electric type HFA relays used in Class 1E safety systems at the Kewaunee Nuclear Power Plant.

Approximately twelve (12) hours of staff time was expended to prepare and review this response.

Very truly yours.

Parlinkesh

Cari i Giesler Vice President - Nuclear Power

JLB/ja

cc - Mr. S. A. Varga, US NRC Mr. Robert Nelson, US NRC Director, Office of I&E, US NRC

8405040042 840425 PDR ADOCK 05000305 PDR

APR 27 1984

TEIL