

INDUSTRIAL PRETREATMENT  
QUARTERLY SELF-MONITORING RESULTS

Perry Nuclear Power Plant  
10 Center Rd.  
Perry, Ohio 44081

Permit No.: 1004911  
Report Date: 3/21/95  
Laboratory: Quanterra

Date of Sample: 3/3 to 3/4/95  
Sample Location: Sewage Pump Station

Time of sample: 900  
Name of Sampler: Greg Newman


Laboratory Address: 1401 Shuffel Dr.  
North Canton OH 44720

Date of Analysis: 3/3 to 3/16/95  
Flow: 33,000 gpd

Name of Analyst: M. Recznik

PARAMETER	SAMPLE TYPE	EPA METHOD	ANALYSIS DATE	ANALYSIS RESULT
COD	Composite	410.4	3/13	120 mg/L
BOD	Composite	405.1	3/3 to 3/8	9 mg/L
TSS	Composite	160.2	3/6 to 3/7	110 mg/L
Silver	Composite	200.7	3/10 to 3/16	None Detected
Mercury	Composite	245.1	3/9 to 3/16	None Detected
pH	Grab	150.1	3/3	8.7 s.u.
Oil/Grease Gravimetric	Grab	413.1	3/13 to 3/14	32 mg/L

I certify under penalty of law that I have personally examined and I am familiar with the information in this report and that, based on my inquiry of those persons immediately responsible for obtaining the information contained in this report, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment.

 6/14  
Signature Date Title  
Vice President - Nuclear

9507100267 950615  
PDR ADOCK 05000440  
R PDR