

Dmb

WISCONSIN PUBLIC SERVICE CORPORATION



P.O. Box 1200, Green Bay, Wisconsin 54305

March 12, 1984

Mr. J. G. Keppler, Regional Administrator
 Region III
 U.S. Nuclear Regulatory Commission
 799 Roosevelt Road
 Glen Ellyn, IL 60137

Dear Mr. Keppler:

Docket 50-305
 Operating License DPR-43
 Kewaunee Nuclear Power Plant
I.E. Bulletin 83-08: Electrical Circuit Breakers With an Undervoltage Trip
 Feature in Use in Safety-Related Applications Other Than the Reactor Trip System

In response to the "Required Actions for Holders of Operating Licenses" in the referenced I.E. Bulletin:

A review of electrical circuit breakers used in safety-related applications has verified that there are no circuit breakers with mechanical undervoltage trip attachments, similar to the DB-50 breaker, being used in safety-related applications other than as reactor trip breakers.

Approximately twelve (12) hours of staff time was expended to prepare and review this response.

Very truly yours,

C. W. Giesler
 Vice President - Nuclear Power

CAS/js

cc - Mr. S. A. Varga, US NRC
 Mr. Robert Nelson, US NRC
 Director, Office of I&E

8403200016 840312
 PDR ADOCK 05000305
 Q PDR

JEH
 MAR 15 1984 110