077



UNITED STATES OF AMERICA NUCLEAR REGULATORY COMMISSION

August 10, 1984

DOCKETED

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

Glenn O. Bright Dr. James H. Carpenter James L. Kelley, Chairman 84 AGO 15 P.1:56

In the Matter of

CAROLINA POWER AND LIGHT CO. et al. (Shearon Harris Nuclear Power Plant, Unit 1) Docket 50-400 OL

ASLBP No. 82-468-01

Wells Eddleman's Contentions on Harris Emergency Plan Brochure


Under orders as noted in the Board's 8-03-84 Order at 25, Wells Eddleman hereby files the following contentions on the Harris plant bruchure "Safety Information for the Shearon Harris Nuclear Power Plant" (Carolina Power and Light Company).

227-A: The brochure is deficient in discussing respiratory protection measures for sheltering and/or evacuation because it fails to explain the best such means of protection, does not tell m which means are relatively ineffective or totally ineffective, and does not give sufficient emphasis to respiratory protection.

NUREG/CR 2272 demonstrates substantial variability, e.g. that a higher quality wet towel (4 layers) protects much better than a sheet, shirt or handkerchief (against everything but CH₃I). Similar variations are observed for dry towels. Respirators (e.g. 3M #8710) perform best, and this should be mentioned in the brochure. Otherwise sheltering

227-B: The brochure's discussion of respiratory protection

may not be effective in protecting public health and safety.



is deficient because it doesn't take sufficient account of the need for, and most effective means of, sealing around the respiratory protection. NUREG/CR-2958 establishes that leakage is least when panytyhouse are used to attach the protection, and much less if only the corners are taped, for example. The need for sealing, the effective means to do it, and the need to pre-stock materials (e.g. pantyhose or tape) to do it should be maximum stated in the brochure. Otherwise, inappropriate responses or ineffective sheltering may take place.

227-C: As the primary means of public education under

10 CFR 50.47(b)(7) the brochure must assure that persons in the
nt

EPZ, including transiems, understand the danger of a nuclear
accident as well as how to avoid it. The brochure should be improved
in clarity, particularly in labeling the pictures on page 1 (e.g.

1 2 3 4 to make it clear that these are steps in a sequential
process. Also the language concerning the process should be improved,
e.g. by positive language under step 1: STAY INDOORS. TURN YOUR
RADIO OR TV to your EBS STATION; GET A BATTERY POWERED RADIO IF
YOU HAVE ONE. DO NOT EVACUATE. It is vital that the informations
concerning what to do in an emergency be as clear and easy to understand
as possible.

227-D. The brochure needs to be clarified on page 1 to avoid inappropriate or possibly dangerous actions: In the 3d columns

concerning school children, there should be an explicit sheltering/
reference (e.g. to a the page re school evacuations) to which anxious parents can turn for information. If day care center children are to be sheltered/evacuated, this should be stated. The instruction to shelter pets and livestock should be clarified -- people should

not endanger themselves or use valuable time sheltering animals when this may endanger their lives or health. In the 4th column the necessity to sign in at the evacuation center should be underscored.

227-E. The brochure (p.1) treatment of sheltering is not clear enough about protection from airborne radioactive materials. This protection is a necessary thing in an accident. 50.47(a)(1). It should explain that the reason you close windows and doors, cut off fans, fires or heaters, etc. is to KERP FROM DRAWING RADIOACTIVE MATERIALS INTO THE HOUSE along with air. Similarly it should tell people how to effectively reduce breathing risk through the use of properly sealed breathing protective devices (e.g. as described in Contentions 227-A and B above). It fails to advise persons staying indoors to adopt breathing protection. 227-F. The Brochure's treatment of sheltering is deficient in that it doesn't explain the necessity to get as far from walls and windows as possible, with as much mass (walls or other objects) between you and the outside as possible. Without such instructions, This will not be "effective" 50.47(a)(1 people may shelter in inappropriate parts of buildings. The instruction "few or no windows" (p.1 col. 3) is misleading if rooms farther from the house walls are available. Instead, the brochure should have persons identify a sheltering space in their home (and tell them how to do it), which they then write in the box on page one, probably after item 1: Our in-home shelter

227-G. The information "when you hear the sirens" on p.2
often
is poorly organized, wordy, stated in passive voice, and fails to
adequately
answer important questions like "why not evacuate just to be extrasafe?". The information should begin with a description of the
siren signal for nuclear accidents. It should explain how it is
different from fire, police, and ambulance sirens (a long steady
tone of 3 to 5 minutes). It should explain when the system is
tested, and why. It should describe back-up actions later.

It should be written in shorter sentences. The answer to why-notevacuate should be that you may get more radiation outside than inside.
227-H. The EBS Stations list on page 3 should emphasize the

m 24-hour radio and TV stations, so that in evacuations at night people will be able to tune in. It should emphasize the need to get hold of portable, or other battery powered radios whenever a real emergency occurs (in case of power failures during/connected with the emergency). The information in the long (nearly as invisible as the warnings in cigarette ads) box at the bottom of the page should be placed in a colored, prominent box higher on the page, so that people will know these MOST IMPORTANT INSTRUCTIONS, e.g. Do what the EBS Station says, If it's different from what's in this booklet, do what the station says. Otherwise, inappropriate actions, or inadequate information flow (thru not tuning in to an on-air station, or losing info when the power is off) could result, violating NUREG-0654 II.G and II.E.5 and 6.

227-I. The instructions for sheltering on page 4 do not adequately explain why sheltering may be the best thing to do.

It should explain that people will be exercise ordered to take shelter when they will get less radiation exposure by staying inside, than they would get if they evacuated or stayed outside. It should emphasize the importance of keeping out outside air (e.g. taping leaky windows), staying away from the outside walls and roof of shelters, keeping as much mass between you and the outside as possible, and respiratory protection as described in contentions 227A and B. Without such instructions clearly presented, ineffective actions may result, violating 10 CFR 50.47(a)(1). People should be encouraged to find their best home sheltering areas in max advance, and be told how to do that.

227-J. The instructions for sheltering (p.4) do not adequately

evacuation, that the accident is over, etc) if you don't have a postable radio to take with you to shelter. It might, e.g. suggest leaving your TV on, very loud, or taking the phone with you.

explain how long one might possibly have to stay in shelter, and

how to receive information (either about changing conditions,

If such instructions aren't given, or another way to provide information provided, NUREG-0654 II.E.6 may be violated, and inappropriate actions (e.g. automatically coming out after 3 or 4 hours even though a radioactive release continues) may ofcur, violating 10 CFR 50.47(a)(1).

benefit instruction for sheltering instructions (p.4) a riskbenefit instruction for sheltering pets or livestock is very
important, but not included. If you would have to go outside to
do this, and a radioactive plume is near or present, the risk
may be greater than the benefit. Some notice of this risk/benefit
and instructions to listen to your EBS station for information
on outside radiation levels, is very important for persons who
make their living with (or partly with) livestock, and for those
who might be tempted to go outside to mearch for a pet or pets.
While the plan cannot stop people from inappropriate actions in
such situations, it needs to warn them, or it violates 10 CFR 50.47
(a)(1) by not reasonably assuring that appropriate protective
measures can and will be taken.

always or well presented. Since evacuation is not clearly identifiable or well presented. Since evacuation is the most difficult of the possible emergency actions, it is most important that the instructions for it be extremely straightforward and clear. For example, it's clearly important to use the exact route in the plan, even though some such routes look circuitous or turn odd directions. This goes unsaid. The need for contamination checks of vehicles during evacuation is not mentioned. The importance of not driving too fast or trying to pass up other drivers, because the opposite lanes are needed for emergency & vehicles, police, fire, wreckers etc. is not mentioned. There are no instructions for the handicapped except to fill out a card-(not much help if an accident is occurring) -- there should be some special instructions here for such persons.

- 227-M. The evacuation information, p.5, is deficient in not

 (1) explaining why doors and vents on cars should be closed and
 houses should be closed up (to prevent radiationactive material
 from getting in), does not explain respiratory protection well

 (it should be as requested in 227 A and B above), does not advocate
 taping over vents on cars whose vents don't seal tightly when closed;

 (2) emphasizing the importance of not contaminating others, especially
 for evacuees who do not choose to go to the evacuation center
- (3) emphasizing the importance of signing in at the evacuation & encouraging it, e.g. center, Assessing for the purpose of making later insurance claims. Without these emphases, inappropriate action may occur.
- 227-N. The provisions for sheltering livestock for an evacuation, and taking pets with you, are insufficient on page 5 because they do not address the risks and benefits of taking time to provide for livestock versus the risk or being outside to go and come from doing that, breathing hard while working, etc. As to petms, you are instructed to take them with you only if you will not stay at an evacuation center, but this ignores how many people feel about pets and may confuse people and even delay their evacuating because they are not sure they can provide for their pets if they don't have an alternate place to stay. It would be clearer to stay that after you sign in at the EC, places for people with pets to stay will be found.
- 227-0. Because the very important maps of the EPZ zones, evacuation routes, and the schools charts are not yet available, intervenor explicitly points out here that their accuracy, clearness, readability and usefulness are crucial to evacuation (and to sheltering where parents may be so concerned for their children that they may go to them at school, if they are not convinced the children will be adequately taken care of). Legibility of all this information is likewise important. These matters cannot be adequately taken

care of without seeing that the info on pp 6,7 and 9 meets these standards. That cannot be done until the info appears.

F.G. reducing the standard EPZ map to $8\frac{1}{2}$ x ll inches would be illegible. Evacuation zones or routes printed in different colors (one for each zone and its routes, e.g.)

227-P. The information for handicapped persons (p.8) is deficient because it doesn't tell you what to do if you haven't sent in the card, e.g. checking with neighbors to see if they can notify you in an accident, help you close your home if your must shelter, etc. The information is also deficient in not advising of helpful actions to take while waiting for help, e.g. appropriate breathing protection (per 227 A and B), locating items you need to take in an evacuation, even if you can't assemble or carry them yourself, locating open windows and staying away from drafts, etc. Without such information, handicapped persons may take inappropriate actions or not take appropriate protective actions which they can perform, violating 50.47(a)(1).

227-Q. The information on page 10 (sirens) is deficient in not referencing page 3 re EBS stations, and the box on page 1 where you are supposed to write names of EBS stations. This could results in delays when a test or accident occurs, in people's tuning in to the emergency broadcast stations. This would not be timely notification, in violation of 10 CFR 50.47(b)(5) and (b)(7).

227-R. The nature of the danger, as presented on pp 11-122, is understated, misleading and vague. The existence of background radiation is irrelevant in evacuations or sheltering, and the discussion seems to indicate that radiation is so common that it's almost OK. It ignores a substantial body of scientific information (e.g. work of John Gofman, Radiation and Human Health 1981, K.Z. Morgan, Cancer and Low-Level Ionizing Radiation, Bull At. Sci. 9/78)

that holds that low-level exposure is potentially harmful, by presenting the information in a self-contradictory manner -- radiation's in everything, but it could be harmful. This should be clarified and related directly to nuclear accidents, not to background. The contradiction between the initial statements about background radiation and the instruction to "go to a place with no radiation" in the middle of the page is especially confusing.

227-S. The description of radiation omits its most important characteristics to the average person -- it cannot be detected by any of our senses (vision, hearing, touch) and it is transmissible.

The nature of harmful health effects -- genetic damage and cancer, me nonother diseases, is not mentioned. This information is misleading
Persons who don't know risks may underestimate them. and could lead to inappropriate actions. Also radiation detectors should be discussed here -- why they are not always sensitive enough to tell you if you're in danger, why you should listen to the EBS.

The brochure should explain these dangers of radiation and how the emergency plan is set up to help you avoid it by sheltering or evacuation in necessary.

227-T. The information on p.ll is confusing and misleading in its discussion of nuclear accidents. Although a reactor cannot create a nuclear-bomb-like explosion, radioactive material can get out of reactors -- the plant can "blow up" from steam explosions, hydrogen explosions, ATWS or other breaches of containment. The reader should be told that the plant can release radioactive material and gases into the air during an accident, and that the wind could carry it to persons in the EPZ. The most important fact about nuclear accidents is that they are possible. That's why evacuation plans exist. The brochure should not

mislead or confuse people on this important point, or people may not take the brochure or its instructions or EBS instructions seriously, leading to inappropriate actions violating 10 CFR 50.47(a)(1).

-9-227-U. The brochure's a discussion of contamination on p.11 is inadequate because it (1) doesn't explain the amount of washing necessary for best demcontamination, or that radiation detectors are needed to be sure it's off; (2) doesn't adequately explain how to reduce exposure from breathing or swallowing radioactive material (e.g. don't eat anything that's been outside, avoid eating during evacuation, take respiratory protection measures) (3) seems to imply evacuation is the only way to deal with "shine" and ground radiation, without explaining that it can be reducted through getting farther from the radiation sources or butting shielding (mass) between you and the radiation. This all violates NUREG - 0654 50x47 II.G.1(c). 227-V. Information on decontamination should be highlighted. and preventive measures and first-aid procedures for contamination should be at least mentioned, if not listed off and explained in

227-V. Information on decontamination should be highlighted, and preventive measures and first-aid procedures for contamination should be at least mentioned, if not listed off and explained in detail (the latter would be better), per 10x NUREG-0654 II.G.1(c). This is an essential part of emergency preparedness for nuclear accidents because it enables people to care for themselves, reduce radiation exposure, and reduce transmission of radioactive meterials (provided the mimportance of decontamination in evacuations is emphasized). Again, the undetectable nature of radiation to the five normal senses people have, should be emphasized.

227-W. The information on page 12 is perhaps confusing and misleading in that it first emphasizes safety (touting CP&L®s performance) and then says evacuations plans must be tested.

Assuring residents that an accident is "unlikely" is irrelevant and against the brochure's purpose, which is to tell people what to do in an emergency. Claims of safety and comparisons with other energy sources are likewise irrelevant. Instead, the space would be better used clearly defining the emergency conditions, e.g. "lower plant safety" and saying the plan was made because "we care".

UNITED STATES OF AMERICA NUCLEAR REGULATORY COMMISSION

In the matter of CAROLINA POWER & LIGHT CO. Et al. Shearon Harris Nuclear Power Plant, Unit 1

Docket 50-400 0.L.

CERTIFICATEOF SERVICE

WE Contentions on Harris Plant I hereby certify that copies of Emergency Planning Brochure, and of List/Exhibits on Eddleman 41 (addl)

HAVE been served this 10 day of August 198 4, by deposit in the US Mail, first-class postage prepaid, upon all parties whose names are listed below, except those whose names are marked with an asterisk, for whom service was accomplished by (for"41" documents)

sending a list and an offer to provide copies on request; this was approved by the Board today in a conference call. Docketing and service agrees to accept 1 or 2 copies if the list is provided. Judges James Kelley, Glenn Bright and James Carpenter (1 copy each) Atomic Safety and Licensing Board (1 copy only of 41 documents) US Nuclear Regulatory Commission Washington DC 20555

*George F. Trowbridge (attorney for Applicants) Shaw, Pittman, Potts & Trowbridge *Ruthanne G. Miller 1800 M St. NA ASLB Panel Washington, DC 20036

Office of the Executive Legal Director Attn Dockets 50-400/401 0.L. USNRC Washington DC 20555

*Docketing and Service Section (3x) Attn Dockets 50-400/401 O.L. Office of the Secretary USNRC washington DC 20555

John Runkle CCNC 307 Granville Rd Chapel Hill No 27514

•Robert Gruber Travins Payne Exec. Director Edelstein & Payne Public Staff Bex 12607 Box 991 Raleigh NC 27605 Raleigh NC 27602

USNRC Washington DC 2055 5 Spence W Perry PTON FEMA Room 840

Washington DC 20740

Dan Read CHANCE /FLP 5707 Waveross NC 27606 Maleigh.

500 C St. SW

DNM

" Dr. Linda W. Little Governor's Waste Mct. Bd. 513 Albemarle Bldg. 325 N. Salisbury St. Raleigh, NC 27611

> Bradley W. Jones USNRC Region II 101 Marrietta St. Atlanta GA 30303

Richard Wilson, M.D. 729 Hunter St. Apex NC 27502

Certified by Wall Eddleman

By al Comments were also recently received from FEMA via NRC with copies provided to the service list.

- 1-14 WHAT IS THE EFFECTIVENESS OF BREATHING THROUGH A DAMP CLOTH FOR REMOVING AIRBORNE RADIOACTIVE VOLATILES AND PARTICULATES? EXPRESS QUANTITATIVELY FOR PROBABLE TYPES OF FABRIC. HOW DEPENDENT IS THE EFFICIENCY OF REMOVAL ON CONCENTRATION IN THE ATMOSPHERE? (DPC, H. D. Brewer)
 - a. Effectiveness is measured in terms of the fraction of contamination that passes through the material. For example, a material that has an effectiveness factor of 0.3 would allow 30% of the contamination to pass through.

Effectiveness of several readily available materials has been measured by D. W. Cooper and published as NUREG/CR-2272, SAND-81-7143. According to this research, a damp cloth such as a sheet folded to 6 layers would have an effectiveness for particulates of between .91 and .22 depending on the particle diameter. For volatiles the effectiveness was determined to be .45.

b. Effectiveness of other probable types of fabric are tabulated below. This information is based on estimated penetration through expedient respiratory protection materials at 50 Pa (0.2 in H₂0) pressure drop and 1.5 cm/s face velocity.

DRY

Material	No. layers	No. layers Aerosol particle diameter (µm)		I ₂ ^b	CH3Ib	
		0.4	1	5		
3M respirator ^a # 8710	2	.03	.004	<.01		
Sheet	20	.66	. 64	.020	1.0	0.6 ^C
Shirt	15	.54	.59	.070		
Lower-quality towel	20	.53	.41	.015		
Higher-quality towel	6	. 24	. 13	<.01		0.6 ^c
Handkerchief	14	.61	.54	.032		
		WE	Т			

Material	No. layers		osol pa		I ₂ ^b	CH ₃ I ^b
Sheet	6	.91	.88	. 22	.45 _d	.8 ^c
Shirt	6	1.0	.51	<.02		
Higher-quality towel	4	.20	<.01	<.01	.21 _d	1.0
Handerchief	2	.98	. 95	.37		

Available commercially in single-layer thickness. Taken from tests at 1.0 cm/s, assuming penetration is the product of single-layer penetrations. Not shown to be statistically different from 1.00. Wetted with 5% by weight baking soda solution. b.

C.

c. Cooper has also performed research (NUREG/CR-2958, SAND -82-7084) to determine the effect of leakage around the seals for different materials, using several methods of attachment. The effectiveness factors including leakage are tabulated below.

Mask	# Layers	Attachment Method	Effectiveness Factor (including leakage)
3M - #8710*	1	Pantyhose	.0058
3M - #8710	1	Fully taped	.015
3M - #8710	1	Strapped	.18
J&J - HRI8131**	1	Fully taped	.042
J&J - HRI8131	1	Tied	.361
Shirt (Oxford)	4	Fully taped	.306
Shirt (Oxford)	4	Corners taped	.744
Handkerchief	4	Fully taped	. 236
Handkerchief	4	Corners taped	.676
Handkerchief	4	Pantyhose	. 277
Toweling (washcloth)	1	Fully taped	.389
Toweling (washcloth)	1	Corners taped	.603
Toweling (washcloth)	2	Corners taped	. 298

^{*}Dust respirator

^{**}Surgical mask

d. The effectiveness factors would not depend on concentration.

- 7-7 HAVE EPZ RESIDENTS BEEN CLEARLY AND IN SUFFICIENT DETAIL ADVISED AS TO WHAT CONSTITUTES INADEQUATE SHELTER? WHAT STRUCTURES ARE LESS EFFECTIVE THAN A CLOSED AUTOMOBILE? (DPC, P. F. Carter, H. D. Brewer)
 - a. See response to 7-6.
 - b. For external exposure, any structure would provide better protection than a closed automobile. Dose reduction depends on two factors;
 - distance
 - attenuation by passage of radiation through material.

Since cars provide little distance and little attenuation, they are not as effective as larger volume houses, buildings, etc. The following reduction factors are provided by WASH-1400, Appendix VI;

	Cars	Wood Frame	Masonry House	
	Cars	House (No Basement)	(No Basement)	
Passing Cloud	1.0	0.9	0.6	
Deposited Material	0.5	0.4	0.2	

For <u>inhalation exposure</u>, the dose reduction is very dependent on infiltration rates. Cars have high infiltration rates and as such would provide less protection than structures.

7-11 WHAT ADVICE CAN BE GIVEN EPZ RESIDENTS IN REGARD TO CONTINUING SHELTERING IF THERE IS A COMMUNICATIONS BREAKDOWN. FOR EXAMPLE IF THE RESIDENT'S LINE POWERED RADIO OR TV BREAKS DOWN OR IS NOT SUPPLIED WITH POWER? (DPC, P. F. Carter)

See Brochure, Page 8, last line, "In case of an emergency, fire, police and rescue units would patrol the affected areas and sound their sirens." Further, use of battery powered radios and car radios would allow EPZ residents to receive information if they lost power.

NOTICE TO PARTIES

RE EDDLEMAN 41

DOCUMENTS DOCKETED

SO-400 OL 84 AGO 15 AT 56

Parties to the 8-10-84 Conference call may know that I am filing approx 500 pages of documents on Contention 41, pipe hanger/QA defects. A list of these documents 15 attached. If you want a copy of any of these Items, please contact me at 919-286-3076 or by mail to 718-A Ivedell St., Durham, NC 27705. Thanks, Wells Eddleman

DS03

DOCUMENT LIST ON [D+5]. EDDLEMAN CONTENTION 41 Cper conference call/oval order 8-09-84)

4-28-82 USNRC REGION II Ltr/Attachments to CP+L re I+E Raport 50-400/82-03

File: SH P-1/2 9-12-80 CONSTRUCTION QA Section Personnel Training (4pp)

CP+L Corporate QA Dept 3-16-81 CQA-1 (41.16) response) Personnel Training + Qualification

"SHERRON HARRIS POWER PLANT QERECEIVING TRAINING PROGRAM"

"Outline for Welder Training Class"
+ training INFO (approx 25pp)

PW-AS-446 (4pp-3+1 attachmt) AS 392 Rev 1 (3pp)

FCR-AS- 334 Rev 1 (3pp) PW-AS- 391 (ZPP) PW-AS- 414 (6pp)

WELD INSP REPORTS PRODUCED IN 1984 (-60PP) 1-18-82 EBASCO EB-S-1730 File #'s 50-P-1 50-M-30

LTR TO JOHN HARRIS, SOUTHWEST FABRICATING + WELDING CO re Fabrication Isometries

- CP+L SHNPP General Welding Procedure MP-08 (2)
 [Revo 11/9/79; Rev 8 4/27/84] General Welding
 Procedure for structural steel (seismic/non-seismic)
 and hangers. (69 pp. +0+21) DOC# 00641
 - CP+L Corporate Quality Assurance Dept: "Visual Examination of Seismic I, Structural and Hanger Welds (SHNPP)
 Initial date: 10/20/82 (19 pp. total) Doct 000643
 - CP+L Corp. Quality Assurance Dept. / Engineering Construction QA/QC Section: "Weld Control" Juitel date: 3/14/81 DOC# 80642
 - CP+L SHNPP General Welding Procedure MP-10: Repair
 of Base Maierials + Weldments Revo-4/28/78,

 Dev. 11-2/14/84 (34 pp. total) Doc# 000644
 - CF+L/SHNPP Welder Evaluation Reports. Doc II's 000645-000659 (14 pp total)
 - (LTR 1000 TO O'REILLY FROM PARSONS 1000 Deted 10/3/83 LOVERING Zed Interim (epoit Re: "Shop welding Deficience in Susmic I Pipe Hangers (Item 95) + Undersize skewed Tee Filler welds on Seismic I Hangers (Item 72)" DOC # 000/022
 - Same as above with report " Pipe Hangers Prenovsly
 Accepted by Ox welding Inspectors (Item 96) and
 undersized Shewed Tee Fret welds on Seismic I
 P. 4's (Item 72) Doc # 000622
 - (PIL SUNPP FCR-AS-4294 (7pp.) Dec # 000621

CP+L SHNPP WORK PROCEDURE WP-110 "Installa- 3)
tion of Seismic Pipe Hangers + Supports for Seismically
Analyzed Pipe" Rev 0-3/1/79, Rev 6-4/9/84. Doc 000618

Aus Di L Structural Weldments Inspection Criteria Modifica.

AWS D1.1 Structured Weldments Inspection Criteria Modifica. Froms 3/9/84 (from EBASCO) DOC# 000626

AWS D1.1 Same as above but marked "Preliminary" dated 8/12/83 Dec. I 000624

"Effect of WELD UNDERCUT ON THE TENSILE BENEVIOR OF LOW Strength Steel" Marked "Preliminary" (also EBASCO) DOC# 000625

CP+L Corp QA Dept. / Engineering and constructions

Quality Assurance / QC Section: "Seismic Pipe
Hanger Inspection Documentation System" 9/13/82

DOC # 000 620

CP+L SHINPP Procedure Charge Notice for Procedure II
WP-139 - Rev O-Change II Z "Pipe Hanger Work
Package Preparation Dan Approved CP+L 4/2/84. Doc 000019

Weld Inspection Criteria (for CP+L QA program) no date DOC-# 000617

(P+L SHNPP FCR-H-979 Rev. 3 (5 pages) 12/10/82 DOC # 000614

(P+L / George white: "FCR-H-979 Rev 3 "Justification"
(no date) Many docs attached, Doc # 000613

39 pp total

LTR From Parsons to O'Reilly 3/21/84 RE: Shop welding Deficiencies in Pipe Hongers (Item 55) and Undersize Skewed tee Fillet welds (Item 72) Covering Report "Interim #3 (4 pp. total Doc# 000592

LTR From CP+L/PARSONS TO O'REILLY Re: Engineering Review of Completed Phase II Pipe Hangers, Item 48 -(3/5/84) (1 p.) DOC # 000590

LTR From CP+L/Parsons to O'Reilly 3/9/84 with attached reply to RI: wpx 50-400/84-03 violetion. Doc 4000591 (2 pp)

MEMO (CP+L intra) TO PARSONS FROM N.J. CHIANOI 9/23/83
Re: Pipe Support Installation Program (3 pr) Doc # 000588

Memo (CP+Lintre) To CHIANGI From Parsons 12/15/83 Re: above (2 pps) doc # 000589

Memo (CP+L Intra) To Parsons from Chiang: 10/24/83 Re: above attached QA Surveillance Sheet (6pp. total) DOC# 000593

LTR from PARSONS to O'REILLY 11/18/83 re: IE inspection Report NOS. 50-400/83-25 and 50401/83-25 (Bemis) DOL# 600594 (17 pp total)

LTR + 4th Interim Report Re: Shopwelding Deficiencies on Seismic Class J Cable Tray Conduit, + HVAC haugers, Itam 77 From Parsons to O'Reilly. Dogoo595 (4 pp)

QA/QC Personnel Training sheets (with descriptions of trainings given + attendees) from 1/27/83-4/5/84. (~50 pps) DOCH 616

CP+L SHINPP PW H. 338 1P DOC# 326
PW-H-303 1P " 327
FCR-H-286 4 PHOTAL 328

CP+L "Reinspection" from Pete Field PHP-1237, 3/31/81
DOC# 310 CIP)

PHP-1154, 3/2/81

DOC# 309 (1P) ... PHP- 696 1219/80 (1P)

Reinspection report from Pete Fiday & PHP- (5)
12/3/80 DOC# 306 (19) CPAL 12/3/80 DOC# 306 (19)

11
1/28/81 DOC# 297 (19) 11 "Corrective Action + Disposit on of Hanger Reinspection" No. RR-153, 2/10/81, Doc 291 (19) CP+L No. RR- 298, 4/29/81, DOC 2866/16 Same as above CP+L Same as above NO. RR-046, 12/15/80, Dec 279(1P) CP+L Same as deone Na. RR-241, 4/16/81, Da 274 (2pp) CP+L (CP+L intra) To R. Hanford from David Timberlake Memo 12/9/80, Re: Welder Creft Training - Bi-Monthly Update (44 pp. total) with attachments of class outline, procedures. Corrective Action + Disposition of Hanger Hacked)
Reinspection No. HR-21 (but no report attached)
nor doc #. Dated 1/28/81 CPIL KTR from Parsons to O'Reilly 3/31/83 re: Seismic Class I Electrical, HVAC + CONDUIT SUPPORTS INSTALLED + ACCEPTED THAT WERE NOT IN ACCORDANCE WITH DESIGN, I tem 119 Change - O'Reilly 3/24/82 Re: undersized Shewed Twelds dranger - O'Reilly 9/13/82 Re: Hangers previously LTR LTR accepted by Oc welding Inspector (I tem 96)

(Outed used in date requested by dixipline engineer)

PW-AS-380 1/8/81 (1pt attachment 2)

FCR-AS-372 Rev. 1 1/13/81 (3ppinc. attachments)

FCR-AS-350 12/18/80(1p)

PW-AS-354 12/12/80 (2pp)

PW-AS-350 12/12/80 (9pp)

PW-AS-349 Rev. 1 3/10/81 (4pp)

PW-AS-347 12/8/80 (3pp)

PW-AS-152 Rev Z 3/26/81 (6PP)

PACKAGE OF HANGER WELD INSPECTION FORMS and
HR-030, HR-038, HR-040, HR-042, HR-046
HR-008, HR-011, HR-012, HR-014, HX-041
(33 pp total)

FCR- AS- 334 Rev. 1 12/17/80 (2pp)

FCR- AS- 218 Rev Z 8/26/80 (1P)

332 (4PP) TCR-H-863 7/28/81 DOC 485 (10) PW-AS- 1528 515182 12 487 (500) FCR- AS- 1924 9/14/82 476 (390) PW- AS- 215 4/28/80 L 478 (3pp) PW- AS- 467 11 3/12/80 479 (4pp) 4/21/81 PW- AS- 541 11 480 (4pp) 9/10/81 11 TCR- AS-807 482 (5pp) 1/8/82 PW- AS- 1125 483 (399) 11 2/16/82 PW- AS- 1245

L 71 #1	18/4/8	1071	
gnn	18/5/18	10111	
hnn	18/12/18	18 171	
5 17 17	18/52/8	51 51	
Zhh	18/18/3	3451	
osh	MOTOTORE.	5501	
887	18/92/1	tood (2 oth	
Ohn	14/41/P	nnoi	
Enn	18/52/8	5151	
Lhh	18/1/8	1041	
8hh	18/61/11	0507	
Lah	18/01/2	1011	
8911	18/hz/Z	5811	
50H	18/8/h	9/121	
144	18/41/4	9081	
2271	18/6/11	9961	
50n	28/82/9	7948	
017	78/1/5	5878	
158	78/82/01	218H	
814	28/12/2	1404	
bin	28/21/0	3352	
798	28/8115	5008	
EZH	28/8/11	5144	
65 tr	88/010	5100	
198	28/51/2	5882	
2Lh	18/8/8	1382	
85h	28/5/5	4582	
onh	18/12/16	hhol	
hen mod	88/08/3	9217	H dif

FACKAGE OF PIPE HANGER PROPERMS:

0.

PHPE	2050	11/14/81	DOC# 448
	2005	11/12/81	449
	5453	3/25/83	451
	5562	4/18/83	458
	5677	5/2/83	457
	5196	314/83	460
	5279	3/14/83	461
	6958	8/16/83	462
	977	1/16/81	466
	1104	2/16/81	467
	1246	4/3/81	469
	1306	4/17/81	471
	636	12/4/80	473
	2576	3/11/82	358
	2510	3/5/82	359
	3025	5/11/82	363
	2989	5/6/82	364
	2953	4/30/82	305
	2772	4/13/82	369
		11/2/81	370
	1432	10/29/81	372
	1871	10/23/81	373
	1824		377
	2325	2/11/82	378
	2293	1/29/82	380
	2198	1/20/82	382
	3801	8/12/82	-0-

2.0 + 605	11/25/80	dochet 12 384
PHP# 605	((103190	40000 1- 359
582	11/21/80	385
562	11/19/80	386
540	11/18/80	387
7398	9/24/83	394
3449	6/25/82	376
903	1/15/81	401
3179	5/27/82	405
3134	5/24/82	406
3583	7/15/82	408
3946	8/30/82	411
4184	10/4/82	417
775	1/2/81	428
795	1/2/81	429
815	1/10/81	430
1778	10/20/81	374

#

101 MARIETTA ST., N.W., SUITE 3100 CAR P. Cook & Juneand. CARCLINA POWER & LIGHT CO. HARRIS N P P APR 2 8 1982 CP&LCO. MARRIS N. P. P. ina Power and Light Company Mr. J. A. Jones, Senior Executive Vice President and Chief Operating Officer 411 Fayetteville Street Raleigh, NC 27602

Gentlemen:

Subject: IE Report No. 50-400/82-03 and 50-401/82-03

This refers to the investigation conducted by Mr. J. Y. Vorse of this office on December 11, 1981 to February 26, 1982, of activities authorized by NRC Construction Permit Nos. CPPR-158 and CPPR-159 for the Shearon Harris facility.

Areas examined during the investigation and our findings are discussed in the enclosed investigation report. Within these areas, the investigation consisted of selective examinations of procedures and representative records, interviews with personnel, and observations by the investigator.

During the investigation, it was found that certain activities under your license appear to violate NRC requirements. These items and references to pertinent requirements are listed in the Notice of Violation enclosed herewith as Appendix A. Elements to be included in your response are delineated in Appendix A.

In accordance with the provisions of 10 CFR 2.790(a), a copy of this letter and the enclosures will be placed in the NRC's Public Document Room unless you notify this office, by telephone, within ten days of the date of this letter and submit written application to withhold information contained therein within thirty days of the date of this letter. Such application must be consistent with the requirements of 2.790(b)(1).

The responses directed by the enclosed Notice are not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL 96-511.

120 00 10,49

Should you have any questions concerning this letter, we will be glad to discuss them with you.

Sincerely,

Vames P. O"Reilly Regional Administrator

Enclosures:

1. Appendix A, Notice of

Violation

Investigation Report Nos. 50-400/82-03 and 50-401/82-03

cc w/encl:

R. Parsons, Site Manager

APPENDIX A

NOTICE OF VIOLATION

Carolina Power and Light Company Shearon Harris Docket No. 50-400 License No. CPPR-158

Based on the results of the NRC investigation conducted on December 11, 1982 to February 26, 1982, and in accordance with the NRC Enforcement Policy 47 FR 9987 (March 9, 1982), the following violations were identified.

A. 10 CFR 50. Appendix B. Criterion XVIII. as implemented by section 1.8.5.17 of the PSAR, require that inspection records identify the individuals who performed the inspection.

Contrary to the above, a welding inspector signed inspection records indicating he had inspected welds and found them acceptable when, in fact, the welds had been inspected by other individuals and he had not personally inspected the welds.

This is a Severity Level IV violation (Supplement II).

B. 10 CFR 50. Appendix B. Criterion II. as implemented by section 1.4.9 (1.58) of the PSAR requires the licensee to comply with ANSI N45.2.6-1973.

Contrary to the above, the licensee did not comply with section 2.2 of ANSI N45.2.6-1973 in that two individuals performed weld inspections before they were certified by the licensee as being qualified to perform the assigned work.

This is a Severity Level IV violation (Supplement II).

Pursuant to the provisions of 10 CFR 2.201, you are hereby required to submit to this office within thirty days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violations; (2) the reasons for the violations if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

APR 2 8 1982

Date:



UNITED STATES NUCLEAR REGULATORY COMMISSION REGION II 101 MARIETTA ST., N.W., SUITE 3100 ATLANTA, GEORGIA 30303

'APR 2 8 1982

INVESTIGATION REPORT NO. 50-400/82-03 and 50-401/82-03

SUBJECT:

Carolina Power and Light Company

Shearon Harris Nuclear Plant

Unit 1

Improper Welding Inspection Practices

DATES OF INVESTIGATION: December 11, 1981 - February 26, 1982

INVESTIGATOR:

. Vorse, Regional Investigator

Enforcement and Investigations Staff

REVIEWED BY:

E/\Alderson, Director

Enforcement and Investigations Staff

Date Signed

A. INTRODUCTION

On December 4, 1981, the NRC Resident Inspector assigned to Carolina Power and Light Company's Shearon Harris nuclear power plant, advised Region II that several personnel had complained to him that a welding inspector was not performing visual weld inspections properly. The personnel who complained had no first hand knowledge; however, the rumor among the welders and welding inspectors was that if a hanger was located in an inaccessible area, the individual would not inspect the weld but would sign it off as acceptable. One complainant identified a specific hanger which was rumored to have not been properly inspected by the welding inspector. This hanger was inspected by the Resident Inspector and all welds appeared to be acceptable. However, the adjacent hanger had one weld which appeared to be rejectable. The Resident Inspector later learned the hanger welds had been inspected and accepted by the welding inspector in question.

Based on the number of personnel who were complaining about the welding inspector's weld inspection practices and the potential impact on the welding inspection program, an investigation was initiated by Region II on December 11, 1981, under the authority provided by Section 161.c of the Atomic Energy Act of 1954, as amended.

B. SCOPE OF INVESTIGATION

A review of the information supplied by the Resident Inspector disclosed one allegation to be addressed during the investigation. This was:

A welding inspector was signing off welds on hangers and pipes as acceptable when he had not visually inspected them.

During the course of the investigation, the Investigator held discussions with numerous current licensee and licensee contractor employees. Formal interviews were conducted with 59 individuals who were considered by the Investigator to have potential knowledge of the alleged acts or practices. The investigation also included an inspection of randomly selected hangers and pipes which had been inspected by the particular welding inspector during the time frame the rumors began forming.

The investigation included a review of appropriate regulatory requirements, NRC records and licensee procedures and records including:

- 10 CFR 50, Appendix B

- Shearon Harris Quality Assurance Program

Personnel Training and Qualification
 Visual Examination of Welds Procedure

This investigation was conducted by one investigator and two inspectors requiring a total of 42 man-hours of investigative and inspection activity on-site.

C. CONCLUSIONS

The allegation was substantiated in that the welding inspector had signed off. weld inspections he had not personally performed; however, the welds had been inspected by inspector trainees who were working with the inspector. This results in two violations of NRC requirements:

- 1. Inspections were performed by uncertified welders; and
- Inspection records do not reflect the correct identity of the individuals who performed the inspection.

DETAILS OF INVESTIGATION

CAROLINA POWER AND LIGHT

SHEARON HARRIS NUCLEAR PLANT

DECEMBER 14, 1981 - JANUARY 22, 1982

A. INDIVIDUALS CONTACTED

The following individuals were contacted during the course of the investigation.

Carolina Power and Light (CP&L)

G. A. DeBarres, QA Weld Inspector

K. A. Douglas, QA Weld Monitor

R. L. Faulkner, QA Weld Control and Surveillance

S. M. Freeman, QA Weld Inspector

A. B. Giles, QA Technician

J. C. McDonnell, QA Weld Inspector

A. Lucas, Senior Resident Engineer

E. W. Mercer, QA Weld Inspector

S. W. Montastle, QA Weld Inspector

R. M. Parsons, Site Manager

W. H. Pere, QA Weld Inspector

K. B. Stanley, QA Weld Inspector

R. B. Strickland, Mechanical Inspector

G. G. Tingen, QA Weld Inspector T. Wait, QA Welding Supervisor

Daniels Construction Company

Crew P-21: Reactor Auxiliary Building (RAB)

R. V. McLeod, General Foreman

W. W. Burton, Pipe-Fitter Helper

R. J. Carr, Welding Foreman

J. F. Goodsell, Welder

B. W. Nguyen, Welder

K. M. Norton, Welder

J. A. Owens, Welder

G. S. Peck, Pipefitter

R. D. Symank, Welder

M. D. Warlick, Welder

Crew P-35 (RAB)

W. T. Bohan, Foreman

D. L. Cauble, Welder

R. W. George, Pipe-Fitter

W. J. Jenkins, Welder

T. R. Merideth, Welder

M. D. Tatham, Welder

J. C. Woznick, Welder

Crew P-17 (RAB)

- D. E. Bradford, Pipe-Fitter
- C. A. Brigman, Foreman
- R. L. Grant, Pipe-Fitter
- T. M. Lazafame, Pipe-Fitter
- W. H. Martin, Welder
- J. E. Newsome, Welder
- J. B. Starnes, Pipe-Fitter Helper
- L. L. Whitehead, Pipe-Fitter
- S. J. Whitlock, Fitter

Crew P-14 (Waste Process)

- R. A. Gardner, Foreman
- W. C. Lynch, Welder
- T. Smith, Welder
- W. B. Surber, Welder

Crew P-20 (Waste Process)

- J. A. Brincheck, Welding Supervisor
- K. T. Davis, Pipe-Fitter Helper
- J. D. Foster, Pipe-Fitter
- D. P. Freeman, Welder
- C. F. Green, Jr., Welder
- J. W. Kilgore, Pipe-Fitter Helper
- J. F. Lynch, Pipe-Fitter
- D. C. Martin, Welder
- D. M. Shargots, Welder
- R. R. Stone, Pipe-Fitter
- N. C. Sulton, Welder
- G. G. Wilbon, Welder

Daniels Technical Services, Ltd.

- D. A. Sands, QA Welding Inspector
- B. L. Holcombe, QA Welding Engineer

Nuclear Regulatory Commission (NRC)

G. F. Maxwell, Resident Inspector

B. ALLEGATION

Occasionally, a welding inspector, Individual A, did not visually inspect welds on seismic hangers and piping. However, he signed documentation showing that he had.

C. BACKGROUND

The Resident Inspector at Shearon Harris nuclear site expressed concerns about certain workers approaching him and complaining about a welding inspector, Individual A. Several workers stated they were hearing other workers saying that Individual A was not looking at some welds he was signing off as acceptable. One individual stated to the Resident Inspector that if a weld was located in a difficult to access location, Individual A would not acquire the appropriate scaffolding to allow him to have access to the weld to be inspected. The Resident Inspector was further informed that he could find an unacceptable weld on seismic category 1 pipe hanger numbered A-3-236-1-CC-H-469. The Resident Inspector looked at the welds on that hanger and found no rejectable welds. However, on an adjacent hanger, No. A-3-236-1-CC-H-342 the Resident Inspector found what was, in his opinion, a rejectable weld. It was later determined by the resident inspector that this weld had been inspected by Individual A. Three additional hangers were looked at by the Resident Inspector and no rejectable welds were noted.

D. INTERVIEWS OF WELDING INSPECTORS

Eight weld inspectors including a supervisor, as well as four other personnel involved in the QA weld inspection program were interviewed by the Investigator. One individual stated he had heard rumors that Individual A "inspected from the floor". Two individuals stated they heard rumors that Individual A sometimes shined his flashlight on hangers from the floor but did not go up and visually check the welds. Five individuals stated they were aware that Individual A had a very bad case of arthritis during the summer months of 1981 and were surprised when they saw him up on the scaffolding. Two welding inspectors, Individuals B and C, stated they inspected welds before they (the inspectors) were certified. Individuals B and C provided the Investigator with signed statements which contained the following information in essence:

Individual B started work as a welding inspector trainee beginning sometime in September 1980. Initially, he was under the direct supervision and received on-the-job-training from Individual A. Individual A showed him what to look for

regarding acceptability and when to reject a weld. After about 2 months, Individual B began inspecting welds by himself, particularly in areas which were relatively inaccessible and high up. Individual A remained on the floor signing off the weld inspection documentation and provided Individual B with a sticker showing the weld had been inspected. Individual B placed the stickers on the hangers on which he had inspected welds. Individual B estimated that he had inspected welds by himself on approximately 50-75 hangers most of which were on the 90ft. and 236ft. elevations in the Reactor Auxiliary Building. Although he inspected the welds prior to being certified in January 1980, Individual B had no misgivings about those welds he accepted. In fact, he believes he was on the conservative side and inspected all welds in accordance with AWS D1.1-75 Standards.

Individual C began his on-the-job-training with Individual A in October 1981 for pipe hanger welding inspection. Individual C estimates that he spent 3 weeks, 40 hours per week with Individual A and, although he could not recall how many hangers they inspected, he estimates he alone inspected about 75% of the welds. That is, those welds which were difficult to get to because of the need to climb scaffolds or physically difficult to get to. When he rejected welds the first several times, Individual A climbed the scaffold, looked at the welds and agreed they were rejectable. Thereafter, Individual C rejected and accepted welds without Individual A looking at them. Individual A always signed the weld inspection forms (Weld Data Report (WDR QA 34 and traveler)) as well as the weld inspection sticker. Individual C estimates that he inspected welds on about 100 hangers by himself before he was certified. In all of these situations, Individual A signed the documentation. Like Individual B. Individual C had no reservations about the welds he had accepted. He also inspected the welds according to AWS D1.1-75 standards.

E. INTERVIEWS OF CRAFT PERSONNEL

Forty-two Craft personnel comprised of welding foremen, welders, pipe-fitters, and pipe-fitter helpers were interviewed by the Investigator. Twenty-seven individuals had no knowledge of Individual A and could provide no pertinent information. Three individuals stated they heard rumors that Individual A would inspect from the floor and shine his flashlight on the welds. Five individuals stated they observed Individual A performing inspections on welds which were high up and difficult to get to. One welder,

Individual D stated that Individual A accepted welds without looking at them. A signed statement was provided to the Investigator by Individual D which contained the following information in essence:

Sometime in the late spring or early summer, Individual D was assigned to assist Individual A in locating and providing access for inspection of welds on piping. This transpired on a Saturday with no one else in the general area. The pipes were located in the waste process area, elevation 236. Individual A remained on the floor and Individual D climbed the scaffolds and ladders, placing stickers on pipes signifying the welds had been inspected. Individual A signed off the paperwork. Individual D estimates that this activity took place on approximately 100 welds, all non-safety Category 6 and 7. Individual D expressed concerns to co-workers and opined that this was the source of all the subsequent talk going around the plant about Individual A not inspecting the welds. Individual D thought Individuals E and F may have knowledge about similar occurrences.

Individual E was interviewed and stated he had no first hand knowledge about improper welding inspection. Individual E only acknowledged hearing rumors that Individual A had welders put stickers on pipes for him. Individual F was interviewed by the Investigator and he provided a signed statement containing the following information in essence:

Individual F, a pipefitter helper, estimates he assisted Individual A in locating welds approximately 500 times. Most of the welds were easily accessible and were looked at by Individual A. On one occasion, however, in September 1981, Individual A glanced at two category 7 (non-safety related) welds which were located approximately 20 ft. above him. These were off the "MY column" and "column 2" of the East-West Hallway of the waste process area. Individual A signed the inspection sheet and handed the carbon copy to Individual F for the craft records. He also gave Individual F two filled out stickers instructing him to place them by the welds. However, Individual F did not do so because there was no scaffolding or ladder available, so he took the stickers home. Individual F. was later requested by the Resident Inspector to provide him with the stickers. Only one was still available and this was given to the Resident Inspector by Individual F. This same sticker was later provided to the Investigator. The sticker bears the initials of Individual A.

Based on the information provided by Individual D regarding Individual A's not inspecting welds on a Saturday when no others were in the indicated area, a foreman, Individual G was asked to provide the names of craft personnel who assisted Individual A on Saturdays. Individual G provided those names to the Investigator. They were: Individuals H, I, J, K, L and M. These personnel were interviewed. Individuals H, I, J and M stated they observed Individual A inspect welds from scaffolds and ladders on Saturdays and he always appeared to be inspecting carefully. Individual K stated he observed Individual A inspect the welds although he seemed reluctant to go high. Individual L stated he assisted Individual A with approximately 100 weld inspections. On one occasion, Individual A shined his flashlight from a distance and accepted one weld. This, according to Individual L, was on code 6 and 7 non-safety related piping, located high off the floor.

F. INTERVIEW OF INDIVIDUAL A (WELDING INSPECTOR)

Individual A was interviewed at Shearon Harris on December 17, 1981 and he provided a signed statement containing the following information in substance:

Regarding signing off welds that he did not actually look at, but which were inspected by trainees, Individual A explained that he was always within close proximity to them. When questioned by the Investigator as to whether or not he remained at floor level while the trainee inspected welds high on the scaffolds, Individual A declined to state where his exact physical location was except that he was in the "immediate vicinity". Individual A explained that sometime around April 1981. EBASCO began sending revisions requiring reinspection of some pipe hangers. Subsequently, for about a 3 month period, Individual A went out and looked at the respective hangers. No welds had to be inspected but he did have to verify the hanger was physically present. Therefore, Individual A would often shine his flashlight on the hanger while standing on the floor to ensure the hanger was present and in its proper location. He would then sign off the revised drawing and give to whoever was assisting him, a sticker indicating the date the hanger was "inspected" to the latest revision. The assistant would then place the sticker somewhere on the hanger. Individual A believes this may have been misconstrued by others in the vicinity that he was signing off welds without actually looking at them. In fact, none of the welds on the hanger required any inspection. Individual A estimates that he inspected approximately 100 hangers in this manner. Individual A denied having not inspected welds on pipes or hangers, but signing them off as acceptable.

G. WELD INSPECTIONS BY NRC

Based on the statements, made by several individuals, that Individual A signed off pipe welds without inspecting them, the Region II Engineering Inspection Branch was requested to conduct an inspection of randomly sampled welds on hangers and pipes. It was further requested that they draw samples from:

Areas which were relatively difficult to access;

Welds which were inspected on Saturdays; and

Welds which were inspected during the April-September 1981 time frame.

The results of the reinspection of welds conducted by NRC inspectors are documented in NRC Inspection Report Nos. 50-400/82-01 and 50-400/82-06. A summary of that inspection is included herewith as Enclosure 1. Two violations were identified by the inspectors and they are discussed in the referenced inspection report.

H. REVIEW OF LICENSEE PROCEDURES

The problem of uncertified individuals performing inspections and the inspection reports for those inspections being signed off by a certified inspector was discussed with the CP&L Site Manager and Senior Resident Engineer. They stated that such actions were permissible in accordance with licensee procedure CQA-1, "Personnel Training and Qualification".

A review of that procedure disclosed that Paragraph 7.1 contains the following:

"Emphasis will be on firsthand experience gained through actual performance of processes, tests examinations, and inspections. As the inspector in training develops proficiency, he may be allowed to perform certain functions with minimal supervision; however, he will not be permitted to "sign-off" hold points in verification of quality requirements for work activities."

In response to the Investigator's comments regarding the inspection records being signed by an inspector who had not actually inspected the weld, the licensee's site management representatives stated that the certified inspector was accepting responsibility for the welds, therefore the inspector would only permit the trainees to accomplish the inspection when he believed they were qualified.

The licensee's procedure and implementation of the procedure is inconsistent with the requirements of ANSI N45.2.6-1973 which the licensee committed to follow in that the trainees had not been certified to perform the inspections in question; that is, no "certificate of qualification" meeting the requirements of Section 2.2.4 of the Standard had been completed for the individuals.

The licensee's procedure is also inconsistent with Criterion 17 of Appendix B to 10 CFR 50, which requires that inspection records identify the inspector who performed the inspection. An inspector cannot "accept responsibility" for an inspection that he did not personally perform.

I. FINDINGS

The allegation was substantiated in that the welding inspector signed inspection records indicating that he had inspected welds and found them acceptable when, in fact, he had not personally inspected the welds. This action results in two violations of NRC requirements. These are:

- The inspection records did not identify the individuals (B and C) who had actually performed the inspections as required by 10 CFR 50, Appendix B, Criterion XVII and Section 1.8.5.17 of the PSAR; and
- The inspections were performed by individuals (B and C) who were not certified to perform the inspections in accordance with ANSI N45.2.6-1973 as required by 10 CFR 50, Appendix B, Criterion II and Section 1.4.9(1.58) of the PSAR.

These violations appear to be the direct result of inadequacies in licensee procedure CQA-1 (Rev. 4), "Personnel Training and Qualification" or the licensee's interpretation of that procedure as discussed in Paragraph H above.

ENCLOSURE 1

Followup on Regional Request

Certain pipe welds and a random sample of difficult access welds on seismic supports inspected by a certain welding inspector during a particular time frame were reviewed by inspectors from the Materials and Processes Section.

 The following seismic Category I welds were re-examined by Region II inspectors during the week of January 19-22, 1982:

COMPONENT ID/WELD NO.	SYSTEM	ITEM INSPECTED
CS-H-1790 CX-H-1623	Chemical and Volume Control Chilled Water Return	Seismic Hanger Seismic Hanger
CC-H-469	Component Cooling	Seismic Hanger
BD-H-144	Blowdown	Seismic Hanger
BR-H-731	Boron Recycle	Seismic Hanger
CS-H-137	Chemical and Volume Control	Seismic Hanger
RM-H-366	Reactor Make-up Water	Seismic Hanger
SI-H-1018	Safety Injection	Seismic Hanger
SF-H-704	Spent Fuel Pool Cooling and Cleanup	Seismic Hanger
CC-H-800	Component Cooling	Seismic Hanger
CT-H-205	Containment Spray	Seismic Hanger
SW-H-2343	Service Water	Seismic Hanger
*CC-H-342	Component Cooling	Seismic Hanger

*NOTE: This hanger was alleged to be unacceptable.

In addition to the above welds, the inspectors also inspected the following welds on the laundry and hot shower tank #591-48, that were alleged to be rejectable.

ISOMETRIC	WELD JOINT	SYSTEM
1-WL-1095	FW-3708	Waste Liquid
1-WL-1092	FW-3702	Waste Liquid
1-WL-1090	FW-3697	Waste Liquid

Discrepancies noted as a result of the NRC reinspection are as follows:

a. The inside of the box frame windows for hanger CC-H-469 had not been welded. A review of the records for this hanger revealed that the weld inspector had mistakenly referenced a field change that would have deleted these welds if the hanger had been designed for a twelve inch pipe or smaller. Hanger CC-H-469, however, was designed for two 18-inch pipes.

- b. Field pipe welds Fw-3708, FW-3702, and FW-3697, located on the top of the laundry and hot shower tank, had small arc strikes on the base metal adjacent to the field welds. Carolina Power and Light Company (CP&L) procedure NDEP-601 for visual examination of welds, paragraph 9.11, states that "weld and adjacent base metal shall be free of visible arc strikes, weld spatter and mishandling marks".
- c. In addition to the above pipe field welds, arc strikes and weld spatter were noted on vendor welds between the above field welds and the tank. The weld inspector had not reported this condition as required by paragraph 19.9 of CP&L's Quality Assurance Program for Radioactive Waste Management System.

The three examples noted above were reported as a violation of 10 CFR 50, Appendix B, Criterion V and was assigned number 50-400/82-01-03, Failure to Follow Procedures/Instructions for Visual Examination of Welds and Reporting of Discrepancies.

d. As a result of the reinspections conducted during January, the Region II inspectors concluded that the samples taken were representative of the more difficult inspections the inspector in question had made on seismic supports. Although one item of noncompliance was found, the NRC inspectors concluded that this was an oversight by the welding inspector. When reading the instructions he apparently failed to see that the field change had size limitations. The NRC inspectors found inspection stickers with the individual in question's name on supports that were very high and difficult to reach.

This indicated that the weld inspector had made the inspections since all of the reinspected supports were examined during the period that the weld inspector was working alone. As for the reinspection of the three pipe welds that were examined by the inspector in question, two discrepancies were noted in this area and reported above. The Region II inspection concluded that a larger sample of pipe welds; particularity Non-ASME welds inspected by this individual would need to be reinspected on a subsequent inspection. An inspector follow-up item 400/82-01-05, Inspection of Pipe Welds was open to track this problem.

2. During the week of February 23-26, 1982 the Non-ASME welds listed below were re-examined by Region II. The safety significance of this non-ASME pipe is established by section 1.8 of the Harris FSAR, which commits to Regulatory Guide 1.143. The Guide identified the radioactive waste management systems as an activity important to safety and requires inspection in accordance with ANSI B31.1. CP&L procedure NDEP-601, Revision 0, conforms with the requirements of ANSI B31.1 and is the procedure used by CP&L for visual inspection of the Waste Processing System.

WELD JOINT NO.	SYSTEM	DATED INSPECTED
*1-WL-641-FW-2353	Waste Processing	9-09-81
*1-WL-642-FW-2358	Waste Processing	7-18-81
1-WL-364-FW-1857	Waste Processing	6-27-81
1-WL-324-FW-1856	Waste Processing	6-27-81
1-WL-365-FW-1846	Waste Processing	Date not recorded by NRC
1-WL-365-FW-1848	Waste Processing	6-27-81
1-WL-608-FW-2305	Waste Processing	8-11-81
1-WL-646-FW-2364	Waste Processing	7-21-81
1-WL-644-FW-2370	Waste Processing	8-11-81
1-2-WL-142-FW-1319	Waste Processing	8-18-81
*1-2-WL-142-FW-1318	Waste Processing	Inspection Sticker had
		been removed
1-WL-717-FW-4016	Waste Processing	7-28-81
1-WL-717-FW-4017	Waste Processing	7-23-81
1-WL-679-FW-4051	Waste Processing	7-22-81
1-WL-717-FW-4015	Waste Processing	7-22-81
1-2-WL-143-FW-1316	Waste Processing	8-24-81

* NOTE: This joint was unacceptable

Discrepancies noted as a result of NRC reinspection were as follows:

- (a) Butt weld joint #'s 1-WL-641-FW-2353 and 1-WL-642-FW-2358 had insufficient weld metal deposited on the external surface of the weld prepresulting in areas of external weld concavity.
- (b) Weld joint #1-2-WL-142-FW-1318 had two arc strikes. One of the arc strikes resulted in a pit in the base metal which had not been ground or liquid penetrant inspected.

The discrepancies noted above were reported as violation number 50-400, 401/82-06-01, "Failure to Follow Procedure for Visual Examination of Pipe Welds."

As a result of the above reinspections the licensee committed to reinspect all Non-ASME pipe weld joints inspected by the welding inspector in question and submit a list of their findings to NRC. This reinspection had commenced prior to this inspector leaving the site on February 26, 1982 and additional discrepancies had been identified by the licensee.



UNITED STATES NUCLEAR REGULATORY COMMISSIC REGION II

101 MARIETTA ST., N.W., SUITE 3100 ATLANTA, GEORGIA 30303

FEB 2 3 1983

Carolina Power and Light Company ATTN: Mr. E. E. Utley Executive Vice President 411 Fayetteville Street Raleigh, NC 27602

41-11

Gentlemen:

SUBJECT: REPORT NOS. 50-400/83-05 AND 50-401/83-05

This refers to the routine safety inspection conducted by Mr. J. W. York of this office on February 1-4, 1983, of activities authorized by NRC Construction Permit Nos. CPPR-158 and CPPR-159 for the Shearon Harris facility and to the discussion of our findings held with Mr. R. M. Parson, Project General Manager, at the conclusion of the inspection.

Areas examined during the inspection and our findings are discussed in the enclosed inspection report. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observations by the inspector.

Within the scope of this inspection, no violations or deviations were disclosed.

Two new unresolved items resulted from this inspection and are discussed in the enclosed report. These items will be examined during subsequent inspections.

In accordance with 10 CFR 2.790(a), a copy of this letter and the enclosure will be placed in the NRC's Public Document Room unless you notify this office, by telephone, within ten days of the date of this letter and submit written application to withhold information contained therein within thirty days of the date of this letter. Such application must be consistent with the requirements of 10 CFR 2.790(b)(1).

Should you have any questions concerning this letter, we will be glad to discuss them with you.

Sincerely,

Verrelli, Chief

Project Branch 1

Division of Project and Resident Programs

Enclosure: Inspection Report Nos. 50-400/83-05 and 50-401/83-05

cc w/enc1:

R. M. Parsons, Project General Manager



UNITED STATES NUCLEAR REGULATORY COMMISS. REGION II

101 MARIETTA ST., N.W., SUITE 3100 ATLANTA, GEOF LIA 30303

Report Nos: 50-400/83-05 and 50-401/83-05

Licensee: Carolina Power and Light Company

411 Fayetteville Street

Raleigh, NC 27602

Docket Nos: 50-400 and 50-401

License Nos: CPPR-158 and CPPR-159

Facility Name: Harris 1 and 2

Inspection at Harris site near Raleigh, North Carolina

Inspectors:

Approved by

ake, Section Chief

heering Programs Branch

Division of Engineering and Operational Programs

SUMMARY

Inspection on February 1-4, 1982

Areas Inspected

This routine, unannounced inspection involved forty-six inspector-hours on site in the areas of independent inspection effort, safety-related pipe support and restraint systems, and other safety-related piping system.

Results

Of the three areas inspected, no violations or deviations were identified.

REPORT DETAILS

1. Persons Contacted

Licensee Employees

*R. Parsons, Project General Manager

*L. Loflin; Manager-Engineering

*N. Chiangi, Manager-Engineering and Construction-QA/QC

*G. Forehand, Director-QA/QC

*A. Lucas, Assist. Project Gen. Manager

*M. Vernon, Superintendent, QC

*E. Willett, Resident Mechanical Engineer

*D. Whitehead, Supervisor, Site QA/QC

*R. Hanford, Resident Engineer, Met./Welding

*M. Thompson, Sr. Resident Engineer

*A. Fuller, Prinicpal Engineer-Mechanical

*G. Simpson, Principal Construction Specialist

*C. Osman, Principal Specialist-OA/QC

*J. Nevill, Principal Engineer-Engineering

Other licensee employees contacted included construction inspectors, technicians, QC inspectors, and office personnel.

*Attended exit interview

2. Exit Interview

The inspection scope and findings were summarized on February 4, 1983, with those persons indicated in Paragraph 1 above. The licensee was informed of the inspection finding listed below. The licensee acknowledged the inspection finding with no dissenting comments.

- a. (Open) Unresolved Item, 400/83-05-01, Ground Areas on pipe support/ restraint No. 1-SW-H-376, Paragraph 6.a.
- b. (Open) Unresolved Item, 400/83-05-02, Administrative procedure for approval of drawings associated with Design Change Notifications, Paragraph 6a.
- 3. Licensee Action on Previous Enforcement Matters

Not inspected.

4. Unresolved Items

Unresolved items are matters about which more information is required to determine whether they are acceptable or may involve violations or deviations. New unresolved items identified during this inspection are discussed in Paragraph 6.a.

5. Independent Inspection Effort - Units 1 and 2 (92706)

The inspectors toured the Carolina Power and Light Research Laboratories near the Shearon Harris Nuclear Plant in order to ascertain the capabilities of these laboratories in the metallurgical and mechanical testing areas. Since the testing for the weld procedure qualifications is performed by these laboratories, the inspectors reviewed the calibrations for the tensile and charpy impact testers.

6. Safety-Related Pipe Support and Restraint Systems - Unit 1 (50090)

The licensee divides the installation and inspection of pipe supports/ restraints into three phases. Phase I involves the installation of the piping and support/restraint. Phase II involves the adjustment of struts, placement of shims in box frame restraints, and the inspection of the support/restraint after it has been totally completed. Phase III involves the comparison of the stress isometric to the as-built locations of the supports/restraints to insure that the analysis was performed for as-built conditions. Shearon Harris Unit 1 has approximately fifty supports/ restraints in the Phase II condition.

The inspectors evaluated the following parts of the support/restraint program:

(a) Observation of work and work activities

The inspectors in conjunction with licensee welding and construction inspectors reinspected the following five supports/restraints that were in the Phase II condition:

- Hanger/Restraint No. 1-SW-H-376 in the Service Water System
- Hanger/Restraint No. 1-PD-H-1590 in the Plumbing and Drainage System
- Hanger/Restraint No. 1-4-WG-H-522 in the Waste Processing System
- Hanger/Restraint No. 1-4-WG-523 in the Waste Processing System
- Hanger/Restraint No. 1-SW-H-4/3 in the Service Water System

At the time of the inspection it appeared that all of the supports/ restraints conformed to the drawing with the exception of support/ restraint No. 1-SW-H-376. This support/restraint had two apparent overground areas, one on the northwest (NW) corner and one on the southwest (SW) corner. Both areas were just above a fillet weld on the same vertical tube steel member. In a telephone communication on February 7, 1983, the licensee stated that measurements were made on

that date using an ultrasonic thickness device that showed the wall thickness in the ground area on the NW corner to be 0.239" and on the SW corner 0.235". The tolerances for the thicknesses on the tube steel are maximum 0.275" and minimum 0.225". Therefore, the areas met the minimum wall thickness requirement and were not reportable. Until the results of the licensee's inspection and the method used for inspecting ground areas on other hangers can be reviewed, this will be Unresolved Item No. 400/83-05-01, Ground Areas on Pipe Support/Restraint No. 1-Sw-H-376. During the inspection, it was noted that the piping tolerances were indicated on Drawing No. CAR-2165, G107S02 (02 indicates sheet 2) with the approval initials in the sign off block and a Professional Engineering (PE) Seal. It appeared that the field installation tolerance for the supports/restraints inspections were being taken from sheet 1 of the drawing. The appropriate signatures and PE Seal were not affixed to this sheet. The licensee stated that sheet 1 was a Design Change Notification (No. 530-0769 Rev. 2). There was insufficient time during this inspection to review the licensee's procedure for handling Design Change Notifications and drawings and the safety significance was not of a level that would warrant an extended inspection. Until the relationship concerning approval signatures for these documents can be reviewed with the licensee, this will be Unresolved Item No. 400/83-05-02, Administrative Approval of Urawings Associated with Design Change Notifications.

(b) Review of UA Implementing Procedures

The inspectors conducted a general review of QA procedures to verify that all craft, NDE, and inspection personnel associated with the installation of pipe supports and restraints have been trained; that documentation for quality requirements of materials and components are met prior to installation; and that nonconformances and defects are documented and processed in accordance with established procedures. The following QA procedures were partially reviewed by the inspectors:

- Procedure CQA-1, "Personnel Training and Qualification", Rev. 12
- Procedure QAI-1.2, "QA/QC Personnel Qualification Requirements", Rev. 13
- Procedure NDEP-10, "Training Qualification and Certification of Nondestructive Examination Personnel", Rev. 3
- Procedure TP-40, "Training and Qualification of Construction Inspection Personnel", Rev. 4
- Procedure CQC-2, "Nonconformance Control", Rev. 4
- Procedure CQC-6, "Receiving Inspection", Rev. 0

(c) Review of Work Procedures

The applicable code for safety-ralated pipe support and restraint systems is the ASME Boiler and Pressure Vessel Code, Section III, Division 1, 1971 Edition including all addends through Summer 1973. Mechanical snubbers shall be to 1977 code plus addends through Summer 1978. The inspectors observed various activities and documents associated with the installation of supports and restraints to determine if code and procedure requirements were being met. The inspectors reviewed the following work procedures pertaining to safety-related pipe support and restraint systems to determine whether they were approved by authorized licensee personnel:

Work Procedure Appr	oved Date
MP-06, "General Welding Procedure for Carbon and Alloy Steel Pipe Weldments", Rev. 14	07/23/82
TP-04, "Calibration of Controlled Tools", Rev. 20	01/12/83
TP-34, "Inspection of the Installation of Safety-Related Pipe Hangers", Rev. 6	09/15/82
TP-39, "Inspection of Drilled-In Expansion Anchors", Rev. 4	10/13/82
WP-33, "Installation of Wedge Expansion Bolt Anchors", Rev. 6	09/28/82
WP-110, "Installation of Seismic Pipe Hangers and Supports for Seismically Analyzed Pipe", Rev. 7	11/11/82

In addition, the inspectors partially reviewed those work procedures to assure that technical adequacy of activities pertaining to safety-related pipe support and restraint systems were being met. This review was also performed to ensure that provisions for required preinstallation and in-process inspections are performed in a timely manner, and that bolts, nuts and washers are of the proper type and correctly installed.

Within the areas inspected, no violations or deviations were identified.

7. Safety-Related Piping - Unit 1

The inspector examined the welding activities described below relative to safety-related piping to determine whether applicable codes and specifications were being met. The applicable code for this work is the ASME Boiler and Pressure Vessel Code, Section III, Subsections NC and ND, 1974 Edition including Addenda through Winter 1976.

..

a. Observation of Welding Activities (55183)

The below listed welds were examined in process to determine work conducted in accordance with traveler; welder identification and location; welding procedure; WPS assignment; welding technique and sequence; materials identity; weld geometry; fit-up; temporary attachments; gas purging; preheat; electrical characteristics; shielding gas; welding equipment condition; interpass temperature; interpass cleaning; process control systems; identity of welders; qualifications of inspection personnel; and weld history records.

Weld No.	System
FW-1977	Service Water
FW-159	Residual Heat Removal
FW-142	Safety Injection
FW-2008	Service Water
FW-1950	Service Water
CS-103-2-SW-1	Chemical and Volume Control

b. Welder Qualification (55187)

The following welder qualifications records were reviewed:

Welder Symbol	System Observed Welding
B-7	Residual Heat Removal
- C-53	Residual Heat Removal
D-76	Service Water

The following welder performance qualification tests were observed in progress:

Welder ID	WPS
32/353	1A4
32/354	1A4

Within the areas inspected, no violations or deviations were identified.

SHEARCH SHEARCH	LINA POWER & LIGHT COMPANY N HARRIS NUCLEAR POWER PLANT HANGE REQUEST/PERMANENT WAIVER FCR.	AP-IX-05 Exhibit 1 Page 1 of 23
Type of Request: Permane	ommended Action Non-ASME ASME	Section III Division 2 Section III Division 1
Identification of Area and It		Q Q Non-Q
	Conflict/Condition	
and subb frag support	ment All structual steel HVA	C, Conduit
not welded connections due to the lack of acc	for support hangers as posessibility or misinter present as sketchely for typical as	fation of the
Recommended Action:	Please Investi	gate and Resolve
a well or where the	Please Resolve is it the construction to the field the option to page three	tuctibility of
	Incontrolled C	ODY
Justification: The requirement of the relocation of will not compresse the	the weld as proposed on structual integrity of	page three
Discipline Engineer	Site Approval: (2) 12/11/8	Dr. AML 12-18-80
irst Distribution: Original) Design Organization Copy) Thuck Forixh	DOCUMENT CONTROL (Com)	THE RESERVE OF THE PERSON NAMED IN COLUMN 2 IS NOT THE OWNER.
	USWISH VEW	

SHEARON HARAIS N. P P.

FCP-A5-384 Rer1	100	Pag	e 2 of 2
Design Organization Approval (AE)☑ (NSSS)□ (N/A) □	(Other)	Telephone R	lesolution 🛛 No
Approved as Recommended Rejected	Псо	nditional App	
This change requires the following Document(s) (Specific	ication Dr	awing SAP	roval
to be changed CHANGES TO BE SHOWN ON A	5-BUILT L	ow6.	tc.)
Comments:			
			1.14
f.n.		,	
Richolas C. Tassoulas AE 1/27/81 Mari	os. Ved	fello sec	1/18/81
Signature Title Date Sign	ature	Title	Date
CP&L Harris Plant Engineering Approval Required	☑ Yes	Telephone	Resolution
	□No	□Yes	⊠No
Approved as Recommended Rejected		ditional App	roval
21.00			
04/11/1 2/20	2/1	1111	- 1.1
Discipline Engineer Date MHPE	or PPE	1 2/2/3	
Site Concurrence: Recommend Dimplementation	OT PPE		Date
Dalternate Resolution	CS.Ham	ant la AML	2-2-81
	Senior Res	ident Engine	
Second Distribution: (Original) Document Control	(Copy)		
(Copy)	(Copy)		
(Copy)	(Copy)		
Implementation Completed as Approved?	□Yes		
Comments:	□No		
			1000
			1000
	Discipline	Engineer	Date
Final Distribution:	Discipline	Engineer	Date
Final Distribution: (Original) File in Doc. Control	Discipline (Copy)	Engineer	Date
	(Copy)	Engineer	Date
(Original) File in Doc. Control		Engineer	Date

SUBJECTDATE	COMPUTATION	FCR-A5-	334 Rer. 1
	, , , , , , , , ,		FORM NO. 1650
4.00 70070	0000	0 40 0 0 0 0 0	A days
		44/	4
Designed		FOR	360
		-1-	*
о́ Н	2		
504			
000	3.	0	V
DESCRED		From	300
00.4 :0 .0 T 0.8 T	0		o To
122		1/1	7/
		17	×
DESIGNED		Proro	V
		74070	20
H	C o		
			V-<
H	- Q	<u> </u>	
DESIGNED		Pearose	

WECELAED

FEB 3 1981

AP-IX-05 Exhibit 1

PROJECT ENCINEEDING PLU- A	5-391		Page	e_2 of 2
Design Organization Approval (AE)点 ()	NSSS) (N/A)	(Other)	Telephone Re	solution 🖸 No
Approved as Recommended	Rejected	T Con	ditional Appr	1
This change requires the following Docu				
to be changed CHANGES TO BE SHOW			wing, SAK, et	.c.)
Comments:				_
1.74.	/	40		, ,
Micholos C. Torroula DE 2/17/8		ry_	- PE 2/	18/11
Signature Title Date	Sign	atufe		Date
CP&L Harris Plant Engineering Approval	Required	Yes	Telephone R	esolution No
Approved as Recommended	Rejected		ditional Appr	oval
0 f Suil 2/5/81	0	Allow!	Malisk	71
Discipline Engineer Date	e MHPE	OT PPE	D	ate
Site Concurrence: Recommend Almplem	entation	,		
	ate Resolution	Senior Rest	dent Enginee	
Second Distribution:		(Copy)		
(Original) Document Control (Copy)		(Copy)		
(Copy)		(Copy)		
		(60)77		
Implementation Completed as Approved?		_		
		□Yes □No		
Comments:				
		0//-1/		
Final Distribution:		Discipline	Engineer	Date
RI	ECEIVE	D		
(Original) File in Doc. Control	1	(Copy)		
(Copy)	FEB 3 1981	(Copy)		1000
(Copy)	Alexander of the section of	(Copy)		
CIVI	M. WEBER			


7-001	CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT	AP-IX-05 Exhibit 1
6/80	FIELD CHANGE REQUEST FERMANANT WAIVER	Page 1 of 2
Type of Request:		tion III Division 2
Identification of I	trea and Item: 188 = 1 HARO Duct Support	Note Q Non-Q
	Conflict/Condition	
Reference Documents	or Attachment Aden Strel Contract No (1.398/ N Sheet F-21
2/	nnection detail drawing as mentioned	,
nformation per	taining to the proper sides to be well	ched Labor Flori
Recommended Action:	Please Investig	ate and Resolve
	Please Resolve	
Alla the field	to weld the sides indicated as s	hown in the
tour skatches	for the above mentioned Poden	St. I.
	11-	Drest chawing.
	Uncontrolled Cop	у
Justification:	TOR INFORMATION CHEY	
Justification:	By Ebases; DESIGN-INTENT.	SATISFIES
Requested by: Discipline Enginee	Site Approval: (S.Hinnant) Date Senior Resident E	2 AML 1-27-81
irst Distribution:	DOCUMENT CONTROL	Ingineer Date
(Original) Design Or	DEGENORES	
Copy Frat France	FEB 20 1981 (Copy)	Parketti and the second
	U) LER SO 1981 III	


SHEARON HARRIS N. P P.


PF-001 ev. 1. 1/6/30	CAROLINA POWER & SHEARON HARPIS NUCL	LIGHT COMPANY	Page.	AP-IX-05 Exhibit 1 of -2-7
Type of Request:	See Recommended Acti	on Mon-ASME	SME Section III	Division 2
Support Hangers	and Item: HUAC, onech	Cable Tray, and	dandit	Q Q Non-Q
Reference Documents or Truy and Conn	Conflict/Con	Four fum 1 s	rel HAC.	Cable
Frior to receive	Continua to	in sheef #	as show	ted by
batch marks (" where the design	m). The circle	should of	oco) indica	hes
FOR INFORM		J Please In	vestigate and Resolve as Follows	
	Allow to	se as is.	MEGE	T CONTROL 2 3 1981
Justification: Dans design drawings of accuracy of the miss. as shown on contract to a major up. Requested by:	interpretation	of the des	aratation of works chis	becoming screpations will
Discipline Engineer First Distribution: (Original) Design Organ (Copy) Fuck French	Date ization	Senior Residence (Copy (Copy (Copy)		Date


Continuation Sheet 1


Fix 45-446











EBASCO ATTACHMENT TO FCR-AS-446


COMMENTS:


As per telecon between Chuck French of CP&L and O S Yue of Ebasco on 4/15/81. Approval of welding any 3 sides of joint connection apply to hanger framings and hanger member to gusset plate joint in which it connects to embedded strip plates only.


76/30 SHE	AROLINA POWER & LIG ARON HARPIS NUCLEAR D CHANGE REQUEST/PE	POWER PLANT	Page Page	AP-IX-05 Exhibit 1 of 23
Type of Request: Permitted Property See	anent Waiver to "us Recommended Action	e-as-is" DASM	El Section III	vision 2
Identification of Area and Support Hangers - Mi	Item: HVAC, Ca leld Connection	ble Tray, and	Condit	□ Q □ Non-Q
Reference Documents or Att	Conflict/Condi	actural sto	el HARC. C	able
Prior to receiving the field welde the attached	djoint con	enections a	5 5 hown	00
where the design w	The circle	symbol (coc	o) indicar	les
FOR INFORMAT	TION ONLY.	Please Inve	stigate and Relive as Follows	solve
	Mow to use	as 15.	APR 2	3 1981 11 U E
Justification: Dure to design drawings and ware of the mising some is shown on continue to a minimum and respected by:	the training	the design	de since de wolds dis	t the becoming crepanies
Discipline Engineer Cirst Distribution:	3/5/8/ Date	Senior Reside	for AML	3-5-4/ Date
(Copy) (Fuck French	ion.	(Copy)		


Continuation Sheet 1


Fi 45-446











EBASCO ATTACHMENT TO FCR-AS-446

COMMENTS:

As per telecon between Chuck French of CP&L and O S Yue of Ebasco on 4/15/81. Approval of welding any 3 sides of joint connection apply to hanger framings and hanger member to gusset plate joint in which it connects to embedded strip plates only.

Fila: SH P-1/2

CONSTRUCTION QA SECTION PERSONNEL TRAINING

FOR THE CONTROL OF SHEET

Date: September 12, 1980
Training Period: 1k hours
Topic: Hanger inspection & documentation
(see attached outline)
Instructor: V. Safarian
The following personnel attended the above described training:

Pete Tingen
Judi McDonnell
Steve Mountcastle
William Pere
Ward Mercer
AT Wade
T.J. Wait

Instructor

Outline for Retraining

- A. Responsibility of Welding Inspectors
 - 1. Quality not Quantity
- * B. Inspection in accordance with requirements of Hanger Package
 - 1. Check PW, DCN, other pertinent data
 - C. Inspection in accordance with the Dwg.
 - 1. Weld symbol review (AWS)
 - 2. Verification of # of welds in accordance with the Dwg.
 - 3. Verification of type of welds in accordance with Dwg.
 - 4. RCI if question occurs in Dwg.
 - 5. No sign off if hanger not in accordance with Dwg. Package.
 - D. Documentation
 - 1. Dwg. sign off
 - 2. Traveler sign off
 - 3. Seismic WDR sign off

File: SH P-1/2

CONSTRUCTION QA SECTION PERSONNEL TRAINING

Date: 4/6/81

Training Period: 2 hours

Topic: Post Weld Heat Treatment

Instructor: Fasih Shaikh- Welding Engineering

The following personnel attended the above-described training:

Bruce Giles Ward Mercer Pete Tingen Jim Root Judi McDonnell Bill Russell Bill Pere Steve Mountcastle Andy Bartrom Clay Rhodes T.J. Wait

Distribution:
Personnel files for
above personnel

Instructor

PER MISSION SHLY

File: SH P-1/2

CORPORATE QA/QC SECTION

PERSONNEL TRAINING

Date: _	12-10-31
Training	Period: December 10, 1981 for 1 hour
Topic:	Inspection and documentation of Seismic Pipe Hangers
Instructo	T.J. Wait
The follo	owing personnel attended the above described training:
Bil	es Root 1 Pere
Ste	Stanley ve Mountcastle
Gil	bert DeBarros

SHERRON HARRIS POWER PLANT

QC RECEIVING TRAINING PROGRAM

INSTRUCTOR:	Dail A Statt
LENGTH OF CLASS	: 8- hours
THE FOLLOWING P	ERSONNEL ATTENDED THE ABOVE DESCRIBED TRAINING:
3. Ray 4. Pa 5. DAU 6. 7. 8.	ett Hint orge Danul ert Cates wel Holler in C. WHOTEHEAD
10.	AWS D.I.I WAS UTILIZED AS COME REFERENCE

all 0 1/2 11.1.00

SHERRON HARRIS POWER PLANT QC RECEIVING TRAINING PROGRAM

0

DATE: SUBJECT COVERED	A. D. S. Welsting Symbols
INSTRUCTOR: LENGTH OF CLASS	1- hour Lucien
1. Da 2. Kh 3	ersonnel attended the above described training: well Holler, ett thunt ent Cotto ange Daniel erd Whitihead
COMMENTS:	AWS DIN WAS USED AS CONE REFERENTE
VERIFIED BY: -	David C. Whitehead Plate Date

SHERRON HARRIS POWER PLANT QC RECEIVING TRAINING PROGRAM

Namelianos	GEORGE M. DANIEL	FULL PENETRAT
NSTRUCTOR:	30 MIN.	
1. Lefter 2. John 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	Hollie Land	CMLY
10.		

VERIFIED BY:

David C. Whitehead QA SPECIALIST 9 11 To

SHERRON HARRIS POWER PLANT

QC RECEIVING TRAINING PROGRAM

DATE: //	-16-79
	TORTION AS DELINEATED IN
INSTRUCTOR: Jeff	vey V.P. MeLeg
LENGTH OF CLASS: 20	min.
THE FOLLOWING PERSONNEL AT	MENDED THE ABOVE DESCRIBED TRAINING:
2. Salar Ceta 2. Salar A Cura 4. DAVIS HOUSE 5. Miles Supplies 6. Line of the Salar Supplies 8. 9. 10.	ue_
ALL QUESTIONS	
LENGTH OF CLI	ASS WAS 20 MIN
VERIFIED BY:	ecolculated 1/16/A wid C. Whitehead Date QA SPECIALIST

be: # Oslick E Gebet

W Szablowski

J Joseph I Grosz A M Gagliardi/P Fi

R Hall File Custodian

Nech File

EBASCO

JAN 18 1982

EB-S-1730 File Nos. :

50-P-1 5Q-M-30

Mr John Harris, Project Manager Southwest Fabricating and Welding Co, Inc PO Box 9449 Houston, TX 77011

Dear Mr Harriss

Subject: CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT SF & W'S FABRICATION ISOMETRICS P O NY-435035

Attached please find the list of SF & W'S Fabrication Isometrics which have been reviewed by Ebasco. Letters shown in the remarks column for each drawing refer to notes applicable to that particular drawing as follows:

- I Reviewed without comments, proceed with fabrication
- Reviewed with comments, do not proceed with fabrication without receipt of Ebasco's comment print

Please note that the required resubmittal of the prints to SF & W Company will follow shortly.

Very truly yours,

PF:mc Attachment

E Gebet .

Assistant Project Manager

cc: L I Loflin L H Martin

Plant Manager c/o C R Gibson

R M Parsons

SOUTHWEST FAB.	OUTHWEST PAB. EBASCO			
ISO NO.	REV	DWG NO. 1364-	REV	REMARKS
1 - SI- 133	,	47154	,	×
141	1	46922	,	
150	,	45059	,	
151	,	45470	1	
. CS - 237	1	469/0	1	
238	1	46911	1	一位是有一位。
229	,	469/2	,	
127	2	43057	1	
176	2	41182	2	
177	2	4/192	2	
178	2 -	41/91	2	
177	2	41190	2	
180	1	41189	1.	
181	1	41188	1	
192	'	41187	1	
1 /22	1	41186	1	•

SOUTHWEST PAB.		EBASCO		
ISO NO.	REV	DWG NO. 1364-	REV	REMARKS
. CS - 200	,	47035	,	×
185	2	41184	2	
201	,	47036	1	
100	,	47038	,	
10;	,	47039	,	
205	,	47040	,	
206	,	47041	1	
207	1	47042	,	
107	,	47157	1	
2/0	1	47044	1	
211	'_	47045	1	
2/2	1	47/58	,	
211	,	47159	1	
1/8	1	47050	1	
210	'	47052	1	
226	,	47054	11	

!

SOUTHWEST PAB.		EBASCO		
ISO NO.	ISO NO. REV		REV	REMARKS
. CS. 226	,	47056	1	×
7 227	1	46500	11	
22.4	1	46901	11	
229	1	66902	Ш	
230		46707	111	
93/	1	66504	Ш	
223	1	46906	\coprod	
276		46507	Ш	
235		46908	Ш	
276		46907	Ш	
240		46913	\prod	
241		46914	$\parallel \parallel$	
242	Ш	46915	\coprod	
243		46916	\coprod	
244		46917	\coprod	A THE STATE OF THE
245		L7/60	111	1

OUTHWEST PAB.		EBASCO				
ISO NO.	DWG NO. REV 1364- REV			REMARKS		
· CS · 248	1	47163	1	X		
249	Ш	47164	\coprod			
250	Ш	47165				
251	Ш	47/66	\coprod			
252	Ш	47/67				
253	\coprod	67167				
254	\coprod	47/69	Ш			
255	4	47/70	Ш			
256	11	27/71	Ш			
260	11	7/75	Ш			
262	. 4	7177	Ш			
263	10	7178	Ш			
264	14	7/79	Ш			
265	4	7/80	Ш			
266	1. 4	7/8/	Ш			
267	14	7/82	11.			

OUTHWEST FAB.		EBASCO	11111	
ISO NO.	REV	DWG NO. 1364- REV		REMARKS
CS. 268	1	47/83	1	×
269	\parallel	47184	11	
270	\parallel	17/85	11	
271		27/86	111	
272		47/87	Ш	
273		47/88	Ш	
274	1	47/89	Ш	
275	2	41190	Ш	
176	1	47191	Ш	rice di Englis
277		47/92		
278		47/93	11.	
277		67/49	Ш	
200		47/50	Ш	
28/		47151	\coprod	
282	4.	47/52	111	
CT: 16	+	45837	111	

CONTROL SO DOCUMENT -

CAROLINA POWER & LIGHT COMPANY

ASME

CORPORATE QUALITY ASSURANCE DEFATIMENT SECTION III

ENGINEERING AND CONSTRUCTION QUALITY ASSURANCE/SLIALITY CONTROL SECTION

41.16

PERSONNE TRAINING AND QUALIFICATION

NUMBER:

COA-1

INITIAL ISSUE DATE:

March 16, 1981

RECOMMENDED FOR APPROVAL

DIRECTOR - SAPP DA/OC

APPROVED BY:

MANAGER - ESC DA/OC

CONTROLED TOCKET

CAROLINA POWER & LIGHT CO-PANY CORPORATE QUALITY ASSLETANCE DEPARTMENT QA/QC - HARRIS PLANT SELTION

'NUMBER

REVISIO4

COA-1

TITLE: PERSONNEL TRANSMIT AND QUALIFICATION

1.0 PURPOSE

The intent of this procedure is to establish requirements and guidelines for training and qualification of personnel assigned to perform DA IC activities at a nuclear power plant.

2.0 SCOPE

This procedure is applicable to the site Quality Assurance/ Quality Control Unit personnel who perform inspections, surveillances, evamination or testing activities; that are intended to assure quality of construction or to verify conformance to quality requirements; and personnel who review and accept or approve inspection, examination or test documentation or other quality affecting documents (e.g. procedures, instructions and specifications). Nondestructive Examination (NDE) personnel training and qualification will be in accordance with Reference 1. For the purposes of this procedure, references to inspection activities includes surveillance. This is an ASME Section III procedure.

3.0 REFERENCES

- 1. Comporate QA Department Nondestructive Examination Manual (NDE Manual)
- 2. Instruction CAI-1.1, Visual Acuity and Color Perception Tests
- 3. Instruction CAI-1.2, CA/CC Personnel Qualification Requirements

4.0 RESPONSIBILITIES

4.1 Manager - CA/CC - Harris Plant Section

The Manager - 24/OC - Harris Plant Section shall be responsible for staffing the QA/QC Unit with personnel meeting the appropriate classification requirements.

4.2 Director - DA TC

The Director - CA/OC shall have overall responsibility for implementation of this procedure.

4.3 Superintendent - QC

The Superintendent - QC is responsible to the Director - QA/QC for implementation of this procedure.

. ...

CAROLINA POWER & LIGHT COMPANY CORPORATE GUALITY ASSURANCE DEPARTMENT QA/QC - HARRIS PLANT SECTION

"LIMBER

REVISION

CCA-1

11

TITLE: PERSONNEL TRAINING AND QUALIFICATION

4.4 Quality Assurance/Cuality Control Subunit Supervisors

QA/QC Subunit Supervisors stall tave overall responsibility for implementation of this procedure in their assigned areas of responsibility.

4.5 Quality Assurance/Quality Common Specialists/Engineers

Site QA/QC Specialists/Engineers shall be responsible for indoctrination, training, qualification and evaluation of QA/QC personnel in their assigner areas of responsibility.

5.0 EDUCATION AND EXPERIENCE

- 5.1 Personnel performing CL/QC activities shall meet the education and experience requirements set forth in Appendix A.
- 5.2 Acceptable equivalents to the education levels listed in Appendix A are as follows:
 - In lieu of high school: Military (USAFI), state, county, or local school system him school equivalency GED; or two (2) years experience in construction operation or inspection work similar to that covered by the inspection activity.
 - 2. In lieu of 2-year degree in angineering/technology:
 Satisfactory completion of college credits which can be
 evaluated to be comparable to that required for a 4-year
 degree; or two (2) years experience as a QA/QC Inspector
 in a nuclear program.
 - 3. In leiu of a 4-year degree in mon-engineering discipline: Satisfactory completion of college credits which can be evaluated to be comparable to that required for a 4-year degree; or two (2) years experience as a QA/QC Inspector in a nuclear program.
 - 4. In lieu of a 4-year degree in engineering: Four (4)
 years experience as a 11/20 Inspector in a nuclear program.

CONTROLLED DOCUMENT

CARCLINA POWER & LIGHT COMPANY CORPORATE CLIALITY ASSURANCE DEPARTMENT CA/CC - HARRIS PLANT SECTION

NUMBER

REVISION

CCA-1

TITLE: PERSONNEL TRAINING AND QUALIFICATION

- 5.3 The experience levels listed in Appendix A are for directly related experience in work that is technically equivalent to that which will be covered by the specific inspection/testing activity. Prior experience in construction operation or inspection work which is only similar to the inspection/ testing activity may be substituted for directly related experience on a 2-month for 1-month basis, not to exceed two-thirds of the total inspection experience requirement.
- 5.2 Prior experience may be applied to the experience level requirements for more than one inspection/testing activity provided the requirements of 5.3 above are met.

6.0 PEYSICAL CONDITION

- 6.1 QA/QC inspection personnel shall meet the physical requirements for the particular CP&L classification involved at initial hiring.
- 6.2 Contracted personnel employed to augment CP&L QA/QC inspertors shall meet the physical requirements of their employers.
- 6.3 QA/QC and augmented inspection personnel shall be tested to assure:
 - 1. Natural or corrected near distance acuity such as being capable of reading the J-1 letters on a standard Jaeger"s test-type chart or equivalent test type.
 - 2. The capability for distinguishing and differentiating contrast between colors as demonstrated by practical demonstration or test performance.
- 6.4 Personnel that fail the near distance acuity or color sense testing may be evaluated and, through satisfactory demonstration of capability to perform the required inspections, forma acceptable for certification for a sub-category of inspection. The personnel records small reflect the evaluation process used and any inspection Limitations imposed.
- 6.5 The test specified in 6.3 (or as allowed by 6.4) shall be conducted on an annual basis.
- 6.6 Prior to fuel loading applicable CA/QC inspection and supervisory personnel (including contract personnel) involved in plant Start-Up/Operations activities will participate in the company sponsored respiratory protection program annual physical.

-3-

CAROLINA POWER & LIGHT COFFANY CORPORATE QUALITY ASSURANCE DEPARTMENT QA/QC - HARRIS PLANT SETTION

NUMBER

REVISION :

CQA-1

17

TITLE: PERSONNEL TRAINING AT THE THEATTON

7.0 INDOCTRINATION AND TRAINING

7.1 Newly assigned personnel (CP&L and augmented) will be trained in the performance of their intended assignment(s). Training shall be accomplished through a program consisting of indoctrination and m-the-job training (OJT) under the direct supervision of qualified personnel. The degree of training will depend on the amount of previous experience and training.

Emphasis will be im firsthand experience gained through actual performance of processes, tests, examinations and inspections. As the inspectur in training develops proficiency, he may be allowed to perform tertain inspection functions under the supervision of the training develops proficiency, he may be allowed to perform tertain inspection functions under the supervision of the training to the qualified inspector is responsible for reinspection to the extent necessary to verify the accomplished by the qualified inspector and certifies his accomplished by the qualified inspector and certifies his accomplished by the completed work.

- 7.2 (a) Personnel performing QA/QC activities shall be incoctrinated in mose project informational areas necessary for effective coordination and accomplishment of their assigned activities and responsibilities. Indoctrination shall be incommented on QA/QC Personnel Indoctrination Check-Off (Form CA-7) and consist of, but not be limited to:
 - . 1. Organizational Relationships
 - 2. Intrauction to appropriate site personnel
 - 3. Dities and Responsibilities
 - 4. CFL CCL CCC Procedures, Instructions, reports
 - 5. Technical objectives of site CCA/CQC Procedures.
 - 6. Codes amd Standards to be employed.
 - (b) QA/QI personnel involved with plant Start-Up/Operations prior to fuel loading will receive indoctrination in:
 - 1. Excisiogical Health & Safety Program
 - 2. Emermony Action
 - 3. Industrial Safety Program
 - 4. Fire Protection Program
 - 5. Security Program

CONTROL ED DOCUMENT

CAROLINA POWER & LIGHT COMPANY CORPORATE CLIALITY ASSURANCE DEPARTMENT QA/2C - HARRIS PLANT SECTION

"L"EER

REVISION

12

TITLE: PERSONNEL TRAINING AND QUALIFICATION

> 7.3 Appendix A to this procedure specifies the training time required for the individual inspection/testing antivities. Where the inspector in training has been previously certified for the inspection/testing activity by another organization, the classroom* hours may be reduced by ome-maif and the OUT ** hours may be reduced by two-thirds. Fersonne: qualified for construction phase CA/QC activities including those qualified through teh CI training program, are considered qualified for equivalent Start-Up and Operation phase QA/QC activities provided indoctrination is received and documented in applicable Start-Up/Operation phase procedures.

- Notes: *Classroom training includes lectures, discussions. and demonstrations of the uses of documents, tools, and equipment related to the inspection, testing activity; and the administration of appropriate examinations and tests.
 - **Where equally applicable to more than one inspection/testing activity, CJT time may be applied to each of the appropriate activites.
- 7.4 Formal training administered by the QA/QC Specialist/ Engineers/Subunit Supervisors to develop or maintain the proficiency of inspection personnel, shall be documented. Those training records shall include the following information:
 - 1. Name of Inspector
 - 2. Subject Matter
 - Date
 - Time Spent
 - 5. List of Attendees

8.0 CUALIFICATION PRIOR TO CERTIFICATION

Prior to assignment to perform specific inspection/testing functions. CA/2C personnel shall meet the minimum requirements for the assignment as delineated in Appendix A. Classroom, self-stury and practical demonstrations shall be performed and documented in accordance with Reference 3.

CONTROLLED DOLMET

CARCLINA POWER & LIGHT COMPARTMENT
CORPORATE QUALITY ASSURANCE COMPARTMENT
CA/CC - HARRIS PLANT SECTION

NUMBER .

REVISION

CQA-1

11

TITLE: PERSONNIEL TRAINING AND CONTENTION

8.0 (cont.)

Qualification recommend of company personnel transferred, from other units or remarked hired from organizations which provide direct services to the DA/OC Unit, will be reviewed for acceptance against the requirements of this procedure. The Inspector's personnel file all the annotated to show the results of the review and identify are training and/or testing required prior to certification. Where me minimized training is required, certification/recertifications may be affected based on previous qualifications.

9.0 CERTIFICATION

- 9.1 Subunit Eurermicrs, CA/OC Specialists and Engineers
 - 9.1.1 Subject Supervisors, QA/QC Specialist and Engineers are assigned supervisory and technical responsibilities masset stally on combinations of formal education, previous training, previous work experience and more letter of indoctrination to satisfactorily perform their assignments. Such personnel are considered qualifies without examination to perform the following functions as applicable to the activities within their assignments:
 - T. Train. qualify and supervise QA/QC personnel in imprectaion, monitoring and testing assignments.
 - Sewimp and administer oral/written qualification
 - E. Ewaliane capabilities and performance of QA/QC
 - Evaluate results of examinations, inspections and tests.
 - 5. Develop and prepare new QA/QC procedures and importantions.
 - E. Hertiew QA/QC and Construction operations procedures and immetractions for appropriate commitments and requirements.
 - 7. Demminal review of site generated documents which furnism documentary evidence of the quality of municipal safety related items and of activities affecting quality.

CAROLINA POWER & LIGHT COMPANY CORPORATE GUALITY ASSURANCE DEPARTMENT QA/QC - HARRIS PLANT SECTION

"MEER

REVISION

CAA-1

13

TITLE: PERSONNEL TRAINING AND QUALIFICATION

9.1.1 (cont.)

- 8. Heriew of procurement occuments for inclusion of GA requirements.
- Feview of Suppliers' documentation to assure produced items comply with LA requirements of producement documents.
- Flan, schedule and supervise inspections and surveillance of construction and operations activities.
- Identify quality problems and initiate, recommend or provide resolutions.
- 9.1.2 Other activities assigned to the Subunit Supervisors are as follows:

9.1.2.1 QA Surveillance

- Perform CA Surveillance of construction installation, inspection and testing activities.
- Perform CA Surveillance of selected general activities supporting rather than directly related to the installation. testing or inspection of permanent plant items or structures.
- Perform technical document review of construction 14 Reports.

9.1.2.2 Civil & Structural

- Sampling and testing of concrete materials (i.e. cement, aggregate, admixtures and water).
- 2. Concrete production.
- 3. Sampling and testing of plastic concrete and grout.
- 4. Compressive testing of concrete and grout.

CAROLINA POWER & LIGHT COMPANY CORPORATE CLIALITY ASSURANCE DEPARTMENT QA/OC - HAPPIS PLANT SETTION

MUMBER

FE / !! ! !!

CQA-1

188

TITLE: PERSONNEL TRAINING AND COALIFICATION

9.1.2.2 (cont.)

- Tensile testing of reinforcing steel bars and cadweld specimens.
- Installation of Mechanical splices (cadwelds, in concrete reinforcing tark.
- Calibration and field adjustment of measuring devices.
- 8. Windsor Probe System of testing contrete strength in place.

5.1.2.3 Materials & Records

- Receipt storage and issue of nuclear safety related plant items and consumables.
- 2. Construction site procurement of nuclear safety related plant items and construction.
- 3. Accumulations, review, filing and common of records which are required to furnish documentary evidence of the quality of nuclear safety related items and of activities affecting quality.
- Control of construction and operations control documents.
- 5. Control of records of permanent plant items transferred between units or off-site.
- 6. Assembly of Code Data Reports for same to the National Board.

F.1.2.4 Mechanical & Welding

- 1. Installation and pressure testing of process
 systems, components and HVAC duct work.
- Field fabrication/modification of piping subassemblies.

CONTROLLED DOCLMENT-

CAROLINA POWER & LIGHT CIFANY CORPORATE QUALITY ASSURANCE DEPARTMENT CA/QC - HARRIS PLANT SECTION

NUTBER REVISION

CQA-1

13

TITLE: PERSONNEL TRAINING AND CLALIFICATION

9.1.2.4 (ccat.)

- 3. Application of "N" type symbol stamp to ASME Come Class piping and subassemblies and systems.
- 4. Preparation of ASVE Code Data Reports.
- 5. Cleanliness inspections of piping systems and components.
- 6. Inspection of code valves.
- 7. Qualification of welders and welding operators.
- B. Field welding of ASME Code Class and non-code class piping.
- 9. Installation welding of pressure boundary components.
- 10. Installation welding of Seismic Category I structural steel members, hangers and supports.
- 11. Field fabrication welting of piping subassemblies. tarks, structural steel members, hangers and supports (including studs).
- 12. Installation welding of steel liner plate.
- 13. Post-weld beat treatment.

9.1.2.5 Start-Up/Operations

- 1. Procedure Review
- 2. Turnovers
- 3. Document Beriew
- 4. Maintenance and Modification Control
- 5. CA Surrellime of Start-Up/Operations
- 6. Inspections

TOTALE DOCIEVI

- 4

CARCLINA POWER & LIGHT COMPANY CORPORATE QUALITY ASSURANCE DEPARTMENT ON TO - HARRIS PLANT SECTION

NU ==

-EVISION

C=1-:

12

TITLE: PERSONNEL TRAINING AND CTALIFICATION

- g.1.3 Farsonnel, not necessarily classified as 12 12 Epecialists/Engineers may be assigned supermissing responsibilities within their areas of terminal expertise when evaluated by the CA/QC Submit Supervisor as being capable of performing the supervisory assignment. The evaluation shall be incumented and shall take into account the following factors:
 - t. Education
 - 2. Experience
 - 3. Demonstration of Capability
- F.2 Personnel performing CA/OC activities will be elimitated for certification after complying with paragraphs E.1 or 9.0 as applicable. Certification shall be documented on CA/OC Personnel Qualification/Certification (From Lagrange shall contain, but not be limited to, the following information:
 - 1. Employer's Name
 - 2. Name of person being certified
 - 3. Activity qualified to perform
 - 4. Date of certification and effective period
 - 5. Basis for certification
 - f. Simature of Director or his designee
- F.3 Certification by the Director means the inspector is notified to perform the following as applicable to the inspection.

 **Testing activity:
 - 1. Record inspection, examination and testing data.
 - 2. Implement approved inspection, examination and terring procedures.
 - Plant inspections, evaluations and tests; serving ment.
 including preparation and set-up of related equipment.
 - Evaluate the validity and acceptability of insperim.
 examination and test results.

CAROLINA POWER & LIGHT CO-PANY CORPORATE QUALITY ASSURANCE DEPARTMENT QA/QC - HARRIS PLANT SECTION

MUTER

REV!SION

CCA-1

11

TITLE: PERSONNEL TRAINING AND QUALIFICATION

9.3 (cost.)

- 5. Report inspection, examination and test results.
- 6. Supervise other inspection/testing personnel.
- 7. Train other personnel.
- Use calibrated tools and equipment required for the inspection/testing activity.
- 9.4 Appendix 4 to this procedure identifies the incivitual supervisory and inspection/testing activities for which CA/QC personnel may be assigned.

10.0 MEN INSPECTION ACTIVITIES

In the event a new work activity and the associated inspection activity are concurrent so as to preclude prior qualification of inspection personnel, inspection of the work shall be under supervisory control of the cognizant QA/QC Specialist, Engineer or Subunit Supervisor. Assistance from the cognizant discipline engineer and manufacturer's representative may be requested to facilitate initial qualification of inspection/testing personnel. The required CUT may be waived upon satisfactory demonstration of ability to perform the inspection/testing function.

11.0 EVALUATION AND RECEPTIFICATION

- 11.1 The job performance of QA/QC personnel shall be evaluated at intervals not to exceed two (2) years. QA/QC personnel who have not performed inspection/testing activities for which qualified within a period of one year shall be reevaluated prior to assignment to perform that inspection or test.
- 11.2 If the results of the performance evaluation(s) are satisfactory, the individual's certification shall be continued.
- 11.3 If, during the above evaluation or at any other time, it is determined that the capabilities of an individual do not meet the requirements of the inspection/testing activity, that individual small be removed from the activity until such time that the required capability has been demonstrates.
- 11.4 Recertification will be documented on QA-49A Forms.

-DITROLED DOCUMENT-

CARILINA POWER & LIGHT COMPANY CORPORATE QUALITY ASSURANCE DEPARTMENT QA OC - HARRIS PLANT SECTION

TUE:

REMISION

22.-

11

TITLE: PERSONNEL TRAINING AND QUALIFICATION

12.3 RECORDS

- 12.1 A file of QA/QC personnel certifications completed QA-9/49A Forms) shall be retained in LA Records.
- 12.2 A file of records required to support the pertification of personnel assigned to perform 14/21 activities small be established and maintained. The file small include. as a minimum:
 - 1. Visual Acuity Test Results (Form 21-72
 - 2. Physical Examination Results or Engraphet Statement
 - 3. Resume' of Education and Experience
 - 4. Indoctrination (Form QA-47)
 - 5. Other training such as the respiration program, health physics, security, att.

13.3 APPENDIX

13.1 Appendix A, QA/QC Education, Experience & Training Requirements

CA/OC EDITATION. EXPERIENCE & TRAINING REQUIREMENTS

	WKS.	EMPERIENCE REQUI	REC	HRS. TRAINING	
INSPECTION/TESTING ACTIVITIES	HIGH	2-YR ENGR/TECH 4-YR NON-ENGR	YR ENGR	CLASS- ROOM	0-1
CIVIL/STRUCTURAL		in makes the life			
Concrete Compression Testing	2	1	3	2	24
Sieve Analysis	2	1.	C	2	-6
Field Testing of Concrete	2	1	3	2	22
Rebar & Cadweld Tensile Testing	2	1	3	3	24
Concrete Material Testing	4	2 -	0	2	45
Grout Testing	2	1	0	1	16
Cement False Set Testing	2	1	0	2	15
Concrete Batch Plant Inspector	12	4	2	4	40
In-Place Concrete Test by Windsor Probe System	2	1	0	2	16
Cacweld Inspector	8	4	2	4	40

QA/CC EDUCATION, EXPERIENCE & TRAINING RESTIREMENTS

	WKS.	EXPERIENCE RENUT	E	ET : HRS. TRAINING		
INSPECTION/TESTING ACTIVITIES	HIGH SCHOOL	4-YE NOW-ENGE	ENGE.	CLASS- ROOM	0,57	
MATERIALS & RECORDS						
Receipt Inspector					143	
1. Secondary (OR Received)	12	f '	4	4	20	
2. Rebar	16		6	4	20	
3. NSR Categories I & II Off-the-Shelf Items Consumables	16	I -	é	4	20	
4. Stock Steel & Bolting Stock Tubing, Pipe and Fittings (FP & Radwaste) Stock Tubing, Pipe and Fittings (Code Class)	24	12	-	6	20	
5. Weld Filler Materials	40	2:	16	8	2	
6. Engineered Items (Seismic I) Engineered Items (NSR Categories I & II, Radwaste & Fire Pro- tection) Primary -Engineered Items	44	Z	17	s	3	
Purchase Requisition Review						
1. Non "Q"-List Items	8		2	8	2	
2. "Q" -List Items	24	-2	6	8	4	
Qi Records Clerk	8	2.1	N/A	5	8	

CAPOC EDUCATION, EXPERIENCE & TRAINING REQUIREMENTS

EXSTRUCTION TESTING ACTIVITIES ACCHARGAL WELLOWS	HIGH	2-YR ENGR, TECH	TR	; CLASS-	, 0,57
MECHANIZAL WELDONG		4-YR NON-ENGR	ENGR	EDIM	1 33.
	1			1	
Cleamess Inspector	8	1 4	2	. I	20
Pressre Tasting Inspector	8	6 .	4		20
Valve am Impinent Installation Inspector	24	8	4		30
Pipe Empol Farmication/ Modification Inspection	12	8 -	4	-	20
Pipe, Pool Liner Weld	24	12	6	:	ac
Structural Wel: Inspector	16	8	4		30
Stud Welding Imspector	16	8	4		40
Post Weld Heat Treatment	8	, 4	2		40

QA/OC EDUCATION. EXPERIENCE & TRAINING REQUIREMENTS

INSPECTION/TESTING	. WKS.	EXPERIENCE RECUI		HRS. TRAINING		
ACTIVITIES	HIGH	2-YR ELGR, TECH 4-YR NIN-ENGR	ENGE.	CLASS-	2,17	
START-UP			furth area	!		
Turnover - Mechanical	24	· -	2	2	16	
Turnover - HVAC	24		2	2	16	
Turnover - Electrical	24	-	2	2	16	
Turnover - I&C	24	-	2	2	16	
Turnover - Structural/Civil	24	-	2	2	15	
Cleanliness Inspections	8	-	2	2	20	
Instrumentation Inspections	24	12	2	4	20	
Mechanical Inspections	24	-:	4	5	. 40	
Electrical Inspections	24	12	4	6	40	
Surreillance - PSI/ISI	24	12	4	3	20	
Surveillance - Operations	24	12	4	2	20	
Surreillance - Maintenance	24	12	4	3	20	
Surveillance - EARC	24	12	4	3	20	
Surreillance - Start-Up Activities	24	12	4	2 -	20	
Surveillance - Administrative	24	:2	4	2	10	
Surveillance - Technical Support	24	12		2	10	
Surveillance - General (Refer to Note 1)	24	12	4	4	20	
Note: 1. General surveillance certification will cover basic item such as cleanliness, house-keeping, training and qualifications. This certification will provide the methods for preparing, conducting and	9					

reporting surveillances.

DA DE EDUTATION. EMPERIENCE & TRAINING REQUIREMENTS

	AKS.	EXPERIENCE RECUI	RED	1 111 - 111 - 1		
INSPECTION, TESTENG	HISH	2-YR ENGR/TECH 4-YR MON-ENGR	4-YR EMGR	CLASS-		
START-UP						
Maintenance Instructor Review	24	8	2	2	:2	
Start-Up Instruction Review	24	8	2	1	:2	
E&RC Instruction Review	24	8	2	1	-2	
General Procedures : Instruction Review	24	8	_ 2			
WR&A Review	16	8	2	2	:2	
CaR&A Review	16	8	2	2	-2	
STs/PTs Reriew	16	8	2	2	:2	
Plant Modification Review	24	12	4	-	2-	
Calibration Monomoformances Review	12	12	1		_	
					Many of the second of the seco	
					The state of the s	
					Marie de Carrello	
					-	

QA/QC EDUCATION, EXPERIENCE & TRAINING REQUIREMENTS

INSPECTION/TESTING	WY.S.	EXPERIENCE REC				
ACTIVITIES	HIGH SCHOOL	2-YR ENGR. TEG 4-YR NON-ENGR	HYR ENGR	CLASS- FOOM	0,57.	
	!			<u> </u>		
TISCELLANEOUS (Non-Inspection/Testing Activities)						
QA/QC Subunit Supervisors	468	364	240	::/à	:/;	
QA/QC Specialist	312	208	_ -:-	: ::/*	::/2	
QA/QC Engineer	N/A	N/A	36	. :::/A	:1/2	
				i		
					-	
					4	

DA TO EXPERIENCE & TRAINING REQUIREMENTS

....

	WMS. EXPERIENCE RECUIRED					
INSFERENCE AND ADDRESS AND ADD	HIGH SCHOOL	2-YR ENGR/TECH 4-YR NON-ENGR	TR ENGR	CLASS-		
CA SURVEIL'LINE						
Concrete Placement Admitor	24	8	4	5	-0	
Concrete Testing William	24	8	4	5	+2	
Grout Placement Montage	12	4	2	3	7.5	
Structural Stat Excelor Monitor	12	4	2	4	+7	
Cadwelding Immail Amitor	12	4	2	-	+D	
Sbils Control Manning	24	8 -	4	5	40	
Expansion Archir Tratallation Monitor	12	4	2	2	7.5	
Electrical Farmary Conduit Installation Monitor	24	8	4		20	
Cable Pulling, Territation and Testing Moritary	24	8	4	-	20	
Cleanness Carrol Manitor	12	4	2	2	50	
Protective Towns implication Monitor	24	8	4	4	50	
Mechanical Egipper Insalla- tion Monitor	- 24	8	4	4	30	
Hydrostatic Test Menitor	12	6	4	-	20	
Hanger & Supert Installation Monitor	24	8	4	4	38	
Piping Installation Monitor	24	8	4	4	30	
HVAC Ductork Installation	16	8	4	4	20	
Receiving Install Maritor	44	22	17	E	40	
In-Process Well Inslity Qualifications Monitor	24	12	6	Ε.	4	
Final Welf Dality Monitor	24	12	6	E	41	
Non-Destructive Exemination Monitor	44	22	17	E	4	
General Latitum Monitor (Refer to Note 3	24	8	4		2	
Electrical Entry Instruenta- tion Installation Monitoring	24	8	4		2	

QA/QC EDUCATION, EXPERIENCE & TRAINING REQUIREMENTS

TYPE PER TON A PER TYPE	WKS.				HAS. TRAINING		
INSPECTION/TESTING ACTIVITIES	HIGH SCHOOL	2-YR ENGT. TECH 4-YR NON-ENGR	YR ENGR	ROOM	0,57		
CA SURVEILLANCE (cont.)							
Note:							
1. Qualification of CA/CC Inspectors for surveillance of on-site contractor activities is provided by qualification for specific surveillance activities. For example, surveillance of contractor welding activities shall be performed by an inspector qualified in weld control surveillance.							
2. Qualification of QA/QC Inspectors for technical review of site generated records is provided by specific activity qualification. QA/QC Inspectors qualified for specific activity are thereby qualified to review records generated within the scope of that activity.							
3. Site CA Surveillance personnel may be considered qualified for general surveillance by virtue of their qualification in one or more specified surveillance activities. In this case, the qualification shall require the completion of required indoctrination, self-study and classroom training; additionally, personnel shall meet the education and							
experience requirements out- lined in this Appendix. OJT, practical demonstrations, and examinations shall not be required when qualification is accomplished by this							

CAST ETCATES. EXPERIENCE & TRAINING REQUIREMENTS

		EXPERIENCE RECUI	1 43. 7.7.7.7	
INSPECTION TESTING	HIGH SCHOOL	2-YR ENGR/TECH 4-YR NON-ENGR	YR ENGR	CLASS- II
QA SURVEILLANCE (com:.)	30302	1		1
personnel may be conscience qualified for surveillance of inspection activities for which they hold or have the valid CPAL certification. In this case, the qualification shall require the completion of required indoctrination and self-study. Additionally, personnel shall meet the editoration and experience requirements outlined in the appendix. No additional QT, classroom training, practical demonstrations are summations shall be required when qualification is accomplished by this method.				

Treining 146

TO: RAY Howford RA 10/20/80

FRAM: Tavid Timber of

SUENTET: Welder Training Class

On Friday October 17,1980 of conducted two welder training classes for the structural welders (#32 craft) and some CP & 2 personnel (engineers and Q.A.).
Attached in an author and lint of attending personnel.

to be produced in response to 41-7

P. O. Box 101, New Hill, N. C. 2756: October 3, 1983

Mr. James P. O'Reilly United States Nuclear Regulatory Commission Region II 101 Marietta Street, Northwest (Suite 2900) Atlanta, Georgia 30303

NRC-126

CAROLINA POWER & LIGHT COMPANY
SHEARON HARRIS NUCLEAR POWER PLANT
1986-90 - 900,000 KW - UNITS 1 & 2
SHOP WELDING DEFICIENCIES IN SEISMIC I PIPE HANGERS
SUPPLIED BY BERGEN-PATERSON, ITEM 95
UNDERSIZE SKEWED TEE FILLET WELDS ON SEISMIC I
PIPE HANGERS, ITEM 72

Dear Mr. O'Reilly:

Attached is our second interim report on the subject items which were deemed reportable per the provisions of 10CFR50.55(e) and 10CFR, Part 21, on August 13, 1982 (Item 95) and November 5, 1982 (Item 72). Carolina Power and Light Company is pursuing this matter, and it is currently projected that corrective action and submission of the final report will be accomplished by December 1, 1984.

Thank you for your consideration in this matter.

Yours very truly,

R. M. Parsons

Project General Manager

Shearon Harris Nuclear Power Plant

RMP/sh

Attachment

cc: Messrs. G. Maxwell/R. Prevatte (NRC-SHNPP)
Mr. R. C. DeYoung (NRC)

10

bee: Mr. H. R. Banks

Mr. N. J. Chiangi

Mr. A. B. Cutter

Dr. T. S. Elleman

Mr. G. L. Forehand

Mr. B. J. Furr

Mr. S. Hinnant

Mr. L. I. Loflin

Mr. R. E. Lumsden

Mr. M. A. McDuffie

Mr. C. H. Moseley, Jr.

Mr. R. M. Parsons

Mr. Sheldon D. Smith

Mr. J. L. Willis

Mr. S. R. Zimmerman

Mr. H. W. Bowles

Dr. J. D. E. Jeffries

Mr. M. F. Thompson

Mr. J. Nevill

CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT

UNITS NOS. 1 AND 2

INTERIM REPORT NO. 2

SHOP WELDING DEFICIENCIES IN SEISMIC I PIPE HANGERS SUPPLIED BY BERGEN-PATERSON ITEM 95

UNDERSIZE SKEWED TEE FILLET WELDS ON SEISMIC I PIPE HANGERS ITEM 72

1983

REPORTABLE UNDER 10CFR50.55(e) REPORTABLE UNDER 10CFR21 SUBJECT:

Deficient shop welds on pipe hangers previously accepted by Bergen-Paterson (B-P) and Ebasco Welding Inspectors.

ITEM:

Seismic Pipe Hangers

SUPPLIED BY:

Bergen-Paterson Pipe Support Corporation, Laconia, New Hampshire

NATURE OF DEFICIENCY:

- 1. Missing and undersized welds
- 2. Cosmetic weld defects
- 3. Undersized skewed tee welds
- Deficient welds accepted by B-P inspectors and Ebasco Vendor Quality Assurance (VQA) inspectors

DATE PROBLEM OCCURRED:

Prior to October 1, 1982

DATE PROBLEM REPORTED:

On August 13, 1982 CP&L (Mr. N. J. Chiangi) notified the NRC (Mr. A. Hardin) that this item (Item 95) was reportable under 10CFR50.55(e) and 10CFR, Part 21. In our November 5, 1982 letter, CP&L (Mr. R. M. Parsons) notified the NRC (Mr. J. P. O'Reilly) that this item (Item 72) was reportable under 10CFR50.55(e) and 10CFR, Part 21.

SCOPE OF PROBLEM:

Seismic Category I pipe hangers which were inspected at the source of fabrication prior to October 1, 1982.

SAFETY IMPLICATIONS:

Deficient welds could cause a safety-related pipe hanger to fail under seismic conditions. As a result, if not corrected, they could adversely affect the safe operation of this facility. However, no hangers evaluated to date with the above type deficiencies have been found to adversely affect the safe operation of this facility.

REASON THE DEFICIENCY IS REPORTABLE:

The conditions reported in Item 95 and Item 72 represent breakdowns in B-P and Ebasco QA programs which allowed supports to be shipped with welds which were not in accordance with design criteria. This incident was identified as reportable under 10CFR50.55(e) and 10CFR, Part 21, due to the extensive evaluation required and the breakdown in the QA programs.

CORRECTIVE ACTION:

- Hangers with shop weld deficiencies were identified during the following processes:
 - A. Receipt Inspection.
 - B. Inspection in the warehouse prior to hanger inssuance to the field.
 - C. Inspection in the field of installed hangers which had not been previously inspected by CP&I: for shop weld deficiencies (does not include those hangers

CORRECTIVE ACTION (cont'd.):

- D. Reinspection of pipe hangers that were installed or partially installed and inspected prior to June 26, 1982. This includes the 347 hangers which were previously reinspected as part of the Corrective Action to NRC Report 50-400/82-03. The June 26, 1982 date was selected because the QC weld inspection program was expanded to include shop welds. 346 hangers which had been installed and inspected prior to June 26, 1982 were removed, voided, or declassified to non-seismic by a subsequent drawing revision and therefore were not reinspected.
- 449 hangers with defective shop welds were identified by processes A and B (see above).

1862 hangers were reinspected by Processes C and D. 728 were identified with shop weld deficiencies.

Deficiencies were resolved as follows:

Welds were cut out.

Design drawing revisions were issued as a result of Engineering evaluation.

Welds were reworked and upgraded to meet the acceptance criteria of FCR-H-373.

Some hangers were on hold due to engineering problems which precluded rework at this time. These hangers will be dispositioned in accordance with the appropriate drawing revision when the engineering holds are removed.

3. Instruction measures have been established to control pipe hangers which have not been installed but were received prior to October 1, 1982. We have taken the option to inspect shop welds prior to issue from the warehouse or to inspect shop welds at the same time field welds are inspected. Defective welds will be identified on DDR's for control and evaluation.

PREVENTIVE MEASURES TAKEN TO AVOID FURTHER NONCOMPLIANCE:

- Field Change Request (FCR) H-979 was developed and issued to provide weld inspection acceptance criteria for both field and shop welds based on the AWS Dl.l code and B-P design criteria.
- 2. Ebasco VQA began performing in-process inspections and 100% inspection of hanger welds on October 1, 1982. This is to be performed throughout the remainder of the B-P purchase order.

PREVENTIVE MEASURES TAKEN TO AVOID FURTHER NONCOMPLIANCE (cont'd.)

- Ebasco VQA management regularly visits the B-P Laconia facility to confer with the Ebasco VQA representative and to witness the VQA inspector's activities.
- B-P welders and inspectors and Ebasco VQA inspectors have received additional training in weld acceptance criteria.
- 100% shop weld inspection is presently being performed on site for hangers received from B-P to ensure this problem does not reoccur.

FINAL REPORT:

Corrective action has been completed on all active hangers. Those hangers on engineering hold will be reinspected and reworked when they become active again, or they will be cancelled if they are voided. For this reason, we cannot close this item until December 1, 1984.

P. O. Box 101, New Hill, N. C. 2756:
October 3, 1983

Mr. James P. O'Reilly
United States Nuclear Regulatory Commission
Region II
101 Marietta Street, Northwest (Suite 2900)
Atlanta, Georgia 30303

CAROLINA POWER & LIGHT COMPANY
SHEARON HARRIS NUCLEAR POWER PLANT
1986-90 - 900,000 kw - UNITS 1 & 2
SEISMIC PIPE HANGERS PREVIOUSLY ACCEPTED BY
QC WELDING INSPECTOR - ITEM 96
UNDERSIZE SKEWED TEE FILLET WELDS ON SEISMIC I PIPE HANGERS - ITEM 72

Dear Mr. O'Reilly:

NRC-127

Attached is our second interim report on the subject items which were deemed reportable per the provisions of 10CFR50.55(e), on August 13, 1982 (Item 96) and November 5, 1982 (Item 72). Carolina Power and Light Company is pursuing this matter, and it is currently projected that corrective action and submission of the final report will be accomplished by December 1, 1984.

Thank you for your consideration in this matter.

Yours very truly,

R. M. Parsons

Project General Manager

Shearon Harris Nuclear Power Plant

RMP/sh

Attachment

ec: Messrs. G. Maxwell/R. Prevatte (NRC-SHNPP)
Mr. R. C. DeYoung (NRC)

bee: Mr. H. R. Banks

Mr. N. J. Chiangi

Mr. A. B. Cutter

Dr. T. S. Elleman

Mr. G. L. Forehand

Mr. B. J. Furr

Mr. S. Hinnant

Mr. L. I. Loflin

Mr. R. E. Lumsden

Mr. M. A. McDuffie

Mr. C. H. Moseley, Jr.

Mr. R. M. Parsons

Mr. Sheldon D. Smith

Mr. J. L. Willis

Mr. S. R. Zimmerman

Mr. H. W. Bowles

Dr. J. D. E. Jeffries

Mr. M. F. Thompson

Mr. J. Nevill

CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT

UNIT NO. 1

INTERIM REPORT NO. 2

PIPE HANGERS PREVIOUSLY ACCEPTED BY QC WELDING INSPECTORS ITEM 96

UNDERSIZED SKEWED TEE FILLET WELDS ON SEISMIC I PIPE HANGERS ITEM 72

1983

REPORTABLE UNDER 10CFR50.55(e)

SUBJECT:

Deficient field welds on pipe hangers previously accepted by

QC welding inspectors.

ITEMS:

Seismic Pipe Hangers

SUPPLIED BY:

N/A - Hangers furnished by Bergen-Paterson, but problem deals with field welds.

NATURE OF DEFICIENCY:

Missing and undersized welds

Cosmetic weld defects 2.

Inaccurate and incomplete QC documentation 3.

QC inspections performed by personnel whose work 4. was suspect

Undersized skewed-tee field welds 5.

DATE PROBLEM OCCURRED:

Prior to July 29, 1982

DATE PROBLEM REPORTED: August 13, 1982 - CP&L (N. J. Chiangi) notified the NRC (A. Hardin) that this item (Item 96) was reportable under the provisions of IOCFR50.55(e). In our November 5, 1982 letter, CP&L (R. M. Parsons) notified the NRC (J. P. O'Reilly) that this item (Item 72) was reportable under 10CFR50.55(e).

SCOPE OF PROBLEM:

3749 Seismic Category I pipe hangers that were installed or partly installed and inspected prior to June 26, 1982 were identified and reinspected. This includes the 349 hangers which were previously reinspected as part of the corrective action to NRC Report 50-400/82-03.

The June 26, 1982 date was selected because the QC weld inspection program was expanded to include shop welds on installed hangers (refer to Item 95). Inspector training was conducted prior to June 26, 1982 to ensure satisfactory inspector performance.

347 hangers which had been installed and inspected prior to June 26, 1982 were removed, voided, or declassified to nonseismic by a subsequent drawing revision and therefore were not reinspected.

SAFETY IMPLICATION:

Deficient welds could cause a safety-related pipe hanger to fail under seismic conditions. As a result, if not corrected, they could adversely affect the safe operation of this facility. However, no hangers evaluated to date with the above type deficiencies have been found to adversely affect the safe operation of this facility.

REASON THE DEFICIENCY IS REPORTABLE:

The conditions reported in Item 96 and Item 72 were identified as reportable under 10CFR50.55(e) due to the extensive evaluation required and the breakdown in the QA program.

CORRECTIVE ACTION:

1329 hangers were identified with deficient field welds as a result of the reinspection effort. Deficiencies were resolved as follows:

Welds were cut out.

Design drawing revisions were issued as a result of Engineering evaluation.

Welds were reworked and upgraded to meet the acceptance criteria of FCR-H-979.

Some hangers were on hold due to engineering problem which precluded rework at this time. These hangers will be dispositioned in accordance with the appropriate drawing revision when the holds are removed.

To ensure that hangers requiring reinspection were not overlooked, QCI 19.3 requires that during the final review process all SWDR's in the hanger work package will be checked to ensure that inspections performed prior to June 26, 1982 have been reinspected and accepted. Any hangers inadvertently missed during the reinspection effort will be reinspected and appropriately dispositioned.

PREVENTIVE MEASURES TAKEN TO AVOID FURTHER NONCOMPLIANCE:

- A pipe hanger inspection documentation instruction (QCI)
 19.3 was developed and issued.
- Additional training classes were held with required attendance for both craft and QC weld inspection personnel involved in pipe hanger inspection. Training classes covered items such as measurement of skewed-tee welds, visual acceptance criteria, proper documentation, applicable work procedures, etc.
- New QC weld inspector candidates are interviewed by the QA/QC Specialist in addition to passing a written examination to ensure they are aware of project requirements pertinent to their assignments.
- Each inspector's documentation of weld inspections is reviewed after each phase of inspection to ensure completeness and correctness.
- Supervisory audits are routinely performed in accordance with Quality Assurance Instruction (QAI) 1.3 on each QC inspector's field work to ensure his satisfactory performance and to ensure that the work complies with the design documents.
- 6. A system was developed to aid in the resolution of technical inquiries that inspector supervision is unable to resolve. Technical inquiries are stated on a Request for Information (RFI) form and forwarded to the QA engineering unit which was established on site to provide engineering support for inspection activities.

PREVENTIVE MEASURES TAKEN TO AVOID FURTHER NONCOMPLIANCE (cont'd.):

7. Field Change Request (FCR) H-979 was developed and issued to provide weld inspection acceptance criteria for both field and shop welds based on AWS Dl.l code and Bergen-Paterson design criteria. Procedure NDEP-605 was issued to address the specific conditions governing pipe hanger weld inspections.

FINAL REPORT:

Corrective action has been completed on all active hangers. Those hangers on engineering hold will be reinspected and reworked w en they become active again, or they will be cancelled if they are voided. For this reason, we cannot close this item until December 1, 1984.

Rev. 21

CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT

AP- IX-05 Exhibit I

FIELD CHANGE REQUEST/PERMANENT WAIVER FCR/PW - - 4294 PAGE I OF _ Permanent Waiver 0 □ Non -Q Field Change ORIGINAL Category ____ THON-ASME Nonconformance _N/A MASME Sect. III Div. I Building CREWERIC ASME Sect. III Div. 2 Elevation GENERAL Isometrics Instruments Valves Lines N/D Cables List All Reference Documents (Drawings, Specs., FCR's, DCN's, Procedures, Etc.) 2165-A-003F/4 Description CRITCHIA MSPELTION Conflict / Condition ASPECTS OF THE WELD WORKETS I CRITICIA REGILIED CLASZFICATION. Recommended Action: Please investigate, Resolve Please Resolve As Follows Kevise CRITERIA AS SHOWN ON ATTREACD Carly and the state of the stat DOCUMENT CONTROL JAN 27 1984

000821

Requested By

Site Approvel :

SHEEDER HARRIS NAR.

APF-001 application 2/26/83
Rev. 21 Fage 8/26/83

(Copy)

FCR/PW A5 - 4294

Exhibit I

PAGE 2 OF Preliminary Approval: fork may proceed prior Discipline Engineer Date MHPE OF PPE Date to final analysis GNPED Only Other O AE ☐ NSSS Design Organization Approval ☐ Yes ENO F No Design Organization Attachments ☐ Yes Telephone Resolution Rejected Conditional Approval Approved as Recommended This change requires the following Document(s) (Specification, Drawing, SAR, Etc.) to be changed: Comments: Title Date Signature Title Date Signature CPSL Harris Plant Engineering Approval FNO HPES Attachments T Yes Rejected Conditional Approval Approved as Recommended Reference Documents: Ofscipline Engineer Date Distribution (Specify those to receive "prior to analysis" dist. by *) (Copy) (Copy) (Copy) (Copy) (Copy) (Copy) (Copy) (Copy) ☐ Yes implementation Completed As Approved - No Comments: Discipline Engineer Cate Pinal Distribution: (Copy) (Original) File in Doc. Control (Copy) (Copy)

(Copy)

1.0 SCOPE

The intent of this design document is to provide the CP&L QA program with acceptance criteria that satisfies the design requirements and thereby allowing clarification from strict code interpretation during receipt inspection, reinspection, and field welding inspection. This criteria is applicable to both primary (first inspection, uncoated) and secondary inspections (receipt inspection included with quality release or reinspection, coated) for structural weldments designed to AWS Dl.l requirements.

Secondary inspections may be performed through coatings. Primary inspections shall not be allowed through coatings unless allowed by the engineer. Any item not specifically covered in this criteria shall refer back to AWS Dl.l.

This criteria covers joints which provide framing for components, such as cable tray, HVAC, conduit supports, instrument racks, ducting air control dampers, doors, hatch covers, pipe supports, etc. This is to include any item welded to AWS Dl.1 standards.

This criteria is applicable to any weld joint where these imperfections are to be visually inspected per AWS D1.1.

As per AWS D1.1, welds with acceptable imperfections in combination shall be acceptable.

Based on the QA programs for acceptance prior to vendor release (or acceptance of field welds), any defects not identified during primary inspection and subsequently covered by coatings are not considered significant.

Visual inspection of welds shall be in accordance with AWS D1.1 except as modified below:

FCK. HS - 4294 (179. 7 57)

All visual inspection shall be performed at an eye-to-examination surface distance of no more than 24 inches, the inspector position within an angular region of 30 to 90 of the examination surface by personnel possessing 20/20 visual acuity. Visual aids which do not enhance 1% capability, such as mirrors, may be used. Visual inspection shall be used unless otherwise noted on design documents.

2.0 ACCEPTABILITY CRITERIA

2.1 Oversize Fillet Welds

Either or both fillet weld legs may exceed design size. Welds may be longer than specified. Continuous welds may be used in lieu of intermittent welds.

2.2 Undersize Fillet Welds

The leg of 1/4" and larger fillet welds may be 1/16" less than the required weld size for a continuous span of 2", provided there is no less than a 6" separation between each undersize increment. For welds less than 8" long, a continuous undersize span of 25% of the total weld run length will also apply. All 1/16" undersize increments less than 1/2" in length will be acceptable. For intermittent welds, 1/16" less than that required size will be accepted provided the undersize condition is no more than 40% of the weld length.

The leg of 3/16" fillet welds may be 1/32" less than the required according to the above provisions or 1/16" less for 10% of the length.

(FOR-AS.) 10 50F)

It is to be understood that the thickness of coatings on secondary inspections are not considered detrimental and the weld size criteria shall not be adjusted. Any unique application of coatings (excessive thickness, putty) shall be brought to the attention of QA management for resolution.

2.3 Porosity

Pores between 1/16" and 1/8" diameter shall be acceptable when separated by a minimum of one inch. Isolated pores less than 1/16" diameter shall be disregarded. Clustered porosity including all sizes to 0.030" contained within up to a 3/8" diameter circle shall be acceptable. Linear, in-line pores shall be considered as clustered porosity. It is to be understood that porosity not visible through coatings on secondary inspection are not considered significant.

2.4 Weld Profile

Fillet and butt weld convexity can be accepted without limit.

2.5 Craters

Welds may have underfilled craters provided underfill depth does not exceed 1/16" and the crater has a smooth contour blending gradually with the adjacent weld and base metal with no evidence of cracking.

2.6 Undercut

Steels 5/16" or thicker which were produced to a maximum specified tensile strength of 60,000 psi may contain weld undercut up to 1/16" in depth for a continuous span of 2" provided its surface width is less than 0.100" and there is no less than a 6" separation between each undercut increment.

- 4 -

Weld runs less than 8" long may contain a continuous undercut span of 25% of the total weld length. All undercut less than 1/2" in length will be accepted provided the above width limit is adhered to. Undercut up to 1/32" depth is acceptable in all steels and all thicknesses.

2.7 Cracks

Cracks are unacceptable. It is to be understood that secondary inspections are intended to identify cracks that result from shipping damage or stress relief and, if relevant, would appear through the coating.

2.8 Arc Strikes

Arc strikes in high-strength, low-alloy steels (minimum specified tensile strength greater than 60,000 psi), shall be removed by grinding. The ground area shall be visually inspected to assure complete removal of the arc strike.

For other maximum specified 60,000 psi tensile steels, arc strikes shall be visually examined and accepted if no cracking is evident. If cracking is evident, the repair shall conform with Section 3.10 of AWS Dl.1. Arc strike regions in these lower strength steels shall not require power brushing or grinding before visual examination. It is to be understood that cracks in arc strikes not visible through coatings on secondary inspections are not considered significant.

2.9 Fusion

Lack of fusion which does not exceed 1/4" in length when measured transverse or along the weld and each increment separated by 6" is acceptable.

For welds between 1" and 6" in length, 1/4" maximum lack of fusion is acceptable. For welds less than 1", lack of fusion is

Criteria for lack of fusion in transverse direction is applicable only in start/stop location.

Criteria for lack of fusion shall apply to overlap also. It is to be understood that lack of fusion not visible through coatings on secondary inspections is not considered significant. Any unique application of coatings (excessive thickness, putty) shall be brought to the attention of QA management for resolution.

P. O. Box 101, New Hill, N. C. 2756; October 3, 1983

Mr. James P. O'Reilly United States Nuclear Regulatory Commission Region II 101 Marietta Street, Northwest (Suite 2900) Atlanta, Georgia 30303

NRC-126

CAROLINA POWER & LIGHT COMPANY
SHEARON HARRIS NUCLEAR POWER PLANT
1986-90 - 900,000 KW - UNITS 1 & 2
SHOP WELDING DEFICIENCIES IN SEISMIC I PIPE HANGERS
SUPPLIED BY BERGEN-PATERSON, ITEM 95
UNDERSIZE SKEWED TEE FILLET WELDS ON SEISMIC I
PIPE HANGERS, ITEM 72

Dear Mr. O'Reilly:

Attached is our second interim report on the subject items which were deemed reportable per the provisions of 10CFR50.55(e) and 10CFR, Part 21, on August 13, 1982 (Item 95) and November 5, 1982 (Item 72). Carolina Power and Light Company is pursuing this matter, and it is currently projected that corrective action and submission of the final report will be accomplished by December 1, 1984.

Thank you for your consideration in this matter.

Yours very truly,

R. M. Parsons

Project General Manager

Shearon Harris Nuclear Power Plant

RMP/sh

Attachment

cc: Messrs. G. Maxwell/R. Prevatte (NRC-SHNPP)
Mr. R. C. De Young (NRC)

bcc: Mr. H. R. Banks

Mr. N. J. Chiangi

Mr. A. B. Cutter

Dr. T. S. Elleman

Mr. G. L. Forehand

Mr. B. J. Furr

Mr. S. Hinnant

Mr. L. I. Loflin

Mr. R. E. Lumsden

Mr. M. A. McDuffie

Mr. C. H. Moseley, Jr.

Mr. R. M. Parsons

Mr. Sheldon D. Smith

Mr. J. L. Willis

Mr. S. R. Zimmerman

Mr. H. W. Bowles

Dr. J. D. E. Jeffries

Mr. M. F. Thompson

Mr. J. Nevill

CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT

UNITS NOS. 1 AND 2

INTERIM REPORT NO. 2

SHOP WELDING DEFICIENCIES IN SEISMIC I PIPE HANGERS SUPPLIED BY BERGEN-PATERSON ITEM 95

UNDERSIZE SKEWED TEE FILLET WELDS ON SEISMIC I PIPE HANGERS ITEM 72

1983

REPORTABLE UNDER 10CFR50.55(e) REPORTABLE UNDER 10CFR21 SUBJECT:

Deficient shop welds on pipe hangers previously accepted by Bergen-Paterson (B-P) and Ebasco Welding Inspectors.

ITEM:

Seismic Pipe Hangers

SUPPLIED BY:

Bergen-Paterson Pipe Support Corporation, Laconia, New Hampshire

NATURE OF DEFICIENCY:

- 1. Missing and undersized welds
- 2. Cosmetic weld defects
- Undersized skewed tee welds
 Deficient welds accepted by B-P

inspectors and Ebasco Vendor Quality
Assurance (VQA) inspectors

DATE PROBLEM OCCURRED:

Prior to October 1, 1982

DATE PROBLEM REPORTED:

On August 13, 1982 CP&L (Mr. N. J. Chiangi) notified the NRC (Mr. A. Hardin) that this item (Item 95) was reportable under 10CFR50.55(e) and 10CFR, Part 21. In our November 5, 1982 letter, CP&L (Mr. R. M. Parsons) notified the NRC (Mr. J. P. O'Reilly) that this item (Item 72) was reportable under 10CFR50.55(e) and 10CFR. Part 21.

SCOPE OF PROBLEM:

Seismic Category I pipe hangers which were inspected at the source of fabrication prior to October 1, 1982.

SAFETY IMPLICATIONS:

Deficient welds could cause a safety-related pipe hanger to fail under seismic conditions. As a result, if not corrected, they could adversely affect the safe operation of this facility. However, no hangers evaluated to date with the above type deficiencies have been found to adversely affect the safe operation of this facility.

REASON THE DEFICIENCY IS REPORTABLE:

The conditions reported in Item 95 and Item 72 represent breakdowns in B-P and Ebasco QA programs which allowed supports to be shipped with welds which were not in accordance with design criteria. This incident was identified as reportable under 10CFR50.55(e) and 10CFR, Part 21, due to the extensive evaluation required and the breakdown in the QA programs.

CORRECTIVE ACTION:

- Hangers with shop weld deficiencies were identified during the following processes:
 - A. Receipt Inspection.
 - B. Inspection in the warehouse prior to hanger inssuance to the field.
 - C. Inspection in the field of installed hangers which had not been previously inspected by CP&I for shop weld deficiencies (does not include those hangers

CORRECTIVE ACTION (cont'd.):

- D. Reinspection of pipe hangers that were installed or partially installed and inspected prior to June 26, 1982. This includes the 347 hangers which were previously reinspected as part of the Corrective Action to NRC Report 50-400/82-03. The June 26, 1982 date was selected because the QC weld inspection program was expanded to include shop welds. 346 hangers which had been installed and inspected prior to June 26, 1982 were removed, voided, or declassified to non-seismic by a subsequent drawing revision and therefore were not reinspected.
- 2. 449 hangers with defective shop welds were identified by processes A and B (see above).

1862 hangers were reinspected by Processes C and D. 728 were identified with shop weld deficiencies.

Deficiencies were resolved as follows:

Welds were cut out.

Design drawing revisions were issued as a result of Engineering evaluation.

Welds were reworked and upgraded to meet the acceptance criteria of FCR-H-979.

Some hangers were on hold due to engineering problems which precluded rework at this time. These hangers will be dispositioned in accordance with the appropriate drawing revision when the engineering holds are removed.

3. Instruction measures have been established to control pipe hangers which have not been installed but were received prior to October 1, 1982. We have taken the option to inspect shop welds prior to issue from the warehouse or to inspect shop welds at the same time field welds are inspected. Defective welds will be identified on DDR's for control and evaluation.

PREVENTIVE MEASURES TAKEN TO AVOID FURTHER NONCOMPLIANCE:

1.

- Field Change Request (FCR) H-979 was developed and issued to provide weld inspection acceptance criteria for both field and shop welds based on the AWS Dl.l code and B-P design criteria.
- 2. Ebasco VQA began performing in-process inspections and 100% inspection of hanger welds on October 1, 1982. This is to be performed throughout the remainder of the B-P purchase order.

PREVENTIVE MEASURES TAKEN TO AVOID FURTHER NONCOMPLIANCE (cont'd.)

- Ebasco VQA management regularly visits the B-P Laconia facility to confer with the Ebasco VQA representative and to witness the VQA inspector's activities.
- B-P welders and inspectors and Ebasco VQA inspectors have received additional training in weld acceptance criteria.
- 100% shop weld inspection is presently being performed on site for hangers received from B-P to ensure this problem does not reoccur.

FINAL REPORT:

Corrective action has been completed on all active hangers. Those hangers on engineering hold will be reinspected and reworked when they become active again, or they will be cancelled if they are voided. For this reason, we cannot close this item until December 1, 1984.

	CTION PROCEDURES	ON OF CRICATO PIDE	HANCEDE	PROCEDURE WP-110		As Approve
BORK P	ROCEDURE AND -SUPPOR	ON OF SEISMIC PIPE TS-FOR -SEISMICALLY	ANALYZED	REVISION	10	
ESCRIP	TION PIPE	To the state	* ***	PAGE - 1	OF	22
	The second secon				8 1981	Rev. 4.
		APR 0 9 19	84 600 10			A STATE OF THE PARTY OF THE PAR
	CARC	DLINA POWER & LIGH		MAY 2	0 1980 1979 R	Kev. Z
		ON HARRIS NUCLEAR		DOCUMEN		A TOTAL CONTRACTOR
		WORK PROCEDUR	2	** The state of th	מת ממב	
* 1 /mgs.		WP-110		IUI		7111 - "-"
7 (3)	Heven Teller	NOV 2 8 198			1 1979	
			2 1983 Bu.8			
3.			5 1982 Rev.		ARRIS N. F	P. P.
100			4 1981 Rev	THE PERSON NAMED IN COLUMN TWO IS NOT THE PERSON NAMED IN COLUMN TWO IS NAMED IN COLUMN TW		-
			3 1981 Rev	3 3		Temperature to
OF P	EWED AND APPROVED BY ARAGRAPH CA-3310 OF A	RTICLE CA-3300 OF	ASME/ACL 359	SECTION I	THE REC	2, WINTER
	ADDENDA.	1		如 战 研	4 7 4	
REV.	DESCRIPTION		APPROVA	LS	***	DATI
	74.	ORIGINATOR	Edward	P1. 71:2	-	3-1-
		CONSTRUCTOR	INNU	//		T 250
			11/10.10	odna)	3-1-
-	Tagued for Use	EGC Q.A.	N/4 6	odna		3-1-7
0	Lasued for Use.	EGC Q.A.	MA E	ed man		
0		EGC Q.A.	119.12 N/A & M/A &	ed man		3-1-7
0		EBC Q.A.	1/4 6 1/4 6 1/4 6 1/4 6 6 durad	M. Mill		3-/-
0		E & C Q.A.	1/4 6 1/4 6 1/4 6 Edward W. S. J.	M. Miles	~	JAR THE
0		E & C Q.A. 'C P & L ' DES. ENG. * ORIGINATOR	1/4 6 1/4 6 1/4 6 6 dured 1/4 6	M. Mile		3-/-
1		E & C Q.A. 'C P & L ' DES. ENG. * ORIGINATOR CONSTRUCTOR	1/4 6 1/4 6 1/4 6 6 dund 1/4 6 1/4 6	M. Miles		3-/- - (3-20 3.2
1		E&C Q.A. 'CPAL ' DES. ENG. * ORIGINATOR CONSTRUCTOR E&C Q.A.	1/4 6 1/4 6 1/4 6 1/4 6 1/4 6 1/4 6	M. Mile		3-/- - (- 3-20 3.2
1		E & C Q.A. CPAL DES. ENG. * ORIGINATOR CONSTRUCTOR E & C Q.A. CP & L	1/4 6 1/4 6 1/4 6 1/4 6 1/4 6 1/4 6	Porlina Corlin		3-/- 3-20 3.20
1		E & C Q.A. 'C P & L DES. ENG. * ORIGINATOR CONSTRUCTOR E & C Q.A. CP & L DES. ENG. *	N/A & A A A A A A A A A A A A A A A A A A	Porlina Corlin	~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~	3-/- 3-20 3-20
1	Revised as Noted.	E & C Q.A. 'C P & L ORIGINATOR CONSTRUCTOR E & C Q.A. CP & L DES. ENG. * ORIGINATOR	1/4 6 1/4 6 1/4 6 1/4 6 1/4 6 1/4 6 1/4 6	John Ja		3-/- 3-20 3.20
	Revised as Noted.	E & C Q.A. 'C P & L ORIGINATOR CONSTRUCTOR E & C Q.A. CP & L DES. ENG. * ORIGINATOR CONSTRUCTOR	1/4 6 1/4 6 1/4 6 1/4 6 1/4 6 1/4 6 1/4 6 1/4 6	Porlina Corlin		3-/- 3-20 3-20
	Revised as Noted. Revised as Noted. Added Exhibit 1.	E & C Q.A. 'C P & L ORIGINATOR CONSTRUCTOR E & C Q.A. CP & L DES. ENG. * ORIGINATOR CONSTRUCTOR E & C Q.A.	11 4 6 11 4 6	John Ja		3-/- 3-20 3-20
	Revised as Noted. Revised as Noted. Added Exhibit 1.	E&C Q.A. 'CP&L DES. ENG. * ORIGINATOR CONSTRUCTOR E & C Q.A. CP & L DES. ENG. * ORIGINATOR CONSTRUCTOR E & C Q.A. CP & L CP & L CP & L CP & L	1/4 6 1/4 6 1/4 6 1/4 6 1/4 6 1/4 6 1/4 6 1/4 6	Joshum James		3-1- 3-20 3-20 5-15

FORM NO. 1779-A									
CONSTRUCTION PRO	CEDURES !	MANUAL .	· SHN	TPP .	PROCED WP-1	URE 10	NO.	As	DATE Approved
WORK PROCEDURE	INSTALLATION AND SUPPORT	ON OF SEL	SMIC PIPE	HANGERS	REVISIO	ON	1.	10 -	
DESCRIPTION	PIPE	IS TOR SE	TOTILONDE	M.ALIZED	PAGE	2	OF		22

CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT

WORK PROCEDURE

WP-110

* REVIEWED AND APPROVED BY EBASCO SERVICES, INC., FOR CONFORMANCE TO THE REQUIREMENTS OF PARAGRAPH CA-3310 OF ARTICLE CA-3300 OF ASME/AC1 359, SECTION III, DIV. 2, WINTER 1975 ADDENDA.


REV.	DESCRIPTION		APPROVALS A	DATE
		ORIGINATOR	Vilain Tamo	321-80
		CONSTRUCTOR	Mallale dos wolf	821-80
3	Revised as Noted. Added Exhibits 2 and 3.	E&C Q.A.	N/A AMLIACH QU	
	Incorporated Procedure Deviation Notice #1.	CPAL	A.M. Lucie & CSH	8/22/8
	Bertaetan investe i 1.	DES. ENG. +	N/A AMELICON and	1 ,
		ORIGINATOR	Waller of French	1-14-8
4	Revised as Noted.	CONSTRUCTOR	111 D. Goodman	1-15-
	Revised Exhibit 3. Incorporated.	E & C Q.A.	N/A RN	
	Deviation Notices 1 and 2.	CPAL	am Luce	1-18-81
		DES. ENG. +	N/A BY	
5	Revised as Noted.	ORIGINATOR	alx Filler 1	6-3-8
	Incorporated Deviation Notices 1 and 2.	CONSTRUCTOR	Ve A Hortman	6.03
	Revised Exhibit 2. Added Appendix A.	E&C Q.A.	N/A BY	
	Audeu Appendix A.	CPAL	am Lux.	6-3-81
		DES. ENG. +	NAGN	

CONSTRUCTION PR	OCEDURES MANUAL	SHNPP	PROCEDU WP-110	RE	NO.	As Approved
WORK PROCEDURE	INSTALLATION OF SEISMIC P	IPE HANGERS	REVISION	4	10	
DESCRIPTION	PIPE		PAGE	3	. OF	22

CAROLINA POWER & LIGHT COMPANY APR 0 9 1984 Rev. 10 SHEARON HARRIS NUCLEAR POWER PLANT NOV 2 8 1983 Rev. 9

WORK PROCEDURE

WP-110



* REVIEWED AND APPROVED BY EBASCO SERVICES, INC., FOR CONFORMANCE TO THE REQUIREMENTS
OF PARAGRAPH CA-3310 OF ARTICLE CA-3300 OF ASME/AC1 359, SECTION III, DIV. 2, WINTER
1975 ADDENDA.

REV.	DESCRIPTION	27-48-28	APPROVALS	DATE
6	Revised As Noted.	ORIGINATOR	Oly Friger	12/4/81
	Incorporated Deviation Notices 2 and 3.	CONSTRUCTOR	N. A. Moduso	1204
	Revised Exhibit 1 and Appendix A.	EBC Q.A.	MAGN	
	Added Exhibit 4.	CPAL	am Lua	124-81
		DES. ENG. #	NA GHY	
7	Revised As Noted.	ORIGINATOR	Puttonal Meel	11-11-8
	Incorporated Deviation Notices As Applicable.	CONSTRUCTOR	W. D. Mortura	11.11-8
	Added Exhibit 5-8 and Appendices B through	E&C Q.A.	NAGN	
	J	CPAL	amfu	11-1-92
to eli		DES. ENG. +	MARY	
8	Revised As Noted.	ORIGINATOR	alex File 1	4-21-83
	Incorporated Deviation Notices As Applicable.	CONSTRUCTOR	W. Good war	421
	Revised Exhibits and Appendices as Noted.	EAC Q.A.	NA EEW	
		CPAL	EEWilles for MFT	421-83
		DES. ENG. +		

SONSTRUCTION PROCEDURES MANUAL	SHNPP	PROCEDURE WP-110	NO.	As Approved
WORK PROCEDURE AND SUPPORTS FOR SEISMICAL PIPE	LLY ANALYZED	REVISION	10	
DESCRIPTION		PAGE 4	OF	22 .

CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT

WORK PROCEDURE

WP-110

- # REVIEWED BY QA /QC FOR COMPLIANCE WITH THE APPLICABLE QA AND CODE REQUIREMENTS.
 - * REVIEWED AND APPROVED BY EBASCO SERVICES, INC., FOR CONFORMANCE TO THE REQUIREMENTS OF PARAGRAPH CA-3310 OF ARTICLE CA-3100 OF ASME/ACT 359, SECTION III, DIV. 2, WINTER 1975 ADDENDA.

REV.	DESCRIPTION		APPROVALS	DATE
9	Revised As Noted.	ORIGINATOR	PN HOUSE	11/29/93
	Incorporated Deviation Notices As Applicable.	CONSTRUCTOR	W. S. Monding	11.288
	Revised Exhibits And Appendices. Added	QA/QC REVIEW .	M.M. Rad	11/286
	New Exhibits Entirely For Exhibits 1, 2, and	CPAL	Marson	Villates
	4.	DES. ENG. +	N/A WAR	11/200
10	Incorporated Procedure Change Notices 2, 3,	ORIGINATOR	Randy Extend	4.3-0
	4, and 5. Revised As Noted. Revised	CONSTRUCTOR	All Donalan	4-3-8
	Appendices A-F and H-K.	QA/QC REVIEW # #	M.M. Had	4/2ke
	Added Exhibit /.	CP&L	att for MET	1/2/20
		DES. ENG. +	N/A / AR	13/1/20
		ORIGINATOR	1 1 1 1 1	1/3/04
		CONSTRUCTOR		
		QA/QC REVIEW .		
		CPAL		
		DES. ENG. +		-

CONSTRUCTION PRO		Procedure No. WP-110		A	s Approved
WORK PROCEDURE	INSTALLATION OF SEISMIC PIPE HANGERS AND SUPPORTS FOR SEISMICALLY ANALYZED	Revisio	10		
DESCRIPTION	PIPE	Page	5	of	22

1.0 SCOPE

- 1.1 This procedure describes the steps to be followed for the installation of seismic pipe supports and spring hangers on seismically analyzed pipe.
- 1.2 For construction purposes, a pipe hanger can be identified to be in accordance with this procedure if it supports a Safety Class I, II, or III pipe or MS or FW pipe by means of a spring cannister except hangers east of the seismic break as defined by FCR-H-II45, or if the hanger sketch is stamped seismic, or if the format of the load sheet is in accordance with Exhibit 6 or if it is a Bergen-Paterson fire protection pipe hanger.

2.0 REFERENCES

- 2.1 MP-08, General Welding Procedure for Structural Steel and Hangers
- 2.2 TP-34, Inspection of the Installation of Seismic I Pipe Hangers/Large Bergen-Paterson Frames and Supports for Seismically Analyzed Pipe
- 2.3 WP-II2, Control of Materials and Equipment That May Be Harmful to Stainless Steel
- 2.4 WP-48, Temporary Construction Loads Supported From Permanent Plant Equipment
- 2.5 WP-102, Installation of Piping
- 2.6 MP-06, General Welding Procedure for Carbon Steel Weldments
- 2.7 MP-07, General Welding Procedure for Stainless Steel Weldments
- 2.8 CAR 2165-G-801 Flow Diagram Reactor Coolant System
- 2.9 TP-04 Calibration of Controlled Tools
- 2.10 WP-108, Protective Coatings Service Level I Embedded Steel Plate,
 Service Level II Steel Surfaces and Balance-of-Plant Steel Surfaces
- 2.11 SD/C-A-1018, Identification of Bergen-Paterson Hanger Parts
- 2.12 SD/C-A-1019, Neutral Axis of Odd-Shaped Structural Members
- 2.13 WP-25, Field Engineering
- 2.14 MP-05, Permanent Marking of Site Material and Components
- 2.15 WP-139, Pipe Hanger Work Package Preparation

FURM NO. 1779 B

CONSTRUCTION PROCEDURES MANUAL SHIPP	Procedure WP-110		A	Date s Approved
INSTALLATION OF SEISMIC PIPE HANGERS WORK PROCEDURE AND SUPPORTS FOR SEISMICALLY ANALYZED	Revision	10		
DESCRIPTION PIPE	Page	6	of	22

- 2.16 WP-140, QA Records Review (Seismic Pipe Hangers and Supports for Seismically Analyzed Pipe)
- 2.17 CAR 2165-G-107501, Field Installation Tolerances for Pipe Hangers

3.0 GENERAL

3.1 Introduction

Unless otherwise noted, the tolerances in the following sections may be used for construction of a pipe hanger. However, to exceed these tolerances, a Field Mod (Exhibit I) must be obtained from the Hanger Engineer. These Mods will allow work and inspections to proceed to completion. The tolerances described herein may also be applied to the Mod requirements.

3.2 Location Tolerances

1. The reference dimensions provided on the hanger drawing for elevations and column line offsets should be used for locating hangers during initial hanger fit-up but not for inspection.

 Dimensions from pipe attachments to pipe elbows or fittings shall be modded. The dimensional tolerance is +1/2".

- Hangers should not be located within 15" of a pipe (butt) weld if the hanger supports Class I or 2 pipe.
- Hangers shall not be installed on a pipe elbow, fitting or butt weld.

5. Pipe clamps may be installed over Code Data Tags provided the clamp halves remain approximately parallel. Box frame hangers may not be installed over Code Data Tags without obtaining a Work Directive from the Hanger Engineer.

3.3 Geometry Tolerance

- Geometry may vary ± 1/2" from the design dimension however this tolerance can not be used to reduce weld length (Example: Structural Steel overlapping embed plates) or to reduce the clearance requirements around the pipe.
- Slopes and angles may vary from design provided the location and geometry dimensions are maintained.

R10

R10

CONSTRUCTION PRO	CEDURES MANUAL SHNPP	Procedure WP-11	No.	As	Approved
WORK PROCEDURE	INSTALLATION OF SEISMIC PIPE HANGERS AND SUPPORTS FOR SEISMICALLY ANALYZED	Revision	10		
DESCRIPTION	PIPE	Page	7	of	22

(3.3.)

- 3. Sway supports must be within $\pm 3^{\circ}$ of the design requirements.
- 4. The neutral axis of structural members shall be used as reference lines for geometric configurations (see SD/C-A-1019).
- 5. Strut lengths must be within 1/2" of design.
- 6. Plate sizes shall be + 1/2", -1/4" from the Bill of Material requirements.


RIO

3.4 Steel Attachment Tolerances

- Hangers are to be attached within ± 1/2" of the embed centerline(s).
- Hangers attaching to cinch anchored base plates shall attach
 within the tolerance given on the anchor bolt and base plate detail
 sheet of the hanger sketch.
- 3. Hangers should attach to the correct embed type which is detailed on the hanger sketch. If the embed in the field is designated as a Dubose plate, reduced tolerances will be necessary and should be provided via a Hanger Mod.
- 4. Hangers must attach within ± 1/2" of the centerline of a structural steel member (existing steel) and may move ± 1/2" along the axis of the structural steel member. In the containment building the centerline of the structural steel member shall be assumed to be on the azimuth required by design.
- 5. Attachments to strip plates with threaded study must be surrounded by acceptable study. See Figures 1 and 2. A threaded stud is not acceptable if it is disengaged by more than 1/8" or if there is a weld within 1/2" of the stud.

If otherwise obtain a Hanger Mod from the Hanger Engineer if possible.





CONSTRUCTION PRO		- WP-110	No.		As Approved
WORK PROCEDURE	INSTALLATION OF SEISMIC PIPE HANGERS AND SUPPORTS FOR SEISMICALLY ANALYZED	Revision	10	H	
DESCRIPTION	PIPE	Page	8	of	22

3.5 Box Frame Hangers

1. Clearances

- Clearances around the pipe in a box frame hanger must be achieved. However, the pipe can not be cold pulled (forced out of its relaxed position) in order to do so.
- If the clearance is specified as 1/16" by design, then the clearances must meet the criteria laid out in Appendix I.
 3.If the clearance specified by design is more than 1/16" then contact the Discipline Mechanical Engineer for requirements via a Field Mod.
- 4. For one-way box restraints, the Hanger Engineer must issue a Mod to detail the clearance requirements.
- 5. The pipe and the hanger shall be visually square with respect to the other; however, clearances shall meet the skewness requirements of Appendix I.

2. Shims

- Shims shall be installed in accordance with the Field Mod around the pipe if clearances are not acceptable.
- Shims called for by the design sketch may be deleted by a
 Field Mod if the pipe clearances are acceptable.
- Shim material must be A-36 or A-569 carbon steel. If otherwise, a Field Mod must be obtained from the Hanger Engineer.
- 4. Shim plates must be in contact with the hanger member at the points where the shim is welded to the hanger member and free of lubricant. Shim surfaces shall not be sandblasted.
- The shim shall overhang the hanger member enough to allow for the weld on both sides.
- 6. The centerlines of the shim and pipe shall be aligned within the $\pm 1/2$ " of each other.

RIO

R10

R10

CONSTRUCTION PROCEDURES MANUAL SHNPP INSTALLATION OF SEISMIC PIPE HANGERS	WP-110	No.	As A	Approved
WORK PROCEDURE AND SUPPORTS FOR SEISMICALLY ANALYZED	Revision	10		
DESCRIPTION PIPE	Page	9	of	22

(3.5.2.)

- The shim and shim weld details shall be provided on a Field Mod.
- Weld length shall be within +1/4"-0" of the length specified on the Mod.

R10

3.6 Catalog Parts

- Combinations of WBA, sway supports and/or pipe clamps must conform with the requirements of Appendix A unless noted otherwise.
- 2. All combinations must be aligned, in order to ensure the strut does not bind with the WBA or Clamp ears. Part numbers 1000 and 1001 should be fitted to other items using the load pin as the neutral axis.

RIO

- Catalog parts may be identified by part numbers or checked against the dimensions provided in the Site Drawing (SD/C-A-1018). Also see Appendix E.
- 4. Care should be exercised to ensure load pins, bolts, nuts, washers, and pipe clamp halves for different hangers/or parts are not indiscriminately exchanged. An inspector shall verify material grades for load pins, bolts and nuts prior to Final Acceptance. (See Appendix C and F).
- 5. If the load pin must be removed from the end attachment, a light lubricant and punch should be used to facilitate removal. Care must be taken to prevent the lubricant from contacting stainless steel pipe.
- 6. The holes in the ears of the WBA or pipe clamps shall not be ground in order to reinsert the load pin. However, the ends of the load pins may be lightly filed to remove mushrooming caused by forced installation. The shank of the load pin shall not be ground for any reason. Also, light tapping may be used to remove or install the load pins. If the end attachment ears are damaged in the process, the end attachment must be replaced. Cotter pins must be spread in opposite directions to prevent the load pin from slipping out.

CONSTRUCTION PROCEDURES MANUAL SEISMIC SEISMIC	HNPP Procedure No.	As	Approved
WORK PROCEDURE AND SUPPORTS FOR SEISMIC		10	
DESCRIPTIONPIPE	Page 10	of	22

(3.6.)

- 7. Bearings should be tightly engaged between the ears of the WBA or pipe clamp. Any gaps should not exceed the clearances specified in Appendix B. Contact the Hanger Engineer if the clearance cannot be reduced with spacer washers per Appendix G.
- 8. When installing the struts, care must be taken to ensure that the pipe is not forced out of its relaxed position (this is called cold pull).
- 9. Tightening of bolts, studs, threaded rod, and U-bolts shall be in accordance with Appendix F. Nuts should be fully engaged on the threads (when the point of the threaded portion is outside the plane of the nut) and should not bear against the bolt shanks.
- 10. Instructions for tightening bolts and nuts in applications other than pipe clamps, U-bolts, threaded rod supports, and springs should be obtained from the Hanger Engineer.
- II. To shorten or lengthen strut assemblies (outside built in adjustment), the Hanger Engineer must provide detailed instructions to the craft via a Field Mod.
- 12. For telescoping struts, there must be 1/4" minimum engagement between the strut and the shank prior to welding. (A 1/4" hole may have to be drilled 1/4" minimum from the end of the barrel to verify shank engagement.) The shank and pipe strut must be aligned. The weld size between the shank and tubing shall be provided on a Mod even if noted otherwise on the Bergen Paterson sketch.

3.7 General Guidelines

I. Lift Points

Installed pipe hangers shall not be used as lift points for loads other than the ones approved by WP-48. The welding of temporary attachments to hangers shall be in accordance with MP-08. All welded temporary attachments will be removed from the hanger prior to any inspections.

R10

CONSTRUCTION PRO	CEDURES MANUAL SHNPP INSTALLATION OF SEISMIC PIPE HANGERS	Procedure No. WP-110	As Approved
WORK PROCEDURE	AND SUPPORTS FOR SEISMICALLY ANALYZED	Revision 10	
DESCRIPTION	PIPE	Page 11	of 22

(3.7.)

2. Pipe Cleanliness

The external surface of all stainless steel piping shall be cleaned of all contaminants (Reference WP-II2) prior to the placing of a pipe clamp around the pipe or surrounding the pipe with a window hanger. Rust on the external surface of stainless steel pipe is acceptable, as is dust which accumulates during normal construction activities. Vendor identification markings may be left on the pipe. Contact the Pipe Superintendent or his designee if cleanliness has not been attained.

R10

3. Box Frame and Anchor-Type Support Box Frame Hangers should not be welded out (tack welds should be sufficiently large to ensure safety). Anchors should not attach (including tack welded) to the pipe until the pipe is installed hard point to hard point.

RIO

4. Temporary Pipe Supports

- 1. Temporary hangers shall be erected to support the pipe in accordance with WP-102 Section 4.2.5.7. These supports should not be removed nor should permanent supports be reworked if the work would compromise the required spacings for the pipe supports.
- 2. Temporary hangers shall also be erected in lieu of permanent hangers when necessary to support RFTs. They shall not be erected (insofar as practicable) in the same location as the permanent support. These temporary hangers will be tagged and may only be removed after the permanent supports have been installed. A Work Directive is necessary for this effort.

5. Coating Requirements

Per WP-108, all steel going into the containment building shall be coated to Service Level I requirements; all stock steel shall be coated to Service Level I requirements prior to issue to the field. Prior to coating, hangers shall be hard marked for hanger and

CONSTRUCTION PRO	CEDURES MANUAL	SHNPP		_ VP-IIO	No.	As	Approved
WORK PROCEDURE	INSTALLATION OF			Revision	10		
DESCRIPTION	PIPE	SEISHIGHEEI	ALALION	Page	12	of	22

(3.7.5. cont'd)

material identifications; stock steel shall be hard marked for material identification. The installation of pipe hangers shall not make an area (steel or concrete) which requires protective coatings inaccessible for application of coating or required inspection of coatings. If installation of an item would cause an area to be inaccessible then prior to the installation, the Pipe Hanger Superintendent or designee shall contact the Paint Superintendent and/or CI Coatings Inspector to verify that required coatings and inspections have been performed and accepted.

R10

6. Material Marking

All steel for future installations shall be hard marked in accordance with MP-05 for material identification. This shall be witnessed by a QC Inspector. If markings will be removed or covered by a construction activity prior to a final QC signoff, the marking shall be transferred and witnessed by the QC Inspector. There shall be no unmarked stock steel in the field surplus room.

7. Snubbers

Since snubbers can't be installed until just prior to Hot Functional testing, "Surrogate" snubber assemblies shall be used in place of the Pacific Scientific part of the B-P snubber assembly (part #2540) load sizes .35, .65, 1.5, 6 and 15. This "Surrogate" snubber assembly will permit weldout of the transition tube to the proper length. A Field Mod shall be issued detailing the transition tube weld and "L" dimension, reference SD/C-A-1018.

R10

8. Access Interferences

If the hanger creates an access interference in a doorway, aisle, or stairwell, etc., or if an interference prevents the hanger from performing its design function, the hanger should not be installed and the Hanger Engineer should be contacted.

CONSTRUCTION PRO	OCEDURES MANUAL SHNPP	Procedure N WP-11	100	As A	Approved	
WORK PROCEDURE	INSTALLATION OF SEISMIC PIPE HANGERS AND SUPPORTS FOR SEISMICALLY ANALYZED	Revision	10			
DESCRIPTION	PIPE	Page 1	3	of	22	

(3.7)

9. Stainless Steel Straps

Stainless steel straps shall not be installed with the pipe hangers even if specified by design. Mods or design revisions are necessary to delete this item from the Bill of Materials.

10. Stiffener Plates

Stiffener plates may be coped or trimmed as necessary in order for the item to be fitted between the flanges of W-shapes.

II. Welded Pipe Attachments (WPA)

Although the installation of WPA's is in accordance with other procedures, it should be verified that all parts of the WPA are installed as designed. Box frame hangers that interface with the WPA should not be installed until the WPA is welded out.

Valve Hangers

Valve hangers should not be installed until after the valve has been welded out.

13. Voided Hangers

A Work Directive shall be issued with voided hangers to have them removed from the field. CI and QC must verify the work was accomplished and sign the Work Directive.

Spring Hangers and Fire Protection Hangers

All spring hangers and nonseismic fire protection hangers were within the scope of WP-109 (Installation of Nonseismic Hangers). As a result, fitup gaps were not recorded, hanger geometry and locations were not checked, and structural welds were not inspected by QC. Spring hangers on seismically analyzed pipe per Revision 7 and Bergen-Paterson fire protection hangers per Revision 8 are within the scope of WP-110. Although the inspector cannot go back and check fitup gaps or other in-process inspections, the inspectors can verify geometry and location and perform a final visual inspection of the welds. For hold points which cannot be met due to installation prior to this procedure, the inspector can so note on the Traveler and/or SWDR.

CONSTRUCTION PROCEDURES MANUAL SHNPP

INSTALLATION OF SEISMIC PIPE HANGERS

WP-110 As Approved

Revision 10

Pipe

Page 14 of 22

(3.7.)

15. Variable Supports

To assure the proper installation of spring type variable supports/hangers, the following criteria shall be adhered to:

- Name plates shall be visible and accessible.
- Sufficient travel clearance shall be provided for piping movement between spring hanger parts and other structures, piping, conduit, etc.
- 3. Rods are permitted freedom of swing.
- 4. Preset pin shall be checked for installation/engagement.
- 5. Adjust rods to remove slack only, this shall be accomplished by rotating turnbuckle/coupling and then tighten locking nuts.
- 6. Where trapeze type spring design is encountered, the asbuilt location of the pipe to be supported shall adhere to design location relative to centerlines of springs within ± 1/4" and the trapeze shall be visually level.

16. Constant Supports

(To be addressed later.)

. 17. Material Requisitioning

- I. Hangers may be requisitioned from the warehouse using the hanger numbers found on the hanger sketches. The material shall consist of all pieces received for the current drawing revision and, if necessary, those items taken from seismic surplus stock. For hangers utilizing snubbers, the warehouse will withhold the snubber and snubber extension if a separate requisition is made for specific parts needed. The parts being withheld can be requisitioned at a later date. At the time of requisitioning, the requisitioner should use the hanger sketch to inventory the materials for the hanger.
- Hanger material shall be placed in a clean, dry area designated by the area superintendent and/or hanger superintendent.

R10

CONSTRUCTION PRO		Procedi	-110	As	Approved
	INSTALLATION OF SEISMIC PIPE HANGERS AND SUPPORTS FOR SEISMICALLY ANALYZED	Revisio	m 10		
DESCRIPTION	PIPE	Page	15	of	22

(3.7.17.)

- 3. All material superseded by later drawing revisions shall be removed from the field. Usable surplus material should be returned to the warehouse in a timely manner. This should avoid work-area congestion and misuse of material.
- Scrap material shall be sent to the designated scrap location.
- 5. Material (Pipe Hangers) may be sent to surplus from Controlled Storage via a CMR. The CMR will state the material that is to be sent to surplus. Provided that is the case the welds will not be removed and only a material verification from QA is required. When material is released to the field from surplus all shopwelds will be cut out and the material appropriately stamped for identification per section 3.7.6.

18. W 4ing

- 1. Welding shall be in accordance with Reference 2.1.
- 2. The use of "Typical" weld symbols by Bergen-Paterson does not mean that welded joints are identical in geometric configuration or made up of parts the same size or shape. The "Typical" weld symbol designation is used for similar joints with the same size weld.
- 3. Welds may be oversized provided the overwelding does not have any detrimental effect on the weld, base material or overall integrity of the hanger. The extra weld is permissible without a Mod provided a weld size or length tolerance is not specified on the drawing as is the case with flexible connections and shims.
- 4. Bergen-Paterson supplied pipe clamps with shop welded attachments shall be considered B-P standard parts, therefore the shop welded attachments and shop welds do not require site inspection.
- Arc strike on piping is not allowed. Contact the Discipline Engineer for guidance prior to the removal of any arc strike from pipe.
- 6. Welding to base plates that require grout should be done prior to grouting except in cases where welding will prohibit the grouting operation. If welding must be performed after

R10

CONSTRUCTION PRO	CEDURES MANUAL SHNPP	Procedure No. WP-110	As Approved
WORK PROCEDURE	INSTALLATION OF SEISMIC PIPE HANGERS AND SUPPORTS FOR SEISMICALLY ANALYZED	Revision 10	
DESCRIPTION	PIPE	Page 16	of 22

(3.7.18.6. cont'd)

grouting has been completed contact the Discipline Engineer for guidance.

 Welding shall not proceed to a point where the inspection of previously made welds could not be performed.

19. Hanger Material Grade

For Bergen-Paterson supplied standard structural shapes the material grade is dependent on the material type. If the material grade is not specified on the B-P hanger sketch Bill of Materials then the material is as follows:

Material Type	Material Grade
Plate or Bar	SA-36
Angle	SA-36
Tube Steel	A-500 Gr. B
Pipe -	SA-106 Gr. B
Channel	SA-36
Wide Flange	SA-36

20. Nonstructural Endcaps

Nonstructural end caps outside the Containment Building are not required to be welded out, they may be tack welded in place. The end caps shall be checked to ensure they cover the full surface area of opening and fit-up gaps do not exceed 3/16". The end cap size or weld need not be shown on a Mod or inspected. Weld mapping of Nonstructural Endcaps is not required therefore, fit-up gaps are not required to be listed on the SWDR.

3.8 Exhibit Instructions

Changes to the content of Work Directives, Travelers, and Hanger Mods must be initialed and dated. Signoff blocks on a Work Directive or the Traveler for a Hanger Mod should be dated on or after the change date.

Field Mods (Exhibit 1)

 Field Mods shall be written and issued by the Resident Hanger Engineer or his designee. RIO

CONSTRUCTION PROCEDURES MANUAL SHNPP INSTALLATION OF SEISMIC PIPE HANGERS	Procedure No. WP-110	As Approved
WORK PROCEDURE AND SUPPORTS FOR SEISMICALLY ANALYZED	Revision 10	
DESCRIPTION FIPE	Page 17	of 22

(3.8.1)

2. Modifications to anchor-type supports or hangers on Class I lines must be limited to corrections in drafting errors, drawing clarifications, weld symbols, and geometry changes within +2".

R10

R10

- 3. The field mod is comprised of two copies, one of which remains in the field for hanger installation, and the original which is routed to the work package group for assignment of FM# and routing to Document Control. (The FM# is a sequential tracking number).
- 4. If NDE requirement holdpoints or welding procedures are affected by the issuance of a Mod, the hanger package should be routed to Welding Engineering and QC Welding for the required changes to the SWDR.
- 5. The field copy of the Mod shall be considered active for ten calendar days. If a controlled (blue) copy has not been inserted in the hanger package within ten calendar days, all work on the hanger shall stop until a controlled copy is received.
- 6. Each Mod shall also have a unique number which shall consist of the Hanger Design revision, M for Mod, and an ascending number starting with I (Ex. 2/A MI). This numerical sequence starts over when a new design revision is received.
- New design revisions shall supersede the previous design revisions and all Mods written against that revision.
- 8. Mods which conflict with an aiready active Mod shall not be issued until the active Mod has been voided. Voiding of Mods shall be accomplished as follows. The voided Mod shall be marked void, initialed, and dated by the Hanger Engineer. The subsequent Mod shall specify the Mod which was voided. This shall serve as notification to Document Control that a Mod was voided.

R10

CONSTRUCTION PRO	CEDURES MANUAL SHNPP	Procedure No. WP-110	As Approved
WORK PROCEDURE	INSTALLATION OF SEISMIC PIPE HANGERS AND SUPPORTS FOR SEISMICALLY ANALYZED	Revision 10	
DESCRIPTION	PIPE	Page 18	of 22

(3.8.1)

 Mods which reflect a major redesign of the hanger should be sent through QC welding prior to weldout.

R10

2. HIC Sticker (Exhibit 2)

The HIC sticker shall be located and completed by the Field Engineers.

- 3. Traveler (Exhibit 3)
 - The Traveler shall be initiated by the Hanger Engineer in order to control the in-process installation and inspections of the pipe hanger.
 - Work Directives, DCN's, PW's, FCR's, and Hanger Mods should be referenced in the applicable blocks at the top of the Traveler. Mod numbers (i.e., 251 MI) are listed under the RCI heading. If any of these documents are voided, the entry should be lined through, initialed and dated by the Hanger Engineer. Superseded documents do not need to be crossed out.
 - Engineered plate thickness determinations should be listed after 7/22/81 by the Hanger or Area Engineer.
 - 4. The phase of construction Preliminary or Final should be appropriately denoted. Completion of either phase shall be to the latest design revision and/or Mod (Examples 2/A MI or ISI M4).
 - 5. For the PRELIMINARY phase of construction, the FIT-UP and WELDOUT signoff blocks shall be initialed and dated by the foreman, the CI block initialed and dated by the Hanger Engineer, and the QC block initialed and dated by the Welding Engineer. The QC block may be marked N/A initialed and dated by the Hanger Engineer.
 - 6. For the Final phase of construction and inspection, the FIT-UP AND WELDOUT blocks may be initialed and dated by the foreman. The CI and QC blocks shall be initialed and dated by CI and QC inspectors respectively. The CI and QC

CONSTRUCTION PRO	CEDURES MANU	OF SEISMIC PIPE	HANGERS	Procedure WP-11	Na 10	As	Approved
WORK PROCEDURE	AND SUPPORTS	FOR SEISMICALLY	ANALYZED	Revision	10		Manage 1
DESCRIPTION	PIPE	ADDRESS OF THE PARTY OF THE PAR		Page	19	of	22

(3.8.3.6 cont'd)

- signoffs are for final acceptance of the hanger, however the actual inspection records are on TP-34 and the SWDR respectively.
- 7. Upon receipt of a new design which does not affect the asbuilt configuration and location of the hanger, signoff blocks shall be N/A'd, initialed and dated and the Hanger Engineer shall make an entry for that revision and note "as-built" on the traveler.
- If the new revision does affect work, the work package is re-issued to the field for completion to that later revision.
- 4. Material Verification (Exhibit 4)

The Material Verification sheet shall be completed by the Hanger Engineer per the instructions provided in Appendix J.

- 5. Work Directives (Exhibit 5)
 - Work Directives shall be issued to detail Construction activities. This includes any work which will void out a previous inspection, however, the re-listing of weld joints in accordance with WP-139 on the SWDR shall serve as sufficient notice to the Craft as well as Inspection Groups that additional work is required.
 - Work Directives shall be initiated, signed and dated by the Hanger Engineer.

RIO

R10

R10

R10

- Work Directive Numbers shall be sequential starting with one. The number shall be assigned by the Hanger Work Package Group.
- 4. Signoff blocks shall be completed by the appropriate persons unless N/A'd by the Hanger Engineer.
- 6. Procedural Deviation (Exhibit 7)

The Procedural Deviation (P.D.) form shall be considered as an attachment to the Traveler (Exhibit 3) where CI shall list the rejectable conditions on the left side, sign and date at the bottom of the form. The Hanger Engineer shall address each discrepancy

CONSTRUCTION PROCEDURES MANUAL	SHNPP	Presedyn 6	No.	As Approved	
WORK PROCEDURE INSTALLATION OF	SEISMIC PIPE HANGERS AND	Revision		10	NAME OF THE OWNER.
DESCRIPTION SUPPORTS FOR SEISMICA	LLY ANALYZED PIPE	Page	20	of	22

(3.8.6. cont'd)

under the Corrective Action section on the right side, sign and date the bottom of the form. CI shall sign and date under the Hanger Engineer acknowledging that each discrepancy has been addressed. When CI rejects the hanger then the P.D. form shall be referenced by CI on the Traveler. A new P.D. form shall be issued for each inspection and have a unique number which shall consist of an ascending letter starting with A (Ex. PD-A) for each revision of the pipe support to which an inspection is made. Discrepancies addressed under the Corrective Action section may be resolved by the following actions:

- 1. Field rework is required.
- 2. Issuance of a Field Modification.
- 3. Stating that the condition is acceptable and has no relevant impact on design. There is no quantitative acceptance criteria for this condition and therefore it will not be reported back to the design organization.

4.0 PROCEDURE

- 4.1 The Field Engineers shall identify interferences and provide reference points (within +1" of design) for hanger installation as requested. The reference points are easily identified by the orange sticker (Exhibit 2). These activities are referred to as the HIC-Hanger Installation Checkout-Program in WP-139.
- 4.2 The Hanger Engineer should establish that the hanger is not on hold for construction, engineering or quality reasons prior to generating the work package. The work package should consist of but not be limited to the Hanger Design drawing, SWDR, and Traveler (Exhibit 3). Instructions outlining work activities shall be included. In addition a Work Directive (Exhibit 5) detailing work instructions to the craft and inspectors shall be included. After the work package is made up in accordance with Reference 2.15 and it has been established that the hanger is ready for construction, it is issued to the Hanger Superintendent for installation.
- 4.3 If the Traveler has been signed off preliminary by CI or Hanger Engineering and by QC or Welding Engineering proceed to section 4.11. If the Traveler has been signed off preliminary by CI or Hanger Engineering only, then proceed to section 4.9.
- 4.4 The Hanger Engineer or the Craft Superintendent or their designees shall requisition the material from the warehouse when necessary.

10

RIO

CONSTRUCTION PRO	CEDURES MANUAL SHNPP	Procedu WP-	110	As	Approved
WORK PROCEDURE	INSTALLATION OF SEISMIC PIPE HANGERS AND	Revision	n	10	
DESCRIPTION	CITEDARE BOR CETACTOLITY LIVER BERGE	Page	21	of	22

- 4.5 The Craft Superintendent or his designee shall investigate the work area and call the Area or Hanger Engineer for an embed thickness determination if the hanger is to be attached to an engineered plate.
- 4.6 The Area or Hanger Engineer, when required, shall determine the engineered plate thickness and record the thickness on the Traveler.
- 4.7 The Craft Superintendent or his designee shall tack weld the hanger members in accordance with MP-08 and sign the Traveler. If NDE requirements are changed due to a Mod or member thickness exceeds I-1/2", Welding Engineering should be contacted. Partial inspections by Welding Engineering and/or QC may be required.
- 4.8 The Hanger Engineer shall list the gap measurements on the SWDR (see Appendix K for criteria); examine the hanger for general geometry, location, and function per design; and signoff the Traveler for preliminary. The Resident Engineer or his designee shall issue Mods as necessary.
- 4.9 The Craft Superintendent or his designee shall weld the hanger members in accordance with MP-08 and sign the Traveler.
- 4.10 The Welding Engineer or his designee shall examine the welds for quality and size, as requested, and signoff the Traveler for preliminary.
- 4.11 The Craft Superintendent or his designee shall prepare the hanger to pass CI and QC Final Inspections adjust struts, check clearances, ensure proper hardware, make remaining welds, etc.
- 4.12 The Welding Engineer or his designee shall examine all welds which have not already been investigated by Welding Engineering and again signoff the Traveler by noting "Ready for Final" beside the preliminary signoff.
- 4.13 The Hanger Engineer or his designee shall examine the hanger for completeness and correctness, verify material, complete Exhibit 4, Mod the as-constructed dimension from the centerline of the pipe attachment to the nearest pipe fitting or elbow, and again signoff the traveler by noting "Ready for Final" beside the preliminary signoff.
- 4.14 CI and/or QC shall inspect the hanger as required and signoff the Traveler for final when all work has been completed per the latest design.


M NO. 1779 B		WF-110	As Appi	roved
P	PROCEDURES MANUAL SHNPP INSTALLATION OF SEISMIC PIPE HANGERS ANALYZED	Revision 10		
NSTRUCTION !	INSTALLATION OF SEISMIC THE ANALYZED AND SUPPORTS FOR SEISMICALLY ANALYZED	Page 22	of 22	
ORK PROCESON	PIPE		s to	R10
4.16 T	he Hanger Engineer shall issue a Work Directive for the welding, geometry, material, or location—the equired. Work shall then proceed in accordance wittens listed above. The Hanger Engineer shall review the Q-documents transmit them to QA Records Review Group after completed and inspected and an as-built of the hand denuing.	s per WP-140 a the hanger hanger has been	able and s been	R10
	incorporated into the design drawing. The Hanger Engineer shall put a CWRA in the wor	k package wh	en	1 ALO
	required.			
5.1 5.2 5.3 5.4 5.5 5.6 5.7 5.8 5.9 5.10 5.11 5.11 5.11 5.11 5.11 5.11 5.11 5.11 5.11 5.11	Appendix B - Gap Tolerances at Load Pins (Rev. Appendix C - Fastener Types (Rev. 4-2/84) Appendix D - Flow Chart (Rev. 1-3/84) Appendix E - Strut Identifications (Rev. 2-3/84) Appendix F - Tightening Criteria (Rev. 2-1/84) Appendix G - Flat and Tapered Washer Reference Appendix G - Flat Appendi	(83) 4-3/84) . 5-3/84) nce Table (Re Steam B-Wall 84) Rev. 3-3/84)	v. 1-11/83)	R1

PROCEED AT RISK	SEISMI	EXHIE C WF
	□ NON-SE	
FIELD	MODIFICATION	
CONDITION:		
	Na Assistantia de la Carta de La Carta de Carta	
5 A C L	DATE CALENDAR	DAYS AND IS SUPERCEDE CONTROLLED COPY.
	''''	ВОМ
50/		
\		
•	15	-
	7/	
	^	
	(0)	-
	1	
		-
	. //	^
	<<	V V
ANGER NO.	MODIFICATION	NUMBER
+		
SYSTEM HANGER NO	DRAWING REV.	MOD. NO.
		moo. 140.

IFA D

EIC STICKER





FORM NO. 10039

QC:

SHAPP

EXHIBIT 3

SEISMIC HANGER INSTALLATION TRAVELER HANGER NO. RFT NO. STRESS NO. LINE NO. ITEM TO ENGR. PL (TYPE) THK FCR / PW / DCN SCI The second second second second second second . 70 0 0 1 1 1 WD MATL. APR. NO. PROCEDURE ITEMS TACKED WITH GAPS INITIAL DATE COMMENTS FIELD: FITUP REV: CI: FIELD: WELDOUT PHASE: QC: FIELD: FITUP REV: CI: FIELD: WELDOUT PHASE: oc: FIELD: FITUP REV: CI: FIELD: WELDOUT PLASE: QC: FIELD: FITUP REV: CI: FIELD: WELDOUT PHASE: QC: FIELD: FITUP REV: CI: FIELD: WELDOUT PHASE: oc: FIELD: FITUP . REV: CI: FIELD: WELDOUT PHASE: QC: FIELD: FITUP SEV: CI: FIELD: WELDOUT PHASE:

MATERIAL VERIFICATION

HANGER NO.

ITEM #	REV. #	WAE	REHOUSE ISSUE VERIFICATION	
	$\equiv \equiv$	1.	These items were part of the as rechanger. Warehouse Engr.	eived as issued steel for this Date
		FIEL	D MATERIAL VERIFICATION	
	$\equiv \emptyset$	D ^{2.}	These items were part of the as rechanger. This was verified by comparevision against the as-constructed	ring the as-received and issued
===	≡	3.	These items were substituted/added record the source of the material. and found to be legitimate with a C	The source has been investigate
=	Ξ	4.	These items have been stamped for inaterial grade conforms with the remarks.	
===	=	5.	These items have been etched for material grade conforms with the re	
	=	6.	These items are oatalogoarts.	
		7.	Per sampling program, there is reas	onable assurance that the
=	=		material conforms to the ASTM man	terial grade requirements of th
	HANGER	ENGIN	EER	
	REV.			1

B = bolt list with 4 or 7

N = nut - list with 4 or 7

L = load pin - list with 5 - no sampling is permissible S = shim - list with 4, 5, or 7

11/82

= CAROLINA POWER & LIGHT CO.

-

MO-		
	-	
	THE PERSON NAMED IN COLUMN	

WORK DIRECTIVE


Need Date

שבייים ל ביניים

azi i mahmam

PIPE HANGER No

A SAN DECUSION



ACKHOWLEDGED DATE

INICEPTENCE CECA REF. R.P. CONPOSITE DYS NOTES NOTES SY L. (PA) DIMENSION-LOCATES PIPE ATTACH. IN DESIGN POSITION WORL NOTES TOTAL 1. (PA) DIMENSION-LOCATES CENTED LINE OF STEEL ATTACHMENT OSSANIAL D. OSSANIAL SELSKIĆ FORMAT		,			1		SE	ISMIC L	OAD SHEE	T				
INTESTERALE ELECA REF. 8.P. CONPOSITE DIFE NOTES NOTES NOTES TOTAL 1. (PA) DIMENSION LOCATES PIPE ATTACH. IN DESIGN POSITION 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL ATTACHMENT. PREMAL 1. (STL) DIMENSION LOCATES CENTER LINE OF STEEL ATTACHMENT. 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL ATTACHMENT. 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL ATTACHMENT. 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL ATTACHMENT. 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL ATTACHMENT. 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL ATTACHMENT. 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL ATTACHMENT. 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL ATTACHMENT. 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL ATTACHMENT. 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL ATTACHMENT. 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL ATTACHMENT. 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL ATTACHMENT. 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL ATTACHMENT. 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL ATTACHMENT. 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL ATTACHMENT. 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL ATTACHMENT. 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL COLOR 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL COLOR 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL COLOR 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL COLOR 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL COLOR 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL COLOR 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL COLOR 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL COLOR 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL COLOR 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL COLOR 2. (STL) DIMENSION LOCATES CENTER 2. (STL) DI	TEM	MAUC!	FIRT NO.	SIZT	-1		140	080	MONT		WOT.			
INTESTERALE ELECA REF. 8.P. CONPOSITE DIFE NOTES NOTES NOTES TOTAL 1. (PA) DIMENSION LOCATES PIPE ATTACH. IN DESIGN POSITION 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL ATTACHMENT. PREMAL 1. (STL) DIMENSION LOCATES CENTER LINE OF STEEL ATTACHMENT. 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL ATTACHMENT. 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL ATTACHMENT. 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL ATTACHMENT. 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL ATTACHMENT. 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL ATTACHMENT. 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL ATTACHMENT. 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL ATTACHMENT. 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL ATTACHMENT. 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL ATTACHMENT. 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL ATTACHMENT. 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL ATTACHMENT. 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL ATTACHMENT. 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL ATTACHMENT. 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL ATTACHMENT. 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL ATTACHMENT. 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL COLOR 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL COLOR 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL COLOR 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL COLOR 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL COLOR 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL COLOR 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL COLOR 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL COLOR 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL COLOR 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL COLOR 2. (STL) DIMENSION LOCATES CENTER 2. (STL) DI													-	
INTERPRETATION OPERATING OPERAT	,—						-	_						-
INIENTERNZ CISCS REF. &P. COMPOSITE DIFE NOTES NOTES TOTAL 1. (PA) DIMENSION LOCATES PIPE ATTACH. IN DESIGN POSITION 2. (STIL) DIMENSION LOCATES ENTER LINE OF STEEL ATTACHMENT BY. DATE PLANTAGE COMPANING COMP	7	-						-						
INTERPRETATION OPERATING OPERAT	•													1
INIENTERNZ CISCS REF. &P. COMPOSITE DIFE NOTES NOTES TOTAL 1. (PA) DIMENSION LOCATES PIPE ATTACH. IN DESIGN POSITION 2. (STIL) DIMENSION LOCATES ENTER LINE OF STEEL ATTACHMENT BY. DATE PLANTAGE COMPANING COMP								*	* ,					
INIENTERNZ CISCS REF. &P. COMPOSITE DIFE NOTES NOTES TOTAL 1. (PA) DIMENSION LOCATES PIPE ATTACH. IN DESIGN POSITION 2. (STIL) DIMENSION LOCATES ENTER LINE OF STEEL ATTACHMENT BY. DATE PLANTAGE COMPANING COMP	-,-				, ,		Telling 1							
INTERPRETAZIONA REF. R.P. COMPOSITE DIFS R	_				-		* 7 .	SHIP OF SHIP OF SHIP OF			-		_	
INICATERIAL CASCA REF. R.P. CONPOSITE DWS RE				-	AND DESCRIPTION OF THE PERSON NAMED IN	Annual Property of	-	THE RESERVE OF THE PERSON NAMED IN						
INICESTERCHE LISEA REF. B.P. COMPOSITE DYG R		1.50				· A	1000	34.74 Y T.L			And Tables 1995	4 42 mg	N N	
INTENSEMBLE CONTROL OF THE PROPERTY OF THE PRO		1.5	Section Sec.		in the	was distant	4.200	A Contract of	4. + 5 Hy	A Street .	The Park Server	THE P.		* *,
INTENSEMBLE CONTROL OF THE PROPERTY OF THE PRO		012		7 00	·			12 4/ 1/	. A. 1996/1975	Bridge The				
REF. R.P. COMPOSITE DWG REF. R.P. COMPOSITE DWG NOTES 1. (PA) DIMENSION LOCATES PIPE ATTACH. IN DESIGN POSITION 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL ATTACHMENT DESIGN POSITION 1. (PA) DIMENSION LOCATES CENTER LINE OF STEEL ATTACHMENT DESIGN POSITION 1. (PA) DIMENSION LOCATES CENTER LINE OF STEEL ATTACHMENT DESIGN POSITION 1. (PA) DIMENSION LOCATES CENTER LINE OF STEEL ATTACHMENT DESIGN POSITION 1. (PA) DIMENSION LOCATES PIPE BY. DATE DESIGN POSITION DESIGN POSITION RELIEF VALVE LOCATION DESIGN POSITION RELIEF VALVE DO DESIGN POSITION DESIGN POSITION SELSMIC FORMAT DESIGN POSITION SELSMIC FORMAT DESIGN POSITION DESIGN P		77.5	7.45.W.T.	Maria California de la	AND REAL PROPERTY.	CHICAGO COMPANIES STATES	ALTERNATION NAMED IN	ASSESSMENT OF THE OWNER, THE OWNE	AND RESIDENCE OF THE PERSON NAMED IN	THE RESERVE OF THE PERSON NAMED IN	THE R. P. LEWIS CO., LANSING			17 ,40
REF. R.P. COMPOSITE DIFF I. (PA) DIMENSION LOCATES PIPE - ATTACH, IN DESIGN POSITION 2. (STL) DIMENSION LOCATES CENTER LINE OF STEEL ATTACHMENT. POPERATING REC. SEC. SEC. SEC. SEC. SEC. SEC. SEC. S	-		THIPPE											22214
OPERATING THERMAL USPATION LOCA Z (OBS EPSPONSS) LD Z (OBS ZPA) LD Z (OBS ZPA) LD Z (PROT, REL SEIS, DISPL) LD RELIEF VALVE UND HYORO LD HANGER WGT GNE-WAY, RESTRAINTS PREVIOUS HOROS STRESS ISO, J S		. COD:	REF. B.P	. COMP	OSITE D'A		ð	- NOTE	A) DIMEN	SION LOCAT DESIGN P	TOTAL TOTAL TES PIPE DISTION ES CENTEP			
OPERATING THERMAL USPATION LOCA Z (OBS EPSPONSS) LD Z (OBS ZPA) LD Z (OBS ZPA) LD Z (PROT, REL SEIS, DISPL) LD RELIEF VALVE UND HYORO LD HANGER WGT GNE-WAY, RESTRAINTS PREVIOUS HOROS STRESS ISO, J S		1-1-9	l ov		BATE	A -24	-5		1000			_		-
CPERATING THERMAL UD VISRATION UD LOCA 2 (OBE RESPONSE) LD 2 (PENT, REL SEIS, DISPL) LD 2 (PENT, REL SEIS, DISPL) LD RELIEF VALVE UD WIND HYDRO LD HYDRO HANGER WOT. FRICTION FORCE F3 OVER-WAY, RESPERAINTS PDENDIES-LOADS REDICATED ARE ONE HALF OF LISTED CONDITION SELSMIC FORMAT OV OV THESS ISO, F STRESS CALC, F REV. STRESS FT. F P.O. NO, 3301 — UNIT NO. PIRMS STRESS FT. S SOUTHWEST FABRICATING & WELDING CO. ITALIANS PRINCE STRESS FT. S SOUTHWEST FABRICATING & WELDING CO. PIRMS STRESS FT. S SOUTHWEST FABRICATING & WELDING CO. ITALIANS PIRMS STRESS INC. S SOUTHWEST FABRICATING & WELDING CO. OPEN CO. PIRMS STRESS FT. S SOUTHWEST FABRICATING & WELDING CO. PIRMS STRESS INC. S STRESS FT. S SOUTHWEST FABRICATING & WELDING CO. PIRMS STRING STRIN	1	1 2	01.		DAIL	a inta total	-	11年 日本日本		where the party of the last of	Chicago de como contrato i servicio	THE RESERVE AND ADDRESS OF THE PARTY OF THE	Che Married Prints Service S	
THERMAL UD VISRATION LD 2 (OBE RESPONSE) LD 2 (O	1	3			, Car (* 10. pr. 0		200		1804	ECA	ECS	ECA	ECI	
VIBRATION LOCA LOCA LOCA LOCA LOCA LOCA LOCA LOCA	1							11		1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	2 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 -	_		
COA 2 (OBE RESPONSE) D 2 (PENT. REL. SEIS. DISPL.) LD 2 (WATER & STM. HAMMER) LD RELIEF VALVE LD WIND HYDRO LD HAMBER WGT. FRICTION FORCE GNE-WAY. RESTRAINTS POENTIES-LAADS INDICATED ARE ONE HALF OF LISTED CONDITION. SEISMIC FORMAT SEISMIC FORMAT SEISMIC FORMAT FIRESS ISO. / REV. STRESS FT. / STRESS FT. / UNIT NO. BERGEN-PATERSON PIPESUPPORT CORP. STRINGS SEISMICATING & WELDING CO. FIRMS SOUTHWEST FABRICATING & WELDING CO. STRINGS SEISMICATING & WELDING CO.	1:-	1							#	at a way	As at the st	100		, -3 0 i
2 (OBE FESPONSE) 2 (OBE ZPA) LD 2 (WATER & STM, HAMMER) LD 2 (WATER & STM, HAMMER) LD MYORO LD MYORO LD MYORO LD MYORO CONSTRUCTION FORCE FS ONE-WAY RESTRAINTS PDEROTES-LAAIS ROICATED AND ONE HALF OF LISTED CONDITION SE ISMIC FORMAT FIGURE OF CONDITION SE ISMIC FORMAT FOR CONDITION SE ISMIC FORMAT FOR CONDITION SE ISMIC FORMAT FRESS ISO, FRESS FT. F STRESS ISO, FRESS FT. F STRESS ISO, STRESS FT. F SOUTHWEST FABRICATING & WELDING CO. FINANCE		15 2						11	2. 1. 1. A 1.	200 1 1 1 1 1 1 1 1	A 1 100 1	1 1	as 1 1 2	arms to
2 (OBE 2PA) 2 (PENT REL SEIS, DISPL) LD 2 (WATER & STM, HAMMER) LD RELIEF VALVE WIND LD MANGER WGT. FRICTION FORCE ONE-WAY RESERVATIONS **PLENTIES-LOADS INDICATED LIKE ONE HALF OF LISTED CONDITION SELSMIC FORMAT. DE STRESS ISO. / PREV. STRESS CALC. / REV. STRESS FORMAT. BERGEN-PATERSON PIPESUPPORT CORP. **PLENTIES CALC. / REV. STRESS FORMAT. BERGEN-PATERSON PIPESUPPORT CORP. **PLENTIES CALC. / REV. STRESS FORMAT. BERGEN-PATERSON PIPESUPPORT CORP. **PLENTIES CALC. / REV. STRESS FORMAT. BERGEN-PATERSON PIPESUPPORT CORP. **PLENTIES CALC. / REV. STRESS FORMAT. BERGEN-PATERSON PIPESUPPORT CORP. **PLENTIES CALC. / REV. STRESS FORMAT. **PLENTIES CALC. / REV. **STRESS FORMAT. **PLENTIES CALC. /	1 -		LOCA :	1.7.3	AL MONANT	The Market	LD.	N		with the same of	i to the second			- in .
2 (PENT, REL. SEIS, DISPL) LD 2 (WATER & STM, HAMMER) LD RELIEF VALVE WIND LD MANGER WGT. FRICTION FORCE ONE-WAY, RESTRAINTS *DENOTES-LOADS INDICATED ARE ONE HALF OF LISTED CONDITION. SEISMIC FORMAT. SEISMIC FORMAT. **STRESS ISO, F** STRESS FT. F** STRESS FT. F* STRESS FT. F* SOUTHWEST FABRICATING & WELDING CO. FIFTING SWORE SOUTHWEST FABRICATING & WELDING CO. FIFTING SWORE FIRMS STRESS FT. STRESS FT. STRESS FT. STRESS FT. SOUTHWEST FABRICATING & WELDING CO. FIFTING SWORE FIRMS STRESS FT. STRESS FT. STRESS FT. SOUTHWEST FABRICATING & WELDING CO. FIFTING SWORE FIRMS STRESS FT. SOUTHWEST FABRICATING & WELDING CO. FIFTING SWORE FIRMS STRESS FT. SOUTHWEST FABRICATING & WELDING CO. FIFTING SWORE FIRMS STRESS FT. STRESS FT. STRESS FT. SOUTHWEST FABRICATING & WELDING CO. FIFTING SWORE FIRMS STRESS FT. SOUTHWEST FABRICATING & WELDING CO. FIFTING SWORE FIRMS STRESS FT. SOUTHWEST FABRICATING & WELDING CO. FIFTING SWORE FIRMS STRESS FT. SOUTHWEST FABRICATING & WELDING CO. FIRMS SWORE FIRMS STRESS FT. SOUTHWEST FABRICATING & WELDING CO. FIRMS SWORE FIRMS SWORE FIRMS STRESS FT. SOUTHWEST FABRICATING & WELDING CO. FIRMS SWORE FIRMS FIRM	7	1 :	2 ICBE A	ESPONSE	H 10% 10%	(September)	9.		7-5	Mark Althory	Action =			2-1
2 (PENT, REL. SEIS, DISPL) LD 2 (WATER & STM, HAMMER) LD RELIEF VALVE WIND LD MANGER WGT. FRICTION FORCE ONE-WAY, RESTRAINTS *DENOTES-LOADS INDICATED ARE ONE HALF OF LISTED CONDITION. SEISMIC FORMAT. SEISMIC FORMAT. **STRESS ISO, F** STRESS FT. F** STRESS FT. F* STRESS FT. F* SOUTHWEST FABRICATING & WELDING CO. FIFTING SWORE SOUTHWEST FABRICATING & WELDING CO. FIFTING SWORE FIRMS STRESS FT. STRESS FT. STRESS FT. STRESS FT. SOUTHWEST FABRICATING & WELDING CO. FIFTING SWORE FIRMS STRESS FT. STRESS FT. STRESS FT. SOUTHWEST FABRICATING & WELDING CO. FIFTING SWORE FIRMS STRESS FT. SOUTHWEST FABRICATING & WELDING CO. FIFTING SWORE FIRMS STRESS FT. SOUTHWEST FABRICATING & WELDING CO. FIFTING SWORE FIRMS STRESS FT. STRESS FT. STRESS FT. SOUTHWEST FABRICATING & WELDING CO. FIFTING SWORE FIRMS STRESS FT. SOUTHWEST FABRICATING & WELDING CO. FIFTING SWORE FIRMS STRESS FT. SOUTHWEST FABRICATING & WELDING CO. FIFTING SWORE FIRMS STRESS FT. SOUTHWEST FABRICATING & WELDING CO. FIRMS SWORE FIRMS STRESS FT. SOUTHWEST FABRICATING & WELDING CO. FIRMS SWORE FIRMS SWORE FIRMS STRESS FT. SOUTHWEST FABRICATING & WELDING CO. FIRMS SWORE FIRMS FIRM		1	2 (OBE Z	PAI	17.47.10		4	143600	111	The star -	of teach is		-	
2 (WATER & STM. HAMMER) RELIEF VALVE WIND LD HYDRO LD MANGER WGT. FRICTION PORCE ONE-WAY RESTRAINTS PDERIOTES-LOADS REDICATED ARE ONE HALF OF LISTED CONDITION. SELSMIC FORMAT. SELSMIC FORMAT. STRESS ISO. F STRESS FT. F PO. NO. 3301 UNIT NO. BERGEN-PATERSON PIPESUPPORT CORP. PIPENO SOUTHWEST FABRICATING & WELDING CO. FIRMS STRESS FT. F SOUTHWEST FABRICATING & WELDING CO. FIRMS STRESS FT. F SOUTHWEST FABRICATING & WELDING CO. FIRMS STRESS FT. F SOUTHWEST FABRICATING & WELDING CO. FIRMS STRESS FT. F SOUTHWEST FABRICATING & WELDING CO. FIRMS STRESS FT. F SOUTHWEST FABRICATING & WELDING CO. FIRMS STRESS FT. F SOUTHWEST FABRICATING & WELDING CO. FIRMS STRESS FT. F SOUTHWEST FABRICATING & WELDING CO. FIRMS STRESS FT. F STRESS FT. F SOUTHWEST FABRICATING & WELDING CO. FIRMS STRESS FT. F STRESS	-		Name and Address of the Owner, where the Owner, which is the	THE RESERVE AND ADDRESS OF A PERSON NAMED IN COLUMN 1 AND ADDRESS OF A P	OF REAL PROPERTY AND ADDRESS OF THE PARTY.	AND DESCRIPTION OF THE PARTY OF	BT DOWN SOME OF		NI	A		A */22	La Sa	
RELIEF VALVE WIND LD HYDRO LD HANGER WGT FRICTION FORCE ONE-WAY RESTRAINTS DENOTES-LOADS INDICATED BRE ONE HALF OF LISTED CONDITION SELSMIC FORMAT OV STRESS ISO, / REV. STRESS CALC, / REV. STRESS ST. / BERGEN-PATERSON PIPESUPPORT CORP. THOSE SOUTHWEST FABRICATING & WELDING CO. SOUTHWEST FABRICATING & WELDING CO. SELSMIC FORMAT PLANT PLANT PLANT PRINT STRESS ST. / BERGEN-PATERSON PIPESUPPORT CORP. THING STRESS ST. / STRESS ST.	-							144.50	1					
WIND HYORO LD HANGER WGT. FRICTION FORCE GNE-WAY RESERVINTS PDENUTES-LOADS INDICATED ARE ONE HALF OF LISTED CONDITION SELSMIC FORMAT. DV STRESS ISO, / REV. STRESS FT. / BERGEN-PATERSON PIPESUPPORT CORP. STRESS F	1	1013	STREET, SQUARE, SQUARE	NAME AND ADDRESS OF TAXABLE PARTY.	OR PERSON NAMED IN COLUMN	THE RESERVE AND PERSONS NAMED IN	THE RESERVE OF THE PARTY OF	-	1	/		7.45		
HYDRO HANGER WGT. FRICTION FORCE ONE-WAY RESERVANTS POENDIES-LUADS RUDICATED ARE ONE HALF OF LISTED CONDITION. SEISMIC FORMAT. DIVIDING THE STRESS ISO. F. REV. STRESS ISO. F. REV. STRESS FT. F. BERGEN-PATERSON PIPESUPPORT CORP. TYPING STRUCTURAL TYPING STRUCTURAL TYPING THE STRUCTURAL		1							10					
MANGER WGT. FRICTION FORCE ONE-WAY RESERVINTS POENOTES-LOADS HIDICATED ARE ONE HALF OF LISTED CONDITION SEISMIC FORMAT. DO THE STRESS ISO, I REV. STRESS CALC, I REV. STRESS CALC, I REV. STRESS CALC, I REV. STRESS FT. I STRESS FT. I STRESS FT. I STRUCTURAL TO STRESS FT. I STRUCTURAL THE		1-13						-			-			
FRICTION FORCE ONE-WAY RESTRAINTS **DENOTES-LOADS HOLICATED ARE ONE HALF OF LISTED CONDITION. SELSMIC FORMAT ON THE STREET AND SELSMIC FORMAT ON THE STREET AND SELSMIC FORMAT PLAN STREET CALC. FR. STREET CALC. STREET CALC. FR. STREET CALC. FR. STREET CALC. STREET CALC. FR. STREET CALC. FR. STREET CALC. STREET CALC. STREET CALC. FR. STREET CALC. STREET CALC. FR. STREET CALC. FR. STREET CALC. STREET CALC.	-			-			- 5	William Char	- 1 - 4 - 7 - 3	1	1 12 1 1 1 1 1 A			
ONE-WAY RESTRAINTS DEMOTES-LOADS INDICATED ARE ONE HALF OF LISTED CONDITION. SEISMIC FORMAT DEMOTES-LOADS INDICATED ARE ONE HALF OF LISTED CONDITION. SEISMIC FORMAT PLA PLA STRESS ISO. J STRESS CALC. J PO. NO. 3301 - UNIT NO. BERGEN-PATERSON PIPESUPPORT CORP TIPHON STRING SOUTHWEST FABRICATING & WELDING CO. 40 TWOSE PIPMS STRESS PRINCE STRUCTURAL TRUCTURAL			THE RESERVE AND PARTY AND PERSONS ASSESSMENT	STREET, SQUARE, SQUARE						-	1	-		
STRESS ISO. / REV. STRESS CALC. / REV. STRESS CALC. / REV. STRESS CALC. / REV. STRESS FT. / STR			-	THE RESERVE OF THE PERSON NAMED IN		Carrie (c) to	7.1.6.	I'm			1	le i		
SOUTHWEST FABRICATING & WELDING CO. 1551. PIPING STRUCTURAL TWOSE THE STRUCTURAL TWOSE THE STRUCTURAL TWOSE THE STRUCTURAL TWO		The state of the s	STRESS	ISO.	ADS INDI		E ONI	REV	USTED CA	HOTTON	PLA N		>	
SOUTHWEST FABRICATING & WELDING CO. 155. PIPING STRUCTURAL 40 THE STRUCTURAL THE	1	14	PO N	0. 3301	er to person	No state	UNI	T NO.		BERGEN	-PATERSO	N PIPESU	PPORT	CORP
SOUTHWEST FABRICATING & WELDING CO. 40 THE STRUCTURAL			-		-		-	121	7	PHO	100 100 12 12 1	199151	Sa. + 5" . * * *	7 ev * v
40 TWOLE	-	17.13	SOLUT	HWEST	FARRIC	TING &	WELD	ING CO	,	THE RESERVE AND ADDRESS OF THE PERSON NAMED IN	and the same of th	y 10 per 10	CT12.11	
SHASON CERVICES INC. (CARSUM 20)		- B - F	V	C. Carling	3		SHIT ST	-				3180	CIURAL	
AS NO.	4	134	1			3 243	CU II	200	1 40		Pusal Chief Co			10.00
	1 -1	7	-	357	1	100	w:-/	T. danger,		CO #5	m	PAS NO.	THO BECT	They want

PROCEDURAL DEVIATION

PIPE SUPPORT	Rev Mod PD		
Description of Discrepancy	- Corrective	Action	
(32)			
50)			
	·		
4			
	(0)		
	. /		
		1.	
	1,		
Construction Inspector Date	Hanger Engineer	Date	
	Acknowledged (CI)	Date	

CATALOGUE PART COMBINATIONS

Strut Part Number & Size		End Attachment (P.A.) & Size	Paddle (S.A.) & Size	Paddle (P.A.) & Size
2000/2010-1.5	2003 -1.5/1001-1.	5 2003 -1.5	2001 -1.5	2002 -1.5
2000/2010-3	2003 -3/1001-6	2003 -3	2001 -3	2002 -3
2000/2010-10	2003 -10	2003 -10	2001 -10	2002 -10
2000/2010-20	2003 -20	2003 -20	2001 -20	2002 -20
2100 -2.5	2003 -1.5	2003 -1.5	2101 -1.5	2101 -1.5
2100 -7	2003 -3	2003 -3	2101 -3	2101 -3
2100 -12	2003 -10	2003 -10	2101 -10	2101 -10
2100 -28	2003 -20	2003 -20	2101 -20	2101 -20
2100 -38	2003 -30	2003 -30	2101 -30	2101 -30
2100 -50	2003 -50	2003 -50	2101 -50	2101 -50
2100 -70	2003 -70	2003 -70	2101 -70	2101 -70
2100 -130	2003 -130	2003 -130	2101 -130	2101 -130
2100 -200	2003 -200	2003 -200	2101 -200	2101 -200
220065	200365	200365	210165	210165
2200 -L5	2003 -1.5	2003 -1.5	2105 -1.5	2101 -1.5
2200 -3	2003 -3	2003 -3	2105 -3	2101 -3
2200 -10	2003 -10	2003 -10	2105 -10	2101 -10
2200 -20	2003 -20	2003 -20	2105 -20	2101 -20
2200 -30	2003 -30	2003 -30	2105 -30	2101 -30
2200 -50	2003 -50	2003 -50	2105 -50	2101 -50
2200 -70	2003 -70	2003 -70	2105 -70	2101 -70
254035	100135/.65	200365	N/A	210165
254065	100135/.65	200365	N/A	210165
2540 -1.5	1001 -1.5	2003 -1.5	N/A	2101 -1.5
2540 -6	1001 -6	2003 -3	N/A	2101 -3
2540 -15	1001 -15	2003 -10	N/A	2101 -10
2540 -50	1001 -50	2003 -50	N/A	2101 -50
2540 -120	1001 -120	2003 -130	N/A	2101 -130
22497	10007	200365		
2249 -1.5	1000 -4	2003 -1.5	SEE APPENDIX	при
2249 -25	1000 -25	2003 -20	SEE AFFENDIX	
2249 -35	1000 -35	2003 -30		
72249-2.5	1000 -4	2003 -1.5		
72249-7	1000 -12	2003 -1.3		
		2000 -0		


The 2000, 2010, 2100, and 2200 strut assemblies may be rotated 180° so that the paddles can be at either the S. A. or P. A. end. When no stamped part number is available, the dimensions in SD/C-A-1018 should be used for identification. For the 1001 and 1000 end attachment, the strut must be used on the side opposite the reinforced side of the end attachment as shown.

ew Part Number for 2003 is 1002.

90° USE STRUT IN THIS AREA

GAP TOLERANCES AT LOAD PINS

The maximum amount of play allowed between the end attachment and the strut is dependent on strut/end attachment combination used, see page 4 of 4. The maximum amount of play allowed between the 2600, 2602, 2640, and 2642 pipe clamps and the strut is dependent on the pin diameter, see page 2 of 4. Washers may have been installed by the vendor to reduce the gap. Note how the beveled edge, if applicable, of the washers is towards the paddle. See Appendix G for washer requirements for WBA and pipe clamps.



X + Y = Gap Tolerance in Appendix B

Stacked washers are allowable provided flat washers are used as spacers. The thickness of the stacked washers or the thickness of single washers does not have to be the same on both sides of the spherical bearing. When beveled washers are used the beveled washers shall be adjacent to the spherical bearing and correctly oriented (washer beveled toward the bearing).

GAP TOLERANCES AT LOAD PINS FOR PIPE CLAMPS

I. The gap tolerance at the load pins for 2600, 2602, 2640, and 2642 pipe clamps R5 is dependent on the pin diameter. Clamp halves shall be approximately parallel.

Pin Diameter	Gap Tolerance
3/8	+ 1/16
1/2	+ 1/16
3/4	+ 1/16
1	+ 1/8
1-1/2	+ 1/8
1-3/4	+ 7/16
2	+ 7/16
2-1/2	+ 7/16
3-1/4	+ 3/4
4	+ 3/4:

See 3.6.3.5.

II. The distance between the ears of the gravity pipe clamp (Part Numbers 91, 175, 298, 304, and 370) is dependent on the pipe diameter. Clamp halves shall be approximately parallel.

DISTANCE BETWEEN THE CLAMP EARS

			Part No.		
Pipe Size	91	175	298	304	370
3/4	5/8		3/4	1-1/16	
1	5/8		3/4	1-1/16	Consult
1-1/4	5/8		3/4	1-1/16	the
1-1/2			3/4	1-1/16	
2			3/4	1-1/16	Discipline
2-1/2			3/4	1-1/16	Mechanical
3			7/8	1-1/16	Engineer
4		3/4	1	1-1/16	
5	1-1/2	3/4	1	1-1/16	
6		7/8	1-1/8	1-7/16	
8	1-3/4	1	1-1/8	1-7/16	

CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT DISTANCE BETWEEN THE CLAMP EARS (CONTD)

PART NO. Pipe Size 298 304 370 175 91 10 2 1 1-3/8 1-7/16 1-7/16 Consult 1-5/8 12 2 1 the 2-1/4 1-1/8 1-5/8 2 14 2 Discipline 1-5/8 16 2-1/4 1-1/8 2 Mechanical 2-1/4 1-1/4 1-5/8 18 2 Engineer 20 1-5/8 2-1/4 1-3/8 2 24 2-1/4 1-5/8 28 2-1/4 2-1/4 2 30 2 2 36 2-1/4

The tolerance on the dimension between the ears of the above pipe clamps is also dependent on the pipe size.

Pipe Diameter	Maximum Total Gap at Load Bolt(in)		
Under 1-1/2 incl.	- 1/32, + 1/32		
Over 1-1/2 - 4 incl.	- 5/32, + 3/32		
Over 4 - 8 incl.	- 5/32, + 3/16		
Over 8 - 12 incl.	- 5/32, + 5/32		
Over 12 - 18 incl.	- 9/32, + 5/32		
Over 18	- 9/32, + 3/16		

END ATTACHMENTS

			ASSEMBLY WITH BLE GAP TOLERAN		
END ATTACHMENT	2000 2010 2200	2100	2540 2410 2411	72249	2249
200365			1/32 (PA)		1/16 (PA)
2003-1.5	1/16 (PA) (SA)	1/16 (PA) (SA)	1/16 (PA)	1/8 ^(PA)	1/8 ^(PA)
2003-3	1/16 (PA) (SA)	1/16 (PA) (SA)	1/16 ^(PA)	1/8 ^(PA)	1/8 ^(PA)
2003-10	1/16 (PA) (SA)	1/16 (PA) (SA)	1/16 ^(PA)	1/16 ^{PA)}	1/16 ^(PA)
2003-20	1/8 (PA) (SA)	1/8 (PA) (SA)		1/8 ^(PA)	1/8 ^(PA)
2003-30	1/8 (PA) (SA)	1/8 (PA) (SA)		1/8 ^(PA)	1/8 ^(PA)
2003-50	1/8 (PA) (SA)	1/8 (PA) (SA)	. 1/8 ^(PA)	1/8 ^(PA)	1/8 ^(PA)
2003-70	1/8 (PA) (SA)	1/8 (PA) (SA)			1/8 ^(P4)
2003-130	1/8 (PA) (SA)	1/8 (PA) (SA)	1/8 ^(PA)		1/8 ^(PA)
2003-200	1/8 (PA) (SA)	1/8 (PA) (SA)	-		
100165			1/16 (PA)		
1001-1.5	1/8 (PA) (SA)		1/8 ^(PA)		
1001-6	1/8 (PA) (SA)		1/8 ^(PA)		
ALL SIZES 1000				1/8 ^(SA)	1/8 ^(SA)
ILL SIZES 1001	-	-	1/8 ^(SA)		
LL SIZES			1/8 ^(SA)		

NOTE: (PA) - PIPE ATTACHMENT END OF THE STRUT ASSEMBLY

(SA) - STEEL ATTACHMENT END OF THE STRUT ASSEMBLY

GAP TOLERANCES AT LOAD PINS FOR 2620 WELDED PIPE ATTACHMENTS

PART NO.	ALLOWABLE GAP TOLERANCE (IN.)
262035	1/32
262065	1/32
2620-1.5	1/32
2620-2.5	1/32
2620-3	1/32
2620-6	1/32
2620-7	1/32
26 20-10	1/16
2620-12	1/16
2620-15	1/16
2620-20	1/16
2620-28	1/16
2620-30	7/32
2620-38	
2620-50	7/32

R5

BOLTING MATERIAL

				Bolt '	Гуре		Locking (See Note
Part No.	(Old No.)	Sizes	SA-38	SA-307 Gr. B	SA-193 Gr. B-7	SA-194 Gr. 2H	Methods 6 and 7)
175	(6100)	All		Bolts		Nuts	Lock Nuts
298	(6101)	All		Bolts		Nuts	Lock Nuts
304	(6150)	All	1.00.1457	Bolts		Nuts	Lock Nuts
370	(6300)	All			Bolt/Studs	Nuts	Lock Nuts
2600		1.5 - 50	10. 1. 4.	Bolts		Nuts	Lock Nuts
		70 - 200			Bolts/Studs	Nuts	Lock Nuts
2602		1.5, 3		Bolts		Nuts	Lock Nuts
	-14.71	2.5			Bolts/Studs	Nuts	Lock Nuts
		7 - 50		Bolts		Nuts	Lock Nuts
2630		All	Mary Street		Bolts	Nuts	Lock Nuts
2632		All			Bolts	Nuts	Lock Nuts
2640		All		Bolts		Nuts	Lock Nuts
2642		.35 - 1.5		Boits		Nuts	Lock Nuts
		6 - 50			Bolts/Studs	Nuts	Lock Nuts
202		All		Bolts		Nuts	Lock Nuts
3252		.35	F-72-15 14 15	Bolts	Studs	Nuts	Lock Nuts
		.65 - 6		Bolts .		Nuts	Lock Nuts
		15 - 50			Bolts/Studs	Nuts	Lock Nuts
5300	14.74	.61 - 1.13		Bolts		Nuts	Lock Nuts

- Note 1: SA-307 Gr. B Bolts are marked with the Bethlehem Steel vendor markings in accordance with ASTM.
- Note 2: SA-193 Gr. B-7 and SA 194 Gr. 2H Bolts/Studs/Nuts are marked for material grade, i.e., B-7 and 2H respectively.
- Note 3: SA-193 Gr. B-7 Bolts/Studs/Nuts are acceptable alternatives to SA-307 Gr. B Bolts. However, the reverse situation does not apply.
- Note 4: A-325 or A-490 Bolts are acceptable alternatives to SA-307 Gr. B and SA-193 Gr. B-7 Bolts/Studs, However the reverse situation does not apply. Bolts for Pipe Clamps may be reused.
- Note 5: Locknuts shall be tightened in accordance with Appendix F.
- Note 6: Anco or Coloc locknuts will be used in lieu of the standard nut/jam nut arrangements.
- Note 7: The locknut and lockwire must be fully engaged on the threads of the stud or bolt.

LOAD PIN MATERIAL

The following chart shows the acceptable material grades for the listed catalog parts. The end marking 'A' stands for SA 564 type 630 material, 'B' stands for SA 193 grade B7 and 'C' stands for SA 36, SA 306 grade 60. Acceptable substitutes are as shown below.


CATALOG PART NO.	MINIMUM LOAD PIN MATERIAL GRADE REQUIRED	ACCEPTABLE LETTERING END MARK SUBSTITUTES
91	SA-306 Grade 60, SA 36	A, B, C
113	SA-193 Grade B7	A, B
216	SA-306 Grade 60	A, B, C
276	SA-306 Grade 60, SA 36	A, B, C
304	SA-306 Grade 60, SA 36	A, B, C
370	SA-193 Grade B7	A, B
377	SA-306 Grade 60, SA 36	A, B, C
1000	SA-564 Type 630-	A
1001	SA-193 Grade B7	A, B
2003	SA-193 Grade B7	A, B
2600	SA-193 Grade B7	A, B
2602	SA-193 Grade B7	A, B
2620	SA-193 Grade B7	A, B
2630	SA-193 Grade B7	A, B
2632	SA-193 Grade B7	A, B
2640	SA-193 Grade B7	A, B
2642	SA-193 Grade B7	A, B
6175	SA-564 Type 630	A

LOAD PIN MATERIAL

CATALOG PART NO.	MINIMUM LOAD PIN MATERIAL GRADE REQUIRED	ACCEPTABLE LETTERING END MARKS		
6202	SA-193 Grade B7	А, В		
6252	SA-193 Grade B7	A, B		
6300	SA-193 Grade B7	A, B		
6515	SA-193 Grade B7	A, B		
6516	SA-193 Grade B7	A, B		
6525	SA-564 Type 630	A		
980	SA-193 Grade B7	A, B		

PIPE HANGER CONSTRUCTION FLOW CHART

HANGER ENGINEER
EXAMINE HANGER
AND NOTE "READY FOR
FINAL" BESIDE
PRELIMINARY SIGNOFF
WHEN HANGER 1S COMPLETS




(E.


CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT

WP-110 Appendix 1 Page 1 of

STRUT IDENTIFICATION





PART NO. 2200



WP-110 Appendix E Page 2 of 3

STRUT IDENTIFICATION







Rev. 2


CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT STRUT IDENTIFICATION

WP-110 Appendix E Page 3 of 3












PART NO. 2100

"Snug Tight" Against Mating Surface



Detail A






Where (2) muts are detailed on the same side of a base material (e.g., U-bolts, rods and welded beam attachments) (See Detail B), use one A-194 2H Coloc or Anco lock nut For U-bolts, tighten only to point where (0) gap exists between pipe and U-Bolt (when (0) gap is specified on B-P hanger design sketch) to avoid damaging pipe. All other cases, tighten to point where nut to base material contact is made.

Detail B

"Snug Tight" Against Mating Material




Detail C

Spring can or strut body assembly Where a locking nut is required on a strut or spring can assembly. (See Detail C) Material grade is not

Material grade is not important since the nut is considered only a locking device.

R2


R2



Tighten nut and bolt until the clamp cannot be rotated using moderate hand pressure and the gap is acceptable (Ref. FCR-H-1095). Clamp halves should not be significantly deflected by the tightening operation.

Where (3) bolt pipe clamp used (i.e., B-P Part #91, 304, 2600, 2602, 2640, 2642, 6202, 6252, 6300) Tighten as shown (Detail D)

Tighten to remove slack plus 1/2 turn (Approx.)



"Snug Tight" against other mut (should use wrench on inside mut while tightening jam nut)




Where (2) bolt pipe clamp (Part No. 175, 298, & 370) used with lugs as shown (Detail E & F)

(2) Lug or (4) Lug Config. may exist

> *Detail E (Part No. 370)

Tighten to remove slack plus approximately 1/2 turn (typical 2 bolts)



Section A-A
Section A'-A'

Note: Anco or Coloc locknuts R2 shall be used in lieu of the nut & jam nut combinations.

*Detail F (Part No. 175,298)

FLAT AND TAPERED WASHER REFERENCE TABLE

Structural	Attachments	
OF REAL PROPERTY AND PERSONS ASSESSED.	Name and Address of the Owner, where the Publishment of the Owner, where the Publishment of the Owner, where the Owner, which is the Owner,	

1000	7	flat	1001	35	flat	2003	65	flat
	-1.5	flat		65	flat		-1.5	tapered
	-4	flat		-1.5	flat		-3	tapered
	-12	tapered		-6	flat		-10	tapered
	-25	tapered		-15	tapered		-20	tapered
	-35	tapered		-50	tapered		-30	tapered
	-60	tapered		-120	flat		-50	flat
	-80	flat					-70	flat
	-130	flat					-130	flat
							-200	flat
							-130	fla

Pipe Clamps

-200 flat

RESOURCE STREET	THE PERSON NAMED IN										
2600	-1.5	flat	2602	-1.5	flat	2640	35	flat	2642	35	flat
	-2.5	tapered		-2.5	tapered		65	flat		65	flat
	-3	tapered		-3	tapered		-1.5	flat		-1.5	flat
	-7	tapered		-7	tapered		-6	tapered		-6	tapered
	-10	tapered		-10	tapered		-15	tapered		-15	tapered
	-12	tapered		-12	tapered		-50	flat		-50	flat
	-20	tapered		-20	tapered		-120	flat			
	-28	tapered		-28	tapered						
	-30	tapered		-30	tapered						
	-38	tapered		-38	tapered						
-	-50	flat		-50	flat						
	-70	flat									
	-130	flat									

Note: Tapered washers can be substituted for flat washers, but flat washers cannot be substituted for tapered washers. Hanger Mods are not required to substitute tapered for flat washers.

INSTALLATION PROCEDURE FOR MAIN STEAM SUPPORTS

| R2

LO SCOPE

Additional instructions for the installation of the main steam B-wall supports and D-Wall Header Supports are provided in this Appendix. They shall be used in conjunction with the instructions provided elsewhere in the procedure.

R2

The following hangers are affected by this Appendix:

MS-H-212 - 216	MS-H-48
MS-H-219	MS-H-64
MS-H-234, 235	MS-H-75
MS-H-237	11 10
MS-H-345	

R2

2.0 REFERENCES

- FCR-H-1186 grouting associated with B-P frames and hangers
- 2. TP-28, Inspection of Equipment Installation
- 3. WP-29, Grouting
- 4. TP-04, Calibration of Controlled Tools
- 5. WP-139, Pipe Hanger Work Package Preparation

3.0 GENERAL

- Mating surfaces in contact with the concrete shall be stripped of all coatings prior to fitup.
- Anchor bolts shall be clean and undamged prior to the installation of the frame or hanger boot.
- 3. The dimension between the boot plate and the face of the concrete shall be maintained to within $\pm 1/4$ " of design.
- 4. There should be 1/4" minimum grout cover on any shims used during erection. This is to ensure that the shims are not exposed which might cause rust and shim deterioration.
- Tighten nuts finger tight. Washers may be installed later after grouting is complete.
- 6. Grouting shall commence after the nuts have a no turned finger tight. Type II grout shall be used in conjunction with WP 9.
- 7. After grout is acceptable, snug the ners at all effort of a man using an open end wrench.
- Tighten all anchor bolts to the designed pre-tension (see the hanger sketch)
 using a calibrated direct tension indicator.
- If washers were not installed prior to grouting, then install one washer
 at a time, snugging each nut respectively. Then perform the action prescribed
 in 3.9 above.
- Shopwelds and shopwelded members that were made inaccessible during fabrication or installation do not require inspection since the assembly received VQA inspection.

INSTALLATION PROCEDURE FOR MAIN STEAM SUPPORTS

R2

4.0 PROCEDURE

- 1. The Hanger Superintendent shall:
 - Work the hanger to the design drawing, this Appendix and WP-110 where applicable.

2. Get the field engineers to provide benchmarks for CI.

- 3. Notify Mechanical CI to inspect for pad preparation per TP-28.
- After setting the frame, notify Mechanical CI to check setting per TP-28.
- 5. Notify the Area Engineer to initiate a grout pour card.
- 6. Reference the grout pour card number on the Traveler.
- 7. Notify Hanger CI to verify each anchor bolt is properly pre-tensioned.
- 8. Notify Hanger CI to inspect as required per WP-110.
- 9. Notify the appropriate group for a weld inspection per WP-110.
- The Work Package Engineer shall:
 - Prepare the package for construction in accordance with WP-139.
- 3. The Area Engineer shall:
 - 1. Initiate the grout pour card.
 - Ensure that Type III grout is used.
- 4. The Field Engineer shall:
 - Provide benchmarks.
- 5. Mechanical CI shall:
 - Inspect per the appropriate procedures for equipment setting.
- 6. Hanger CI shall:
 - Verify that the anchor bolts are properly pre-tensioned using a calibrated tension indicator.
 - Verify the hanger was installed to the design drawing, this Appendix and WP-110.
 - Verify the signed off copies of the grout pour card and Exhibit 1 of TP-28 are in the Work Package.
- 7. The Discipline Mechanical Engineer shall:
 - Perform functions referenced in the body of WP-110 for Pipe Hanger Installation.
- The weld inspections shall be performed by the appropriate group as detailed in WP-110.




Figure 1
Horizontal Run of Pipe




Figure 2 Vertical Run of Pipe

$$A + B = 1/32$$
" (min.)
See $A + B = 1/8$ " (max.)
Note $C + D = 1/32$ " (min.)
Below $C + D = 1/8$ " (max.)

NOTE: See page 4 of 4
for cross sectional
view detailing
location with
respect to hanger
member where minimu
and maximum
clearances are to b
checked

CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT CLEARANCES AROUND PIPE





Figure 3




HORIZONTAL PIPE

CAROLINA POWER & LIGHT COMPANY


SHEARON BARRIS NUCLEAR POWER PLANT

CLEARANCES AROUND PIPE

A. Design Requires 1/16" Clearance




Horizontal Pipe Run



- A + B Visual clearance min. 1/8" max. (read to nearest 1/16")
- C = 1/8" max., visual clearance min. (read to nearest 1/16") Visual contact gravity side

- A + B = Visual clearance min. 1/8" max. (read to mearest 1/16")
- C + D = Visual clearance min. 1/8" max. (read to mearest 1/16")

B. Design Requires O" Clearance



Borizontal or Vertical
Pipe Run

A + B = 0" min. 1/8" max. (read to nearest 1/16")


C + D - 0"

CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT CLEARANCES AROUND PIPE

Clearance shall be measured at the edge of the hanger member or shimplate as shown below. Care shall be exercised to ensure that pipe skewness with respect to the hanger shall not exceed 1/32" if the hanger member is less than 6" wide and 1/16" if the hanger member is 6" wide or greater. Contact the Discipline Mechanical Engineer if this cannot be achieved. If a shim is not required, pipe skewness with respect to the hanger is not a checkpoint.

Total maximum and minimum clearances are to be checked at the closest point on each side of the pipe regardless of whether or not shims are installed.

Example:



Clearances are to be checked at point (b) and (c). Although the clearances are acceptable (i.e., b + c = 1/32" + 1/16" = 3/32" minimum is 1/32", maximum is 1/8") the pipe is skewed more than 1/32" (i.e., a - c = 1/8" - 1/16" = 1/16"). This is unacceptable.

R3

R3

Appendix J WP-110 Sheet 1 of 3

MATERIAL VERIFICATION PROGRAM

The following instructions are to be used by the Hanger Engineer to complete Parts I-7 on Exhibit 4.

Part 1

All material which was issued prior to 9-6-83 maintained identification via material control. To ensure the controls were implemented, the Hanger Engineer shall need to know what material was received and issued for construction. The Warehouse Engineer shall provide that information in Part I of Exhibit 4. He shall research receipt records and list items and the drawing revision for which the material was supplied. He shall sign and date the entry.

	Ite	ms	Rev.	
Example:	1	2	7	3

Part 2

The Hanger Engineer shall verify the as-built steel is the as-received asissued material for the pipe hanger. He must perform a field check on the
items listed in Part I and compare the physical parameters, except length, of
the as-built steel to the Bill of Materials of the drawing revision for which
the material was supplied. In addition, the hanger material must:

- Be coated with red oxide primer (except in the Containment Building) or,
- Be coated with flat white primer (only in the Containment Building) or,
- Be coated with gloss white paint and stamped with the hanger number or,
- 4. Be an uncoated structural shape less than 6" long or,
- Be an uncoated plate which has an exposed area less than 3" from a weld
- Not be marked with another hanger number or PO number
- Not have documentation in the package to indicate the material was supplied from surplus or stock.

Appendix J WP-110 Sheet 2 of 3

MATERIAL VERIFICATION PROGRAM

If the material has been determined to be the original issue, the Hanger Engineer shall list the item numbers in Part 2 of Exhibit 4.

Part 3

The Hanger Engineer shall list those items in Part 3 of Exhibit 4 whose source of material can be determined from Work Package documentation (i.e., Speed Letter, RCI or CMR). However the source must be legitimate with a Certificate of Comformance from a qualified vendor. This is evidenced by a stamp - "Source Accepted" - on the CMR, Speed Letter, or RCI.

Part 4 & 5

All material issued after 9/6/83 will be stamped or etched for positive identification. The following will be the acceptance criteria for this material.

- A-36 plate, channel, wide flange, and angle shall be stamped with the 36 symbol unless it is less than 3/16" thick,
- . A-500 Grade B tube steel shall be stamped the 36 symbol.
- U bolts and threaded rod will be stamped or etched with the material grade.
- Stock pipe tubing for struts shall be etched with the material grade.
- Steel other than A-36 or A-500 Grade B shall be stamped with the
 material grade. However some material was stamped with the
 purchase order number. That P. O. shall be entered on Exhibit 4
 and investigated to ensure the material grade.

If the material is marked and is acceptable, the Hanger Engineer shall list the item numbers under Part 4 or 5 as appropriate.

R3

R3

Appendix J WP-110 Sheet 3 of 3

MATERIAL VERIFICATION PROGRAM

Part 6

Catalog parts shall be identified by the physical characteristics of the item or by the stamped catalog part number. The catalog part identity must be in accordance with The Bill of Materials. The Hanger Engineer shall list these item numbers in Part 6 of Exhibit 4 and not under Parts 2, 3, 4, 5, or 7.

Part 7

A sampling program is set up for structural shapes, plates, and shims which cannot be identified under part 2, 3, 4, or 5. The Hanger Engineer shall list these items in Part 7 of Exhibit 4.

General Notes:

If more than one of an item is to be considered, each piece shall be listed in the appropriate section. For example, if there are two piece 7's and both pieces are stamped, Item 7 should be listed twice in Part 4. After the form is completed, the Hanger Engineer shall sign, date, and enter the drawing revision the items were checked against. A copy of the form shall be removed from the Work Package and returned to the office to determine the scope of the sampling program and to initiate any material testing. Welded pipe attachments (trunnions, lugs, etc.), anchor bolts and cinch anchored plates shall not be listed on Exhibit 4. Nonstructural end cups and shims are considered Non-Q material, do not require verification of the material identification markings, and do not need to be entered on Exhibit 4.

GAP MEASUREMENT GUIDANCE CRITERIA





Fig. 1


Since gap A is larger than gap B, the gap shall be listed as A and the weld size must be increased by A.



For joints of this type, gaps should be measured at the root. If the weld requirement is a flare bevel, the gap should not exceed 3/16".

and should be recorded as

\$\leq 3/16\cdots\$.



Fitup gaps between non-structural end caps and tube steel should not be measured or recorded.

R1

R1

CONTROLLED DOCUMENT -

CAPOLINA POWER & LIGHT COMPANY

SECTION III

CORPORATE QUALITY ASSURANCE DEFARTMENT ENGINEERING AND CONSTRUCTION QUALITY ASSURANCE/QUALITY CONTROL SECTION

41.10

PERSONNEL TRAINING AND QUALIFICATION

NUMBER:

A COA-1

INITIAL ISSUE DATE:

March 16, 1981

RECOMMENDED FOR APPROVAL

DIRECTOR - SHAPP QA/QC

APPROVED BY:

CONTROLE DOCLET

CAROLINA POWER & LIGHT COPANY CORPORATE QUALITY ASSLETICE DEFARTMENT QA/QC - HARRIS PLANT SECTION

'NUMBER

REVISION

CCA-1

TITLE: PERSONNEL TRADITING AND CONTINUENTION

1.0 PURPOSE

c. /.

The intent of this procedure is to establish requirements and guidelines for training and qualification of personnel assigned to perform QA 2C activities at a nuclear power plant.

2.0 SCOPE

This protecture is applicable to the site Quality Assurance/ Quality Control Unit personnel who perform inspections, surveillances, examination or testing activities; that are intended to assure quality of construction or to verify conformance to quality requirements; and personnel who review and accept or approve inspection, examination or test documentation or other quality affecting documents (e.g. procedures, instructions and specifications). Numbertructive Examination (NDE) personnel training and qualification will be in accordance with Reference 1. For the purposes of this procedure, references to inspection activities includes surveillance. This is an ASME Section III procedure.

3.0 REFERENCES

- 1. Corporate QA Department Nondestructive Examination Manual (NACE Manual)
- 2. Instruction CAI-1.1, Visual Acuity and Color Perception Tests
- 3. Instruction QAI-1.2, QA/QC Personnel Qualification Requirements

4.0 RESPONSIBILITIES

4.1 Manager - CA/CC - Harris Plant Section

The Manager - 14/00 - Harris Plant Section shall be responsible for staffing the QA/QC Unit with personnel meeting the appropriate classification requirements.

4.2 Director - DA TC

The Director - Ci/OC shall have overall responsibility for implementation of this procedure.

4.3 Supermittendent - QC

The Superintendent - QC is responsible to the Director - QA/QC for implementation of this procedure.

CONTROLLED DOCUMENT-

CAROLINA POWER & LIGHT COMPANY CORPORATE GUALITY ASSURANCE DEPARTMENT QA/QC - HARRIS PLANT SECTION

LIMBER

REVISION

CCA-1

11

TITLE: PERSONNEL TRAINING AND QUALIFICATION

4.4 Quality Assurance/Cuality Control Subunit Supervisors

QA/QC Subunit Supervisors stall have overall responsibility for implementation of this procedure in their assigned areas of responsibility.

4.5 Quality Assurance/Quality Common Specialists/Engineers

Site QA/QC Specialists/Engiteers shall be responsible for indoctrination, training, qualification and evaluation of QA/QC personnel in their assigner areas of responsibility.

5.0 EDUCATION AND EXPERIENCE

- 5.1 Personnel performing CA/QC activities shall meet the education and experience requirements set forth in Appendix A.
- 5.2 Acceptable equivalents to the edication levels listed in Appendix A are as follows:
 - In lieu of high school: Wiltary (USAFI), state, county, or local school system high school equivalency GED; or two (2) years experience in construction operation or inspection work similar to that covered by the inspection activity.
 - 2. In lieu of 2-year degree in engineering/technology: Satisfactory completion of college credits which can be evaluated to be comparable to that required for a 4-year degree; or two (2) years experience as a QA/QC Inspector in a nuclear program.
 - 3. In leiu of a 4-year degree in non-engineering discipline:
 Satisfactory completion of college credits which can be
 evaluated to be comparable to that required for a 4-year
 degree; or two (2) years experience as a QA/QC Inspector
 in a nuclear program.
 - 4. In lieu of a 4-year degree in engineering: Four (4) years experience as a 11/20 Inspector in a nuclear program.

CNTROLLED DOCUMENT

CAROLINA POWER & LIGHT COMPANY CORPORATE QUALITY ASSURANCE DEPARTMENT CAVOC - HARRIS PLANT SECTION

NUMBER

REVISION

CQA-1

-1

TITLE: PERSONNEL TRAINING AND QUALIFICATION

- 5.3 The experience levels listed in Appendix A are for directly related experience in work that is technically equivalent to that which will be covered by the specific inspection/testing activity. Prior experience in construction operation or inspection work which is only similar to the inspection/testing activity may be substituted for directly related experience on a 2-month for 1-month basis, not to exceed two-thirds of the total inspection experience requirement.
- 5.2 Prior experience may be applied to the experience level requirements for more than one inspection/testing activity provided the requirements of 5.3 above are met.

6.0 FEYSICAL CONDITION

- 6.1 QA/QC inspection personnel shall meet the physical requirements for the particular CP&L classification involved at initial hiring.
- 6.2 Contracted personnel employed to augment CP&L QA/QC inspectors shall meet the physical requirements of their employers.
- 6.3 QA/QC and augmented inspection personnel shall be tested to assure:
 - 1. Natural or corrected near distance acuity such as being capable of reading the J-1 letters on a standard Jaeger"s test-type chart or equivalent test type.
 - The capability for distinguishing and differentiating contrast between colors as demonstrated by practical demonstration or test performance.
- 6.4 Personnel that fail the mear distance acuity or color sense testing may be evaluated and, through satisfactory demonstration of capability to perform the required inspections, found acceptable for certification for a sub-category of inspection. The personnel records small reflect the evaluation process used and any inspection limitations imposed.
- 6.5 The test specified in 6.3 (or as allowed by 6.4) shall be conducted on an annual basis.
- 6.6 Prior to fuel loading applicable CA/QC inspection and supervisory personnel (including contract personnel) involved in plant Start-Up/Operations activities will participate in the company sponsored respiratory protection program annual physical.

-3-

r 31

CAROLINA POWER & LIGHT CO-FAINY CORPORATE QUALITY ASSURANCE TEMPLET ENT QA/QC - HARRIS PLANT SETTION

NUMBER

REVISION

CQA-1

17

TITLE: PERSONNEL TRAINING AT CHATTER

7.0 INDOCTRINATION AND TRAINING

7.1 Newly assigned personnel (CPAL and augmented) will be trained in the performance of their intended assignment(s). Training shall be accomplished through a program consisting of indoctrination and metherjob training (OJT) under the direct supervision of qualified personnel. The degree of training will depend on the amount of previous experience and training.

Emphasis will be on firsthand experience gained through actual performance of processes, tests, examinations and inspections. As the inspectur in training develops proficiency, he may be allowed to perform certain inspection functions under me supervision of the qualified inspector; however, the qualified inspector is responsible for reinspection to the extent necessary to verify the inspector of the trainee's inspection. Holdpoint "sign-off" small be accomplished by the qualified inspector and certifies his inspector and certifies his inspector of the completed work.

- 7.2 (a) Personnel performing QA/QC activities shall be intoctrinated in mose project informational areas necessary for effective coordination and accomplishment of their assigned activities and responsibilities. Indoctrination shall be incommented on QA/QC Personnel Indoctrination Check-Off (Form CA-7) and consist of, but not be limited to:
 - 1. Description and Organizational Relationships
 - 2. Intrauction to appropriate site personnel
 - 3. Dities and Responsibilities
 - 4. ITL CLICOC Procedures, Instructions, reports
 - 5. Technical objectives of site CCA/CCC Procedures.
 - 6. Codes amd Standards to be employed.
 - (b) QA/QI personnel involved with plant Start-Up/Operations prior to fuel loading will receive indoctrination in:
 - 1. Excisionical Health & Safety Program
 - 2. Emermony Action
 - 3. Inturnal Safety Program
 - 4. Fire Protestion Program
 - 5. Security Program

CONTROLLED DOCUMENT

CAROLINA POWER & LIGHT COMPANY CORPORATE CLIALITY ASSURANCE DEPARTMENT QA/2C - HARRIS PLANT SECTION

"LIVEER

REVISION

C1-1

12

TITLE: PERSONNEL TRAINING AND QUALIFICATION

7.3 Appendix A to this procedure specifies the training time required for the individual inspection/testing activities. Where the inspector in training has been previously certified for the inspection/testing activity by another organization, the classroom* hours may be reduced by two-chairs. Personnel qualified for construction phase CA/QC activities including those qualified through teh CI training program, are considered qualified for equivalent Start-Up and Operation phase QA/QC activities provided indoctrination is received and documented in applicable Start-Up/Operation phase procedures.

Notes:

- *Classroom training includes lectures, discussions, and demonstrations of the uses of documents, tools, and equipment related to the inspection, testing activity; and the administration of appropriate examinations and tests.
- **Where equally applicable to more than one inspection/testing activity, CJT time may be applied to each of the appropriate activites.
- 7.4 Formal training administered by the QA/QC Specialist/
 Engineers/Subunit Supervisors to develop or maintain the proficiency of inspection personnel, shall be documented. Those training records shall include the following information:
 - 1. Name of Inspector
 - 2. Subject Matter
 - 3. Date
 - 4. Time Spent
 - 5. List of Attendees

8.0 CUALIFICATION PRIOR TO CERTIFICATION

Prior to assignment to perform specific inspection/testing factions, CA/2C personnel shall meet the minimum requirements for the assignment as delineated in Appendix A. Classroom, self-stary and practical demonstrations shall be performed and documented in accordance with Reference 3.

CONTROLLED DOT WE'T

CAROLINA POWER & LIET COFTANY CORPORATE QUALITY ASSURANCE SECTION

NUMBER

REVISION

CQA-T

11

TITLE: PERSONNEL TRAINING AND CONTESTICATION

8.0 (cont.)

Qualification recorns of company personnel transferred, from other units or recornel hired from organizations which provide direct services to the DA/CC Unit, will be reviewed for acceptance against the remitrements of this procedure. The Inspector's personnel file of the annotated to show the results of the review and identify any training and/or testing required prior to certification. Where me minimized training is required, certification/recertifications many be affected based on previous qualifications.

9.0 CERTIFICATION

- 9.1 Subunit Supermicrs, 2A/2C Specialists and Engineers
 - 9.1.1 Submit Supervisors, QA/QC Specialist and Engineers

 are assisted supervisory and technical responsibilities

 based stally on combinations of formal education,

 previous training, previous work experience and

 belief of indoctrination to satisfactorily perform

 belief assistments. Such personnel are considered

 qualified without examination to perform the following

 functions as applicable to the activities within their

 assistments:
 - T. Trz: qualify and supervise QA/QC personnel in imsucción, monitoring and testing assignments.
 - 2. Develop and administer oral/written qualification
 - E. Ewaliate capabilities and performance of CA/QC
 - 4. Ewaliane results of examinations, inspections and
 - 5. Develop and prepare new QA/QC procedures and importantions.
 - 5. Bertiew QA/QC and Construction operations procedures and instructions for appropriate commitments and requirements.
 - 7. The minal review of site generated documents which furnish documentary evidence of the quality of must sar safety related items and of activities affecting quality.

CONTROLLED DOCUMENT

CAROLINA POWER & LIGHT COMPANY CORPORATE QUALITY ASSURANCE DEPARTMENT QA/QC - HARRIS PLANT SECTION

"UMBER

REVISION

CQA-:

13

TITLE: PERSONNEL TRAINING AND QUALIFICATION

9.1.1 (cont.)

m 50 "

- 8. Beview of procurement accuments for inclusion of CA requirements.
- Feview of Suppliers' documentation to assure procured items comply with 14 requirements of procurement documents.
- 10. Flan, schedule and supervise inspections and surveillance of construction and operations activities.
- 11. Identify quality problems and initiate, recommend or provide resolutions.
- 9.1.2 Other activities assigned to the Subunit Supervisors are as follows:

9.1.2.1 QA Surveillance

- Perform QA Surreillance of construction installation, inspection and testing activities.
- Perform CA Surreillance of selected general activities supporting rather than directly related to the installation, testing or inspection of permanent plant items or structures.
- Perform technical document review of construction LA Records.

9.1.2.2 Civil & Structural

- Sampling and testing of concrete materials (i.e. cement, aggregate, admixtures and water).
- 2. Concrete production.
- 3. Sampling and testing of plastic concrete and grout.
- 4. Compressive testing of concrete and grout.

-DATE DOUTET

CORPORATE QUALITY ASSURANCE DEPARTMENT QA/DC - HARRIS PLANT SECTION

NUMBER

HE / TIELT

CQA-1

-

TITLE: PERSCHINE TO ANTING AND CLALIFICATION

9.1.2.2 (cont.)

- Tensile testing of reinforcing steel bars and cadweld specimens.
- 6. Installation of Mechanical splices (cadwelds) in concrete reinforcing tars.
- Calibration and field adjustment of measuring devices.
- 8. Windsor Probe System of testing contrate strength in place.

5.1.2.3 Materials & Records

- Receipt storage and issue of nuclear safety related plant items and consumables.
- 2. Construction site procurement of number safety related plant items and constants.
- 3. Accumulations, review, filing and common of records which are required to furnish documentary evidence of the quality of nuclear safety related items and of activities affecting quality.
- Control of construction and operations control documents.
- 5. Control of records of permanent plant items transferred between units or off-site.
- 6. Assembly of Code Data Reports for same to the National Board.

F.1.2.4 Mechanical & Welding

- 1. Installation and pressure testing of process
 systems, components and HVAC duct work.
- Field fabrication/modification of piping subassemplies.

CONTROLLED DOCLMENT-

CAROLINA POWER & LIGHT COMPANY CORPORATE QUALITY ASSURANCE DEPARTMENT CA/QC - HARRIS PLANT SECTION

NUMBER

REVISION

CQA-1

13

TITLE: PERSONNEL TRAINING AND CIALIFICATION

9.1.2.4 (ccat.)

- Application of "N" type symbol stamp to ASME Dome Dlass piping and subassemblies and systems.
- 4. Preparation of ASME Code Data Reports.
- Cleanliness inspections of piping systems and components.
- 6. Inspection of code valves.
- Qualification of welders and welding operators.
- Field welding of ASME Gode Class and non-code class piping.
- Installation welding of pressure boundary components.
- Installation welding of Seismic Category
 I structural steel members, hangers and
 supports.
- 11. Field fabrication welding of piping subassemblies, tarks, structural steel members, hangers and supports (including studs).
- 12. Installation welding of steel liner plate.
- 13. Post-weld beat treatment.

9.1.2.5 Start-Up/Operations

- 1. Procedure Review
- 2. Turnovers
- 3. Document Review
- 4. Maintenance and Modification Control
- 5. CA Surveillance of Start-Up/Operations
- 6. Inspections

TARGUE DOCKENT

CARELINA POWER & LIGHT COMPANY CORPORATE BUALITY ASSURANCE DEPARTMENT DATES - HARRIS PLANT SECTION

NC.

== VISION

C=1-7

12

TITLE: PERSONNEL TRAINING AND CTALIFICATION

- 9.1.3 Fersonnel, not necessarily classified as 22 22 Specialists/Engineers may be assigned supervisor responsibilities within their areas of terminal expertise when evaluated by the CA/QC Submit Supervisor as being capable of performing the supervisory assignment. The evaluation shall be incommented and shall take into account the following factors:
 - t. Education
 - 2. Experience
 - 3. Demonstration of Capability
- Farsonnel performing CA/QC activities will be elimitated for certification after complying with paragraphs E.I or 9.0 as applicable. Certification shall be documented on CA/QC Personnel Qualification/Certification (Form Lagrange shall contain, but not be limited to, the following information:
 - 1. Employer's Name
 - 2. Name of person being certified
 - 3. Activity qualified to perform
 - 4. Date of certification and effective period
 - 5. Basis for certification
 - 6. Signature of Director or his designee
- F.3 Certification by the Director means the inspector is mainlied to perform the following as applicable to the inspection.
 testing activity:
 - 1. Record inspection, examination and testing data.
 - Implement approved inspection, examination and testing procedures.
 - Plant inspections, evaluations and tests; set-up tests. including preparation and set-up of related equipment.
 - *. Evaluate the validity and acceptability of insperment examination and test results.

CAROLINA POWER & LIGHT CO-PANY CORPORATE QUALITY ASSURANCE DEPARTMENT QA/QC - HARRIS PLANT SECTION

NUTEER

REVISION

Ci-1

11

TITLE: PERSONNEL TRAINING AND QUALIFICATION

9.3 (cost.)

.. .

- 5. Report inspection, examination and test results.
- 6. Supervise other inspection/testing personnel.
- 7. Train other personnel.
- 8. Use calibrated tools and equipment required for the inspection/testing activity.
- 9.4 Appendix A to this procedure identifies the incimital supervisory and inspection/testing activites for which CA/QC personnel may be assigned.

10.0 MEW INSPECTION ACTIVITIES

In the event a new work activity and the associated inspection activity are concurrent so as to preclude prior qualification of inspection personnel, inspection of the work shall be under supervisory control of the cognizant QA/QC Specialist, Engineer or Subunit Supervisor. Assistance from the cognizant discipline engineer and manufacturer's representative may be requested to facilitate initial qualification of inspection/testing personnel. The required CJT may be waived upon satisfactory demonstration of ability to perform the inspection/testing function.

11.0 EVALUATION AND RECEPTIFICATION

- 11.1 The job performance of QA/QC personnel shall be evaluated at intervals not to exceed two (2) years. QA/QC personnel who have not performed inspection/testing activities for which qualified within a period of one year shall be reevaluated prior to assignment to perform that inspection or test.
- 11.2 If the results of the performance evaluation(s) are satisfactory, the individual's certification shall be continued.
- 11.3 If, during the above evaluation or at any other time, it is determined that the capabilities of an individual do not meet the requirements of the inspection/testing activity, that individual small be removed from the activity until such time that the required capability has been demonstrates.
- 11.4 Recertification will be documented on QA-49A Forms.

CITROLED DOCMENT-

CARILINA POWER & LIGHT COMPANY CORPORATE QUALITY ASSURANCE DEPARTMENT QA OC - HARRIS PLANT SECTION

TILIEE REJISION

17

TITLE: PERSONNEL TRAINING AND QUALIFICATION

12.: RECORDS

- 12.1 A file of QA/QC personnel certifications completed QA-9/49A Forms) shall be retained in LA Records.
- 12.2 A file of records required to support the tertification of personnel assigned to perform 14/00 activities small be established and maintained. The file stall include. as a minimum:
 - 1. Visual Acuity Test Results (Form 11-72
 - 2. Physical Examination Results or Engineer Chatement
 - 3. Resume' of Education and Experience
 - 4. Indoctrination (Form QA-47)
 - 5. Other training such as the respiratory protestion program, health physics, security, att.

13.3 APPENDIX

13.1 Appendix A, QA/QC Education, Experience & Training Requirements

CA/OC EDITATION. EXPERIENCE & TRAINING REQUIREMENTS

INSPECTION/TESTING		WKS.	EXPERIENCE REQUI	RED	D HRS. TRAININ			
Concrete Compression Testing 2 1 2 2 3 3 5 Sieve Analysis 2 1. 0 2 3 3 5 5 Sieve Analysis 2 1. 0 2 3 3 5 5 Sieve Analysis 2 1. 0 2 3 5 5 Sieve Analysis 2 1. 0 2 3 5 5 Sieve Analysis 2 1. 0 3 5 5 Sieve Analysis 2 1 0 2 5 5 Sieve Analysis 2 5 Si	INSPECTION/TESTING ACTIVITIES	HIGH	2-YR ENGR/TECH	YR	CLASS- RCOM	0.57		
Sieve Analysis Sieve Analysis Field Testing of Concrete Rebar & Cadweld Tensile Testing Concrete Material Testing Concrete Material Testing Comment False Set Testing Concrete Batch Plant Inspector In-Place Concrete Test by Windsor Probe System Z In-Place System Z In-Plac	CIVIL/STRUCTURAL							
Field Testing of Concrete 2 1 3 2 3 3 2 3 3 3 3 3 3 3 3 3 3 3 3 3	Concrete Compression Testing	2	1		2	24		
Rebar & Cadweld Tensile Testing Concrete Material Testing Grout Testing Cement False Set Testing Concrete Batch Plant Inspector In-Place Concrete Test by Windsor Probe System	Sieve Analysis	2	1.	0	2	-6		
Testing 2 1 0 3 4 Concrete Material Testing 4 2 0 1 1 0 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	Field Testing of Concrete	2	1	3	2	32		
Grout Testing 2 1 0 1 Cement False Set Testing 2 1 0 2 Concrete Batch Plant Inspector 12 4 2 4 In-Place Concrete Test by Windsor Probe System 2 1 0 2		2	1	0	3	24		
Cement False Set Testing 2 1 0 2 Concrete Batch Plant 12 4 2 4 In-Place Concrete Test by Windsor Probe System 2 1 0 2	Concrete Material Testing	4	2	0	2	-5		
Concrete Batch Plant Inspector In-Place Concrete Test by Windsor Probe System 2 12 4 2 1 12 4 2 1 12 13 14 2 14 2 15 16 17 18 18 18 18 18 18 18 18 18	Grout Testing	2	1	0	1	16		
Inspector 12 4 2 1 In-Place Concrete Test by Windsor Probe System 2 1 0 2 1	Cement False Set Testing	2	1	٥	2	16		
Windsor Probe System 2		12	4	2	4	40		
Cadweld Inspector 8 4 2 4	In-Place Concrete Test by Windsor Probe System	2	1	0	2	16		
	Cadweld Inspector	8	4	2	4	40		

DA/OC EDUCATION, EXPERIENCE & TRAINING RESTREMENTS

***************************************	WKS.	ENFERIENCE RELUI	7.0	HAS. TR	THE RESERVE OF THE PERSON NAMED IN
INSPECTION/TESTING ACTIVITIES	HIGH SCHOOL	2-YR ELGRATELE 4-YR NEW-ENGR	YE. ENGE	CLASS- FROM	000
MATERIALS & RECORDS					
Receipt Inspector		1			
1. Secondary (QR Received)	12	±'	4	4	2
2. Rebar	16	1	6		2
3. NSR Categories I & II Off-the-Shelf Items Consumables	16		6	4	2
4. Stock Steel & Bolting Stock Tubing, Pipe and Fittings (FP & Radwaste) Stock Tubing, Pipe and Fittings (Code Class)	24	1.2	7	6	2
5. Weld Filler Materials	40	2:	16	8	2
6. Engineered Items (Seismic I) Engineered Items (NSR Categories I & II, Radwaste & Fire Pro- tection) Primary -Engineered Items	44	2	17	8	3
Purchase Requisition Review					
1. Non "Q"-List Items	8		2	8	2
2. "O" -List Items	24	'2	6	6	4
QA Records Clerk	8	2. 4	N/A	5	8

CQA-1 Appendix A. Page 3 of 3

CAPIC EDUCATION, EXPERIENCE & TRAINING REQUIREMENTS

EXEFECTED N. TESTING	WYS.	EXPERIENCE RECUI		HES. TRAITING		
ACTIVITIES	HIGH	2-YR ENGR. TECH 4-YR NON-ENGR	YR ENGR	EDIM	ן יייי	
MECHATIAL VELICIO						
Cleamers Impector	8	4	2	1 2	20	
Pressure Testing Inspector	8	6 .	4		20	
Valve and Imponent Installation Dispector	24	8	4		30	
Pipe Empi Farmication/ Modification Inspection	12	8 -	4		20	
Pipe, Pool Liber Weld Inspector	24	12	6	;	ac	
Structura Mei: Inspector	16	8	4		30	
Stud Welsing Impector	16	8	4		40	
Post Weld Heat Treatment Inspector	8	, 4	2		40	

QA/OC EDUCATION, EXPERIENCE & TRAINING REQUIPEMENTS

INSPECTION/TESTING	· WKS.	EXPERIENCE RECUE		HRS. TRAINING		
ACTIVITIES	HIGH	2-YR EDGR, TECH 4-YR MON-ENGR	ENGR	CLASS- RCOM] OJT	
START-UP					1	
Turnover - Mechanical	24		2	2	16	
Turnover - HVAC	24		2	2	16	
Turnover - Electrical	24	-	2	2	16	
Turmover - I&C	24		2	2	16	
Turnover - Structural/Civil	24		2	2	16	
Cleanliness Inspections	8	-	2	2	20	
Instrumentation Inspections	24	12	2	4	20	
Mechanical Inspections	24	12	4	5	. 40	
Electrical Inspections	24	12	4	6	40	
Surreillance - PSI/ISI	24	72	4	3	20	
Surweillance - Operations	24	12	4	2	20	
Surreillance - Maintenance	24	1.2	4	3	20	
Surveillance - EARC	24	12	4	3	20	
Surveillance - Start-Up Activities	24	12	4	2	20	
Surveillance - Administrative	24	12	4	2	10	
Surveillance - Technical Support	24	12		2	10	
Surveillance - General (Refer to Note 1)	24	12	4	4	20	
Note: 1. General surveillance certification will cover basic items such as cleanliness, house-keeping, training and qualifications. This certification will provide the methods for preparing, conducting and						

reporting surveillances.

DA DE EUGLATION. ETFERIENCE & TRAINING REQUIREMENTS

	W.S.	EMPERIENCE RECUE	RED			
INSPECTION TEXT NG	RIGH	2-YR ENGR/TECH 4-YR NON-ENGR	4-YR ENGR	CLASS-	1000	
START-UP						
Maintenance Instruction Review	24	9	2	2	:2	
Start-Up Instruction Review	24	8	2		:2	
E&RC Instruction Review	24	8	2	ż		
General Procedures & Instruction Review	24	9	_ 2		-2	
WR&A Review	16	8	2	2	:2	
CAR&A Review	16	8	2	Ξ	.5	
STs/PTs Review	16	8	2	2	:2	
Plant Modification Review	24	12	4	-	2-	
Calibration Monomoformances Review	12	12	1		_	
				e it.		

OA/OC EDUCATION. EXPERIENCE & TRAINING REQUIREMENTS

INSPECTION/TESTING	WKS. EXPERIENCE REQUIRED			+ HRS. TFAINING		
ACTIVITIES	HIGH SCHOOL	2-YR ENGR. TE 4-YR NON-ENG		CLASS- ROOM	0,57	
AISCELLANEOUS (Non-Inspection/Testing Activities)						
AA/OC Subunit Supervisors	468	354	zes	::/A	::/#	
CA/OC Specialist	312	208	_ 1 -:-	: ::/^	::/:	
QA/QC Engineer	N/A	N/A	75	, IVA	::/:	
					1	
				i		
			V			
					45	

DA IT EXPATION, EMPERIENCE & TRAINING REQUIREMENTS

***************************************	WES. EXPERIENCE RECUIRE			1 CLass-	
INSFERENCE ATTACK	HIGH SCHOOL	2-YR ENGR/TECH 4-YR NON-ENGR	YR ENGR	EDOX	_
A SURVEILLICE					
Concrete Placement Amentor	24	8	4	5	•
Concrete Tesming Womanor	24	8	4	=	
rout Placement Montage	12	4	2	3	•
Structural Steel Erection	12	4	2	_	
Cadwelding Carral Amita	12	4	2		
Sbils Control land	24	8 -	4	: =	
Expansion Ambur Installation Monitor	12	4	2	2	
Electrical Backary Conduit	24	8	4		
Cable Pulling, Terrinating	24	8	4	-	
Cleanness Carroll Maritor	12	4	2	2	
Protective Comming Application Monitor	24	8	4	4	
Mechanical Equipment Installation Monitor	24	8	4	4	
Hydrostatic Test Memitor	12	6	4	-	
Hanger & Support Installation Monitor	24	8	4	4	
Piping Installation Monitor	24	8	4	-	
HVAC Ductor	16	8	4	1 -	
Receiving Instantan Monitor	44	22	17	E	
In-Process Well Instity Qualifications Montor	24	12	6	E	
Final Weld Duality Monitor	24	12	6	E	
Non-Destructive Elemination Monitor	44	22	17	E	
General Activity Activation (Refer to Mora 3	24	8	4		
Electrical Entry Instrumenta-	24	8	4		



., ., 5

QA/QC EDUCATION, EXPERIENCE & TRAINING REQUIREMENTS

TYPECTTON /TESTENS	WES.		110	1 HAS. TA	AINING
INSPECTION/TESTING ACTIVITIES	HIGH	2-YR ENGR. TECH	TR	CLASS-	1 05
ACTIVITIES	SCHOOL	4-YR NON-ENGR	ENGR	ROOM	1
NA SURVEILLANCE (cont.)					
lote:					
nspectors for surveillance of on-site contractor acti- ities is provided by quali- ication for specific sur- cillance activities. For example, surveillance of contractor welding activities shall be performed by an inspector qualified in weld control surveillance.					
Inspectors for technical review of site generated records is provided by specific activity qualification. NA/OC Inspectors qualified for specific activity are thereby qualified to review records generated within the scope of that activity.					
3. Site CA Surveillance personnel may be considered qualified for general surveillance by virtue of their qualification in one or more specified surveillance activities. In this case, the qualification shall require the completion of required indoctrination, self-study and classroom training; additionally, personnel shall					
meet the education and experience requirements out- lined in this Appendix. OJT, practical demonstrations, and examinations shall not be required when qualification is accomplished by this					

CARCO ESTATION, EXPERIENCE & TRAINING REQUIREMENTS

. . .

	W. 3.	EXPERIENCE RECUI	1 23. 7.2.13			
INSPECTION TESTING	HISH	2-YR ENGR/TECH	YR	1 CL-55-		
ACTIVITIES	SCHOOL	4-YR NON-ENGR	ENGR	FICH		
	1	•		1 1		
QA SURVEILLANCE (com:.)				A STATE OF THE STATE OF		
	1					
. Site QA Surveillance						
ersonnel may be considered						
ualified for surre				la l		
nspection activities for wich						
hey hold or have her val-						
P&L certification In this						
ase, the qualification shall						
equire the completit of re-						
wired indoctrination and						
elf-study. Additionally,	1					
ersonnel shall meet the edi-				11		
ation and experience require-				l li		
ents outlined in man						
ppendix. No additional O.T.						
lassroom training, practical						
emonstrations and somminations						
hall be required when quali- ication is accomplished by						
his method.						
his method.						
			i			
				Applied to the second		
			1 7 7 3 8			
	1					
			1			
	- New York					

File:
Treining
T46

TO: RAY Harfor PH 10/20/80

FRAM: Tavid Timber of co

SUCIECT: Welder Training Class

On Friday October 17,1980 of inductions two welder training classes for the structural welders (#32 craft) and some CP& 2 personnel (engineers and Q.A.). Attached in a outline and lint of attending personnel.

to be produced in sepanse to 41-7

Other for Welder Training Class.

I Introduction

A. HAND-out on weld symbols given to each person in alass. (Attached). Attendance Taken.

B. Reason men brought to class... HANGER Acti.

NRC

I Weld Symbols

A. Reference line:

Size a Type weld And finish information given above a below reference line.

Information given below line reference line for arrow side of given about side of given.

Information about sides of given refers to side of given arrow opposite arrow opposite arrow and line refers to side of given arrow opposite arrow opposite arrow opposite arrow opposite arrow and weld will be performed.

Broken arrow ___ shows which piece will be prepared. example on next page.

example: Traced basel show in rod. c. <u>Supplementry</u> <u>Symbol</u>: 1. Weld All Around: O ex. - vog requires continuous fillet weld All Are member at joint. Note: This should not be confuse. with which mean fillet weld on both sides yet ki All Around. 2. Field Weld symbol: old symbol . New AWS synbol 9 used to specify welding process or specification or other supplementing

information. Often omitted.

to Section allegan

ex. smay

when "TYP." is specified, sometimes drawing is not clear. welder should get with forman to contact mechanical Engineers on weld Engineer for clarification, when this is not clear.

E. Typical weld Symbols seen on Berg. Patterson Draw.

1. Fillet weld .


a) size of fillet weld Always should be specified on chrawing in front of fillet symbol.

ex.

size is measure of leg length.

ex.


Excessive concavity or converty of the



2. Flare Weld


10

Example: Tube Steel on plate




Note: This is Not A full
penetration weld.
Sometimes weld symbol on
drawings calls for fillet weld
rather than flare. This mistake
should be brought to Atlention
of mechanical Engineering.

3. Bevel



Full penetration bevel welds without backing should not be welded with WPS IAI. Welder should be qualified for open root welding with WPS IAB prior to attempting these welds.


ex.




Applicable procedures (wos, mx

F. Combination Weld Symbols

1. Bevel with Fillet



2. Flare with Fillet



III Discussion of Misunderstood Procedures ! + 1

A. Stanifing - MP-05
1. Changes to MP-05 to help prevent
 excessive stamping on Hanger Welds
2. Request that All welders obtain
"Nissen" Pipe markers to use for
"boxing in" of All stencil marking
 for welder identification.

3. Welders who have stencils with (3) three on (4) four letters are having problems stamping the complete identification marking on plates. New stencils have been ordered and ill be available to welders. Each stecil will only have one letter or number and therefor should be ensier to stamp with.

B. Material Control - MP-03

- . Welders must discontinue the throwing Away of good welding electrodes
- 2. Foremen must start being more accurate on Job description which is placed on WMR. These records are used to maintain welder's certification and must be accurate.
- C. Welders should reveiw All MP procedu
 which are sent to field to be
 reveiwed. Otherwise, welders will Not
 Know about New changes to procedures


D. Weld Procedure Specifications are being issued to welders . when they receive we rods. Welder should reveiw procedure prior to welding.


- t 1


IV Conclusion

All work performed must be as specific on drawings. If conflict arrises between actual work that can be performed vs. that which is called for, welder show contact foreman and he should contact mechanical or welding.

		Basic	Welding Symboli	and Their Loci	tion Significanc		Fla	100
Location Significance	Fillet	Plug or Slot	Spot or Projection	Seam	Back or backing	Surfacing	Edge	Corner
Arrow side	70	4	>0	-	weid symbol	\pm/	71	>11
Other side	M	×	عد	>€ \	Groove	Not Used	ملا	11
Soth sides	>+	Not used	Not used	Not used	Not used	Not pused	Nc: uses	Nut used
No arrow side or other side significance	Not used	Not used	\~	\ \ \	Not used	Not - used	Not used	N:-








AAC Bir carbon arc cutting AAR air activiene welding ABO adhesive bonding AB arc brazing AC arc cutting AHM allows before welding	8 Brazing 88 Block brazing 8MAW bare metal arc weeding CAC carbon arc cutting CAW carbon arc weeding	CW DB DFB DFW DS	cold weiding dip brazing diffusion brazing diffusion ericing dip soldering electric arc spraing electric arc spraing	ESW EXW FB FCAW FCAW EG	electrosiag welding explosion welding functional formation and functional flux cored arc welding flux cored arc welding electrogas flow brazing flow brazing flux cored arc welding electrogas	FOC FOW FPW FS FW	chemical flux cun forge werz friction werz furnace societ flash werd gas metal arc cut
AND stame hydrogen weeding AOC oxygen arc cutting AW Arc weeding	CAW S shielded carbon arc welding CAW T built carbon arc welding	EBC	electron beam cutting electron beam welding	FLSP	flow weiding flame spraying	GMAN EG	gas metal arc welding—electro

Basic Welding Symbols and Their Location Significance						Supplementary Symbols			
Square		k Berel	Groove	-	Flare-V	- Flare-bavel	Wetd-att - Around	Freid Weid	Mett thru
	1	~~~	>~	رمر	100	* >TC	0	E	-
4	بعر	کلار	>	رير	معد	· Lec	-	Contour	
++	\ X	- X	>*	VK	×	* >+	Flush	Conves	Concave
4	Not used	tot used	Not used	Not used	Not used	Not	-	~	~



Designation of Welding and Allied Processes by Letters

W P gas metal arc welding—purse 5 gas metal arc weld 5 short circuling 1-C gas tungsten arc cu 1-2 gas tungsten arc cu 1-2 gas tungsten arc welding—purse 1-3 gas tungsten arc welding—purse 1-3 gas metal arc welding—purse 1-3 gas metal arc welding—purse 1-4 gas tungsten arc 1-4 gas tung	er INS arc IRB ting IRS ting IS arc IW ting LBC	induction brazing iron soldering infrared brazing infrared brazing induction soldering induction soldering induction sending laser braam cutting laser beam welding	LOC MAC OAW OC OFC OFC A OFC H OFC M	oxygen lance cutting metal arc cutting oxygen cutting oxygen cutting oxyfuel gas cutting oxyaceryiene cutting oxyacyologen cutting oxyacyologen cutting oxyacyologen cutting	OFC P OFW OHW PAC PAW PEW PGW POC	dispropane cutting distributing as welding distributing an ewiding plasma are cutting plasma are certaing percussion welding pressure gas welding metal powder cutting	PSP RB RPW RS RSEW RSW ROW RW	plasma spraying resistance brazing projection weiding resistance soldering resistance sam weiding resistance sam weiding resistance weiding resistance weiding	SAW SAW S SMAC SMAW SSW SW TB	soldens submerged arc websit series submerged arc websit shielded metal arc cutti- shielded metal arc websit solid state websit stud arc metal- torch brazir
--	--	---	---	--	--	---	--	---	---	--

DANIEL CONSTRUCTION COMPANY SHEARON HARRIS NUCLEAR POWER PLANT TRAINING RECORD

DATE 10 - 17-80 TIME	12:40 LENGTH OF CLASS 2how
COURSE & TITLE Welding Sc	mbolo Class
INSTRUCTOR Wayne Harris	117
	IN ATTENDANCE
NAME	BAUGE NO.
1. John Treel	CP3L 239
20 Rel state.	CP82 75
3. James Neuill	CP4L 57
4. Stre Mounteasur	CD46-119
5. Al Wade	CPL-201
6. Pete Tingin	98/1164
7. IR. DANIS	CP { L 338
8. Cha Maa	CP\$4 169
9. C.O Buske	32-4
O. SW Bran	32-558
1. Yw Call	72-1418
2. John McLean	CPL 49
3. Klare Africa	32-738
4. William Tera	CFL - 196
5 Games Root	CPL -344
6. William Salman	32-63
108. 7 Kennan	32-01
8. P. Fulmore	32-859
9. A. Theref	32 588
o.D. Bohler	39 549
127 Milas	37-1428
2. 4.5. A. Corns	32/67
3. I minor	32-1429
4. N Sound	32-567
5. C. Barnett	32-550
6. A. Euri	32.782
1. Rudlin Loudout	32-119
8. Kus Dawson	32-456
9 mg P. Klaudy /	71 375
30.D W.K. HOLM	\$ 2 -59
W. T. Alle	25-23

Red Schedaud Beb Strather CP12 Jumi Angrown Grad Strate

32/54) 33/560 80 52/14/9 32/44

1

DANIEL CONSTRUCTION COMPANY SHEARON HARRIS NUCLEAR POWER PLANT

TRAINING RECORD

MIRSE & TITLE Welding Sun	0:30 LENGTH OF CLASS 2 hro.
ISTRUCTOR / hune Harres Chau	(1) Sliffen SHIFT 13T
PERSONS IN	ATTENDANCE
NAME	BADGE NO.
. Thomas W. Delles	6.6-405
. Howard H Galfers	
3. L. 9 Lawry	16-435
· miles X Relay	66-409
5. Sam Ellis	16-401
s. C.E. Fisher	32.788
1. C. Al. Things	32-974
3. Credy Struckland	50-101
3.702 tholyes	3.2/946
o. James Camplell	32/65
Maymond Tacker	66/4/2
2. Carpe of tonty	66/1468
3. Mingland Shel	66/4/5
4. I Buknu	52/170
5. MACTY JOHNSON	56.714
5. Kendy Workied	66 - 1454
1. Wall 99 change	38-514
8. AND MAXINEY	32-246
o. Francist kon	3)-533
This thinganhy	CP+L 191
Gydi McConell	66 1395
The contract of the	35/438
4. A.J. Williams	461427
5. 8 / 8 / Soral	35/2026
ATP MILED	20/19/69
	83-490
8. Janes Mi Ladden	32-493
9 Kours D. Vos	CPEL 211
10. Cam L. Sodimh	CP\$L 399
11-Marty Jackson	66/426
C VIII .	
2-E C Jack 32-11	12 66 H33

Speed Letter.

To_FILE	From DAVID TIMBERLAKE
Subject SKEWED T- FILLET WE	TLO MEASUREMENT CLASS
CLASS ON THE ABOVE COVERED THE USE OF SURING SKEWED T FILE	Date FEB. Z, 10 EZ CONDUCTED A TRAINING SUBJECT. THE CLASS PARRALEL LINES IN MEA- LETS AS OUTLINED IN E 2.7.1. THE ATMOMED TENDED THE CLASS
ED. WILLETT	Signed Did stell
REPLY	Date19
-No. 7 & 10 FOLD	
	Signed
Vilson Jones Company	RECIPIENT—RETAIN WHITE COPY, RETURN PINK COPY

SKEWED T-FILLET WELD MEASUKEMENT CLASS

NAME BA Ful Exal Mour Chy Filler Low Bried Chase Thomas William C Hartley Pat Chriscoe Jim Kirly C. West A. DeBanos An Martineti Reggie Saulken

Speed Letter. TO TEXMY WAIT From TAVID TIMBELLAZO ALEX FULLER Subject SKEWED T- FILLET MEASUKEMENT Date - 1411. 19 19 92 MESSAGE I WILL CONDUCT A SHORT CLASS ON THE ACOVE SUBJECT ON THUISHAY LAU. 21, 1982 AT STEAM IN THE LANCE CONFEDERER KOOM FLEASE IMYE ALL AFTRUPRIME , ELSONEL UNITED YOUR SUPTRIVISION TO ATTENE. THIS SUBJECT WILL ALSO BE COVELED IN THE NEXT WITHOUT CRAFT TEANING CLASS. CC: RAY HANFORD GEONGE FOREHAND EU WILLETT ASHLEIGH LUCAS

AMERICAN AND AND AND AND AND AND AND AND AND A
- CONCLUSION OF CONTRACTOR OF THE CONTRACTOR OF
THE POST OF THE PO
Signed'
Wilson taken a service of the street was retained to the street and the street an

CHAILMENON HAND STAN

4/2

April 14, 1982

TO: Jim Tranmel

FROM: David Timberlake

SUBJECT: "Welding Inspection Training" Classes

One class on the above subject was held on each of the following two days;

April 7, 1982 and April 8, 1982. The attached information includes the class
outline, class time, instructor, and list of attendees.

David Timberlake

cc; Frank Taylor Fasih Shaikh File

WELDING INSPECTION TRAINING CLASS

OUTLINE

- I. Visual Inspection of Welds (AWS D1.1-75, Examples of Various Defects)
 - A Proper Profile
 - 1 Convexity Formula
 - 2 Overlap
 - 3 Undercut no more than 1/32"
 - B Cracks (including crater cracks)
 - C Porosity
 - D Non Fusion
 - E Slag
 - F Arc Strikes
 - G Weld Spatter
 - H Tools of Inspector Magnifying lens, flashlight, mirror
- II. Fillet Weld Symbols
 - A Examples
 - B Leg, effective throat measurement
- III. Skewed Tee Fillets
 - A Examples
 - B Leg Measurement (use of parallel lines)
- IV. Plug Welds/ Repairs

DANIEL CONSTRUCTION COMPANY SHEARON HARRIS NUCLEAR POWER PLANT TRAINING RECORD

OURSE & TITLE WELDING INSPECTION TEN	ALING,
NSTRUCTOR DAVID TIMBERLAKE	SHIFT 1 SE
PERSONS IN ATTE	INDANCE
NAME	BADGE NO.
1. Frank Taylor	220
2. Eugene Martin and 4/16	-485
3. EUGENE E. VICK	543
4. Mudden Kins	5-44
5. Toka Bain	521
6. JIM BROWN	98
7. STEVE MOUNTORSTUS	119
8. (ht Rate	183
9. Felal Merce	167
O. Calbert A DeRance	466
1. If Redamell,	460
2. Kichord W. Vemlino	126
3. Regueld of tulker	465
4. Wayne D. Monting	525
5. sach C Hulett	533
6. Mames D. Stores	527
17. IM lark W. Hale	354
8. DAVE DE JARUTS	223
19. THOMAS B. DANIEL	397
20. Jone W. West	398
11.	
2.	
3.	
4.	
5.	
5.	
7.	
18.	
29.	
10.	

DANIEL CONSTRUCTION COMPANY SHEARON HARRIS NUCLEAR POWER PLANT TRAINING RECORD

	LENGTH OF CLASS 1 1/Z /	+125
COURSE & TITLE WELDING INSPECTION .	TKNG	
INSTRUCTOR DAVID TIMBERLAKE	SHIFT /St	
PERSONS IN AT	TENDANCE	
NAME	BADGE NO.	
1. HARK D. TALLEN	CP32 477	- 4
2. Paus SUDDUTH	TEL SEE	
3. ROBERT STEELE	754 109	
4. 1. 1. Eliam Pere	CPE: 196	
5. Kennylink Somelac	CP1L 313	
6. Tonmer Dillet	Spit 700	
7. Pete Tuasan	CP+L 371	
8. Clay Thodes	CP7L 370	
9. Gald to long	TSC 352	
10.		
11.		
12.		
13.		
14.		
15.		
16.		
17.		
18.		
19.		
20.		
21.		
22.		
23.		
24.		
25.		
26.		
27.		
28.		
29.		
30.		



Company Correspondence

May 20, 1982

MEMO TO: Jim Trammel

FROM: David Timberlake

SUBJECT: "Welding Inspection Training" Class

One class on the above subject was held on May 20, 1982. The attached information includes the class outline, class time, instructor and list of attendees.

David Timberlake

cc: Brent Firestone - QC Fasih Shaikh Frank Taylor - QC

File

DT/c

WELDING INSPECTION TRAINING CLASS

OUTLINE

- I. Visual Inspection of Welds (AWS D1.1-75, Examples of Various Defects)
 - A Proper Profile
 - 1 Convexity Formula
 - 2 Overlap
 - 3 Undercut no more than 1/32"
 - B Cracks (including crater cracks)
 - C Porosity
 - D Non Fusion
 - E Slag
 - F Arc Strikes
 - G Weld Spatter
 - H Tools of Inspector Magnifying lens, flashlight, mirror
- II. Fillet Weld Symbols
 - A Examples
 - B Leg, effective throat measurement
- III. Skewed Tee Fillets
 - A Examples
 - B Leg Measurement (use of parallel lines)

DANIEL CONSTRUCTION COMPANY SHEARON HARRIS NUCLEAR POWER PLANT TRAINING RECORD

DURSE & TITLE " ELT LE 18815	FUT IN TURB
STRUCTOR TO TIMBELLAYET	The state of the s
	ERSONS IN ATTENDANCE
NAME	BADGE NO.
1. Poul Roxbury	62.5
2. BOB STEELS	. 209
3. Eugene Martin	485
4. KEVIN M. KENYON	547
5.	45.5
6. Dava SUDAUTH	523
7- Dave Louses	5-32
8. Donalas M. Brown,	546
9. Judi McDonnell	191
10. Telen Brest Furston	559
11. AL TITLE	624
12. Robert Tombinson	608
13.	
14.	
15.	
16.	
17.	
18.	
19.	
20.	
21.	
22.	
23.	
24.	
25.	
26.	
27.	
28.	
29.	Çıc.
30.	

Speed Letter, 44-902	Gra	nine Swarwing Town
TO BAY HANGERO /FILE	Speed Letter	· DAVID TIMBERLAKE
Subject TRAINING CLASS PER	- HANGER	Welpers
MESSAGE A one (1) hour frain 1981 by me as the at sheet details.	ing class	was held on June 4, thing and attendence
cc: W.D. Goodman	Date 6-5-81	.^
REPLY		The state of the s
-No #FOLO		
	Date	Signed
Wilson Jones Company GRANUNG FORM 44-007 3 PANT C 1978 - PRINTEO W V.S.A.		RECIPIENT—RETAIN WHITE COPY, RETURN PINK COPY

SENDER-DETACH AND RETAIN YELLOW COPY, SEND WHITE AND PINK COPIES WITH CARBON INTACT.

PART I WELD QUALITY

9.25 Quality of Welds

9.25.1 Visual Inspection. All welds shall be visually inspected. A weld shall be acceptable by visual inspection if it shows that:

9.25.1.1 The weld has no cracks.

9.25.1.2 Thorough fusion exists between weld metal and base metal.

9.25.1.3 All craters are filled to the full cross sec-

9.25.1.4 Weld profiles are in accordance with 3.6.

9.25.1.5 The frequency of piping porosity in fillet welds shall not exceed one in each 4 in. (102 mm) of length and the maximum diameter shall not exceed 3/32 in. (2.4 mm). Exception: for fillet welds connecting stiffeners to web, the sum of the diameters of piping porosity shall not exceed 3/8 in. (9.5 mm) in any linear inch of weld and shall not exceed 3/4 in. (19.0 mm) in any 12 in. (305 mm) length of weld.

9.25.1.6 A fillet weld in any single continuous weld shall be permitted to underrun the nominal fillet weld size required by 1/16 in. (1.6 mm) without correction, provided that the undersize weld does not exceed 10 percent of the length of the weld. On web-to-flange welds on girders no underrun is permitted at ends for a length equal to twice the width of the flange.

9.25.1.7 Complete joint penetration groove welds in butt joints transverse to the direction of computed tensile stress shall have no piping porosity. For all other groove welds, the frequency of piping porosity shall not exceed one in 4 in. (102 mm) of length and the maximum diameter shall not exceed 3/32 in. (2.4 mm).

9.25.1.8 Visual inspection of welds in all steels may begin immediately after the completed welds have cooled to ambient temperature. Acceptance criteria for ASTM A514 and A517 steels shall be based on visual inspection performed not less than 48 hours after completion of the weld.

3.6 Weld Profiles

3.6.1 The faces of fillet welds may be slightly convex. flat, or slightly concave as shown in Fig. 3.6 A, B, and C, with none of the unacceptable profiles shown in Fig. 3.6D. Except at outside corner joints, the convexity shall not exceed the value of 0.1S plus 0.03 in. where S is the actual size of the fillet weld in inches. (See Fig. 3.6C.)

3.6.2 Groove welds shall preferably be made with slight or minimum reinforcement except as may be otherwise provided. In the case of butt and corner joints, the reinforcement shall not exceed 1/8 in. (3.2 mm) in height and shall have gradual transition to the plane of the base metal surface (Fig. 3.6E). They shall be free of the discontinuities shown for butt joints in Fig. 3.6F.

3.6.3 Surfaces of butt joints required to be flush shall be finished so as not to reduce the thickness of the thinner base metal or weld metal by more than 1/32 in. (0.8 mm) or five percent of the thickness, whichever is smaller, or leave reinforcement that exceeds 1/32 in.




Fig. 3.6-Acceptable and unacceptable weld profiles.

However, all reinforcement must be removed where the weld forms part of a faying or contact surface. Any reinforcement must blend smoothly into the plate surfaces with transition areas free from edge weld undercut. Chipping may be used provided it is followed by grinding. Where surface finishing is required, its roughness value" shall not exceed 250 μ in. (6.3 μ m). Surface finished to values of over 125 μ in. (3.2 μ m) through 250 μ in. shall be finished parallel to the direction of primary stress. Surfaces finished to values of 125 μ in. or less may be finished in any direction.

3.6.3.1 Ends of butt joints required to be flush shall be finished so as not to reduce the width beyond the detailed width or the actual width furnished, whichever is greater, by more than 1/8 in. (3.2 mm) or so as not to leave a

reinforcement at each end that exceeds 1/8 in. (3.2 mm). Ends of butt welds shall be faired to adjacent plate or shape edges at a slope not to exceed 1 in 10.

3.6.4 For buildings and tubular structures, undercut shall be no more than 0.01 in. (0.25 mm) deep when its direction is transverse to primary tensile stress in the part that is undercut, nor more than 1/32 in. (0.8 mm) for all other situations.

3.6.5 For bridges, undercut shall be no more than 0.01 in. (0.25 mm) deep when the weld is transverse to the primary stress in the part that is undercut. Undercut shall be no more than 1/32 in. (0.8 mm) deep when the weld is parallel to the primary stress in the part that is undercut.

3.6.6 Welds shall be free from overlap.

[&]quot;ANSI B46.1 Surface Texture, in microinches (µin.).

PART I WELD SYMBOLS

WELD ALL ARGEND SYMBOL

O.S. REPERDUCE LINE

SIZE OF FILLET WELD

SYMBOL

(ALSO COVERED FLARE

BEVEL AND SINGLE BEVEL

GROWE)

Instructor; David Timberlake

Weed Quality & Symbols

attendance Stal

61-11

Celle Menter 98-272 Sac Lendergraes 66 17 QA welding PA Walding Brane 9A Walding STERES MEUNIONSTEES OF KLEENING Ken Donglas Q.A. Welding Chase Thema - CPEL (Macn.) CATE aly Fuller C. gmati 66-40 Jan Erent , 66-518 Chailes Harpes 66/462 16 mc Garin 66-15-38 1 Duan Price 66-368 Vin Sordin 64-711 2 cm Wes 66-38 Celif Crawley 66-170 Juange J Mashes 66-688 Chus Sutt CPIL Jany Coste CP&L PATCHRISCOE CPEL CPTI DARRENDASSUR6 Mu Hourd CPTL Burnie Marton 66/11 (OVER)

CAROLINA POWER & LIGHT COMPANY

CORPORATE QUALITY ASSURANCE DEPARTMENT

ENGINEERING AND CONSTRUCTION QUALITY ASSURANCE/QUALITY CONTROL SECTION

WELD CONTROL

NUMBER:

CQC-19

INITIAL ISSUE DATE:

March 16, 1981

RECOMMENDED FOR APPROVAL

BY:

DIRECTOR - SHIPP QA/QC

APPROVED BY:

MANAGER - E&C QA/QC

CAROLINA POWER & LIGHT COMPANY

CORPORATE QUALITY ASSURANCE DEPARTMENT

QA/QC - HARRIS PLANT SECTION

CQC-19

12

3/19/84

TITLE: WELD CONTROL

REVISION RECORD

The following is a list of the pages and paragraphs affected by this revision. Changes or additions are indicated by a vertical bar in the right-hand margin of the revised page(s). Manual holder is to replace affected pages only. This record is to be retained behind the title page of the procedure intil a subsequent revision is issued.

Page(S)	Paragraph, J.
1	2.0; 3.0
2	3.0
3	4.4
5	6.1.2
7	(No content change)
8	6.1.4
9	(No content change)
10	6.1.6
11	6.1.6; 6.1.3
14	6.1.9; 6.1.10
16	6.2
17	6.2.4 - 6.3.4
18	6.3.4 - 6.3.5
19	6.3.6 - 6.4.2
20	6.4.3 - 6.4.7
21	6.4.8 - 6.4.9
22	6.4.10 - 6.4.12

RECOMMENDED FOR APPROVAL BY:

APPROVAL BY:

DL Forthand

DIRECTOR - QA/QC - HARRIS FLANT

MANAGER - DA/CC - HARRIS PLANT

CAROLINA POWER & LIGHT COMPANY

CORPORATE QUALITY ASSURANCE DEPARTMENT

QA/QC - HARRIS PLANT SECTION

NUMBER REVISION DATE

CQC-19 12 3/19/84

TITLE: WELD CONTROL

REVISION RECORD

The following is a list of the pages and paragraphs affected by this revision. Changes or additions are indicated by a vertical bar in the right-hand margin of the revised page(s). Manual holder is to replace affected pages only. This record is to be retained behind the title page of the procedure intil a subsequent revision is issued.

?3ke(s)	Paragraph.2
23	6.4.13 - 6.4.14
24	7.0; 8.0 - 8.1.4
25	8.3 - 8.4.1
26	8.4.2

RECOMMENDED FOR APPROVAL BY:

APPROVAL BY:

See Page 1 of 2

DIRECTOR - QA/QC - HARRIS F_ANT

See Page 1 of 2

MANAGER - GA/GC - HARRIS PLANT

CAROLINA POWER & LIGHT COMPANY

CORPORATE QUALITY ASSURANCE DEPARTMENT

QA/QC - HARRIS PLANT SECTION

NUMBER

REVISION

CQC-19

12

TITLE:

WELD CONTROL

LIST OF EFFECTIVE PAGES

Page No.	Rev. No.
1	8
2	8
3	0
4	2
5	8
6	
7	9
8	8
9	8
1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18	8 8 7 8 7 9 8 8 8 8 8 6 7 7 6
11	8
12	0
13	
14	7
15	0
16	4
17	4
18	4
19	2
20	2
21	3
22	
19 20 21 22 23 24	
24	
25	4 2 2 3 1 1 2 2 2
26	-

CAROLINA POWER & LIGHT COMPANY

CORPORATE QUALITY ASSURANCE DEPARTMENT

QA/QC - HARRIS PLANT SECTION

NUMBER

REVISION

CQC-19

8

TITLE: WELD CONTROL

1.0 PURPOSE

The purpose of this procedure is to establish measures for the control and documentation of welding activities at a nuclear plant.

2.0 SCOPE

This procedure is applicable to welding activities related to ASME Code, Section III, Classes 1, 2, 3 and MC Items; Categories 4 and 5 Mainsteam and Feedwater Systems; Category 7 Blowdown System; Waste Gas, Waste Liquid, and Secondary Waste Systems in the Radwaste System; Fire Protection System; Fuel Pool Liner; Seismic Class 1; and NNS Category I (Seismically Designed) Items. This is an ASME Section III procedure.

3.0 REFERENCES

1. E&C QA Procedures and Instructions

- a. CQA-1, Personnel Training and Qualifications
- b. CQA-4, QA Records
- c. CQC-1, Tool and Measuring Device Control
- d. CQA-3, Nonconformance Control
- e. CQC-20, Post Weld Heat Treatment Control
- f. CQC-21, Seismic Category I Steel Fabrication
- g. NDEP-10, Training, Qualification & Certification of NDE Personnel
- h. NDEP-601, Visual Examination of Piping System and Component Welds (SHNPP)
- NDEP-605, Visual Examination of Seismic I, Structural and Hanger Welds (SHNPP)
- j. NDEP-701, Leak Testing (Vacuum Box)
- k. QCI-19.1, Preparation of WDR, Repair WDR and TFWR
- QCI-19.3, Seismic Pipe Hanger Inspection Documentation System
- m. QCI-19.4, Preparation of Seismic I WDR
- n. CQC-12, Inspection of Code Valve Installation, Disassembly and Reassembly
- o. QCI-19.5, Identification and Documentation of Base Metal Deficiencies Outside of the Weld Area of Interest

CAROLINA POWER & LIGHT COMPANY

CORPORATE QUALITY ASSURANCE DEPARTMENT

QA/QC - HARRIS PLANT SECTION

NUMBER

REVISION

CQC-19

8

TITLE: WELD CONTROL

3.0 (cont.)

£ .

- p. QCI-19.6, Material Verification
- q. QCI-6.4, Material Status Verification

2. SHNPP Construction Procedures

- a. MP-03, Welding Material Control
- b. MP-05, Stamping of Weldments
- MP-06, General Welding Procedure for Carbon Steel Weldments
- d. MP-07, General Welding Procedure for Stainless Steel Weldments
- e. MP-08, General Welding Procedure for Structural Steel and Hangers
- f. MP-10, Repair of Base Materials and Weldments
- g. MP-12, Control of Welding on Non-Permanent Plant Items
- h. MP-13, Welder Qualification for Area of Limited Accessibility
- MP-14, General Welding Procedure for Stainless Steel Liner Plate
- j. MP-24, General Welding Procedure for Installation of Tubing and Instrumentation
- k. MP-15, Welding of Bottom Mounted Incore Tubing
- 1. MP-19, Field Erected Stainless Steel Storage Tanks
- m. WP-01, Installation of Cadwelds
- n. WP-18, Miscellaneous Steel Fabrication
- o. WP-30, Erection of Structural Steel
- p. WP-102, Installation of Piping
- q. WP-105, Installation of Equipment Safety Related Seismic Class I and NNS
- r. WP-110, Installation of Seismic Pipe Hangers and Supports for Seismically Analyzed Pipe
- s. WP-203, Installation of Seismically Support Cable Tray and Conduit Boxes and Bus Ducts
- t. WP-302, Installation of Supports for Safety and Seismically Related Instruments, Tube Tracking and Tubing
- u. WP-304, Installation of Safety Related and Seismic Process Tubing and Instrumentation
- v. WP-400, Installation of HVAC Seismic Category I Supports
- w. WP-402, Installation of Safety Related Seismic Class I and Non-Nuclear Safety HVAC Ductwork

CAROLINA POWER & LIGHT COMPANY CORPORATE QUALITY ASSURANCE DEPARTMENT QA/QC - HARRIS PLANT SECTION

NUMBER

REVISION

CQC-19

8

TITLE: WELD CONTROL

3.0 (cont.)

3. Site Specifications

- a. 030, Field Fabrication and Erection of Power Piping
- b. 031, Requirements for Field Welding of Category 1, 2 and 3 and Balance-of-Plant Piping Systems, Seismic and Non-Seismic Structures
- c. 033, Structural Welding
- d. 034, Non-Destructive Examination Requirements for Class 1, 2 and 3 and Balance-of-Plant Piping Systems, Seismic and Non-Seismic Structures

4.0 RESPONSIBILITY

4.1 Director - QA/QC

The Director - QA/QC has overall responsibility for implementation of this procedure.

4.2 Superintendent - Quality Control

The Superintendent - QC is responsible to the Director - QA/QC for implementation of this procedure.

4.3 Quality Control Sub-Unit Supervisor

Each applicable QC Sub-Unit Supervisor shall be responsible for the implementation of this procedure.

4.4 Quality Assurance/Quality Control Specialist

The QA/QC Specialist shall be responsible for review and verification of data and designated holdpoints on weld records; ensuring that SRIWDR's, WDR's and RWDR's for ASME Code welds are forwarded to the Authorized Nuclear Inspector (ANI); for review and insertion of additional holdpoints; and final acceptance of the welding activity. The Pipe Welding QA/QC Specialist shall supervise the Pipe, Pool Liner Weld Inspectors in the performance of weld inspections and monitoring activities related to welding.

CAROLINA POWER & LIGHT COMPANY CORPORATE QUALITY ASSURANCE DEPARTMENT QA/QC - HARRIS PLANT SECTION

NUMBER

REVISION-

CQC-19

7

TITLE: WELD CONTROL

4.4 (cont.)

The Structural Welding QA/QC Specialist shall be responsible for review and verification of data and designated holdpoints on Seismic Weld Records; for review and insertion of additional holdpoints; and final acceptance of the welding activity. The Structural Welding QA/QC Specialist shall supervise the Structural QC Inspectors in the performance of weld inspections and monitoring activities related to welding.

4.5 Quality Control Inspectors

QC Inspectors shall perform welding inspections and monitoring of welding activities as directed by the appropriate QA/QC Specialist.

5.0 PERSONNEL QUALIFICATION

- 5.1 QC Welding inspection personnel shall be trained and qualified in accordance with Reference 3.1 a and 3.1 g.
- 5.2 Nondestructive Examination (NDE) personnel shall be trained and qualified in accordance with Reference 3.1 g.

6.0 PROCEDURE

- 6.1 ASME Code Class 1, 2, 3 & MC and Seismic Class 1 Category 4 & 5 Mainsteam and Feedwater
 - 6.1.1 ASME Code Class 1, 2, 3, MC and Category 4 & 5
 Mainsteam and Feedwater welds shall be documented on a
 Weld Data Report (WDR), QA-28 Form. Instrumentation
 tubing joints involving welding, for ASME Code Class 1,
 2 and 3, shall require a Safety-Related Instrumentation
 Weld Data Report (SRIWDR) Form QA-40. Class MC and
 Category 4 & 5 Mainsteam and Feedwater welds shall meet
 the Code technical requirements but do not require
 inspection and acceptance by ANI. Other category welds
 requiring RT/UT or PWHT shall be documented on a WDR.

CAROLINA POWER & LIGHT COMPANY

CORPORATE QUALITY ASSURANCE DEPARTMENT

QA/QC - HARRIS PLANT SECTION

NUMBER

REVISION

CQC-19

8

TITLE: WELD CONTROL

- 6.1.2 The QA/QC Specialist, or his designee, shall take the following action, as appropriate, when the WDR is received from Welding Engineering:
 - a. Ensure mandatory holdpoints have been designated as required by Reference 3.3 d and enter additional holdpoints determined to be necessary.
 - b. Review technical data and applicable drawings and coordinate with the ANI as necessary. (The ANI will stipulate his holdpoints.)
 - c. The white copy of the WDR will be transmitted to the Mechanical Engineering Unit. The white copy of the SRIWDR will be transmitted to the Instrumentation Engineering Unit.
 - d. Technical additions or changes made to the WDR after review by QC and the ANI shall be initialed and dated by Welding Engineering and QC. It shall be resubmitted to the ANI for his initial and date indicating concurrence with the change and for additional holdpoints, if needed.
 - e. The following changes are considered non-technical and may be corrected by the QC Inspector or QA/QC Specialist:
 - (1) Changes in weld material heat number, lot number, rod sizes, welder's identification, and revision numbers to procedures.
 - (2) Changing magnetic particle testing to liquid penetrant testing or vice versa, as necessary, for joint accessibility.
 - (3) Addition or correction to unit number and turnover numbers.

CAROLINA POWER & LIGHT COMPANY

CORPORATE QUALITY ASSURANCE DEPARTMENT

QA/QC - HARRIS PLANT SECTION

NUMBER

REVISION-

CQC-19

7

TITLE: WELD CONTROL

6.1.2 (cont.)

- (4) Addition of and changes to CQC-19 revision numbers.
- (5) Addition or changes to revision numbers of isometric (as documented in remarks section of WDR).
- (6) Correction to the area and elevation listed in "weld joint record".
- f. When applicable, Field Change Request (FCR) number(s) shall be entered, by Welding Engineering, in the remarks section of the WDR/SRIWDR/RWDR prior to issuance/re-issuance to construction except as noted in paragraph 6.1.2.h.
- g. FCR's affecting WDR's, SRIWDR's, or Repair WDR's already issued shall be implemented into construction in one of the following methods:
 - (1) If the FCR does not dictate any rework instructions but does describe inspection requirements, a technical revision to the WDR, SRIWDR, or Repair WDR will not be necessary. However, upon mutual concurrence between Welding Engineering, the QA/QC Specialist, and the ANI, the QC Inspector will be made aware of the inspection criteria and shall have available to him and the ANI, a copy of the FCR for use in performing the inspection. Upon completion of the inspection, the QC Inspector shall enter the FCR number in the remarks section of the WDR (i.e., accepted to FCR-H-1142).

CAROLINA POWER & LIGHT COMPANY CORPORATE QUALITY ASSURANCE DEPARTMENT QA/QC - HARRIS PLANT SECTION

NUMBER

REVISION

CQC-19

9

TITLE: WELD CONTROL

6.1.2 (cont.)

- (2) If the FCR requires rework of the weld, or changes instructions already detailed in the WDR, SRIWDR, or Repair WDR, the WDR, SRIWDR, or Repair WDR will be forwarded from construction to Welding Engineering for the necessary revisions to be made and the FCR number(s) added in the remarks section of the WDR.
- h. When an FCR addressing an ASME Code case becomes applicable to an inspection being performed by the QC Inspector, he shall, upon acceptable completion of the inspection, reference the number of the ASME Code case being invoked, in the remarks section of the WDR, SRIWDR, or Repair WDR.
- 6.1.3 The QC Inspector will review the applicable installation drawings, isometrics, Field Change Requests (FCR's), and Design Change Notices (DCN's) to ensure he understands the configuration and weld requirements. Any drawing problems such as missing, wrong, or confusing weld symbols or instructions shall be resolved through construction engineering prior to acceptance of the welds in question.
- 6.1.4 The QC Inspector shall ensure any changes or additions to the WDR have been properly initialed and dated per Paragraph 6.1.2 d, 6.1.2 e and 6.1.2 g and perform the prescribed visual inspection in accordance with Reference 3.1 h. Where applicable, the following items, in addition to those required by Reference 3.1 h, shall be verified prior to final acceptance:
 - Welded items have been accepted or conditionally accepted.

CAROLINA POWER & LIGHT COMPANY CORPORATE QUALITY ASSURANCE DEPARTMENT QA/QC - HARRIS PLANT SECTION

NUMBER

REVISION

CQC-19

8

TITLE: WELD CONTROL

6.1.4 (cont.)

- b. Component identification and National Board Numbers (verify component identification against the isometric and National Board numbers against the component documentation) are entered on the WDR. Heat numbers for stock pipe that is not NPT stamped (verify per Reference 3.1p) are entered on the WDR. Instrumentation components are identified only by heat number on the component. Piece numbers listed on the SRIWDR are verified only against the ISO. Heat numbers for minor permanent attachments need not be entered if the requirements of ASME III NC4435 are met.
- c. Cold pull/spring is within specified limits. (Obtain copy of the <u>Cold Pull Record Form</u>, Exhibit 1 to WP-102.)
- d. Pipe longitudinal seams offset in accordance with Reference 3.2 c.
- e. Pipe ovality in accordance with Reference 3.2 c.
- f. Valves are correctly installed in accordance with Reference 3.1 n.
- g. ISI weld centerline benchmark is stamped in accordance with Reference 3.2 b.
- h. Weld joints requiring volumetric (UT) in-service inspection may have a counterbore less than 2T (pipe joint only, but greater than or equal to T + 1/4"). The actual dimension shall be recorded in the remarks section of the WDR at prefit inspection.
- Weld joint identification stamping is applied in accordance with Reference 3.2 b.

CAROLINA POWER & LIGHT COMPANY

CORPORATE QUALITY ASSURANCE DEPARTMENT

QA/QC - HARRIS PLANT SECTION

NUMBER

REVISION

CQC-19

8

TITLE: WELD CONTROL

6.1.4 (cont.)

- j. The specified welding procedure and welding procedure specification is used, and is being followed.
- k. The welder is qualified to the procedure and position (and limited access, where required).
- Weld filler metal heat/lot number(s) are entered on the QA field copies of the WDR. (Check the WMR in the welder's possession.)
- m. Tack welds are applied and incorporated, or removed, in accordance with Reference 3.3 b.
- n. No peening is done on the initial layer, root, or final weld layers.
- o. No grinding is done within the heat affect zone in the ID of CS, RC or SI system piping after completion of welding.
- p. ISI welds requiring Volumetric Examination (UT) shall have their crowns finished and contoured in accordance with Paragraph 3.2 c and d. Other ISI welds requiring surface examination only, (MT or PT) shall be free from sharp surface irregularities such as deep valleys between stringer beads, and a 250 microinch finish shall be established in the examination area.
- q. Visual inspection, per Reference 3.1 h and NDE required by Reference 3.3 d is performed after removal of temporary attachments, arc strikes, weld spatter and backing rings.
- r. Welder's symbol(s) stamping are applied in accordance with Reference 3.2 b.
- s. PWHT inspection is performed in accordance with Reference 3.1 e.

REVISION

CQC-19

8

WELD CONTROL TITLE:

- 6.1.5 Deficiencies noted during pre-fitup, fitup and inprocess inspections which cannot be corrected by routine rework shall be reported as nonconformances in accordance with Reference 3.1 d.
- 6.1.6 The QC Inspector shall inform the ANI when the holdpoints are reached. When specified NDE holdpoints are reached, the QC Inspector will inspect for appropriate surface preparation and perform the required NDE (if qualified) or initiate the NDE Request (QA-37 Form). (NDE procedure revision numbers are entered on WDR after receiving completed NDE Request and Report.) NDE Requests shall be processed as follows:
 - a. The QC Inspector shall fill in pertinent information and submit along with the WDR to the QA/QC Specialist, or his designee.
 - b. The QA/QC Specialist, or his designee, shall review the NDE Request for accuracy; sign and date; and return to the inspector who will forward the original and one copy to NDE. One copy shall be attached to the WDR.
 - The NDE Unit or qualified inspector after performing the specified NDE, shall complete the appropriate NDE Report. The original copy of the NDE Request, appropriately marked "Accept" or "Reject", signed and dated will be forwarded to the QA/QC Specialist.
 - d. If the NDE is rejected for surfaces not suitable for test, or where the surface is inaccessible for Magnetic Particle Inspection and the QC Inspector or QA/QC Specialist changes the required NDE to Liquid Penetrant Inspection, the QC Inspector shall place an appropriate asterisk (*) by the applicable Visual Inspection holdpoint, and note in the remark section "Reinspection required for surface

CAROLINA POWER & LIGHT COMPANY

CORPORATE QUALITY ASSURANCE DEPARTMENT

QA/QC - HARRIS PLANT SECTION

NUMBER

REVISION

CQC-19

8

TITLE:

WELD CONTROL

6.1.6 (cont.)

preparation" and initial and date. The WDR/SRIWDR shall be returned to the craft foreman for surface preparation. After reinspection and acceptance, the QC Inspector shall list "accept" and initial and date reinspection note in remarks section. If the ANI has a holdpoint on the visual inspection, he shall be notified for reinspection. After reinspection of weld is complete, the QC Inspector shall re-initiate the NDE Request (QA-37) per 6.1.6 a and b.

- 6.1.7 Holdpoints accepted by the QC Inspector and the ANI will be intialed and dated on the white copy of the WDR or SRIWDR, as applicable.
- 6.1.8 Unacceptable holdpoints will be checked in the "Reject" column, but will not be signed on the WDR. An "R" shall be listed in the status block for rejects on SRIWDR's. The details of the unacceptable condition for visual inspection will be written in the "Remarks" section of the WDR.
 - a. If the unacceptable condition is in the weld (including 1/2" of base material for ASME Class 1, measured from the toe of the weld, on both sides of the weld) and is detected by NDE at a required holdpoint, a copy of the NDE Report will be forwarded to the Welding Engineer for disposition. If the unacceptable condition is detected by Magnetic Particle or Liquid Penetrant method, the WDR, SRIWDR, or RWDR may be revised to allow rework excluding weld repair, and QC/ANI holdpoints shall be re-established for reinspection. Weld metal surface defects may be removed by grinding or machining and not repaired by Welding provided:
 - The remaining section thickness is not below the minimum design wall thickness; and

CAROLINA POWER & LIGHT COMPANY
CORPORATE QUALITY ASSURANCE DEPARTMENT

QA/QC - HARRIS PLANT SECTION

NUMBER

REVISION

CQC-19

6

TITLE: WELD CONTROL

6.1.8 (cont.)

 The depression, after defect removal, is blended uniformly into the surrounding surface; and

3. Liquid Penetrant (PT) or magnetic particle (MT) examination of the area, after blending indicates the defect was removed or the indication was reduced to an acceptable limit.

When repair by welding is required, a Repair WDR (QA-30 Form) will be initiated in accordance with Reference 3.1 k. The area will be examined as follows:

- Unacceptable defects shall be removed by a. mechanical means or by thermal gouging processes. The area prepared for repair shall be examined by the magnetic particle or liquid penetrant method, except for partial penetration welds (i.e., tube to tube sheet welds, fillet welds for attachment of lugs, rings, trunions, shoes, pipe saddles, and brackets), where defect removal essentially removes the full thickness of the weld, in which case, a visual inspection to the satisfction of the ANI to determine suitability for rewelding shall be performed. The NDE (RT, MT, PT, UT) of weld repairs shall be repeated, as required, for the original weld except that repair of defects originally detected by MT or PT methods when the repair cavities do not exceed the lesser of 3/8 or 10% of the thickness, need only be reexamined by the MT or PT methods.
- b. Where the repair results in complete removal of the weld and repreped for a new joint, a new WDR or SRIWDR shall be generated in accordance with Reference 3.1 k.

CAROLINA POWER & LIGHT COMPANY CORPORATE QUALITY ASSURANCE DEPARTMENT QA/QC - HARRIS PLANT SECTION

NUMBER

REVISION

CQC-19

7

TITLE: WELD CONTROL

6.1.8 (cont.)

- c. Unacceptable conditions detected by visual inspection and consisting of weld defects which occur during the welding process (i.e. slag, porosity, burn through in the root pass or backing ring, or a root weld defect) require in-process rework and reinspection, but will not require handling as a nonconformance or documentation on a Repair WDR.
- For removal of indications in the base metal d. outside the area 1/2" from toe of weld that were detected by NDE where removal will not necessitate weld metal deposition, the required QA/ANI holdpoints shall be reestablished on the SRIWDR, WDR, or RWDR, even if weld inspection area is acceptable. If the unacceptable condition has damage to, or a defect in the base material which cannot be corrected by routine rework, it will be handled as a nonconformance in accordance with Reference 3.1 d. The NCR number will be noted in the "Remarks" section of the WDR. ANI concurrence with the proposed repair or rework shall be obtained prior to starting work. Repairs involving the deposition of weld metal will be documented on a Repair WDR. Inspection of the prepared cavity shall be entered as a QC inspection holdpoint on the Repair WDR so that the QC Inspector can measure the excavation. If the excavation exceeds the lesser of 3/8" of 10% of the section thickness, the QC Inspector shall ensure a sketch showing the location, length, width and depth of the excavation is prepared and attached to the Repair WDR. Examinaton of base metal repaired by welding shall be in accordance with Reference 3.3 d.

-CONTROLL ED DOCUMENT-

CAROLINA FOWER & LIGHT COMPANY CORPORATE QUALITY ASSURANCE DEPARTMENT QA/QC - HARRIS PLANT SECTION

NUMBER

REVISION

CQC-19

7

TITLE:

WELD CONTROL

6.1.8 (cor.t.)

- e. Repairs to weldments and base materials shall be verified to comply with Reference 3.2 f.
- 6.1.9 If a QC or ANI holdpoint is by-passed, it shall be reported as a nonconformance in accordance with Reference 3.1 d. The pipe foreman will be notified to stop welding until satisfactory dispositioning has been achieved and accepted by the ANI and the QA/QC Specialist.
- 6.1.10 At designated holdpoints as applicable and during random weld monitoring , the QC Inspector will check the welder's copy of the WMR to verify that the specified type of weld material (backing, consummable inserts, and filler metal) is being used, and that the material that the welder has in his possession is that which is identified on the WMR. When the original copy/copies of the WMR is received by QC Welding, it will be reconciled with the corresponding WDR to ascertain that all appropriate weld material information has been entered correctly on the WDR. The QA/QC Inspector will reconcile the following items on the WMR against the WDR: Weld procedure, size of material, heat number of backing material, consummable insert, and bare electrodes, and heat and lot numbers for coated electrodes, welder symbol, ISO and FW numbers. The WDR and supporting documentation, along with the attached WMR's will then be reviewed by the QA/QC Specialist, or his designee. After the Specialist, or his designee has made his review, and accepted the WDR by signing and dating it, the WDR Package will be transmitted to the Authorized Nuclear Inspector for his review. The WMR's will be filed in a designated storage area for possible future reference.

CAROLINA POWER & LIGHT COMPANY

CORPORATE QUALITY ASSURANCE DEPARTMENT QA/QC - HARRIS PLANT SECTION

NUMBER

REVISION

CQC-19

6

WELD CONTROL TITLE:

6.1.11 Inspection and Test Requirements for ASME Section III Code Class 1, 2 and 3 Safety Related Instrumentation Tubing

- Inspection and testing shall be performed in accordance with References 3.1 h, 3.2 j, and 3.3 d with special emphasis being put on the following for ASME Code Class 1 and 2 butt weld joints.
- b. When the Automatic GTAW process is used, ASME Code case N-127 shall be invoked for material thickness less or equal to .200" and tubing nominal size less than or equal to 2 inches.
- c. After machine set-up and prior to beginning of production welding, on each given workday (12 hour shift), QC shall be notified to witness and document on a Field Inspection Report, the acceptance of two consecutive sample weld prepared for:
 - (1) Each welding machine.
 - (2) Welding procedure specification.
 - (3) Welding position.
 - (4) Nominal tube size.
 - (5) Nominal wall thickness.
 - (6) P-Number group of material.
 - (7) In addition, one acceptable sample weld shall be prepared (in the presence of QC) after each four-hour period of production welding.

Acceptance shall be based on complete root penetration and shall be documented by QC on a Field Inspection Report. If the sample weld is found unacceptable, all weld production since the previous acceptable sample weld shall be examined by the radiographic method. The SRIWDR's applicable shall be revised to include RT.

CAROLINA POWER & LIGHT COMPANY

CORPORATE QUALITY ASSURANCE DEPARTMENT

QA/QC - HARRIS PLANT SECTION

NUMBER

REVISION

CQC-19

TITLE: WELD CONTROL

6.1.11 (cont.)

- d. In addition to NDEP-601, acceptance criteria, the following shall apply:
 - (1) Concavity on the outside weld surface shall not exceed 10%, of the nominal wall thickness. Concavity which exceeds 10%, but not more than 20% of the nominal wall' thickness may be handled as in-process weld repair using the manual GTAW process; however, SRIWDR must be revised to include the additional welding procedure and RT.
 - (2) Arc strikes outside the weld zone shall be rejected.
- 6.2 Fire Protection, Radwaste and Category 7 Blowdown Piping Systems
 - 6.2.1 Fire Protection, Radwaste Piping and Category 7
 Blowdown welds shall receive final layer visual
 inspection in accordance with Reference 3.1 h.
 - 6.2.2 The visual inspection will be documented on the Visual Examination Report (VT-1 Form). Welds shown on a given isometric may be listed on the same VT-1 Form. The QC Inspector will mark-up the appropriate isometric indicating acceptance of the weld joint(s).
 - 6.2.3 If the final weld inspection is rejectable, the QC Inspector will document the rejection on a separate VT-1 Form. The VT-1 Form with a rejection documented on it will be retained in QC files until the weld is reinspected and accepted in accordance with Reference 3.1 h. All reinspections of the rejected weld will be documented on the same QA VT-1 Form.

CAROLINA POWER & LIGHT COMPANY CORPORATE QUALITY ASSURANCE DEPARTMENT QA/QC - HARRIS PLANT SECTION

NUMBER

REVISION

CQC-19

4

TITLE: WELD CONTROL

- 6.2.4 The QC Inspector shall verify the following prior to closing the VT-1:
 - a. Installed item is in QA Accept status or a Conditionally Accepted status which does not restrict welding.
 - b. Welder's symbol(s) and weld identification stampings are on the completed joint in accordance with Reference 3.2 b.

6.3 Fuel Pool Liner Plate

- 6.3.1 Fuel pool liner welds shall be documented on the fuel pool liner weld maps with the exception of modifications and base metal repairs which wil be documented on Seismic Weld Data Reports (Form QA-34).
- 6.3.2 Fuel pool liner welds shall be visually inspected in accordance with Reference 3.1 h.
 - Fitup and preheat will be inspected on a random basis.
- 6.3.3 The QC Inspector will review the applicable installation drawings, Field Change Requests (FCR's), and Design Change Notices (DCN's) to ensure he understands the configuration and weld requirements. Any drawing problems such as missing, wrong or confusing weld symbols or instructions shall be resolved through Construction Engineering prior to acceptance of the welds in question.
- 6.3.4 Where applicable, the following items shall be verified prior to final acceptance:
 - a. Welded items have been accepted or conditionally accepted.

CAROLINA POWER & LIGHT COMPANY CORPORATE QUALITY ASSURANCE DEPARTMENT QA/QC - HARRIS PLANT SECTION

NUMBER

REVISION

CQC-19

4

TITLE: WELD CONTROL

6.3.4 (cont.)

- b. Weld joint identification is applied in accordance with Reference 3.2 b.
- c. The appropriate welding procedure and welding procedure specifications were used.
- d. The welder is qualified to the procedure and position.
- e. Welder's symbol is applied in accordance with Reference 3.2 b.
- 6.3.5 When specified NDE holdpoints are reached, the QC Inspector will inspect for appropriate surface preparation and perform the required NDE (if qualified) or initiate the NDE Request (Form QA-37). NDE Requests shall be processed as follows:
 - a. The QC Inspector shall fill in pertinent information and submit to the QA/QC Specialist, or his designee.
 - b. The QA/QC Specialist, or his designee, shall review the NDE Request for accuracy; sign and date; and return to the inspector who will forward the original and one copy to NDE.
 - c. The NDE Unit or qualified inspector after performing the specified NDE, shall complete the appropriate NDE Report. The original copy of the NDE Request, appropriately marked "Accept" or "Reject", signed and dated, and the original and one copy of the NDE Report will be forwarded to the requesting QA/QC Inspector.

CAROLINA POWER & LIGHT COMPANY CORPORATE QUALITY ASSURANCE DEPARTMENT QA/QC - HARRIS PLANT SECTION

NUMBER

REVISION

CQC-19

2

TITLE: WELD CONTROL

- 6.3.6 For base material repairs or liner modifications, a Seismic I Weld Data Report (Form QA-34) will be initialed by the Discipline Engineer and forwarded to the Welding Engineer. After the Welding Engineer has entered welding requirements, the SWDR will be forwarded to the QA/QC Specialist. The QA/QC Specialist, or his designee, will review the SWDR for all technical data and assignment of mandatory holdpoints and if acceptable shall sign and date to release for welding and forward to the Discipline Engineer for issuance to craft.
- 6.3.7 The QC Inspector will perform inspections when notified and indicate "Accept" or "Reject" on the SWDR in the appropriate block, initial and date. Required NDE will be handled in accordance with Paragraph 6.3.5.

6.4 Seismic Category I

- 6.4.1 Seismic I Weld Data Report (QA-34 Form) shall be generated for documentation and control of field walding in the following categories:
 - a. Fabrication, modification and installation of Seismic Category I hangers, restraints and equipment supports.
 - b. Fabrication, modification and installation of Seismic Category I structural steel, which includes Electrical, HVAC Ductwork, Cable Tray, Instrumentation Supports and Hangers.
 - c. Fabrication, modification and installation of structural steel members attached to Seismic Category I reinforcing steel bars.
 - d. Cadweld repairs by welding in accordance with Reference 3.2 m.
- 6.4.2 The QA-34 Form may be used to document multiple welds

CAROLINA POWER & LIGHT COMPANY

CORPORATE QUALITY ASSURANCE DEPARTMENT

QA/QC - HARRIS PLANT SECTION

NUMBER

REVISION

CQC-19

2

TITLE: WELD CONTROL

6.4.2 (cont.)

associated with a given component, hanger or support.

6.4.3 The QA-34 Form is to be initiated by the craft foreman for welding of structural members and cable tray, conduit or HVAC support members with thickness 1-1/2" or less, requiring only fillet or flare bevel welds, provided welds are not made to engineered embedded plates or strip plates with screwed-in studs. All others are initiated by the Discipline Engineer with weld procedures and mandatory holdpoints specified by the Welding Engineer.

Forms, in both cases, are then forwarded to the Welding QA/QC Specialist for review and designation of additional holdpoints, as needed.

- 6.4.4 The Welding QA/QC Specialist, or his designee, will verify the designated inspection and NDE holdpoints on the QA-34 Form and designate additional holdpoints, as needed.
- 6.4.5 Mandatory QC holdpoints for structural welds will be designated in accordance with References 3.1 1, 3.1 m, and 3.3 d as applicable.
- 6.4.6 Technical data changed, or additions made on the SWDR after review by QC, shall be initialed and dated by the craft foreman, or Welding Engineering as appropriate, and QC.
- 6.4.7 The QC Inspector will review the applicable installation drawings, Field Change Requests (FCR's) and Design Change Notices (DCN's) to ensure he understands the configuration and weld requirements. Any drawing problems such as missing, incorrect or confusing weld symbols shall be resolved through construction engineering prior to acceptance of the welds in question.

CAROLINA POWER & LIGHT COMPANY

CORPORATE QUALITY ASSURANCE DEPARTMENT

QA/QC - HARRIS PLANT SECTION

NUMBER

REVISION

CQC-19

3

TITLE:

WELD CONTROL

- 6.4.8 The QC Inspector will inspect the item in accordance with the approved drawing and other approved design documents. Acceptance of the welding will be withheld until all deviations from the approved design documents have been resolved through the Discipline Engineer.
- 6.4.9 The QC Inspector will verify the following during the initial weld inspection or prior to closing the SWDR, for any given hanger, support or structural component:
 - a. Weld types agree with drawings.
 - Qualification of welder(s) to the procedure and position.
 - c. Installed items are in a QA Accept status or Conditionally Accepted status. Material status is verified in accordance with Reference 3.1 q except pipe hangers which will be verified in accordance with Reference 3.1 1.
 - d. Tack welds used for fitup purposes are either removed or incorporated into the final weld.

(Special attention shall be given to the opposite side of the welded pieces.)

Any problems noted with an item will be handled as "inprocess" conditions unless it involves a pipe hanger in the final phase of the installation process, as described in Reference 3.2 r, in which case it will be handled as a nonconformance in accordance with Reference 3.1 d.

CAROLINA POWER & LIGHT COMPANY

CORPORATE QUALITY ASSURANCE DEPARTMENT

QA/QC - HARRIS PLANT SECTION

NUMBER

REVISION

CQC-19

1

TITLE: WELD CONTROL

- 6.4.10 After final inspection of pipe hanger inspection, the QC Inspector will review all documentation to ensure that filler plate and bridge plate welds were inspected and documented during subsequent inspections. If there is no evidence that the welds were inspected, then the welds will be inspected and documented during the final phase of inspection.
- 6.4.11 The QC Inspector shall monitor welding activities within his assigned area(s). Activities monitored will include, but not be limited to the following:
 - a. Fitup of non-full penetration joints (configuration, gap cleanliness). Enter on appropriate QA-34 Form.
 - b. Correct welding procedure and welding procedure specification is used and is being followed.
 - c. Qualification of welder to procedure and position.
 - d. Specified filler metal being used.
 - e. Preheat technique and temperature satisfactory. (Use temperature indicating crayon or contact pyrometer.)

Deficiencies noted with items b, c or d and any other deficiencies which cannot be corrected by routine rework shall be handled as nonconformances in accordance with Reference 3.1 d.

6.4.12 The QC Inspector shall perform the required visual inspections in accordance with Reference 3.1 i and initiate the NDE Request when the specified NDE holdpoints are reached.

CAROLINA POWER & LIGHT COMPANY

CORPORATE QUALITY ASSURANCE DEPARTMENT

QA/QC - HARRIS PLANT SECTION

NUMBER

REVISION

CQC-19

1

TITLE: WELD CONTROL

- Minor surface defects detected by visual inspection will be identified on the item by marking the defective areas with black marking ink and indicating the nature of the defects. The QC Inspector will check the appropriate "Reject" block on the SWDR (QA-34), but not initial and date. He shall then enter the quantitative data for the rejection in the deficiency/description block of the SWDR; initial and date. These are inprocess defects and not reported as nonconformances. After the deficiencies are corrected, and the weld has been reinspected and accepted, the QC Inspector will check the appropriate "Accept" block on the SWDR; initial and date.
- 6.4.14 When a weld is found to be rejectable by NDE, the QC Inspector will check the appropriate "Reject" block on the SWDR (QA-34), but not initial and date it. He shall then enter in the deficiency/description block of the SWDR "NDE Rejected", the date of the rejection; initial and date. He will forward a copy of the NDE Report to the Welding Engineer.
 - a. If the defect is in the weldment, rework is considered "in-process" and not reported as a nonconformance.
 - b. If the defect is noted in the base metal, it shall be handled in accordance with Reference 3.1 o.

When the deficiencies have been corrected by either the use of a Repair SWDR or by the re-establishment of the holdpoints on the original SWDR, the QC Inspector shall check the appropriate "Accept" block on the SWDR; initial and date it.

CAROLINA POWER & LIGHT COMPANY CORPORATE QUALITY ASSURANCE DEPARTMENT QA/QC - HARRIS PLANT SECTION

NUMBER

REVISION

LANT SECTION

CQC-19

2

TITLE:

. M. Jain.

415

WELD CONTROL

7.0 INSPECTION AIDS

The QC Inspector will utilize written Visual Welding Inspection Guidelines and visual inspection aids such as gauges, instruments, magnifying glasses (5% should be used; up to 10% may be used for final anomalies) and flashlights for weld inspections. Gauges and instruments shall be examined by the inspector for damage and wear prior to use. Those requiring calibration shall have a current calibration label as required by Reference 3.1 c.

8.0 DOCUMENTATION

8.1 ASME Class 1, 2 and 3

- 8.1.1 The QC Inspector shall assemble and submit the completed WDR/RWDR, NDE Reports and supporting documents to the Welding QA/QC Specialist.
- 8.1.2 The Welding QA/QC Specialist, or his designee, shall review the WDR/RWDR package for accuracy, completeness, legibility and identification. If satisfctory, he will sign and date the WDR/RWDR and forward it to the ANI.
- 8.1.3 The ANI will review the WDR/Repair WDR, sign and date it, if satisfctory, and return it to the Welding QA/QC Specialist.
- 8.1.4 The Welding QA/QC Specialist, or his designee, will assemble all the documents (i.e. WDR/Repair WDR's, PWHT Charts, NDE Reports and repair sketches) pertinent to the weld into a "WDR Package" mark it for filing and transmit it to QA Records in accordance with Reference 3.1 b.

CAROLINA POWER & LIGHT COMPANY

CORPORATE QUALITY ASSURANCE DEPARTMENT

QA/QC - HARRIS PLANT SECTION

NUMBER

REVISION

CQC-19

2

TITLE: WELD CONTROL

8.2 Seismic Category I

- 8.2.1 The QC Inspector shall assemble the documents pertinent to the welds listed on given QA-34 Form (i.e. QA-34 Form; Miscellaneous Steel Fabrication Requests, Exhibit 1 to WP-18; NDE Reports and PWHT Charts) in weld number order and submit to the Welding QA/QC Specialist.
- 8.2.2 The Welding QA/QC Specialist, or his designee, shall review the package for accuracy, completeness, legibility and identification. If satisfactory, he will sign and date the QA-34 Form, mark the package for filing and transmit it to QA Records in accordance with Reference 3.1 b.

8.3 Fire Protection and Radwaste and Category 7 Blowdown

- 8.3.1 If the final weld inspection is acceptable in accordance with Reference 3.1. h. The QC Inspector will submit the completed VT-1 Form to the QA/QC Specialist, or his designee. The marked-up isometric drawing will be retained in QC files.
- 8.3.2 The QA/QC Specialist, or his designee, shall review each QA VT-1 Form as it is presented to him for accuracy, completeness, legibility, and identification and transmit it to QA Records in accordance with Reference 3.1 b.

8.4 Fuel Pool Liner Welds

8.4.1 The QC Inspector shall assemble and submit the weld map, SWDR, NDE Reports and supporting documents to the QA/QC Specialist when the weld map has been completed in full.

CONTROLLED DOCUMENT—

CAROLINA POWER & LIGHT COMPANY

CORPORATE QUALITY ASSURANCE DEPARTMENT

QA/QC - HARRIS PLANT SECTION

NUMBER

REVISION

CQC-19

2

TITLE:

WELD CONTROL

8.4.2 The QA/QC Specialist, or his designee, shall review the weld map, SWDR package for accuracy, completeness, legibility and identification. He shall mark it for filing and transmit it to QA Records in accordance with Reference 3.1 b.

CAROLINA POWER & LIGHT COMPANY CORPORATE QUALITY ASSURANCE DEPARTMENT

VISUAL EXAMINATION OF SEISMIC I, STRUCTURAL AND HANGER WELDS (SHNPP)

NUMBER:

NDEP-605

RECOMMENDED FOR APPROV

NDE LEVEL III

NONDESTRUCTIVE EXAMINATION PROCEDURE

INITIAL ISSUE DATE:

October 20, 1982

APPROVED BY:

MANAGER - ESC DA/OC

QA-PC-1 Rev. 0

CAROLINA POWER & LIGHT COMPANY ENGINEERING & CONSTRUCTION QUALITY ASSURANCE SECTION

NONDESTRUCTIVE EXAMINATION MANUAL/PROCEDURE DEVIATION NOTICE

Affected	tle VISUAL EXAMINATION OF SEISMIC I, STRUCTURAL & HANGER WELDS (SHNPP)
Paragraphs	Description of Deviation
6.1	Add to end of sentence of paragraph 6.1: or other qualified program
	approved by the Level III.
- 15	
One time	e Condition; Deviation Notice to be closed as follows:
	nt Condition; revision to procedure in process.
he approval	of this Procedure Deviation Notice authorizes deviation from the name procethe limits described above.
	f the affected procedure shall retain this notice with the procedure until in the next procedure revision or until otherwise closed.
riginator:	Mgr. E & C QA Approval:
John wo of	curcha 1. 12/20/82 Telephone
	Memorandum
optoved:	Set 12/20/82

QA-PC-1 Rev. 1 5/83

CAROLINA POWER & LIGHT COMPANY

CORPORATE NDE UNIT

NONDESTRUCTIVE EXAMINATION MANUAL/PROCEDURE INTERIM CHANGE

Affected Paragraph	Description of Deviation
aragrapi.	Description of Deviation
3.7	Change to read: Ebasco design documents A: CAR-SH-BE-04A
	B: CAR 2165 A-003
9.0	Change to read: Evaluation shall be made in accordance with the following
	criteria for welds fabricated in accordance with Reference 3.1, except as
	modified by reference 3.7.B. See paragraph 4.0, Definitions, for specific
	details or discontinuities and acceptance limits except as modified by
	Reference 3.7.B as applicable, in this procedure.
One ti	me Condition; Interim Change to be closed as follows:
Permane	ent Condition; Revision to procedure in process.
Permana e approva	
Permane approva	ent Condition; Revision to procedure in process. I of this Procedure Interim Change authorizes deviaiton from the named procedure limits described above. Of the affected procedure shall retain this notice with the procedure until
Permanente approvation the holder of	ent Condition; Revision to procedure in process. I of this Procedure Interim Change authorizes deviaiton from the named procedure limits described above.
Permane approva thin the permane holder of acorporate riginators	ent Condition; Revision to procedure in process. I of this Procedure Interim Change authorizes deviaiton from the named procedure limits described above. Of the affected procedure shall retain this notice with the procedure until in the next procedure revision or until otherwise closed. Mgr. QA/QC Harris Plant Approval:
Permane e approvation the holder corporate iginator:	ent Condition; Revision to procedure in process. I of this Procedure Interim Change authorizes deviaiton from the named procedure limits described above. Of the affected procedure shall retain this notice with the procedure until in the next procedure revision or until otherwise closed.
Permane approvation that the holder corporate riginators	ent Condition; Revision to procedure in process. I of this Procedure Interim Change authorizes deviaiton from the named procedure limits described above. Of the affected procedure shall retain this notice with the procedure until in the next procedure revision or until otherwise closed. Magr. QA/CC Harris Plant Approval:
Permane the approvation of the holder of the corporate riginators.	ent Condition; Revision to procedure in process. I of this Procedure Interim Change authorizes deviaiton from the named procedure limits described above. Of the affected procedure shall retain this notice with the procedure until in the next procedure revision or until otherwise closed. Mgr. QA/CC Harris Plant Approval: Signature Telephone Approval Obtained By:
Permanente approvation the holder of holder of holder riginators.	ent Condition; Revision to procedure in process. I of this Procedure Interim Change authorizes deviaiton from the named procedure limits described above. The affected procedure shall retain this notice with the procedure until in the next procedure revision or until otherwise closed. Mgr. QA/CC Harris Plant Approval: Signature Telephone Approval Obtained By:

CAROLINA POWER & LIGHT COMPANY CORPORATE QUALITY ASSURANCE DEPARTMENT

NUMBER

REVISION

11

NDEP-605

TITLE: VISUAL EXAMINATION OF SEISMIC I, STRUCTURAL AND HANGER WELDS (SHNPP)

1.0 PURPOSE

The purpose of this procedure is to delineate the visual welding examination criteria for Seismic Class I structural weldments such as pire hangers, restraints, structural steel, HVAC ductwork, equipment, etc., at the Shearon Harris Nuclear Power Plant (SHNPP).

2.0 SCOPE

This procedure applies as applicable to welds fabricated in accordance with AWS D1.1, AWS D1.3 and other welding performed as directed by approved Engineering documents. This procedure may be utilized, when deemed by Engineering as appropriate, for visual examination of welds related to other codes specifications or safety related items. This precedure may be used for receipt inspection activities at SHNPP when required by other site documents or deemed appropriate by Engineering.

3.0 REFERENCES

- 3.1 AWS D1.1, Structural Welding Code, 1975 Edition.
- 3.2 AWS D1.3, Specification for Welding Sheet Metal in Structures, 1978 Edition.
- 3.3 CP&L Corporate QA Department Nondestructive Examination Manual.

CAROLINA POWER & LIGHT COMPANY CORPORATE QUALITY ASSURANCE DEPARTMENT

NUMBER

REVISION

NDEP-605

TITLE: VISUAL EXAMINATION OF SEISMIC I, STRUCTURAL AND HANGER WELDS (SHNPP)

3.4 SHMPP MP's

- A. MP-04 Procedure for Post Weld Heat Treatment
- B. MP-05 Permanent Marking of Site Material and Components
- C. MP-08 General Welding Procedure for Structural Steel (Seismic, Non-Seismic) and Hangers
- D. MP-10 Repair of Base Material and Weldments
- E. MP-17 General Welding Procedure for HVAC Duct System (Seismic, Non-Seismic)
- F. MP-21 Repair of Base Materials for HVAC Duct Systems (Siesmic, Non-Seismic

3.5 SHNPP Work Procedures

- A. WP-110 Installation of Safety Related (Seismic Class I)
 Pipe Hangers
- 3.6 SHNPP TP-04
- 3.7 Ebasco Specification CAR-SH-BE-04A

3.8 E&C QA/QC Procedures and Instructions

- A. CQC-2 Nonconformance Control
- B. CQC-6 Receiving Inspection
- C. CQC-19 Weld Control
- D. QCI-19.1 Preparation and Submittal of Weld Data Report, Repair
 Weld Data Report, Tank Fabrication Weld Record and
 Seismic I Weld Data Report
- E. QCI-19.2 Visual Inspection of Permanent Impression Stamping

3.9 SHMPP Site Specification

- A. 033 Structural Welding for Permanent Plant Construction
 B. 034 Nondestructive Examination, Visual Inspection, and
 Testing Requirements for Code Class 1, 2, 3, MC, Seismic
 and Non-Seismic Structures for Permanent Plant Construction.
- C. 040 Nuclear Safety Related and Seismic Class I Complex
 Embedded Steel & Related Items Requiring NDE or PWHT for
 Permanent Plant Construction

CAROLINA POWER & LIGHT COMPANY CORPORATE QUALITY ASSURANCE DEPARTMENT

NUMBER

REVISION

MDEP-605

TITLE: VISUAL EXAMINATION OF SEISMIC I, STRUCTURAL AND HANGER WELDS (SHMPP)

3.10 "Arc Strike Evaluation" Instructions

3.11 AWS 3.0 - 80 Welding Terms and Definitions

4.0 DEFINITIONS

The following are definitions of words and terms used in this procedure. Definitions of weld discontinuities are to be used by the Visual Examiner to aid in determining the type of discontinuity and, when applicable, the acceptable limits of discontinuities. They are intended to aid the Visual Examiner in determining acceptable limits of discontinuities as well as establish a unified definition of the discontinuities and other words, as used in this procedure. Definitions found in Reference 3.0 shall also be used.

Site Documents - Drawings, engineering and site specifications, construction and examination procedures/instructions, engineering documents and other approved documents as referenced by these documents, as applicable.

Weld Spatter - The metal particles expelled during welding and which do not form a part of the weld. Weld spatter that resists vigorous wire brushing shall be acceptable provided it is not on a faying surface and/or will not inhibit the performance of required NDE.

Porosity - Cavity type discontinuities formed by gas entrapment during solidification. Acceptable limits are as given in the applicable part of this procedure.

Slag Inclusions or Flux Coatings - Non-metallic inclusion on or embedded in the surface of weldments.

Undercut - Excessive melting of the base metal at or near the toe of the weld.

Overgrind - Excessive grinding that reduces the weld/base metal below the minimum thickness required. Overgrind is unacceptable.

Tungsten Inclusion - Tungsten that is embedded in the weldment due to the tungsten electrode (GTAW Process) contracting the weldment and breaking off. Tungsten inclusions are unacceptable.

CAROLINA POWER & LIGHT COMPANY CORPORATE QUALITY ASSURANCE DEPARTMENT

NUMBER

REVISION

NDEP-605

TITLE: VISUAL EXAMINATION OF SEISMIC I, STRUCTURAL AND HANGER WELDS (SHNPP)

Overlap - The protrusion of weld metal beyond the toe, face, or root of the weld. Any overlap is unacceptable.

Arc Strike - A discontinuity consisting of any localized remelted metal, heat affected metal, or change in the surface profile of any part of a weld or base metal resulting from an arc. Arc strikes may be caused by welding electrodes, weld machine ground clamp or magnetic particle prodicontacts. Unless otherwise specified by Nuclear Power Construction Department Engineering, no arc strikes are allowed.

5.0 PROCEDURE QUALIFICATION

5.1 Nondestructive Examination Procedure Qualification Record, No. PQR-605 describes the actual qualification activity for this procedure.

6.0 PERSONNEL QUALIFICATION

6.1 Personnel performing visual examinations in accordance with this procedure shall meet qualification requirements as specified in Carolina Power & Light Company Corporate QA Procedure NDEP-10.

7.0 EQUIPMENT

- 7.1 The following equipment may be used to aid the Visual Examiner in his evaluation of items being examined:
 - 7.1.1 Flashlight or other illuminating device that provides adequate lighting as described in 7.2.

CAROLINA POWER & LIGHT COMPANY CORPORATE QUALITY ASSURANCE DEPARTMENT

NUMBER

REVISION

NDEP-605

TITLE: VISUAL EXAMINATION OF SEISMIC I, STRUCTURAL AND HANGER WELDS (SHMPP)

- 7.1.2 Cambridge Weld Gauge
- 7.1.3 6" Ruled Scale
- 7.1.4 Magnifying Glass
- 7.1.5 Boroscope and Fiber Optics
- 7.1.6 Fillet Weld Gauges
- 7.1.7 Mirrors
- 7.1.8 Optical Comparators
- 7.1.9 Micrometers
- 7.1.10 Depth Gauges
- 7.1.11 Other equipment may be used as necessary, but will be required to meet the conditions of 7.2 and 7.3, if applicable.

7.2 Illumination

Visual examination shall be performed in an area illuminated with flashlight or other auxiliary lighting to attain a minimum of 15 foot candles (160 Lux) for general examination and a minimum of 50 foot candles (540 Lux) for the detection or evaluation of small anomalies, unless otherwise specified.

7.3 Optical Aids

- 7.3.1 When optical aids such as boroscope, magnifying glass, mirror etc., are used for remote examination, the system shall have a resolution capability equivalent to or better than that obtained by direct observation.
- 7.3.2 When use of optical aids is specified, optical aids shall have a minimum power of magnification called out in the specification, code or procedure. Lighting and resolution shall be verified either at the examination point or verified prior to the actual examination under simulated conditions.

7.4 Mechanical Aids and Instruments

7.4.1 Mechanical aids used for examinations shall have graduated scales in useable increments that are easily discernable.

CAROLINA POWER & LIGHT COMPANY CORPORATE QUALITY ASSURANCE DEPARTMENT

NUMBER

REVISION

MDEP-605

TITLE: VISUAL EXAMINATION OF SEISMIC I, STRUCTURAL AND HANGER WELDS (SHNPP)

7.4.2 Dial depth gauges, micrometers, optical comparators and other precision mechanical measuring devices used for final acceptance examinations shall be calibrated in accordance with Reference 3.6.

7.4.3 Rules, scales, gauges such as cambridge and fillet and other measuring devices used to aid the visual examiners shall be reasonably accurate but do not require calibration.

8.0 EXAMINATION

8.1 General

- 8.1.1 Visual examinations shall normally be performed without magnification. The examination shall be such that the surface to be examined is within 24" of the eye, and at an angle not less than 30° to the surface to be examined.
- 8.1.2 Visual examination performed using optical equipment shall be performed only when required by site documents or Engineering using equipment that conforms to 7.3. Magnifiers may be used to aid in the evaluation of discontinuities detected during the visual examination.
- 8.1.3 When remote visual examination must be performed in lieu of direct visual examination, the visual aid(s) shall be in accordance with Paragraph 7.3.
- 8.1.4 When using remote visual equipment, the technique used shall be verified for resolution and lighting capabilities prior to use by resolving a 1/32" black line on an 18% neutral gray card. This verification may either be done at the point of examination or under simulated conditions expected to be encountered during the examination.

8.2 Visual Examination

8.2.1 Visual examinations shall be performed when required by site documents or when the appropriate holdpoints are reached on Seismic I Weld Data Reports (SWDRs).

CAROLINA POWER & LIGHT COMPANY CORPORATE QUALITY ASSURANCE DEPARTMENT

NUMBER

REVISION

MDEP-605

TITLE: VISUAL EXAMINATION OF SEISMIC I, STRUCTURAL AND HANGER WELDS (SHNPP)

8.2.2 This examination shall also verify the suitability of the surface for subsequent NDE. If the examiner determines that the surface will inhibit the proper interpretation of NDE, he/she will mark the areas for subsequent rework.

8.3 Examination Points

Items to be examined at a particular stage of fabrication when specified by site procedures are listed in Attachment A.

9.0 EVALUATION

9.1 Evaluations shall be made in accordance with the following criteria for welds fabricated in accordance with Reference 3.1. See paragraph 4.0, Definitions, for specific details of discontinuities and their acceptable limits, as applicable, in this procedure.

9.1.1 Prefitup Examination

9.1.1.1 Cleanliness of Joint

- a. Surfaces to be welded and surfaces adjacent to a weld (within 1" of where the toe of the weld will be) shall be free from loose or thick scale, slag, rust, moisture, grease and other foreign material that would prevent proper welding or produce objectionable fumes. Mill scale and rust that can withstand vigorous wire brushing, a thin rust-inhibitive coating (such as deoxaluminate paint), or antispatter compound may remain with the following exception: for girders, all mill scale shall be removed from the surfaces on which flange-to-web welds are to be made by submerged arc welding or by shielded metal arc welding with low hydrogen electrodes.
- b. The surfaces of base metal one inch adjacent to the weld joint prior to welding need only be cleaned of those loose materials which may fall into the molten weld metal and coatings which, due to fumes caused by heating or burning, could leave a harmful residue in the weld. Tight adhering rust which has been cleaned with a hand wire brush shall be permissible but all paint, grease, or other coatings with the exception of deoxaluminate should be removed.

CAROLINA POWER & LIGHT COMPANY CORPORATE QUALITY ASSURANCE DEPARTMENT

NUMBER

REVISION

NDEP-605

TITLE: VISUAL EXAMINATION OF SEISMIC I, STRUCTURAL AND HANGER WELDS (SHNPP)

c. Deoxaluminate paint can remain on the base metal and the prepped edges and surfaces to be welded. If rust appears where deoxaluminate paint has been applied to the prepped edges and surfaces to be joined by welding, it shall be removed; however, if rusting appears on the base metal within the area one inch from the weld prepped edges, only wire brushing of these areas is necessary to remove any loose particles which could fall into the molten weld metal during welding of the joint. Surfaces on the base metal, due to corrosion, may contain pitting. Wire brushing of these surfaces is adequate to remove loose rust scale without removing tightly adhering rust oxide film from the pits.

9.1.1.2 Joint Weld End Prep

a. Joint weld end prep and dimensional configuration shall be in accordance with applicable site documents.

b. Discontinuities in excess of those outlined in Table 1 of Attachment A shall be repaired as required by Table 1 of Attachment A and/or other appropriate site procedures.

c. Discontinuities in excess of 1" long and 1" deep shall be repaired prior to welding in accordance with Table 1 of Attachment A and/or other appropriate site

documents.

CAROLINA POWER & LIGHT COMPANY CORPORATE QUALITY ASSURANCE DEPARTMENT

NUMBER

REVISION

HDEP-605

TITLE: VISUAL EXAM NATION OF SEISMIC I, STRUCTURAL AND HANGER WELDS (SHNPP)

9.1.2 Fitup Examination

9.1.2.1 Cleanliness

a. Surfaces shall meet the requirements of Paragraph 9.1.1.1.

9.1.2.2 Joint Dimensions and Tolerances

- a. Dimensions (bevel angle(s), root opening, root face, etc.) shall be in accordance with the drawing or applicable Welding Procedure Specification (WPS).
- b. Butt welds shall not be offset more than 10% of the thickness of the thinner member being joined or 1/8", whichever is less.
- c. Parts may be drawn to a slope of 1/2" in 12" maximum, to correct misalignment.
- d. Measurement of offset is from the center line of the parts to be joined.
- e. The cross section of groove welded joints shall not exceed the tolerances of Table 2 of Attachment A.

9.1.2.3 Material Identification

a. The filler, base and backing materials (when applicable) shall be examined in accordance with Reference 3.8c.

9.1.2.4 Tack Welds

- a. Tack welds shall be free from the same discontinuities as final welds.
- b. Multiple pass tack welds shall have cascaded ends.
- c. Tack welds for fitup can be left in the as-welded condition, when practical, except that the ends may need to be feathered by grinding to ensure adequate tie-in with subsequent weld passes.

CAROLINA POWER & LIGHT COMPANY CORPORATE QUALITY ASSURANCE DEPARTMENT

NUMBER

REVISION

NDEP-605

TITLE: VISUAL EXAMINATION OF SEISMIC I, STRUCTURAL AND HANGER WELDS (SHNPP)

9.1.3 Completed Weld Examination

9.1.3.1 Undercut/Overgrind

- a. Undercut in excess of 0.01" deep when the weld is transverse to the primary stress in the part that is undercut shall be unacceptable.
- b. Undercut shall not exceed 1/32" deep in a weld that is parallel to the primary stress in the part that is undercut.
- c. Overgrind which can result in notch-like grooves shall not exceed 1/32". Grinding should not reduce thickness below acceptable thickness and should be gradual faying or blending with surrounding area.
- 9.1.3.2 Coatings should be no closer than approximately 1/2" from the toe of the weld. Additional removal of coatings may be required so that NDE examinations and/or visual examinations may be performed.

9.1.4 Weld Profiles

9.1.4.1 Fillet Welds

a. Fillet Welds with profiles in excess of Fig. 1 shall be unacceptable.

9.1.4.2 Groove Welds

- a. Groove weld profiles shall be as stated by applicable site documents.
- b. Butt and corner joints with groove welds shall have a maximum reinforcement of 1/8".

9.1.4.3 Butt Welds

a. Surfaces of butt welds shall be as required by applicable site documents.

9.1.5 Impression Stamping

9.1.5.1 Impression stamping required by site documents shall be examined in accordance with Reference 3.8e.

CAROLINA POWER & LIGHT COMPANY CORPORATE QUALITY ASSURANCE DEPARTMENT

NUMBER

REVISION

NDEP-605

TITLE: VISUAL EXAMINATION OF SEISMIC I, STRUCTURAL AND HANGER WELDS (SHIPP)

9.1.6 Unacceptable Weld Discontinuities

- 9.1.6.1 Welds shall be examined for freedom from slag, cracks, and incomplete fusion.
- 9.1.6.2 Craters must be filled to the full cross section of the weld.
- 9.1.6.3 Welds not meeting the acceptable profiles of Fig. 1 shall be unacceptable.
- 9.1.6.4 Piping porosity in fillet welds shall not exceed one porosity hole in 4" length of weld nor shall the diameter be larger than 3/32" except for fillet welds connecting stiffeners to webs, the sum of the diameters of piping porosity shall not exceed 3/8" in any linear inch of weld nor 3/4" in any 12" length of weld.
- 9.1.6.5 Groove welds shall be free of piping porosity.

 Linear, random scattered and clustered porosity shall be acceptable, independent of the criteria for piping porosity, provided that all pores have a greatest dimension of less than 1/16" and the sum of their greatest dimension does not exceed 3.8" in any linear inch of weld (example: A cluster of porosity with twelve (12) pores each of which has a greatest dimension of 1/32 inch or less would be acceptable 12 x 1/32" = 12/32" = 3/8" provided there was no other porosity linear, random scattered and/or clustered within the one linear inch of weld.).
- 9.1.6.6 Fillet weld size may be 1/16" less than the nominal size required provided the undersized area does not exceed 10% of the length of the weld.
- 9.1.6.7 On web-to-flange welds on girders, no underrun in the required fillet weld size is permitted at the ends for a length equal to twice the width of the flange.

CAROLINA POWER & LIGHT COMPANY CORPORATE QUALITY ASSURANCE DEPARTMENT

NUMBER

REVISION

MDEP-605

TITLE: VISUAL EXAMINATION OF SEISMIC I, STRUCTURAL AND HANGER WELDS (SHMPP)

- 9.1.7 Defect removal/repair shall be examined by the Visual Examiner to ensure the following:
 - Defects listed below in welds shall be removed by approved means outlined in applicable site documents.
 - Cracks found in weld or base material shall be removed completely as well as 2" of sound metal beyond each end of the crack prior to rewelding.
 - Incomplete fusion and unacceptable porosity and slag shall be removed completely.
 - 4. Excessive concavity, undercutting, craters and undersized welds shall be suitably prepared and additional weld metal deposited.
 - 5. Overlap and excessive convexity shall be removed to acceptable limits.
- 9.2 The visual Examiner shall evaluate each required holdpoint in accordance with the following criteria for welds fabricated in accordance with Reference 3.2.
 - 9.2.1 Welds are acceptable if they meet all the following requirements:
 - a. No cracks are present
 - b. Square groove, arc spot and arc seam welds must have at least 1/32" reinforcement.
 - c. Undercut/overgrind does not exceed 10% of the thickness.
 - d. Faces of fillet welds shall be flat or slightly convex.

CAROLINA POWER & LIGHT COMPANY CORPORATE QUALITY ASSURANCE DEPARTMENT

NUMBER

REVISION

MDEP-605

TITLE: VISUAL EXAMINATION OF SEISMIC I, STRUCTURAL AND HANGER WELDS (SHIPP)

10.0 MARKING OF INDICATIONS

10.1 Marking of rejectable indications shall be marked on the weld or base material, as applicable, using site approved marking materials.

11.0 DOCUMENTATION

- 11.1 Document performance of visual examination on the Seismic I Weld Data Report (Form QA-34). After the inspection items is accepted, check off the appropriate status, initial and date.
- 11.2 For visual examinations of HVAC hangers, the Visual Examiner shall sign the appropriate slot signifying visual acceptance of the weld.

CAROLINA POWER & LIGHT COMPANY CORPORATE QUALITY ASSURANCE DEPARTMENT

NUMBER

REVISION

NDEP-605

TITLE: VISUAL EXAMINATION OF SEISMIC I, STRUCTURAL AND HANGER WELDS (SHNPP)

ATTACHMENT A - EXAMINATION POINTS

		STRUC. JOINTS	SHEET METAL WELDS	
1.0	PRIOR TO FIT-UP	Х		
	a. Joint Scarf/Bevel Cleanliness (oxides, rust, dirt, etc) b. Cleanliness of External Surface(s) Adjacent to Weld c. Cleanliness of Backing Strip d. Joint End Prep Dimensional Configuration and Finish e. Freedom from Joint Surface Defects f. Removal/Repair of Joint Defects	X X X X X		
2.0	FIT-UP	Х		
	a. Joint Cleanliness b. Fit-Up Dimensions (i.e. root opening, clearance, etc.) c. Joint Alignment and Offset d. Component Identification and Heat Numbers e. Tack Welds	X X X X		
3.0	EXTERNAL SURFACE AFTER COMPLETION OF WELD	Х	t	
	 a. Weld Profiles b. Undercut or Overgrind c. Suitability of Surface for Required NDT (i.e. removal of weld spatter, arc strikes, etc.) d. Peening e. Joint Identification f. Fillet Size g. Blending Base Metal h. Freedom from Unacceptable Discontinuities i. Impression Stamping j. Removal/Repair of Defects 	X X X X X X X X	X X	

ATTACHMENT A

Table I -Limits on acceptability and the repair of cut-edge discontinuities of plate

Description of discontinuity	Plate repair required	
Any discontinuity 1 in. (25.4 mm) in length or less	None — need not be explored	
Any discontinuity over 1 in. (25.4 mm) in length and 1/8 in. (3.2 mm) maximum depth	None, but the depth should be explored	
Any discontinuity over 1 in. (25.4 mm) in length with depth over 1/8 in. (3.2 mm) but not greater than 1/4 in. (6.4 mm)	Remove, need not weld	
Any discontinuity over 1 in. (25.4 mm) in length with depth over 1/4 in. (6.4 mm) but not greater than 1 in.	Completely remove and weld. Aggregate length of welding shall not exceed 20 percent of the length of the plate edge being repaired	
Any discontinuity over 1 in. (25.4 mm) in length with depth greater than 1 in.	Sœ Notes 1 thru 4	

'A spot check of ten percent of the discontinuities on the oxygen-out edge in question should be explored by grinding to determine depth. If the depth of any one of the discontinuities explored exceeds 1/8 in. (3.2 mm) then all of the discontinuities remaining on that edge shall be explored by grinding to determine depth. If none of the discontinuities explored in the ten percent spot check have a depth exceeding 1/8 in. (3.2 mm), then the remainder of the discontinuities on that edge need not be explored.

(1) Where discontinuities such as (W), (X), or (Y) in Fig. .2. are observed prior to completing the joint, the size and shape of the discontinuity shall be determined by ultrasonic testing. The area of the discontinuity shall be determined as the area of total loss of back reflection, when tested in accordance with the procedure of ASTM A435.

(2) For acceptance, the area of the discontinuity (or the aggregate area of multiple discontinuities) shall not exceed four percent of the plate area (plate length x plate width) with the following exception: if the length of the discontinuity, or the aggregate width of discontinuities on any transverse section, as measured perpendicular to the plate length, exceeds 20 percent of the plate width, the four percent plate area shall be reduced by the percentage amount of the width exceeding 20 percent. (For example, if a discontinuity is 30 percent of the plate width, the area of discontinuity cannot exceed 3.6 percent of the plate area.) The discontinuity on the cut edge of the plate shall be gouged out to a depth of 1 in. (25.4 mm) beyond its intersection with the surface by chipping, air carbon are gouging, or grinding, and blocked off by welding with the shielded metal are process in layers not exceeding 1/8 in. (3.2 mm) in thickness.

(3) If a discontinuity, (Z), not exceeding the allowable area in para. 2 is discovered after the joint has been completed and is determined to be 1 in.




Table II -Edge discontinuities in cut plate.

(25.4 mm) or more away from the face of the weld, as measured on the plate surface, no repair of the discontinuity is required. If the discontinuity (Z) is less than 1 in. away from the face of the weld, it shall be gouged out to a distance of 1 in. from the fusion zone of the weld by chipping, air carbon are gouging, or grinding. It shall then be blocked off by welding with the shielded metal are process for at least four layers not exceeding 1/8 in. (3.2 mm) in thickness per layer.

(4) If the area of the discontinuity (W), (X), (Y), or (Z) exceeds the allowable in para. 2 the plate or subcomponent shall be rejected and replaced, or repaired at the discretion of engineering.




Fig. I -Acceptable and unacceptable weld profiles.

JUSTIFICATION

AWS D1.1 STRUCTURAL WELDMENTS INSPECTION CRITERIA MODIFICATIONS

SCOPE

This is prepared to provide a weld zone visual inspection criteria for structural weldments designed to AISC and AWS Dl.1 requirements.

INTRODUCTION

The need for modification of D1.1 weldments workmanship inspection criteria became apparent following realization that industry conventional fabrication methods, when applied according to procedures used since the inception of joining metals by welding, are not capable of meeting requirements. This occurred because the inspection process philosophy has changed from rejection/ acceptance decisions based upon experience, to the present literal adherence to AWS D1.1 criteria. This has caused a five fold or even greater increase in the number of repair required defect citations to emanate from the inspection process. There is universal agreement among Materials Specialists that a defects repair effort of this magnitude can cause a new set of workmanship and metallurgical problems. This deleterious-to-service-life possibility may have been recognized by the AWS Committee on Structural Steel Welding, which stated in their 1982 Commentary on AWS D1.1, that "the fundamental premise of the Code is to provide general stipulations applicable to any situation and to leave sufficient latitude for the exercise of engineering judgements". Recourse to this statement is being taken for the ensuing changes, which reflect careful consideration of manually applied fabrication methods, their capability for meeting present inspection acceptance criteria, viz-a-viz their effect on the mechanical properties of material and the intended service conditions.

PROBLEM DEFINITION

A detailed review of the inspection results of fillet welds in various shop fabricated power plant components and the re-inspection results of a 200 unit sample of construction site installed pipe hangers has shown that the majority of those welds requiring rework were found deficient because of (a) incomplete fusion, (b) insufficient weld throat, (c) weld overlap, and (d) weld zone undercut. The significance of these defects for other than aesthetic purposes appears negligible, owing to the short, less than 1/4 inch length for an overwhelming majority. Causes for such weld defects, their impact on service performance and the rationale for development of a reasonable and technically adequate inspection criteria is given in the following sections.

WELD ZONE DEFECTS, THEIR SIGNIFICANCE AND OCCURRENCE PROBABILITY


Incomplete Fusion - This term describes a weld zone region within which the desired coalescence of base metal and weld metal did not take place, owing to the absence of complete melting. Areas of non-fusion cannot be ascertained with certainty when evaluating welded components designed to AMS D1.1 because of the visual inspection method used in the judgement process. For this reason a meaningful inspection process must employ circumstantial evidence, such as postulated and actual temperatures at the welding arc, as well as other arc characteristics, weld are manipulation by the workman and the physical properties of metals.

The single most important practice for properly welded components achievement is the control imposed by Dl.1 on the welding procedure, and the performance test which all welders must execute satisfactorily. These are the prime industry accepted safeguards for prevention of incomplete melting. In addition,

WELD ZONE DEFECTS, THEIR SIGNIFICANCE AND OCCURRENCE PROBABILITY (Cont'd)

Incomplete Fusion - (Cont'd)

the energy release at the welding arc, which produces a reported weld zone temperature of 10,000°F, well above the nominal 2700°F melting temperature of steel is another built in safeguard against non-fusion. These temperature differences provide forgiving conditions which allow considerable latitude for welder arc manipulation variations which might otherwise indeed cause weld zone fusion difficulty. Furthermore, the molten weld metal droplets transferring across the weld arc are at steel vapor temperature, 5200°F. It can be seen, that given the above temperatures, the risk of non-fused regions for a weld run length of 1/2 inch or more, is remote. A pictorial example of the onset of a possible non-fused region is shown by the arc reignition condition of Figure A.



Arc Ignition


Figure A presents conditions which will not assure achievement of

the desired base metal-weld metal coalescence, owing to the considerable thermal quench of the work piece at arc ignition. However, the thermal imbalance occurs for a very short time, because of the extremely high welding arc energy release. Minimal concern has been accorded lack of fusion presence at the weld arc reignition points of components which were constructed of nominally 60,000 psi tensile strength steel.

Figure B, represents conditions which exist along the weld run. Note the absence of risk for non-fused areas, owing to the high welding arc energy release. There are improper techniques which can cause lack of fusion to occur along the weld run shown by Figure B, presented in the ensuing section and identified as weld overlap by the industry.


Weld Overlap - This condition is shown by Figure C, which can occur during arc ignition or when a large single pass fillet weld is deposited in the horizontal position. Unfortunately, the Dl.1 exclusion of preheat when single pass welds are employed encourages fabricators to proceed with one pass welds procedures. The avoidance of preheat by application of the single pass 5/16" fillet weld can cause the gravity induced rollover of liquid metal, followed by the occurrence of overlap. It must be noted however, that this happens after base metal/weld metal melting has taken place. It follows that the superheated weld metal in contact with base metal will cause

melting and coalescence before the gravity induced rollover takes place. For this reason, overlap such as in Figure C is not considered detrimental, provided the required weld size is achieved. A classic example of another weld overlap condition, produced when the welding methods and parameters specified by D1.1 are not applied, is shown by Figure D, below.



GRAVITY INDUCED OVERLAP

Figure C



CAUSES ARE: LOW ARC ENERCY IMPROPER ARC MANIPULATION DIRTY BASE METAL

Figure D

The condition shown by Figure D can be present along either joint member, thus differing from the gravity induced condition of Figure C. Causes for the Figure D profile are improper weld conditions or base metal uncleanliness. Welds as shown by Figure D are the result of welder inattention or improper training Such defective weld zone regions, by nature of their cause are never only short segments of a weld run, rather they occur continuously along a major portion of a weld run length. Although

Figure C and D profiles are treated as one by many inspectors, there is a distinct recognizable difference, as shown by the profiles, the important feature being the region of the arrows. These differences are often not included in the inspection process.

Insufficient Weld Throat - Weld throat is the plane which bisects the 90° angle of a fillet weld (Figure E). Fillet weld size is specified by the amount of weld metal attached to each joint member (the fillet weld leg). However, the weld throat dimension, which is about 30% less than the leg size, is the important parameter because the majority of the working stresses on fillet welds are shear mode; along the weld throat plane.




Figure E

A 1/16" undersize fillet reduces the weld size (and the weld throat dimension) by 12.5% for a 1/2" weld and 25% for a 1/4" weld, this change theoretically increasing the stress proportionally.

These values are tabulated in Table 1, below.

Table I

Fillet Weld Size	Throat Dimension Full Weld Leg Size	Throat Dimension 1/16" Undersize Weld	Effective Throat Decrease	Applied Stress Increase
1/4"	.177"	.132"	25	33.3
5/16"	.221"	.177"	20	25.0
3/8"	.265"	.221"	16.7	20.0
1/2"	.354"	.309"	12.5	14.3

The two areas of concern in an undersize weld are the increase in stress in the throat of the weld and the increase in stress in transmitting the load through the weld into the base metal. Since weld metal is generally of higher strength than its minimum specified tensile strength, (72,000 psi), rarely only meeting this minimum value, its ability to tolerate a theoretical increase in stress for short lengths is not unreasonable. In like manner the base metal is generally of higher yield strength than the minimum ascribed 36,000 psi, this strength further increased by the thermal cycle imposed on the weld heat-affected zone, so that its ability for tolerating a theoretical increase in stress for short lengths of undersize is also not unreasonable, the overstress expected to be redistributed without danger of failure. The result of a short run undersize weld correction is the risk of component quality degradation, this condition believed to be more deleterious to service performance than a relatively small overstress for short lengths of an overall weld length.

Weld Zone Undercut - This condition is caused by melting away of base metal at the toe of a weld. Undercut is considered harmful

Weld Zone Undercut - (Cont'd)

to weldment service life because its cross sectional geometry is considered to be a "v" - shaped depression, as well as causing a reduction of base metal cross section, this configuration creating a stress raiser.

Stringent inspection attention is accorded to undercut by the fabrication industry. A major reason for this concern is the widespread belief that the root region of the undercut notch will be the origin of cracks, which grow when exposed to service induced fluctuating stresses. This concept for crack propagation has persisted, despite universal agreement among those expert in materials behavior that the degree of sharpness of a notch which can initiate a slowly propagating crack must be several orders of magnitude sharper than the radius at the root of a typical weld undercut caused by arc melting. Although neither sharp nor rounded undercut root radii are desirable weld zone profiles, the rounded root radius, which is a direct result of the weld zone melting process, is the more forgiving and will permit stress redistribution without apparent distress.

This difference in the crack initiation behavior of varying notch-root radii is not given proper consideration during the inspection process. The problem is compounded when strict adherence to described or sketched weld zone profile inspection procedures are used. The result of such inattention is the initiation of extensive weld upgrading efforts. This practice must be given much more attention because the risk for weld zone

deterioration, always present during weld upgrading activity, increases appreciably when a larger-than-normal scale upgrading effort is initiated.

An investigation, designed to examine the shape of severely undercut weld zones and the effect of the notch on uniaxial tensile properties was conducted to provide data concerning the mechanical behavior of steel which contained weld undercut. Details describing test sample preparation, photos and mechanical property test results are presented in the Appendix of this report. Except for two (2) samples which broke at the undercut, the balance failed in the base metal, outside the weld heat-affected zone. One reason for the tensile test results of the undercut samples is that following initial local yielding at the undercut root, this region is constrained from further yielding by surrounding elastic material. Relocation of the energy absorption region for further yielding improves the load carrying capability of the undercut region. It will be noted that the sole conclusion of the evaluation is that weld undercut to nominal 1/16" depth can be present in steel produced to a specified tensile strength of 60,000 psi for relatively short lengths, and that this condition will not be detrimental to service performance.

Porosity - Steel weld metal porosity is almost always caused by inadequate shielding of the welding arc, as will occur when welding is performed in an air draft of 3 to 5 miles/hour. This condition can cause the nitrogen in air to be introduced into the weld arc, causing porosity when sufficient nitrogen is present. Another source of nitrogen is paint. Hydrogen also causes steel

WELD ZONE DEFECTS, THEIR SIGNIFICANCE, ETC. (Cont'd)

weld metal porosity, this constituent usually introduced by oil and grease, generally present in weld zone regions as a surface film.

It can be seen that only a minor amount of nitrogen or hydrogen can be introduced into the weld arc under ordinary conditions, by nature of the form of the contaminant. It follows that the extent of the porosity, which results because molten steel weld metal solidifies before all the gas has issued from the liquid weld metal, is not as severe as is assumed by pore acceptance criteria, which treats all pores as extending through the entire weld deposit thickness. A modification of the degree of porosity acceptance in structural weldments is warranted per the above.

<u>Unfilled Weld Craters</u> - The reduced throat thickness caused by this condition precludes its acceptance in grooved butt and full or partial penetration Tee welds. For reasons given earlier for insufficient weld throat, a 1/16" deep, smooth surface crater is not considered deleterious in fillet welds.

Cracks - These defects contain sharp edges at extremities. For this reason they must be removed to sound metal and rewelded.

Arc Strikes - This condition is caused by inadvertent arcing between the welding electrode and the base metal, causing a small amount of base metal melting in the arc impingement region. More than ordinary attention is given this region in steel because of its hardness and its reported propensity for cracking. An extensive penetrant evaluation was conducted to examine crack occurrence in the arc strike regions of steel produced to a

WELD ZONE DEFECTS, THEIR SIGNIFICANCE, ETC. (Cont'd)

specified tensile strength of 60,000 psi. No cracks were found, which indicates that the material is sufficiently tough and only moderately hardenable when subjected to the high cooling rates of an arc strike heat affected zone. This study indicates that arc strikes, left inadvertently in steel produced to a specified tensile strength of 60,000 psi can be disregarded.

SUMMARY

A description and causes for the eight (8) most common weld zone defects have been provided for understanding defects formation and occurrence probability, so as to serve as base for visual inspection criteria modification and application.

CRITERIA DEVELOPMENT

Our review of various welded component workmanship rejections has shown that an overwhelming majority were the result of undersize welds and weld zone undercut.

Undersize Weld - This term is considered here as applicable to four reject conditions, incomplete fusion, insufficient weld throat, weld overlap and unfilled weld crater. Since the amount of base metal attachment by weld metal is affected by all, each of these conditions cause the shear strength of a fillet weld to be reduced.


The method by which an undersize weld judgement is made is misleading, because the weld leg size, not the weld throat is used for its determination, even though the weld throat is used

CRITERIA DEVELOPMENT (Cont'd)

Undersize Weld - (Cont'd)

for shear stress calculation. This overemphasizes the loss in shear stress capability of the fillet weld, because the weld throat is smaller than the weld leg by a factor of 30%. Furthermore, the throat dimension change decreases as the fillet weld increases, this behavior also affecting shear stress as shown by the curve presented below:

LONGITUDINAL SHEAR STRESS VS INCREASED FILLET SIZES



- A Shear stress on full size welds when AISC allowable load applied.
- B Shear stress on 1/16 inch undersize welds for full length - AISC allowable load unchanged.
- C Shear stress on 1/16 inch undersize welds for 25% the full weld length. AISC allowable load unchanged.

CRITERIA DEVELOPMENT (Cont'd)

Undersize Weld - (Cont'd)

The effect on shear stress increase of a 1/16 inch undersize weld which extends along 25% of a weld run, when the AISC allowable load is unchanged, is as follows:

1/4" weld - 1383 psi increase 3/8" weld - 928 psi increase 5/16" weld - 1083 psi increase 1/2" weld - 798 psi increase

Recognition should be given to the method used by the AISC in establishing the stress allowable for base metal and weld metal. The base metal allowable shear stress has been set as $0.4 \times 36,000$ (A36 min yield strength); 14,400 psi for ASTM A36. Weld metal allowable stress is determined by 0.3 min tensile strength - which for E7018 electrodes is 72,000 psi - $0.3 \times 72,000$; 21,600 psi. This relation may be inappropriate because a common base is not used for weld metal and base metal.

Selecting yield stress for this purpose, the minimum specified yield strength of E7018 weld metal is 60,000 psi. The stress allowable according to the 40% minimum yield stress concept used for base metal would be 0.4 x 60,000; 24,000 psi. This corresponds to a stress allowable difference of 9,600 psi between weld metal and base metal, about 7 times the increased stress of nominal 1,400 psi for welds which are undersize by 1/16 inch over 25% of the full weld length as discussed above.

Recognition of the substantial allowable stress overmatch which has been accorded weld metal, its well known superior ductility and notch toughness mandates the imposition of more realistic workmanship acceptance criteria, such as the proposed acceptance of fillet welds which are 1/16 inch undersize for 25% or less of a weld run length.

CRITERIA DEVELOPMENT (Cont'd)

<u>Undercut</u> - The limited investigation reported in the attached Appendix has shown that weld undercut up to 1/16 inch deep, in steels produced to a maximum specified tensile strength of 60,000 psi, is not deleterious to tensile strength.

The test samples were undercut full length and stressed transverse to weld direction. Undercut depth to 1/16 inch extending over 25% of a weld run length is proposed here in recognition of the satisfactory tensile test results of the more severely undercut and stressed test samples discussed in the Appendix.

The possibility for crack initiation and growth at the undercut root is not given consideration because the vertically positioned fillet joint member which invariably contains the undercut in production welds, exhibits ample root radius owing to the nature of its occurrence in horizontally positioned fillet welds.

ACCEPTABILITY CRITERIA

Oversize Fillet Welds - Either or both fillet weld legs may exceed design size. Welds may be longer than specified.

Undersize Fillet Welds - The size of 5/16 inch or larger fillet welds may be 1/16 inch less than required for a continuous span of 2 inches provided there is no less than a 6 inch separation between each 2 inch long undersize increment. Weld runs less than 8 inches long may contain a continuous undersize span of 25 of the total weld length. Undersize fillet weld spans less than 1/2 inches long shall be disregarded.


Porosity - Pores between 1/16" and 1/8" diameter shall be acceptable when separated by a minimum of one inch. Pores less

ACCEPTABILITY CRITERIA (Cont'd)

Porosity - (Cont'd)

than 1/16" diameter shall be disregarded. Clustered porosity contained within a 3/8" diameter circle shall also be acceptable.

Weld Profile - Convexity height and butt weld reinforcement may be accepted without limit, however a minimum 120° included angle must be present between weld runs in multipass welds for acceptable profile (shown by adjacent sketch).



Craters - Underfilled craters are not acceptable in continuous groove butt and grooved full or partial penetration Tee welds. For reasons given earlier for insufficient weld throat acceptance, underfilled craters not exceeding 1/16 inch depth are acceptable for fillet welds, provided the underfilled crater has smooth contour, blending gradually with the adjacent weld and base metal.

<u>Undercut</u> - Undercut up to 1/32 inch depth is acceptable in all steels. Undercut in 5/16 inch or thicker steels produced to a specified tensile strength of 60,000 psi, is acceptable to a depth of 1/16 inch, for a continuous span of 2 inches, provided there is no less than a 6 inch separation between each undercut increment. Weld runs less than 8 inches long may contain an undercut span of 25% of the total weld length. Undercut spans less than 1/2 inches long shall be disregarded.

ACCEPTABILITY CRITERIA (Cont'd)

Cracks - Cracks are unacceptable.

Fusion - Incomplete fusion between weld metal and base metal is unacceptable provided evidence such as shown by Figure D on Page 5 is visible. Incomplete fusion is acceptable provided a weld profile such as shown by Figure C on Page 5 is visible.

Arc Strikes - Arc strikes in high-strength low-alloy steels (minimum specified tensile strength greater than 60,000 psi), shall be removed by grinding. The ground area shall be visually inspected to assure complete removal of the arc strike.

For steels produced to a specified 60,000 psi tensile strength, arc strikes shall be visually examined and accepted if no cracking is evident. If cracking is evident, cracked region shall be ground to smooth contour and checked to ensure soundness. Arc strike regions which are not cracked shall not require brushing or grinding before visual examination.

ACKNOWLEDGEMENT:

The assistance, consultation and advice on various structural concepts contained in this paper by R D Steele, Ebasco Consulting Department Civil Engineer, is gratefully acknowledged.

L M Petrick

Chief 'daterials Engineer

Ebasco Services Inc

New York, N Y

March 9, 1984

SHERRON HARRIS POWER PLANT GO RECEIVING TRAINING PROGRAM

	Training Sor Visual Weld Examination
INSTRUCTOR:	- Jane A State
LENGTH OF CLAS	
	PERSONNEL ATTENDED THE ABOVE DESCRIBED TRAINING:
2. Rat 3. Rat 4. Da 5. DA 6. 7. 8. 9.	verta Cates verta Holler
COMMENTS:	AWS D.I.I WAS UTILIZED AS CONE REFERENCE

ell 0 1/2 11.1.50

SHERRON HARRIS POWER PLANT QC RECEIVING TRAINING PROGRAM

DATE: SUBJECT COVER	ED: A. D. S. Welsting Symbols
INSTRUCTOR: LENGTH OF CLA	SS: 1- hour Lescried Training:
1. 7 2. k 3. 4. 5.	Pavich Holler, Buth Hunt June allend Polent Cate Daniel area Whitihead
COMMENTS:	AWS DIOI WAS USED AS CODE REFERENCE
VERIFIED BY:	David C. Whitehead Date Date

SHERRON HARRIS POWER PLANT QC RECEIVING TRAINING PROGRAM

()

DATE: SUBJECT COVERED:	PARTIAL PENETRATION & FULL PENETRATION
WELD SYMB IS REQUIRED	
INSTRUCTOR:	GEORGE M. DANIEL
LENGTH OF CLASS:	30 MIN.
THE FOLLOWING PERSO	NNEL ATTENDED THE ABOVE DESCRIBED TRAINING:
1. Richard 2. Jakes 3. Mart 2 5. Chart 6. Robert 7. Barbara 8.	Coon Town Town Town Town Town Town Town T
COMMENTS:	
RE	· · · · · · · · · · · · · · · · · · ·
VERIFIED BY:	David C. Whitehead Date

QA SPECIALIST

SHERRON HARRIS POWER PLANT

QC RECEIVING TRAINING PROGRAM

DATE: 11-16-79
SUBJECT COVERED: PWHT (POST WELD HEAT TREAT) REQUIREMENTS FOR EMBED PLATES WELDED INTO A TEE FULL OR PARTIAL PENETRATION AS DELINEATED IN RCJ-W-021 (EU.)
INSTRUCTOR: Jeffrey V.P. Me Leg
LENGTH OF CLASS: 20 min
THE FOLLOWING PERSONNEL ATTENDED THE ABOVE DESCRIBED TRAINING:
2. Ballant House 3. Enter A Davis House of 5. Mant Supplet 6. Link opins 7. 8. 9.
COMMENTS: -LASS WAS SATISFACTORY AND ALL QUESTIONS WERE ANSWERED. LENGTH OF CLASS WAS 20 MIN.
VERIFIED BY: David C. Whitehead Date



SCOPE

This is prepared to provide an Ebasco weld zone inspection criteria for structural weldments designed to AISC and AWS Dl.1 requirements.

INTRODUCTION


The need for modification of the presently used D1.1 weldments workmanship inspection criteria became apparent following realization that industry conventional fabrication methods and techniques are not capable of meeting the criteria specified by AWS Dl.1. This conclusion has come about because the examination process philosophy applied by inspectors has changed from rejectacceptance decisions based upon experience, to the present literal adherence to AVS D1.1 criteria, resulting in a five fold and even greater increase in the number of repair required defect citations. There is universal agreement unit Materials Specialists that a defects repair effort of this magnitude can cause new combinerating and retailingsial problems. This concernious-to-service-life possibility was recognized by the AWS Committee on Structural Steel Welding, which stated in their 1982 AVS Communitary on the Structural Welding Code, that "the fundamental premise of the Code is to provide general stipulations applicable to any situation and to leave sufficient latitude for the exercise of engineering judgements". Recourse to this statement is being taken for the ensuing changes, which reflect careful consideration of the short comings of accepted fatrication methods and techniques, the mechanical protorty and allowable stress factors used for the design, and the intended service conditions.

PROBLEM DEFINITION

A detailed review of receiving inspection results at Shearon Harris, of filler welds in shop fabricated components and the re-inspection results of a 210 unit sample of site installed pipe hangers at Waterford, has shown the majority of unacceptable defects to be (a) incomplete fusion, (b) insufficient weld throat. (c) weld overlap and (d) weld zone undercut. The significance of these defects on component service performance is considered minimal, owing to the short length of an overwhelming majority of the cited defects (less than 1/4 inch), the considerable AISC safety factor employed in the design, and the outstanding service performance experience of similarly fabricated weldments.

For the record, the ATSC limits the maximum unit stress which is a second in the design of weld-ress within its jurisdiction to 30% the nominal weld metal tensile strength and 60% nominal base metal yield strength. This results, for those structural steel base metal/weld metals combinations most often used for power plant structural framing in a stress allowable for the weld metal and the base retained. It illustrates of a particle of the considerate safety factor, nominally 50,000 psi for weld metal, is proposed here. This

000824





PROBLEM DEFINITION (Cont'd.)

procedure follows accepted practice for engineered components design changes when service conditions to be imposed are, as is the present situation, well known.

WELD ZONE DEFECTS, THEIR SIGNIFICANCE AND OCCURRENCE PROBABILITY

Incomplete Fusion - This term describes a weld zone region within which the desired coalescence of base metal and weld metal did not take place, owing to absence of complete melting in the region. Limits on the welding process selection for structurals fabrication and the welder performance test requirement imposed by AVS Dl.l are industry accepted safeguards for prevention of such incomplete melting. Furthermore, the energy release at the welding arc, which produces a reported weld zone temperature of 10,000°F, well above the nominal 2700°F melting temperature of steel, allows considerable latitude for welder are ranipulation variations, a possible cause for fusion prollers when accompanied by inadequate joining process conditions. Furthermore, the molten weld metal droplets transferring across the weld arc are at the steel vapor temperature, 5200°F. It can be seen that, given the above temperatures, the risk of meaningful non-fusion regions for a weld run length of 1/2 inch or mire, is reported. In pictorial enample of the one to 1/2 possible ren-fused region is shown by the arc reignition condition of Sketch A.





The desired base metal-weld metal coalescence may not always be achieved to the fullest possible extent, as shown by the above Sketch A, because of the considerable thermal quench of the work piece at arc ignition. This thermal imbalance occurs for a limited time duration, because of the extremely high welding arc energy release. The fact that an inadequate thermal condition makes present for a very short time, if at all, and the good service performance of structural weldments which had been fabricated according to Dl.1 accepted

WELD ZONE DEFECTS, THEIR SIGNIFICANCE AND OCCURRENCE PROPABILITY

welding procedure/certified welder test precautions are the reasons proposed for reduced concern for lack of fusion at arc restrike regions of a weld run.

Insufficient Weld Throat - Weld throad is the plane which bisects the 90° angle fillet weld. Fillet weld size is described by the amount of weld metal attached to each joint member (the fillet weld leg). However, the weld throat dimension, which is 30% less than the leg size, is the important parameter because the working stresses on fillet welds are in the shear mode. Furthermore, the percent effective throat reduction decreases as the fillet weld size increases. Advantage of this relation should be taken because it affects weld joint efficiency. The full size/undersize fillet weld throat dimension relationship has been calculated for several popular fillet weld sizes, the results tabulated and plotted below.

Structural Framing Fillet Welds

Fillet Weld Size	Throat Dimension Full Weld Log Size	Throat Dimension 1/16" Undersize Vald	Effective Throat Decrease	% Effective	30	1		
3/16" 1/4" 5/16" 3/8"	.132" .177" .221" .265"	.066" .132" .177" .221"	33.3 25.4 19.9 16.6	Throat Decrease	10-		1	
1/2"	.35-"	.309"	12.7			E 4	=====================================	7, 1

Effect of Universe Filler Welds on Threat Size.

A more detailed review of these data and curve indicates that 1/- inch and larger fillet welds, which are undersized by 1/16 inch for continuous lengths up to 25° of the total weld length will reduce the weld region design safety factor from to 18%. The reduced risk of component quality degradation, because of a reduction in upgrading requirements, to be gained by use of a less conservative design safety factor will significantly enhance the overall service life capability of structural components.


Weld Overlap - This condition may occur in structural weldments when a large single pass fillet weld is deposited in the horizontal position. The overlap, or weld metal rollover, results after base metal/weld metal melting had taken place, one reason for its posturence being a low solidious to result in the system. Because weld frint member melting had taken place before the liquid rollover, overlap is not considered detrimental, provided the required weld size, within the guidelines of the earlier insufficient weld throat discussion, is achieved. }


- 0 - 55 m


The second secon

WELD ZONE DEFECTS, THEIR SIGNIFICANCE AND OCCURRENCE PROBABILITY

classic example of weld overlap, not readily produced with welding methods and parameters used by the industry, is shown below.







low are energy improper are manipulation. Induced overlap

Weld Zone Undercut - This condition is caused by melting away of base metal at the toe of a weld. Undercut is considered harmful to weldment service life because the area is often a "U" shaped depression, which reduces the base metal cross section and acts as a stress raiser.

Stringent inspection attention is accorded to undercut by the fabrication industry. A major reason for this concern is the widespread belief that the rost region of the orderout rotch will be the cripin of cracks, which grow when exposed to service induced reversing stresses. This concept for crack propagation has persisted, despite universal agreement among those expert to materials behavior that the degree of sharpness of a notch, necessary for the occurrence of a cyclically stressed, slowly propagating crack, is several orders of magnitude sharper than the radius at the root of a typical well undercut region. Although neither sharp nor rounded undercut root radii are desirable weld profiles, the rounded root radius which is a direct result of the melting process is the more forgiving.

Difference in the crack initiation behavior of varying notch-root radii is not given proper consideration during the inspection process. The problem is compounded when strict adherence to described or sketched weld zone profile inspection procedures are used. The result of such inattention is the initiation of ententive weld appreciate offerer, the result industry. This being concerns akin to those for underest by the alreast industry. This practise must be given much more attention because the risk for we'd rone deterioration, always present during weld upgrading activity, increases appreciably when a larger than normal scale upgrading effort is initiated.

The street of the second of th

The state of the s

An investigation, designed to examine the shape of severely undercut weld zones and the effect of the notch on uniaxial tensile properties was conducted to provide data concerning the mechanical behavior of weld undercut containing steel. Details describing test sample preparation, photos and mechanical property test results are presented in the Appendix of this report. It will be noted that the sole conclusion of the evaluation is that weld undercut to 1/16" depth can be present in steel produced to a minimum specified tensile strength of 60,000 psi and that this condition will not be deleterious to its service performance.

Porosity - Steel weld metal porosity is almost always caused by inadequate shielding of the welding arc, as will occur when welding is performed in an air draft of 3 to 5 miles/hour. This condition can cause nitrogen, an air constituent, to be introduced into the weld arc, hausing porosity when sufficient nitrogen is present. Another source of nitrogen is paint. Hydrogen also causes steel weld metal porosity, this constituent usually introduced by oil and grease, generally present as surface films.

It can be seen that only a minor amount of nitrogen or hydrogen can be introduced into the weld are under ordinary conditions, by nature of the form of the contaminant. It follows that the extent of the borosity, which occurs because molten steel weld metal solidifies before all the gas has issued from the liquid weld metal, is not as severe as is assumed by pore extent accertance criteria, which treats all pores as extending through the entire weld deposit thickness. A modification of the degree of porosity acceptable in structural weldments seems warranted per the above.

Unfilled Weld Craters - The reduced throat thickness caused by this condition precludes acceptance in grooved butt and full or partial penetration Tee welds.

Tracks - These defects contain sharp early at extremities. For this reason they must be removed to sound metal and revelded when the minimum required weld zone thickness is violated.

Arc Strikes - This condition is caused by inadvertent arcing between the welding electrode and the base metal, causing a small arcent of base metal, melting in the arc impingement region. More than ordinary attention is given this region in steel because of its hardness and its propensity for cracking. An extensive penetrant evaluation was conducted at Waterford to examine crack occurrence in the arc strike regions of steel produced to a minimum specified tensile strength of 60,000 psi. No cracks were found, which indicates that the material is sufficiently tough and only moderately hardenable when subjected to the high cooling rates of an arc strike zone. This study indicates that arc strikes left inadvertently in steel produced to a minimum specified tensile strength of the last car be disregarded.

the trade of the t

WELD ZONE DEFECTS, THEIR SIGNIFICANCE AND OCCURRENCE PR

PRELIMINARY A description and causes for the eight (8) most common weld zone defects been provided above for understanding of defects formation and occurrence probability, so that a base for inspection criteria modification can be initiated. The extent of acceptance criteria modification will also be influenced, by the design intent of specific structural weldments and the severity of the cyclic service loads which the various plant components may encounter.

CLASSIFICATION OF WELD JOINTS

Category 1 Joints - These joints are part of the main building frame and are expected to carry principle design loads. Severe stress reversing service load conditions are not expected for this categor;, owing to the damping characteristics of floor concrete.

Category 2 Jeints - These joints are not part of the main building frame, but rather provide support/attachment for systems, components, and equipment. Reversing stress conditions are expected to be more severe for this category. however, modifications can be introduced because of notch radii, low vibration amplitudes, the conservative allowable stress used in the design, and the toughness of the steels used in this application.

Category 3 Joints - These joints are not part of the main building frame or support systems, rather they provide framing for components such as instrument racks, ducting, air control dampers, doors, hatch covers, etc. Cyclic service conditions are expected to be minimal, owing to the flexibility of the commoments materials of construction, the framing under discussion providing a degree of rigidity to the component.

ACCEPTABLICTO OF STEP SA + CATEGORY 1 COSMITS

THE THE PARTY OF T

Oversize Fillet Welds

Either or both fillet weld legs may exceed design size. Welds may be longer than specified.

Underside Fillet Welds

The fillet weld leg dimension may not underrun the nominal required size by more than T/15 inch for a continuous run of up to twenty (20) percent of the total weld length.

Porosity

The weld may contain a maximum of 5 percenty by surface area of unaligned; unclustered porosit).

I will be a server of the serv

ACCEPTABILITY CRITERIA - CATEGORY 1 JOINTS (Cont'd.)



Weld Profile

Convexity height and butt weld reinforcement may be accepted without limit. however a minimum 120° included angle must be present between weld runs in multipass welds for acceptable profile.

Craters

Underfilled craters are not acceptable in continuous groove butt and grooved full or partial penetration Tee welds. Underfilled craters, not exceeding 1/16 inch depth are acceptable for intermittent welds, provided the underfilled crater has smooth contour, blending gradually with the adjacent weld and base metal and that the underfilled crater extends beyond the specified weld length.

Thiorest

Undercut up to 1/32 inch depth is acceptable in all steels. Undercut in steels produced to a minimum specified tensile strength of 1.000 psi is acceptable up to 1/16 inch depth for continuous weld run of 20 percent of the total length provided its surface width is equal to or is greater than its depth. Summation of short run undercut regions shall not be considered for acceptance/rejection.

Cracks

Cracks are unacceptable.

Fusion


Incomplete fusion between weld metal and have men't is unacceptable now evidence such as shown by Figure B on Page 2 is visible. Incomplete fusion is acceptable provided a weld profile such as shown by Figure A on Page 2 is visible.

Arc Strikes

Arc strikes in high-strength low-alloy steels (minimum specified tensile strength greater than 60,000 psi), shall be removed by grinding. The ground area shall be visually inspected to assure complete removal of the arc strike.

For minimum specified 60,000 psi tensile steels, are strikes shall be visually examined, and accepted if no cracking is evident. If cracking is evident, the repair shall conform with Section 3.10 of AWS Dl.1. Arc strike regions in these lower strength steels shall not require brushing or grinding before

ACCEPTABILITY CRITERIA - CATEGORY 2 JOINGS



Either or both fillet weld legs may exceed design size. Welds may be longer than specified. Continuous welds may be used in lieu of intermittent welds.

ELIMINAR

Undersize Fillet Welds

The fillet weld leg dimension may not underfun the nominal required size by more than 1/16 inch for a continuous run of up to twenty (20) percent total weld length.

Poresity

The weld may contain a maximum of 5 percent by surface area of unalign '.

Weld Profile

Convexity height and butt weld reinforcement may be accepted without limit, however a winiment 120 included angle must be present between weld runs in multipass welds for acceptable profile.

Craters

Underfilled craters are not acceptable in continuous groove butt and grooved full or partial peretration Tee welds. Intermittent welds may have underfilled craters provided underfill depth does not exceed 1/16 inch, the crater has a smooth contour, blending gradually with the adjacent weld and base metal and that the underfilled crater extent.

Triercut

Undercut up to 1/32 inch depth is acceptable in all steels. Undercut in steels produced to a minimum tensile strength of 60 0000 psi is acceptable up to 1/16 depth for a continuous weld run of 20 percent of total weld length, provided its width is equal to or is greater than its depth. Summation of short run undercut regions shall not be considered for acceptance rejection.

Cracks


Cracks are unacceptable.

Fusite

Incomplete fusion between weld metal and base metal is not acceptable when a condition such as shown by Figure B on Page 2 is visible. Incomplete fusion is acceptable provided a weld profile such as shown by Figure A on Fage 1 is visible.

ACCEPTABILITY CRITERIA - CATFORY 2 JOINTS (Cont'd.)

Arc Strikes



For other minimum specified 60,000 psi tensile steels, arc strikes shall be visually examined and accepted if no cracking is evident. If cracking is evident, the repair shall conform with Section 3.10 of AWS D1.1. Are strike regions in these lower strength steels shall not require power brushing or grinding before visual examination.

ACCEPTABILITY CRITERIA - CATEGORY 3 JOINTS

Oversize Fillet Welds

Either or both fillet weld legs may exceed design size. Welds may be longer than specified. Continuous welds may be used in lieu of intermittent welds.

Undersize Fillet Welds

The fillet leg dimension may not underrun the nominal required fillet size by more than 1/16 inch for a continuous run of up to 20 percent of the total weld length.

Fordelty

The weld may contain a maximum of 10 percent by surface area of unaligned unilistered tit.

Wall Profile

Convexity height and butt weld reinforcement may be accepted without limit.

Cratera

Welds may have underfilled craters provided underfill depth does not exceed 1/16 inch and the crater has a smooth contour blending gradually with the adjan t weld and base metal.

Undergut

Undercut up to 1/32 inch depth is acceptable in all steels. Undercut in steels produced to a minimum specified tensile strength of 60,000 psi is acceptable for a continuous run of 20 percent provided its surface width is equal to or greater than its depth. The summation of short run undercut regions shall not be considered for acceptance rejection.

Cracks

Cracks are unacceptable.

L. M. Petrick August 12, 1983

EFFECT OF WELD UNDERCUT ON THE TENSILE BEHAVIOR OF LOW STRENGTH STEEL



SCOPE

This evaluation was undertaken to examine weld undercut, specifically its shape and depth, produced using conditions most favorable for its occurrence, and its effect on uniaxial mechanical properties. The information to be developed was intended for evidence considered necessary to support an Ebasco structural weldments inspection acceptance criteria modifications effort.

Conclusion


The conclusion drawn from this evaluation is that a weld undercut depth up to 1/16 inch, in steels produced to a minimum specified tensile strength of 60,000 psi is not deleterious to its service performance.

Test Material Preparation


Plate material, 10 inches wide by 12 inches long by 3/8 inch thick ASTM A36 steel was used to produce bead on plate test samples. The test weldments were deposited along the 12 inch direction, employing AWS E7018, 1/8 inch diameter electrodes in the horizontal (2G) position. Weld undercut was additionally enhanced by orienting the welding electrode 10° from the horizontal plane. Three weld test panels were produced per the above electrode orientation at 140 amperes, these conditions selected to produce severe undercut. An additional two test panels were produced using weld conditions which would eliminate or reduce substantially the degree of undercut. These test welds were deposited with 120 amperes.

Test Results

Macro photos at IX magnification, of the weld zone adjacent to material removed for tensile test specimens are presented below. These photos show the undercut as would be seen by visual inspection. Photos 1, 2 and 3 present welds produced with 140 amperes, photos 4, A and B, of welds produced at 120 amperes. These photos indicate that the undercut, which is most severe in test welds 1, 2 and 3, is not continuous, the edge undulating such that undercut and non-undercut intervals are present along the weld run.







000325

Test Results (Cont'd.)

RRELIMINAR Undercut depth of weld zones in the material sectioned for tensile tests was measured at five (5) locations along the 1-1/2 inch reduced section of the tensile bar. The depth, tensile strength and % elongation in 2 inches data are tabulated below:

Undercut Depth, (Inches)

			1	ensile Sp	ecimen No.			
	171	IT-2	21-1	2T-2	37-1	3T-2	4A	4B
1 2 3 4 5	.035 .030 .052 .036	.020 .028 .015 .030	.020 .030 .005 .027	.030 .025 .020 .053	.026 .035 .052 .033	.022 .028 .035 .040	.003 .004 .002 .005	.021 .005 .008 .009
			.070		Strength			
6	74500	75000	74700	75200 Elongati	75100 on in 2"	74500	74400	75000
7	29.0	32.0	29.0	23.0	29.0	32.5	29.0	31.5

It will be noted that the deepest undercut found was .053 inches. The high arc energy conditions, used to produce test samples 1, 2 and 3 were substantially in excess of the conditions generally employed for 2G position welding. For this reason, the undercut depth in the three (3) panels is believed to be representative of worst condition production welds.

The material was prepared for tensile testing following photography and undercut depth measurement. The weld reinforcement was removed, care taken to assure that the undercut side of the weld pass would not be disturbed. Rupture strength of all undercut specimens varied only slightly, ranging from a maximum of 75,200 to a minimum of 74,400 psi. These data and the elongation indicate that the undercut zone did not experience mechanical property deterioration behavior to be expected of material in the minimum 60,000 psi strength range for specimens which are not sharply notched.

The shape of a typical notch in a severely undercut sample is shown by the cross sections presented below at 1% and at 3% magnification. Attention is directed to the wide span at the surface of the undercut. This condition, noted for all the severely undercut material was expected, owing to the melting action which caused undercut to occur and the position of the test plate during the bead on plate weld deposition.





Test Results (Cont'd.)

PRELIMINAR Several photos of the tensile specimens showing undercut presence before testing and failure locations of ruptured samples are presented below.




Fig. A is presented to show that the undercut portion of the test plate was not disturbed in tensile specimen preparation. The ruptured test material shows that failure had taken place in the other samples, base metal removed from to undercut zone. Attention is directed to the amount of elongation which occurred in the undercut zone of test samples IT-1 and 31-1.

Discussion

PRELIMINAR The absence of sharp notches in the undercut zone of welds deposited in the horizontal (2G) position is expected to be difficult to accept. Also unexpected is the insensitivity of the undercut notched specimens, stressed in tension, to anticipated reduced rupture strengths.

The rounded root present in the undercut, is the result of the plane in which the weld was deposited, simulating that of production fillet welds, and the melting action of the arc. Rupture strength variances insensitivity, as affected by the tensile bar thickness reductions at the undercut, appears to have been caused by its presence in the weld heat affected zone, specifically the rapid cool from welding temperatures. The relatively mild hardenability and toughness of steels generally selected for structural framing applications are the reasons for the tensile behavior reported in this study.

Conclusion

The conclusion drawn from this evaluation is that a weld undercut depth up to 1/16 inch, in steels produced to a minimum specified tensile strength of 60,000 psi is not deleterious to its service performance.

> L. M. Petrick August 12, 1983

CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT FIELD CHANGE REQUEST/PERMANENT WAIVER

AP-IX-05 Exhibit 1

FCR/5 H-979 Ra 3

Page 1 of 5

The second secon
Type of Request:
Permanent Waiver to "use-se-ie"
Field Change ORIGINAL ASME Section III Division 1 ASME Section III Division 2
Identification of Area and Item:
Shop and field weld inspection of Bergen-Paterson Pipe Hungers
(clarification of design regurances)
Conflict/Condition
Reference Documents or Attachment CAR-SH-M-30 Rcv 15
Field and shop wells are not being inspected to the same
[14] 이렇게 [14] [14] 이렇게 하다 다른 아이들이 되었다. 그는 그는 그는 그는 그를 보는 그는 그는 그를 보는 그를 보는 것이 되었다. 그는 그는 그를 보고 있다면 하는 것이 없었다.
criteria on B-P pipe Rungers.
DOCUMENT CONTROL
DEC 1 5 1982
SHEARON HARRIS N.P.P.
Recommended Action: Please Investigate and Resolve
Please Resolve as Follows
Allow the visual inspection criteria on sheets 3,4, ands to be
used for all field and stop wells on B-p pipe hangers. The
general provisions of AWS DI.1 (workmanship, technique, and
other NDE criteria) will still be used.
one area on som or one.
Justification:
This provides a common inspection procedure for both field and
shop wells that is in accordance with B-P procedures.
Requested by: Sith Approval:
02 5 27
ay Full 12/10/82 EE/10/82 FOMFT 12-10-82
Discipline Engineer Date Senior Resident Engineer Date

A STATE OF THE PARTY OF THE PAR 100 H-979 Rev 3

Page . 2 of 5


Design Organization Ap	proval O AE O	RSSS TO THE ON	aly [] Other	
			. Conditional	Approval
to be changed				
Comments:			Transfer Land	
Signature Titl	e Date	Signature	Title	Date
	CP&L Harris Plant	Engineering Approva	l .	
	HPES Attachment	s 🗆 Yes 🔯	No	
Approved as Recom	mended □	Rejected	☐ Conditional	Approval
Menig (2 W) Rin Discipline Engineer	/2/10/82	MARPOR PE	level 12	113/82
Site Concurrence: Rec				Ace
Site Concurrence. Rec	Alternate I	Resolution ££	Resident Engi	MF7 /2-13 82
Distribution:		(Copy)		
(Original) Document Co	putrol	(Cot.A)		
(Copy)		(Copy)		
Implementation Complete	ted as Approved?			
Comments:				
Counciles.				
Final Disambunian		Discipline H	ingineer	Date
Final Distribution:				
(Original) File in De	oc. Control	(Copy		
(Copy)		(Copy	MERCHANIP SEASON OF THE PERCHANISM STATE OF THE PERCHA	
(COOV)	A Control of the Cont	((00)		

VISUAL INSPECTION CRITERIA OF FIELD AND SHOP WELDS

- The area to be examined shall be sufficiently free from foreign matter to allow for examination of the weld area. Shop welds may be inspected through paint.
- Surfaces and edges to be welded shall be smooth, uniform and free from fins, tears, cracks, and other discontinuities which would adversly affect the quality or strength of the weld.
- 3. Check to assure the weld has no cracks.
- 4. Check to assure that complete fusion exists between weld and base metal and adjacent layers of weld matal. Indications of apparent lack of fusion which do not exceed 1/4" in length shall be considered acceptable. Total length of such indications shall not exceed 1/4" in any six inches of continous well. Check to assure that all crators are filled to the full cross section

of the weld.


- 6. Confirm the weld profiles are in accordance with the illustrations outlined on figure #1.
- A fillet weld in any single continous weld shall be permitted to underrum the nominal filler weld size required by 1/16" without correction, provided that the cumulative length of undersized weld does not exceed 10% of the length of the weld. On web-to-flange welds on girders no underrum is permitted at the ends for a length equal to twice the width of the flange.
- Check to assure that any conditions of undercut do not exceed 1/32" in depth.
- Surface porosity shall be less than 1/16" in size of greatest dimension. The sum of the greatest dimensions of porosity shall not exceed 3/8" in any linear inch of weld. Piping porosity in fillet welds shall not exceed one . in four inches of weld length and the maximum diameter shall not exceed 3/32" in size.
- Skewed tee fillets and flare bevel groove welds shall be measured in 10. accordance with the outlined illustration in figure #2.
- When the toe of a fillet extends into the radius of a tube steel member and that leg is determined to be undersized, a check shall be made to confirm that the undersized leg is equal to the theoretical effective throat. The entire profile of the weld shall be equal to or greater then the theoretical effective throat. (see figure #3)
- Tight adhering weld spatter is acceptable. 12.
- 13. Arc strikes 1/16" or less shall be considered acceptable provided the base metal or deposited metal is not cracked and there is no bimetallic inclusion (copper, stainless steel filler metal).
- Non-structural end cap welds shall meet the above acceptance criteria except that indications less than 3/16" in length per one inch of weld length shall be considered non-revelant.




THE PARTY PROPERTY


ILLUSTRATIONS OF WELD PROFILES

Shed 4055 FCR-H-979 Rev-3






Desirable Fillet Weld Profile



Unacceptable Fillet Weld Profiles



Unacceptable Butt Weld Profiles

Wes INSPECTEN GRITARIA 2165-6-003 P/4

1.0 SCOPE

The intent of this design document is to provide the CP&L QA program with acceptance criteria that satisfies the design requirements and thereby allowing clarification from strict code interpretation during receipt inspection, reinspection, and field welding inspection. This criteria is applicable to both primary (first inspection, uncoated) and secondary inspections (receipt inspection included with quality release or reinspection, coated) for structural weldments designed to AWS Dl.1 requirements.

Secondary inspections may be performed through coatings. Primary inspections shall not be allowed through coatings unless allowed by the engineer. Any item not specifically covered in this criteria shall refer back to AWS Dl.1.

This criteria covers joints which provide framing for components, such as cable tray, HVAC, conduit supports, instrument racks, ducting air control dampers, doors, hatch covers, pipe supports, etc. This is to include any item welded to AWS D1.1 standards.

This criteria is applicable to any weld joint where these imperfections are to be visually inspected per AWS Dl.1.

As per ANS Dl.1, welds with acceptable imperfections in combination shall be acceptable.

Based on the QA programs for acceptance prior to vendor release (or acceptance of field welds), any defects not identified during primary inspection and subsequently covered by coatings are not considered significant.

Visual inspection of welds shall be in accordance with AWS D1.1 except as modified below:

to medical to the the contract of the second of the second

All visual inspection shall be performed at an eye-to-examination surface distance of no more than 24 inches, the inspector position within an angular region of 30 to 90 of the examination surface by personnel possessing 20/20 visual acuity. Visual aids which do not enhance 1% capability, such as mirrors, may be used. Visual inspection shall be used unless otherwise noted on design documents.

2.0 ACCEPTABILITY CRITERIA

2.1 Oversize Fillet Welds

Either or both fillet weld legs may exceed design size. Welds may be longer than specified. Continuous welds may be used in lieu of intermittent welds.

2.2 Undersize Fillet Welds

The leg of 1/4" and larger fillet welds may be 1/16" less than the required weld size for a continuous span of 2", provided there is no less than a 6" separation between each undersize increment. For welds less than 8" long, a continuous undersize span of 25% of the total weld run length will also apply. All 1/16" undersize increments less than 1/2" in length will be acceptable. For intermittent welds, 1/16" less than that required size will be accepted provided the undersize condition is no more than 40% of the weld length.

The leg of 3/16" fillet welds may be 1/32" less than the required according to the above provisions or 1/16" less for 10% of the length.

It is to be understood that the thickness of coatings on secondary inspections are not considered detrimental and the weld size criteria shall not be adjusted. Any unique application of coatings (excessive thickness, putty) shall be brought to the attention of QA management for resolution.

2.3 Porosity

Pores between 1/16" and 1/8" diameter shall be acceptable when separated by a minimum of one inch. Isolated pores less than 1/16" diameter shall be disregarded. Clustered porosity including all sizes to 0.030" contained within up to a 3/8" diameter circle shall be acceptable. Linear, in-line pores shall be considered as clustered porosity. It is to be understood that porosity not visible through coatings on secondary inspection are not considered significant.

2.4 Weld Profile

Fillet and butt weld convexity can be accepted without limit.

2.5 Craters

Welds may have underfilled craters provided underfill depth does not exceed 1/16" and the crater has a smooth contour blending gradually with the adjacent weld and base metal with no evidence of cracking.

2.6 Undercut

Steels 5/16" or thicker which were produced to a maximum specified tensile strength of 60,000 psi may contain weld undercut up to 1/16" in depth for a continuous span of 2" provided its surface width is less than 0.100" and there is no less than a 6" separation between each undercut increment.

Weld runs less than 8" long may contain a continuous undercut span of 25% of the total weld length. All undercut less than 1/2" in length will be accepted provided the above width limit is adhered to. Undercut up to 1/32" depth is acceptable in all steels and all thicknesses.

2.7 Cracks

Cracks are unacceptable. It is to be understood that secondary inspections are intended to identify cracks that result from shipping damage or stress relief and, if relevant, would appear through the coating.

2.8 Arc Strikes

Arc strikes in high-strength, low-alloy steels (minimum specified tensile strength greater than 60,000 psi), shall be removed by grinding. The ground area shall be visually inspected to assure complete removal of the arc strike.

For other maximum specified 60,000 psi tensile steels, arc strikes shall be visually examined and accepted if no cracking is evident. If cracking is evident, the repair shall conform with Section 3.10 of AWS Dl.1. Arc strike regions in these lower strength steels shall not require power brushing or grinding before visual examination. It is to be understood that cracks in arc strikes not visible through coatings on secondary inspections are not considered significant.

2.9 Fusion

Lack of fusion which does not exceed 1/4" in length when measured transverse or along the weld and each increment separated by 6" is acceptable.

Criteria for lack of fusion in transverse direction is applicable only in start/stop location.

Criteria for lack of fusion shall apply to overlap also. It is to be understood that lack of fusion not visible through coatings on secondary inspections is not considered significant. Any unique application of coatings (excessive thickness, putty) shall be brought to the attention of QA management for resolution.

CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT PROCEDURE CHANGE NOTICE

Page 1 of 1

since the weldser sors: See Section 4.5.1.3
since the welder
ors: See Section 4.5.1.3
COLIMENT CONTROL
APR 0 4 1984
EARON HARRIS N. P. P
1

The approval of this Procedure Change Notice authorizes deviation from the named procedure to the extent described above.

The holder of the affected procedure shall retain this notice with the procedure until the next procedure revision is in effect.

	APPROVALS	DATE
ORIGINATOR	Kardy & luna	3-28-84
QA/QC REVIEW	MM. Puel	3/30/84
CP&L	lotte for the met	4/1/24

.00319

CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT Page __ of __ PROCEDURE CHANGE NOTICE

The contract of the contract o	o. WP-139 Revision No. O Change No. 1
Procedure Ti	THE PIDE HOUSER WORK PACKAGE PREPARATION PROUMENT CONTROL
Managed on the co	一一一一一一一一一一一一一一一一一一一一一一一一一一一一一一一一一一一一一一
Applicable -	FCR's: DCN's: DCN's: DCN's:
and the second	
Affected	Description of Change SHEARON HARRIS N. F. P.
regraphs	Description of Change SHEARON HARRIS N P.
4.5.1.3	(Revise to Read)
	SWDR-WPG Engineer will (site) welded joints.
teración Total	Shopwelded e listed on the SKIDR
The same of the sa	Mote: The Main Steam B-Wall Supports as
A photo the Parks	designated by Appendix H of WP-110 do not
A Maria	require the shop welded ; oints to be identified
The American	on the controlled copy of the hanger sketch,
West Transport	there fore shop welded joints will not be listed
A Comment	on the SWDR.
	Field welded joints under joint L.D.
HER STANDS	The same and the s
NA formal	
Vinter in the control of the control	
- Lucassial	of this Procedure Change Notice authorized desired

approval of this Procedure Change Notice authorizes deviation from the named procedure the extent described above.

The nolder of the affected procedure shall retain this notice with the procedure until the next procedure revision is in effect.

ORIGINATOR	Randy Henry	2-14-24
QA/QC REVIEW	mm-tur	12/15/84
CP&L -	losto for Mr.	- 2/10/2


CONSTRUCTION PROCEDURES MANUAL SHNPP	PROCEDURE NO. DATE
WORK PROCEDURE	REVISION 0
DESCRIPTION PIPE HANGER WORK PACKAGE PREPARATION	PAGE 1 OF 9

CAROLINA POWER & LIGHT COMPANY

SHEARON HARRIS NUCLEAR POWER PLANT

WORK PROCEDURE

WP-139



- * REVIEWED BY QA /QC FOR COMPLIANCE WITH THE APPLICABLE QA AND CODE REQUIREMENTS.
 - * REVIEWED AND APPROVED BY EBASCO SERVICES, INC., FOR CONFORMANCE TO THE REQUIREMENTS OF PARAGRAPH CA-3310 OF ARTICLE CA-3100 OF ASME/ACI 359, SECTION III, DIV. 2, WINTER 1975 ADDENDA.

REV.	DESCRIPTION		APPROVALS,	DATE
		ORIGINATOR	Roll C Finon	12/2/2
0	Issued For Use.	CONSTRUCTOR	11 D. Horduca	1 12
		QA/QC REVIEW * *	M. M. Pugh	12/2/5
		CPAL	Man For HI	FT 126
		DES. ENG. *	11/1/1/100	FF 12/2
		ORIGINATOR		72
		CONSTRUCTOR		
		QA/QC REVIEW # #		
		CPAL		
		DES. ENG. *		
		ORIGINATOR		
		CONSTRUCTOR		
		QA/QC REVIEW . *		DESCRIPTION OF THE PERSON OF T
		CPAL		
		DES. ENG. *		

CONSTRUCTION FROCEDURES MANUAL SHNPP	Procedure No39	As Approved
WORK PROCEDURE	Revision 0	
DESCRIPTION PIPE HANGER WORK PACKAGE PREPARATION	Page 2	of 9

1.0 SCOPE

1.1 The purpose of this procedure is to delineate the functions of the Work Package Group (WPG) and describe the steps to be taken in the preparation and control of a pipe hanger work package.

Note: Due to the major changes to present practices, detailed in this procedure, all packages issued for construction shall be in compliance with this procedure within ninety (90) days after procedure issuance from Document Control. No hanger packages shall be Final Accepted by CI and QC unless in compliance with this procedure and WP-110.

2.0 REFERENCES

- 2.1 WP-110, Installation of Seismic Hangers and Supports for Seismically Analyzed Pipe
- 2.2 WP-140, QA Records Review
- 2.3 WP-33, Installation of Wedge Expansion Bolt Anchors
- 2.4 AP-XIII-08, Material Issue
- 2.5 QCI-19.3, Seismic Pipe Hanger Construction Documentation System
- 2.6 WP-42, Installation of Maxi-Bolts, Undercut Expansion Anchors

3.0 GENERAL

- 3.1 This section outlines the phases of the work package preparation and the actions taken during each phase.
 - 1. The end result of the operations described below is to assure that the work package, issued to construction, is free from apparent problems. The operations will include, but are not limited to, the following:
- 3.2 Computer Control (CC) will create a computerized record of supports listing all pertinent data relative to the supports and will track their progress through the entire installation and review process.

CONSTRUCTION PROCEDURES MANUAL SHNPP	Procedure No. WP-139	Date As Approved
WORK PROCEDURE	Revision	
DESCRIPTION PIPE HANGER WORK PACKAGE PREPARATION	Page 3°	f 9

- 3.3 An Initial Review (IR) is to be performed on each support detail drawing to be sure that there are no obvious problems with the detail drawing or with its ancillary attachment points.
- 3.4 A Material Verification (MV) will also be performed to determine that the necessary material is available for construction and meets the minimum requirement for the design installation.
- 3.5 A Hanger Installation Checkout (HIC), will be conducted in the field to identify interferences and/or construction errors that would prevent the support from being installed as designed.
- 3.6 Final Package Preparation (PP) will include the assembly of required quality documents and necessary instructions into the Work Package to be issued for construction and inspection.
- 3.7 An Internal Package Control (PC) will be responsible for maintaining an orderly document file and to provide a controlled issuance of the Work Packages.

4.0 PROCEDURE

- 4.1 Computer Control Functions
 - 1. New drawing issues from Document Control
 - 1. Create new record, enter all available data.
 - 2. Create hanger folder and transmit to Package Control.
 - Issue a "Screen Print" to engineer as notification that the hanger is available for review (Exhibit 2).
 - 2. Drawing Revision from Document Control
 - Update records with new or changed data.
 - Issue recall notices (1) Package Control, (1) Hanger Superintendent, (1) CC File (Exhibit 3).
 - Issue a "screen print" to engineer as notification to work.
 - 3. Provide on request, lists of supports available for review, supports available for issue and supports in field being worked. Other lists may be requested depending upon the subject under investigation.
 - 4. Maintain a continual status and location update.

CONSTRUCTION PROCEDURES MANUAL SHNPP	Procedure No. WP-139	As Approved
WORK PROCEDURE	Revision	
DESCRIPTION PIPE HANGER WORK PACKAGE PREPARATION	Page 4	of g

- 5. Monitor outstanding documents and their resolution.
- 4.2 The Initial Review will consist of:
 - 1. For Original Issue
 - A cursory review of the support detail drawing for legibility of dimensions, weld symbols and presence of sufficient information for erection.
 - Investigate the status of ancillary attachment points (other supports, framing steel, etc.) as depicted on detail drawing.
 - Issue drawings that have no apparent problems to the HIC for field survey.
 - 2. For Subsequent Revisions
 - 1. Review for legibility and definition of revision.
 - 2. Determine possible impact on construction.
 - 3. Establish necessary routing of revision (HIC, Material Verification, etc.)
- 4.3 The Hanger Installation Checkout will include:
 - A detailed dimensional check and calculations required to verify or provide dimensions necessary to the layout and future installation of the support.
 - Establishing control points using existing monuments and reference marks and the attachment of location stickers.
 - Use the established control points, check for potential interferences, misplaced embeds and conditions that would prevent the installation of the support in accordance with the detail drawing.
 - Deficiencies, resulting from the above checkout, will be the subject of a MOD or PHP depending upon the severity of the problem. (Appendix A) (Appendix B)
 - 5. Support detail drawing utilizing anchor plates will require an anchor plate layout and the preparation of a sketch which will be transmitted to Harris Plant Engineering Section (HPES) for review and base plate design.

CONSTRUCTION PROCEDURES MANUAL SHNPP	Procedure No. WP-139	As Approved
WORK PROCEDURE	Revision . 0	
DESCRIPTION PIPE HANGER WORK PACKAGE PREPARATION	Page 5 o	ıf 9

 Upon receipt of the base plate design an Anchor Placement Record (APR) is prepared and issued for base plate installation. (Appendix C)

Note: Completed and accepted APR's are returned to the WPG as notification that the work package can be issued to construction.

- 7. Supports that attach to embedded engineered plates will require investigation by the Area Engineer as to the thickness of the embedded plate. This information is to be entered on the support traveler for use by the Weld Engineer to determine preheat requirements.
- 4.4 Material Verification will consist of the following:
 - The WPG Office Engineer will:
 - Review the C.C. screen to determine the revision level of the material received and that nonconformances have been closed out.
 - Review the Warehouse Material Received screen to verify that all items have actually been received.
 - Prepare the Construction Material Request (CMR) for supports ready to be issued to construction (Appendix F).
 - 2. The WPG Warehouse Engineer will:
 - Upon receipt of a Support Material Receiving Report
 (MRR), create a record of the material received by support
 number, bill of material item number and description. This
 record will be updated to reflect material changes, additions
 and deletions as future drawing revisions dictate (Exhibit 4).
 - 2. Investigate CMR's for material replacement or field supplied material (for design revisions) using "Surplus" seismic parts to ascertain that the source as stated actually exists and has a Certificate of Conformance. The CMR should be stamped "Source Accepted", initialed and dated.

CONSTRUCTION PROCEDURES MANUAL SHNPP	Procedure No. WP-139	As Appro
WORK PROCEDURE	Revision	
DESCRIPTION PIPE HANGER WORK PACKAGE PREPARATION	Pagu 6	of Q

 Fill out the Material Verification Form to document the material issued to construction (Appendix E).

4.5 Work Package Preparation:

- Work packages having no apparent problems or outstanding documents will have the following sheets prepared and/or assembled and inserted into the Work Package prior to issuance:
 - Support Drawing- Verify that the latest revision is in the package and that all documents reflect that same revision. The engineer will perform a "Joint Mapping" operation on the support drawing. All joints will be assigned an alphanumeric number with a leader indicating the designated joint.

Note: See section 4.5.1.3 for the weld designations and SWDR application.

- Traveler- WPG Engineer will enter applicable portion of heading and data (Appendix G).
- SWDR- WPG Engineer will enter applicable portion of the heading and itemized weld joint description for field (site) welded joints.

Shop welded joints will be identified as SJ-1, SJ-2, etc. on the controlled copy of the hanger sketch but will not be listed on the SWDR.

Field welded joints will be identified as FJ-1, FJ-2, etc., on the controlled copy of the hanger sketch and listed on the SWDR under joint I.D.

All field joints requiring complete cut-out and rewelding will have a letter suffix designation beginning with "A" to the joint number and will continue in ascending sequence for subsequent cut-outs. (i.e. FJIA indicates that field joint

CONSTRUCTION PROCEDURES MANUAL SHNPP	Procedure No. Date WP-139 As Approved
WORK PROCEDURE	Revision
DESCRIPTION PIPE HANGER WORK PACKAGE PREPARATION	Pege 7 of Q

No. 1 has been completely cut-out and rewelded one time. FJ3 B indicates that field joint No. 3 has been completely cut-out and rewelded twice.)

Shop welded joints completely cut-out and rewelded will be redesignated as field joints and listed on the SWDR. Both shop welded joints and field welded joints that require rework by welding, will have a suffix designation of "RW" to the joint number and a numerical identification in ascending sequence (i.e., FJIRWI indicates that field joint No. has been reworked once after initial QC acceptance. SJ3RW2 indicates that shop joint No. 3 has been reworked, on site, twice after initial QC acceptance.)

Note: The suffix designations and changing of shop joints to field joints will only show work activity after initial itemized joint identification on the hanger sketch and SWDR.

- Work Directive- WPG Engineer will prepare the Work Directive giving detailed installation instructions. (Appendix "H")
- 5. Material Verification See Paragraph 4.4.2.3.
- 6. Anchor Placement Record The completed and approved APR is to be in the package to verify that the anchor plate has been installed.
- Modification Sheet White copy is to be included to show installation deviations and to permit construction to proceed.
- Other documents pertinent to the hanger drawing will be retained in the PC files until the Work Package is ready for WPG-Final Review.
- 4.6 The completed Work Package will then be transmitted to the Welding Engineer (WE) for a detailed weld check and for the annotation of the weld procedure, filler metal, weld instructions and signature on the SWDR.

CONSTRUCTION PROCEDURES MANUAL SHNPP	Procedure No. Date WP-139 As Apporved		
WORK PROCEDURE	Revision		
DESCRIPTION PIPE HANGER WORK PACKAGE PREPARATION	Page 8 of 9		

- 4.7 Quality Control (QC) will review the package and insert desired hold points on the SWDR and signs to release.
- 4.8 Upon completion of the WE and QC review, the WPG will perform a final review of the Work Package to assure that all necessary documents are present and complete.
- 4.9 The work package is to be transmitted to construction.
- 4.10 Package Control
 - The primary purpose of the Package Control (PC) section is to provide a central location for the assembly and storage of the Work Packages and to establish a control and record of their issuance.
 - PC will create and maintain a file of Work Packages and a manual card file for tracking the location of those issued for work. (Exhibit 5).
 - PC will also be involved in operations such as filing, up-dating Work Packages, distribution of packages and revisions and other tasks pertinent to the operation of the WPG.


5.0 EXHIBITS AND APPENDICES

- 5.1 Exhibit 1 Work Package Group Flow Chart (Rev. 0-12/83)
- 5.2 Exhibit 2 Computer Control Format Page 1 of 2 (Rev. 0-12/83)
- 5.3 Exhibit 2 Directions for Computer Control Format Data Input Page 2 of 2 (Rev. 0-12/83)
- 5.4 Exhibit 3 Recall Notice (Rev. 0-12/83)
- 5.5 Exhibit 4 Warehouse Material Status (Rev. 0-12/83)
- 5.6 Exhibit 5 Package Control Card (Rev. 0-12/83)
- 5.7 Appendix A Field Modification (Rev. 0-12/83)
- 5.8 Appendix B PHP Transmittal Sheet, Page 1 of 2 (Rev. 0-12/83)
- 5.9 Appendix B PHP Transmittal Preparation Sheet, Page 2 of 2 (Rev. 0-12/83)
- 5.10 Appendix C Anchor Placement Report, Page 1 of 2 (Rev. 0-12/83)
- 5.11 Appendix C Anchor Placement Report Preparation, Page 2 of 2 (Rev. 0-12/83)

CONSTRUCTION PROCEDURES MANUAL SHIPP	Procedure WP-	No. 139	1	Date As Approved
WORK PROCEDURE	Revision	0		
DESCRIPTION PIPE HANGER WORK PACKAGE PREPARATION	Page	9	of	9

- 5.12 Appendix D Seismic Weld Data Report, Page 1 of 2 (Rev. 0-12/83)
- 5.13 Appendix D Seismic Weld Da. Report Preparation, Page 2 of 2 (Rev. 0-12/83)
- 5.14 Appendix E Material Verification (Rev. 0-12/83)
- 5.15 Appendix F Construction Material Requisition (Rev. 0-12/83)
- 5.16 Appendix G Seismic Hanger Installation Traveler, Page 1 of 2 (Rev. 0-12/83)
- 5.17 Appendix G Seismic Hanger Installation Traveler Preparation, Page 2 of 2 (Rev. 0-12/83)
- 5.18 Appendix H Work Directive, Page 1 of 2 (Rev. 0-12/83)
- 5.19 Appendix H Work Directive Preparation, Page 2 of 2 (Rev. 0-12/83)
- Note: These appendices are shown for <u>reference</u> only and will not be revised in this procedure. For the latest revision of the appendices shown that are exhibits in other approved procedures, see the applicable procedures.

WORK PACKAGE GROUP FLOW CHART



COMPUTER CONTROL FORMAT

0				
2,50		TYPE	HOLDS	HGR STATUS
r. REV. 2	INST. REV. 12		DWG '	32)
w REV. 3	PHASE 13	RIGID	MATL	
NL DATE		BOX	HPES	18 HIC CHECKOUT
LESS 3		- ANCH	NPCD	19 PIPE CHECKOU
NE 6	· @	SPRING	FIELD	20 ENG. O.R.
E 1	1010	W/WPA	QC	
E RFT 3	0		RECALL	21 CI COMPLETE
M RFT 9		WPA 15		22 COMPLETE
	50	16 INSTALLE	D-	
SMIC 10				
		41		
TSTANDING DO	CUMENTS	TURNOVER	TRANSMITTAL	
(11)	ADD	25 COLD HY	DBO 23	ADD
•		26 HOT FUN	/ A 1 -	LOCATION (24)
			_ ^	
		AS-BUILTS	(29) CWRA	
			D 30 REMSPEC	т
		28 SUBMITTE	ED (20
				1.
MMENTS				

DIRECTIONS FOR COMPUTER CONTROL FORMAT DATA INPUT

		OTER CONTROL FORMAT DATA INPUT
ITEM	ENTER BY	
1	WPG-CC	
2	WPG-CC	FROM INFO BLOCK ON DWG.
3	. WPG-CC	FROM WHSE BILL OF LADING
4	DAN'L COST	FROM INFO BLOCK ON DWG.
5	WPG-CC	(BASED ON REPORT BY CONSTRUCTION)
6	WPG-CC	FROM INFO BLOCK ON DWG.
7	WPG-CC	FROM INFO BLOCK ON DWG.
8	CPLANCO	FROM INFO BLOCK ON DWG.
9	CPLSTU	DIRECT INPUT
10	WPG-00	DIRECT INPUT
п	WPG-CC	FROM INFO BLOCK ON DWG.
12	WPG-CC	FROM LOGS, TRANSMITTALS AND DOCUMENTS
13	DAN'L COST	THOM COMPLETED TRAVELER
14	WPG-CC	DIRECT INPUT (W/ITEM 4)
15	PIPE DEPT.	FROM WPG. IR REVIEW
16	PIPE DEPT	DRECT INPUT (WPA #)
17	AUTO & WPG-CC	DIRECT INPUT (BY WPG-CC IF NO # 1)
	moro a wpg-cc	FROM WPG ENG, FIELD ENG, & QC (ALSO AUTO PER
18	WPG-CC	
19	WPG-CC	DATE FROM HIC TRANSMITTAL
20	WPG-CC	DATE FROM PIPE DEPT. OR FIFE D THE
21	WPG-CC	DATE FROM WHG & FIELD ENG
22	WPG-CC	DATE FROM COMPLETED TRAVELED
23	WPG-CC	DATE FROM COMPLETED TRAVELED
24	AUTO	LOCATION CODE AND DATE FROM TRAVEN
25	WPG-CC	
26	WPG-CC	DATA FROM HPES ESSENTIAL HGRS FOR TEST)
27	WPG-CC	FROM HPES (ESSENTIAL ACRE FOR THE
8	WPG-CC	THE PROM FIELD ENG
9	WPG-CC	DATA FROM FIELD ENG
0	WPG-CC	DATE FROM FIELD ENG.
	WPG-CC	DATE FROM FIELD ENG.
2	AUTO	INFO. FROM NOTES BY WPG & FIELD ENG
		BASED ON ITEM 23 & 17

RECALL NOTICE

	Date	
то:		
FROM: Mechanical Work Package Group		
SUBJECT: Revised Hanger Drawings		
The following hanger drawing revisions have	been received in the Mechani	cal Office.
Therefore, nor further work should be done	o the old revision currently in	the field.
Please return the work packages noted below revision can be inserted.	to the Mechanical Office so	the proper
revision can be inserted.		
50/		
Hanger Drawing	RFT	Revision
	\rightarrow	
	1/2	
	1/	
	<u> </u>	
	~	
	1	
	//	
	·	
	→ →	^
	A MARKET BUILDING	1
		(V)
		7

WAREHOUSE MATERIAL STATUS

REV. #	MRR #	B/M ITEM	QTY. DESCRIPTION	MAT'L SPEC.	A. STO
0/A ·	1234	1	1 T-5 3'x3'x.250'x2'-6" LG	A500GRB	3
0/A	1234	2	1 L 2'x2'x3/16"x0'-G" LG	SA36	D 3
1/B	5678	3	1 T-S. 2'x2'x.250'x0'-6" L	G A500GRB	A 3
	7	0			
DDR/CAR	3/0)	OS&D		MRR
			4321 13	TEM 3 SHORT	B765


The above shows:

- 1. Rev. O/A Mat'l received on MRR# Nest and is stored in area 3B.
- 2. Rev. 1/B Mat'l received on MRR#5678. That item 3 was added (A) and replaces item 2 item 2 which was deleted (D) and can be put into the surplus area.
- 3. That any DDR is open (0) or closed-out (C)
- 4. That an OS&D exists, what is short and the MRR that the item was finally received under.



PACKAGE CONTROL CARD

HGR#	REV	
ISSUED TO/REV/DATE	RETURN/REV/DATE	
	•	
•		
-200-		
(0)		
-		
-		
	/	
	1	
	9/	



Rev. Q 12/83			_ SEISMIC	Appendix A WP-139
			. NON-SEISMIC	SH OF Exhibit -1
CONDITION:	FIELD MO	DDIFICATION		(WP-110 -1)
		•	•	
ENG	MERTO	DATE	WHITE ORIGINAL IS DAYS AND IS SUPERI BLUE CONTROLLED	CEDED BY A
		;		вом
	- SP			
	V	1		
		15		-
			^	
		4	<u>o</u>	
		,	1	
				7
			110	
PF -443ER NO		REVISION	MODI	FICATION
OBLEM				

12/83 CAROLINA POWER & LIGHT	
RFT.	PRIORITY 1.
ATTENTION : GEORGE WHITE	PHP NO.
HANGER NO	- н - []
SEISMIC NON-SEISMIC	REV. [3.
PROBLEM TYPE	
$ \alpha \omega$	
The second secon	

8.

PHP TRANSMITTAL SHEET PREPARATION

<u>ITEM</u>	ENTERED BY	
1	WPG-HIC	INFO FROM SYSTEM ENG.
2	WPG-HIC	ISSUED BY WPG-CC
3	WPG-HIC	FROM DWG TITLE BLOCK
4	WPG-HIC	FROM DWG TITLE BLOCK
5	WPG-HIC	FROM DWG TITLE BLOCK
6	WPG-HIC	BRIEF ACCURATE DESCRIPTION OF PROBLEM
7	WPG-HIC	LEGIBLE SKETCH OF PROBLEM AND/OR RESOLUTION
8	WPG-HIC	ORIGINATOR SIGN AND DATE
9	SUPERV.	INITIAL FOR APPROVAL
	Note: Items 1-8	may also be entered by Field or Systems Engineer when pertaining to
	eonstructi	ion problems.
Category I	Permanen	t Waiver request to "use as is" the construction or tested configuration.
Category I		equest to correct a design error which "cannot be constructed" or "cannot perated."
	b. Char	nges which are minor in nature and enhance construction, operation,
		or testing of the plant while creating little or no design, construction, or ation impact.

Category III , Any design change request not falling in Category I or Category II.

Sheet 1 of 2 m No. 80038 Exhibit 1 WP-33 CP &L ANCHOR SHNPP PLACEMENT IS BEARING GROUT REQUIRED YES NUMBER REPORT UNDER FIXTURE (3) NO LOCATION (BUILDING, ELEVATION, DISTANCE FROM COLUMN LINES) DATE: BOLT (DIAMETER, LENGTH & QUANTITY) ANCHOR TYPE PRIMARY DWG. NO., DCN NO., FCR/PW/PHPNO,ETC (PRELIMINARY) (NEEDED FOR HOLE LOCATION) MAXI-BOLT PHILLIPS CONCRETE DESIGN STRENGTH REI NO. (9 UNIT OF WORK LEDINGS TRIP PLATES, NAME/TITLE PERSON SUBMITTING THE ABOVE DUIT ETC.) BY: TITLE: DATE: (12) CONSTRUCTOR SIGNOFF (CRAFT SUPT.) TIME: A.E. CHECK FOR EMBEDED PIPES OR CONDUITS COMPLETED FIELD ENGINEER (LOCATION SIGNOF MECHANICAL ELECTRICAL CIVIL TO ASSURE ADEQUATE REFERE INITIAL: INITIAL: INITIAL: POINTS ARE PROVIDED CONSTRUCTION INSPECTION SIGNOFF TIME : ___ DATE: TIME: DATE : _ REMARKS. (ATTACH RELEVANT REPORTS (IN COSE OF RUNS (IE. CONDUIT & PIPING) PROVIDE SKETCH SHOWING ORIGIN & TERMINATION OF RUN. ONLY ONE RUN PER ANCHOR PLACEMENT REPORT. IS CONCRETE PLACEMENT AT LEAST LENGTH, DIAMETER OF 28 DAYS OLD APPROVAL 1 YES NO ANCHORS. SECTION PW/FCR NO _ CONSTRUCTION INSPECTION TIME: RCI NO LIST ALL DOCUMENTS NEEDED FOR APPROVAL. DATE: DESIGN APPROVAL WERE UNUSED HOLES TIME: YES (AREA ENGINEER) DATE: REPAIRED AS REQUIRED CONSTRUCTION INSPECTOR SIGNOFF CONSTRUCTION SIGNOFF (CRAFT SUPT.) NAME : __ NAME ._ DATE : _ DATE: ___ INSPECTION SUPERVISOR NAME :_

DATE :-

ANCHOR PLACEMENT REPORT PREPARATION

ITEM	ENTER BY	
1		LEAVE BLANK
2	WPG-HIC	NUMBER ISSUED BY APR GROUP
3	WPG-HIC	DATA FROM DWG.
4	WPG-HIC	DATA FROM DWG.
5	WPG-HIC	DATA FROM DWG.
6	WPG-HIC	DATA FROM DWG (AND BOLT CHART)
7	WPG-HIC	DATA FROM DWG (AND BOLT CHART)
8	WPG-HIC	ENTER PHP NO.
9	WPG-HIC	DATA FROM CONCRETE CHART
10	WPG-HIC	DATA FROM WORK PACKAGE
п	WPG-HIC	DATA FROM WORK PACKAGE
12	WPG-HIC	DATA FROM WORK PACKAGE
13	WPG-HIC	DATA FROM WORK PACKAGE

Rev. 0

QA/ PECIALIST

(PROCEDURE CQC-19)

WP-139)			
Sheet	1 of	2		
	PAGE		OF	

1. 2 BUILDING 3.EL	9) (4)	5. ENG./FOREMAN (12)	DATE	6. DRAWING , SHT. NO. CONTRACT NO.		8. WELD MIL. TY.	REQUIRED NOE	A-MT/B-PT/C-RT/D-U
EASE FOR WELDING	14)	ATE:	DOR NO.	CLOSED MAT	L STATUS	A R	INSP INIT	DATE:
TID OR . DEVICEN	WLDR TO. PREHEA		-	EXAMINATION		L EXAMINATION	TO TOWN	DEFICIENCY * * DESCRIPTION
	LEMP H A R	NSP DATE H A R INSP DAT	E H A R INSF	DATE REO H A R INSP	ATE N A R II	SP DATE RED WAR	NSP DAYE H A R THIS	DATE
(1)						1111		
						a III	1	
					IIN	$X \cap X \cap X$		
						$\Psi \square \square$		
			1	THE	311	-		
					Ш			
			11/2					
			1111		1111			
		143						
		1111111	+++-		+++	++-++++++++++++++++++++++++++++++++++		
SE QA-34A TO LIST A	DOITIONAL WEL		Ш	W W CUANT	TATIVE DA	TA MUST BE LIST	50 500 ALL 05	
END : H - HOLDPOINT		MEANS HOLD FOR Q	c. R	EMARKS:		TA MOS. DE LIS	TON ALL NES	
A - ACCEPT R - REJECT	*		-					

DATE

SEISMIC WELD DATA REPORT PREPARATION

ITEM

- I Items 1 thru 6 will be filled out by WPG-Eng.
- 2 Data is obtained from information blocks on detail drawing.
- 3 Data is obtained from information blocks on detail drawing.
- 4 Data is obtained from information blocks on detail drawing.
- 5 Data is obtained from information blocks on detail drawing.
- 6 Data is obtained from information blocks on detail drawing.
- 7 WPG-ENG will enter detailed description of all field welds shown on detail dwg. See 4.5.1.3
- 8 Signature and date by initiating WPG-ENG
- 9 Requirements entered by Weld. Eng.
- 10 Requirements entered by Weld. Eng.
- ll Requirements entered by Weld. Eng.
- 12 Signature and date by Weld. Eng.
- Mandatory hold points entered by Weld. Eng
 Desired "Hold" points entered by QA/QC.
- 14 Signature and date by QA/QC Specialist after Initial Review
- 15 Signature and date by QA/QC Specialist after Final Review

CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT

MATERIAL VERIFICATION

Exhibit 4 WP-110

			HANGER NO.
ITEM #	REV. #	WA	AREHOUSE ISSUE VERIFICATION
	==	1.	These items were part of the as received as issued steel for this hanger. Warehouse Engr. Date
		FIE	ELD MATERIAL VERIFICATION
		2.	These items were part of the as received-as issued steel for this hanger. This was verified by comparing the as-received and issue revision against the as-constructed revision.
===		3.	These items were substituted/added and there is documentation to record the source of the material. The source has been investigat and found to be legitimate with a C of C.
<u>c==</u>		4.	These items have been stamped for material identification and the material grade conforms with the requirements of the Bill of Materials.
===		5.	These items have been etched for material identification and the material grade conforms with the requirement of the Bill of Materials.
		6.	These items are catalog parts.
===	=	7.	Per sampling program, there is reasonable assurance that the material conforms to the ASTM material grade requirements of the Bill of Materials.
	HANGER	ENGI	NEER DATE
	REV.		
	B = bolt -	10. 10.	###. HT - HT
C	N = nut - 1 L = load p	ist wi	

			_	4	2		3
A	P	Эe	1	Q	2	x	
T.T	p _	. 1	3	Q.			

= CAROLINA POWER & LIGHT CO. =

CONSTRUCTION MATERIAL REQUISITION

Exhibit 1 AP-XIII-08

	SHNPP	Dogwieitian Na	82063
	Requisiti Craft/Cre	oner:	
		•	
at Warehouse			
	Time:	Rec'd By	
SCRIPTION OF MATERIAL 8	TAG NUMBER	P.O. #	Q/C
~~~		<b>-</b>	
	11		
	7/		
	<u> </u>	)	
		1	2
		1	
			3.7
AUTHOR	ITY .	ISSUED	
BAUGE NO.	FOREMAN OR SUPT.	THE RESERVE AND ADDRESS OF THE PERSON NAMED IN	ARFHOUSEMAN

# CAROLINA POWER & LIGHT COMPANY

Appendix G WP-139 Rev. 0 12/83 SHNPP Sheet 1 of 2 SEISMIC HANGER INSTALLATION TRAVELER RE NO. 14. STRESS NO LINE NO. ITEM TO ENGR. PL (TYPE) THK FCR / PW/DCN 301 (5. 6. WD MAT -12R 10 PROCEDURE INITIAL ITEMS TACKED WITH GAPS COMMENTS DATE FIELD: FITUP REV: CI: FIELD: WELDOU PHASE: QC: FIFL D: FITUP

REV:	FIELD FITOP		1	
	CI:	-	1	
PHASE:	FIELD: WELDOUT	10		
(	oc:			^
REV:	FIELD: FITUP		/	7
	CI:		1/2	3
PHASE:	FIELD: WELDOUT		7	1/
	oc:		-	/
75.4	FIELD: FITUP			
REV:	CI:			1
PHASE:	FIELD: WELDOUT			~
	qc:			
PEV:	FIELD: FITUP			
	CI:			
PHASE:	FIELD: WELDOUT			
	95:			
REV	FIELD: FITUP			
	CI			

FIELD: WELDOUT

FIELD: WELDOUT

FIELD: FITUP

GC:

C::

REV:

PHASE

# SEISMIC HANGER INSTALLATION TRAVELER PREPARATION


ITEM	ENTER BY	
1	WPG-PP	DATA FROM DWG TITLE BLOCK
2	WPG-PP	DATA FROM DWG TITLE BLOCK
3	WPG-PP	FROM WORK PACKAGE
4	WPG-PP	FROM FACE OF DWG.
5	AREA ENGR	
6	AREA ENGR	
7	ORIGINATOR	FROM WPG-CC SCREEN OR LOGS

Appendix H WP-139 Sheet 1 of 2

WD- 1

# WORK DIRECTIVE

		0	*	2
PIPE HAN	IGER No.	(2)	REV.	





# WORK DIRECTIVE PREPARATION

ITEM	ENTER BY				
1	WPG-PP	NUMBER ASSIGNED BY WPG-CC			
2	WPG-PP	FROM DWG TITLE BLOCK			
3	WPG-PP	DETAILED DESCRIPTION OF WORK TO PERFORM AND INSPECT			
4	AS REQ'D	SIGNATURES OF THOSE REQUESTED ON FORM			
	Note:	Items 1-3 may also be entered by Field or Systems Engineers as applicable.			

# CAROLINA POWER & LIGHT COMPANY CORPORATE QUALITY ASSURANCE DEPARTMENT ENGINEERING AND CONSTRUCTION QUALITY ASSURANCE/QUALITY CONTROL SECTION

SEISMIC PIPE HANGER IMSPECTION DOCUMENTATION SYSTEM

NUMBER:

QCI-19.3

INITIAL ISSUE DATE:

September 13, 1982

RECOMMENDED FOR APPROVAL

BY: as functione for

F. Taylor GA/QC SUPERVISOR APPROVED BY:

DIRECTOR - QA/QC

000320.

Little Court

-AL-1.	
Exhibit	1-C
P 2	

# - CONTROLLED DOCUMENT-

CAROLINA POWER & LIGHT COMPANY
CORPORATE QUALITY ASSURANCE DEPARTMENT
QA/QC - HARRIS PLANT SECTION

NUMBER QCI-19.3

REVISION 8

TITLE:

SEISMIC PIPE HANGER INSTALLATION DOCUMENTATION SYSTEM

# REVISION RECORD

Changes and additions are indicated by a vertical bar in the right-hand margin of the revised page(s). Manual holder is to replace affected pages only. This record is to be retained behind the title page of the instruction.

Rev.	Description	Signatures	Date
2	MAJOR REWRITE *ALL PAGES HAVE BEEN	Prepared By: (1) D. Minim	3/2/193
	REVISED DUE TO SECTION NAME CHANGE.	Approved By: It fording	3/21/83
3	*ALL PAGES HAVE BEEN REVISED DUE TO FORMAT	Prepared By: Elas Man	8/31/83
3	CHANGE WITH THE EXCEPTION OF THE EXHIBITS.	Approved By: 40 forthand	8/31/83
4	Para. 6.8 (Add)	Prepared By: Was Meyer	9/22/83
	Para. 4.1.4	Approved By: Cliffe Jam	9-22-83
5	Para. 6.8	Prepared By: Pura Man	10/2/23
		Approved By: 4 + factioned	11/3/53
6	Paragraphs 3.5; 5.1.7	Prepared By: Fland Main	10/26/83
		Approved By: Callegain	10-26-83
7	Paras. 5.1.3; 5.1.7; 6.3	Prepared By: Prop Moun	12/12/87
		Approved By: allegan	12-12-83
8	MAJOR REWRITE; ALL PAGES HAVE BEEN REVISED WITH EXCEPTION OF ATT. 2, 2A, 3, 3A (deleted)	Prepared By: Elfand Marca	2-17-84
		Approved By: Allega-	2-17-84
		Prepared By:	
		Approved By:	

# CAROLINA POWER & LIGHT COMPANY

CORPORATE QUALITY ASSURANCE DEPARTMENT

QA/QC - HARRIS PLANT SECTION

NUMBER

REVISION

QCI-19.3

8

TITLE: SEISMIC PIPE HANGER INSPECTION DOCUMENTATION SYSTEM

# LIST OF EFFECTIVE PAGES

Page No.				Rev. No.	
1				5	
2				5	
3				4	
4				5	
5				6	
6				5	
7				Delete	
Attachment	1			1	
Attachment	2	***		Delete	
Attachment	2A			Delete	
Attachment	3			Delete	
Attachment	ЗА			Delete	

CONTROLLED DOCUMENT-

# CAROLINA POWER & LIGHT COMPANY

CORPORATE QUALITY ASSURANCE DEPARTMENT
QA/QC - HARRIS FLANT SECTION

NUMBER

REVISION

QCI-19.3

5

TITLE: SEISMIC PIPE HANGER INSPECTION DOCUMENTATION SYSTEM

## 1.0 PURPOSE

To provide guidelines for the completion of the Seismic Weld Data Report, ensure consistency in the documentation of pipe hanger weld inspections and identify weld inspection criteria.

## 2.0 SCOPE

This instruction applies to weld inspections and reinspections of Seismic I pipe hanger field welds.

### 3.0 REFERENCES

- 3.1 Procedure CQC-19, Weld Control
- 3.2 Procedure WP-110, Installation of Safety Related Seismic Class I Pipe Hangers
- 3.3 Procedure MP-08, General Welding Procedure for Structural Steel (Seismic and Non-Seismic) and Pipe Hangers
- 3.4 Instruction QCI-19.4, Preparation and Submittal of Seismic I Weld Data Reports
- 3.5 CAR-2165-A-003, Weld Inspection Criteria
- 3.6 Procedure NDEP-605, Visual Inspection of Seismic I, Structural and Hanger Welds (SHNPP)
- 3.7 Procedure WP-139, P'pe Hanger Work Package Preparation
- 3.8 Procedure WP-140, Final Engineering Review of Documentation for Seismic Pipe Hangers and Supports
- 3.9 Procedure CQA-3, Nonconformance Control

## 4.0 INSTRUCTION

#### 4.1 Initiation of SWDR

4.1.1 Welding QC will receive the Seismic Weld Data Report (SWDR) from Welding Engineering.

CONTROLLED DOCUMENT-

REVISION

QCI-19.3

5

TITLE: SEISMIC PIPE HANGER INSPECTION DOCUMENTATION SYSTEM

4.1.2 The QA/QC Specialist/designee shall review the SWDR for accuracy and completeness, ensure the correct weld procedure and filler material hve been specified, enter additional holdpoints as required, sign and date in the "Release for Welding" block.

Note: The drawing revision including any applied modifications shall be entered next to the signature in the "Release for Welding" block.

- 4.1.3 All copies of the SWDR will be routed back to the Work Package Group after review.
- 4.1.4 A new SWDR shall be used for reinspections except as clarified in Para. 5.1. Attach the original SWDR and other documentation needed to substantiate previous weld inspection (i.e. preheat, fitup, root, final inspections, etc.).

## 4.2 Field Inspection

- 4.2.1 The QC Inspector shall verify the preheat, fitup and root NDE holdpoints, as applicable, when notified by the craft. All field welds which have not been inspected will be inspected to the latest revision of the drawing in the hanger package. Acceptance criteria will be in accordance with Reference 3.5.
- 4.2.2 The QC Inspector shall verify increase in fillet weld sizes due to fitup gaps, as applicable, in accordance with Reference 3.2.

Note: CI was not required to document fitups prior to issuance of Reference 3.2, Revision 6, dated 12/4/81. When encountering hangers welded before that date, the gap shall be considered less than 1/16" unless there is visual evidence that the gap is equal to or greater than 1/16", in which case an increase in the fillet weld size shall be in accordance with Reference 3.5.

# CAROLINA POWER & LIGHT COMPANY CORPORATE QUALITY ASSURANCE DEPARTMENT QA/QC - HARRIS PLANT SECTION

NUMBER

REVISION

QCI-19.3

4

TITLE: SEISMIC PIPE HANGER INSPECTION DOCUMENTATION SYSTEM

4.2.3 All field weld inspections will be documented on the SWDR for individual inspections performed in accordance with Reference 3.7.

4.2.4 During final inspection, the QC Inspector will ensure that all field welds have been inspected. Any welds that have not been inspected and accepted will be inspected and documented at this time. Prior to signing off on the SWDR for acceptable welds, the QC Inspector shall verify the status of surplus stock used on the hanger, in accordance with Reference 3.2, Appendix J. Ensure any other document sign-offs required by Reference 3.2 and 3.7 have been signed. After inspection has been completed the hanger package will be reviewed in accordance with Paragraph 7.0.

### 5.0 INSTRUCTIONS FOR MAKING ENTRIES ON FORMS

- 5.1 Upon completion of each individual inspection, if the weld is acceptable, the QC Inspector shall check "Accept" in the appropriate block on the SWDR, initial and date. If the weld is unacceptable, he shall check "Reject" in the appropriate block on the SWDR, but not initial and date. He shall then document the quantitative data of the rejection in the deficiency/description block using the defect code chart (Attachment 1), initial and date. After the deficiencies are corrected and the weld has been reinspected and accepted, the QC Inspector will check the appropriate "Accept" block on the SWDR, initial and date.
- 5.2 NCR numbers are to be recorded in the appropriate section of the SWDR, as applicable.
- 5.3 The QC Inspector shall enter in the appropriate block on the SWDR the revision of the drawing (including field modification numbers) to which he performed each inspection.

## CONTROLLED DOCUMENT.

# CAROLINA POWER & LIGHT COMPANY

# CORPORATE QUALITY ASSURANCE DEPARTMENT

QA/QC - HARRIS PLANT SECTION

NUMBER

REVISION

QCI-19.3

5

TITLE: SEISMIC PIPE HANGER INSPECTION DOCUMENTATION SYSTEM

# 6.0 SEISMIC HANGER INSTALLATION AND INSPECTION TRAVELER

6.1 The QC Inspector shall ensure required sign-off blocks are completed prior to his sign-off in accordance with Reference 3.2.

### 7.0 QA RECORDS FINAL REVIEW PROCESS

- 7.1 The engineering package will be reviewed by QC after final inspection. Documentation making up the QC portion of the engineering package will consist of the following:
  - a. Seismic Weld Data Report(s) (QA-34)
  - b. NDE Request and Report (when applicable)
- 7.2 During the final review process, all previous SWDR's in the hanger work package will be checked to ensure inspections performed prior to 6/26/82 have been reinspected and accepted. Any hangers found that have not been reinspected should be brought to the attention of the QA/QC Specialist and subsequently reinspected.
- 7.3 The closure of any NCR or DDR referenced on the SWDR will be verified prior to the QA/QC Specialist, or his designee, signing off the SWDR as complete.
- 7.4 Verification of material status on added members from surplus hangers/stock steel will be accomplished as outlined in Reference 3.2 if not previously accomplished in the field. The results will be documented in the material status block on the SWDR.
- 7.5 The QA/QC Specialist, or his designee, will perform a technical review of the SWDR to ensure the requirements of Paragraph 4.0 and 5.0 of this instruction have been performed.

-CONTROLLED DOCUMENT-

CAROLINA POWER & LIGHT COMPANY

CORPORATE QUALITY ASSURANCE DEPARTMENT

QA/QC - HARRIS PLANT SECTION

NUMBER

REVISION

QCI-19.3

6

# TITLE: SEISMIC PIPE HANGER INSPECTION DOCUMENTATION SYSTEM

7.5 (cont.)

When he is satisfied that all of the documents are in order, the QA/QC Specialist, or his designee, will sign and date the bottom of the SWDR*. The entire engineering package will then be transmitted to the Work Package Group.

*Note: Signature does not imply verification of shop welds. Inspection records of shop welds are maintained in the QA/QC Records Vault.

# 8.0 ADDITIONAL GUIDELINES

- 8.1 Inspectors shall not sign-off an inspection if a holdpoint is by-passed. Nonconformances shall be identified in accordance with Reference 3.9.
- 8.2 The QC Inspector shall acknowledge any work directive, as required by Reference 3.2.
- 8.3 At the completion of a visual inspection, if subsequent NDE is to be performed, the inspector will ensure that the surface is adequately prepared, in conjunction with Reference 3.6.
- 8.4 The QC Inspector shall verify the qualification of all welders listed on the SWDR. Qualification will be verified on the latest Qualification Status Report available.
- 8.5 For shims, shank welds and spacer plates, a Field Modification Form (Exhibit 1, WP-110) will be used to identify installation instructions, including weld symbols and assignment of field joint numbers.

CAROLINA POWER & LIGHT COMPANY

CORPURATE QUALITY ASSURANCE DEPARTMENT

NUMBER

REVISION

QCI-19.3

5

TITLE: SEISMIC PIPE HANGER INSPECTION DOCUMENTATION SYSTEM

- 8.6 When installation of one hanger member to another hanger member will hide identification markings (i.e. A36 stamp or material grade), and relocation of markings is not possible, or impractical, the QC Inspector will verify the presence of the markings on the material and document the verification in the "Remarks" section of the SWDR.
- 8.7 Periodically, on a random basis, the QC Inspector will check material status on vendor supplied hanger material by reviewing receiving documentation in the QA Records Vault.

#### 9.0 ATTACHMENTS

Attachment 1 - Defect Code Chart

### DEFECT CODE CHART

AS - Arc Strike

CR - Crack

CT - Crater

EC - Excessive Concavity

IF - Incomplete Fusion

IT - Insufficient Throat

MT - Melt Thru

NW - Not Welded

PO - Porosity

SI - Slag Inclusion

SP - Spatter

SS - Surface Slag

UC - Undercut

US - Undersize

FORM NO. 2001		erel		DATE	
		Carolina Pov	ver & Light Company	PAGE OF	
PURPOSE	USER:	- FPPED	FILE NO.	CS NO.	
SKETCH		CNSS	PM NO.	JR NO.	
CALCULATION		□ CONST	WR & A NO.	PT/MI NO.	
COMMENT		MAINT	LCO NO	LER NO.	
DATA		□ PPED		OTHER	
OTHER		OTHER		11 m	
PRIGINATOR	FORGE (	2 WHITE	CHECKED BY	Hellell	
	NA NA	ME		/ NAME	
		0 11 000	- and the second		
		K-H-414 R	EV 3 - JUSTIFICATI	ON	
		-			
F	CR-H-9	79 WAS WELT	IEN TO PROVINC INST	SCTION CRITISEIA FUA	
			WHERES SINCE B-F		
	Alile	DI. THE ALL	E COMECA.A MAG		
				MS PECTION Are E	
MOI	RE RE	TRICTIVE TUAN	1- 74 = CEITERIA USE	D By THE R.A.	
MOI SH	RE RE	PROCEDURE BI	1-74 = CEITERIA USE 195, SUPF) PEV 1	WAS ISSUED TO	
MOI SH Cup	RE RE	PROCEDURE BI THE CRITERIA,	1747 CEITERIA USE 195, SUPF) PEV 1 As to well size, t	WAS ISSUED TO	
Moi SH Cus	RE RE	PROCEDURE BI THE CRITERIA, AS WRITTEN TO	AT TO WELD STEELT ON WORD PRATE ZEUG	WAS ISSUED TO THE PROFILE.	
Moi SH Cus	RE RE	PROCEDURE BI THE CRITERIA, AS WRITTEN TO	AT TO WELD STEELT ON WORD PRATE ZEUG	WAS ISSUED TO THE PROFILE.	
Moi SH Cup Re	RE RE	PROCEDURE BI THE CRITERIA, AS WRITTEN TO ROCEOURE BP	AS TO WELD SIEF, TO INCORPORATE REUCE -9-5, SUP G) AND TO	WAS ISSUED TO  UPF & PROFILE.  SELS CRITERIA FROM  DELLOW THE CRITERIA	
Mor SH Cus Pe B-	RE RE	PROCEDURE BI THE CRITERIA, AS WRITTEN TO ROCEDURE BP USED FOR PA	AS TO WELD SIEF, TO INCORPORATE REUCH -9-5, SUP G) AND TO ELD WELDS INSTEAD	WAS ISSUED TO  WAS ISSUED TO  YEE & PROFILE.  SELS CRITERIA FROM  OR ALLOW THE CRITERIA  OF AWS DI.I.	
Mor SH Cus Pe B-	RE RE	PROCEDURE BI THE CRITERIA, AS WRITTEN TO ROCEDURE BP USED FOR PA	AS TO WELD SIEF, TO INCORPORATE REUCH -9-5, SUP G) AND TO ELD WELDS INSTEAD	WAS ISSUED TO  WAS ISSUED TO  YEE & PROFILE.  SELS CRITERIA FROM  OR ALLOW THE CRITERIA  OF AWS DI.I.	
Mor SH Cus Pe B-	REV 3	PROCEDURE BITTURE THE CRITERIA, AS WRITTEN TO ROCEOURE BRITTEN TO THIS FOR	AS TO WELD SIZE IT OF WELD SIZE IT OF WELD SIZE IT OF WELD SIZE IT OF THE WELDS INSTEAD AND THE AND THE CHANGES THE A	WAS ISSUED TO  WAS ISSUED TO  YEE & PROFILE  SENS CRITERIA FROM  OF ALLOW THE CRITERIA CE ALLOW THE CRITERIA  CCGTANCE, CRITERIA	
Mor SH Cus Pe B-	RE RE.	PROCEDURE BITTURE THE CRITERIA, AS WRITTEN TO POCEDURE BP.  TO THIS FOR FILL TO THIS FOR	THE CRITERIA USE  195, SUPP F) PEU 1  AS TO WELD SIZE, TO INCORPORATE REUSE  19-5, SUIP G) AND TO  ELD WELDS INSTERNO  LR CHANGES THE A  TYPE INDICATIONS TO	WAS ISSUED TO  WAS ISSUED TO  YEE & PROFILE.  SELD CRITERIA FROM  OF ALLOW THE CRITERIA  OF AWSDI.I.  CLEMANCE, CRITERIA  WIS WAS DONE	
MOI SH CUG PE 3- To	REV 3	PROCEDURE BITTUE CRITERIA, AS WRITTEN TO POCEDURE BP.  TO THIS FOR PICTURE TO THIS FOR PASSION"  THE B-P WELD	AS TO WELD SIEF TO INCORPORATE REUDE -9-5, SUPP G) AND TO -9-5, SUPP G) AND TO ELD WELDS INSTERNO LR CHANGES THE A TYPE INDICATIONS TO	WAS ISSUED TO  WAS ISSUED TO  YEE & PROFILE.  SELD CRITERIA FROM  OF AWSDI.I.  CCGMANCE, CRITERIA  WIS WAS DONE  SE A PROCESS	
Mor SH Cus Pe B- To	REV 3	TO THIS FOR THE TO THE CRITERIA, TO THIS FOR THE COLON TO THE TO THE TO THE TOTAL TO THE B-P WELD THE TOTAL	THE CRITERIA USE  195, SUPP F) PEU 1  AS TO WELD SIEF, TO INCORPORATE REUSE  19-5, SUIP G) AND TO  19-6-5, SUIP G)  19-6-6, SUIP G)  19-6-	WAS ISSUED TO  WEET PROFILE.  SEND CRITERIA FROM  OF ALLOW THE CRITERIA  OF AWSDI.I.  CCGTANCE, CRITERIA  WIS WAS DONE  SE A PROCESS  TRANSFER) WHICH	
More SH Cure S	REV 3	TO THIS FOR THE TO THE CRITERIA, TO THIS FOR THE COLON TO THE TO THE TO THE TOTAL TO THE B-P WELD THE TOTAL	THE CRITERIA USE  195, SUPP F) PEU 1  AS TO WELD SIEF, TO INCORPORATE REUSE  19-5, SUIP G) AND TO  19-6-5, SUIP G)  19-6-6, SUIP G)  19-6-	WAS ISSUED TO  WEET PROFILE.  SEND CRITERIA FROM  OF ALLOW THE CRITERIA  OF AWSDI.I.  CCGTANCE, CRITERIA  WIS WAS DONE  SE A PROCESS  TRANSFER) WHICH	
Mor SH CLA Pe B- To	REV 3	PROCEDURE BITTURE THE CRITERIA, AS WRITTEN TO ROCEOURE BRITTEN TO THIS FOR THE TO THIS FOR THE TRANSFER THE APPEARANT	AS TO WELD SIEF TO INCORPORATE REUDE -9-5, SUPP G) AND TO -9-5, SUPP G) AND TO ELD WELDS INSTERNO LR CHANGES THE A TYPE INDICATIONS TO	WAS ISSUED TO  YEE & PROFILE.  SED CRITERIA FROM  OF ALLOW THE CRITERIA  CECHANCE CRITERIA  MIS WAS DONE  TRANSFERD WHICH  DISCONTINUITIES, AND	

WILL UNHECESSARILY REJECT A MUMBER OF WELDS, FOR WELANG AT SHE, WE HAVE LITTLE PROBLEM WITH REJECTIONS FOR "LACK DE PUSION" THE CRITERIA IS TO MPATIALE WITH DESIGN RECAUSE! NF ( WWIGE '73 ADDENOUM WED FOR REFERENCE) DOES HOT STECIFICALLY ADDRESS "LACK OF FUSION" FOR VISUAL INSPECTION.

CRACKS OR "LINEAR DISCONTINUTIES" EXCECOING YIG" IN LENGTH ARE REJECTABLE, HOWEVER THERE IS NO PROVISION FOR REJECTION RASED ON CHMULATIVE LENGTH OF DISCONTINUITIES. AWS DIT IS NOT CLEAR ON SUCH DISCONTINUITIES UNDER "VISUAL INSPECTION", BUT DOES PLLOW DISCONTINUITIES UP TO 12" FOR LANGE WELDS, AND ALSO ALLOWS UP TO 3/8" TOTAL DISCONTINUITY

PER INCH OF WELD. WE ALLOW OWLY 14" OF "FUSION TYPE" DISCONTINUITY PER 6" OF WELD, AND IN ADDITION, WE LIMIT PUROSITY TO A MAK OF 38" CHMMULATIVE, PER INCH OF WELD. (POROSITY IS NOT REJECTABLE POR HF)

SEE ALSO BP/EBASCO INFO, ATTACHED, FOR ADDITIONAL LOIFAJALTIUL

NOTE: AWS DI. | PARA 2.15. SAYS "SPECIAL INSPECTION BEONEROUS SHALL BE HOLED ON THE DEMINES OF M

BERGEN-PATERSON OF FILE COPY NONCONFORT W	CE REPORT
CUSTOMER: EBASCO, INC.	REPORT NO: 12
CUSTOMER P.C. NO: 3301-1	JOB NO: 2291
PROJECT: Shearon Harris Nuclear Power Plant	PAGE 1 OF 1
ITEM/DOCUMENT IDENTIFICATION: (1) Disposition Tags: A-3, A-4, A-5, A-6, A-9, A-10, A-21, A-26, A-27, A-13.	1-18, A-19, A-20,
NONCONFORMANCE DESCRIPTION:  (2) Lack of fusion on standard parts  Insufficient leg on standard part (weld leg)  Undercut on standard part (excessive)	COPY TO: ME DATE
Charles Grant for Ebasco (QC) DATE: 10/27/82 AGREE  EY:	Y: Tau (Serre (245) (MEG)
RECOMMENDED DISPOSITION: XX USE-AS-IS REPAIR  (3)  SCRAP REJECT/RE  COMMENTS:(provide technical justification, repair proced. et  Please provide answers as to whether the parts are Bergen-Paterson standard practice.	TURN TO VENDOR c. as applicable)
By Lauteur Cantelles .Mes.) _ AGREE _ DISAGREE B	Y: A Libour (20 M=)
CONCURRENCE BY:  Authorized Muclear Inspector  Mattis Confication  Customer Rep. (signature)  Title	Bug. 11/23/82
DISPOSITION VERIFIED BY: NA -	(QC)DATE:
MATERIAL REVIEW BOARD ACTION: (including cause of notes)  It is the decision of the M.R.B. that the condition non-relevant. A review of the weld stresses show actual to Code Allowables. Parts with the describing tested with results confirming the engineering evaluation of the Material Transfer of TRNHTL, 1082-321A.  What as Material Transfer (Freduct Materials) (SA Materials)	ons described are conservatism of bed deficiencies were aluation. REF:

	BE EN-PATERSON PIPESUPPORT CORF NO. 8-3
	DISPOSITION TAG DATE 10-26-12
	JOB/LOT NO. 2291 4 6909 QTY. 1 SIZE 1.5
_	DISCREPANCY: LACK of FUSION ON PRODLE AT
.0	NG AS- 236-1-CH-H-140 (LONC)
	COMMENTS: FURTHER ACTION REQUIRED
	DISPOSITION COMPLETED
	QCUSE
907	GC CHIEF EXAM. GEN. FOREMAN
	BERGEN-PATERSON PIPESUPPORT CORP. NO. 8-4
	DISPOSITION TAG DATE 10-36-82
	JOB/LOT NO. 2291 44 80%9 OTY. / SIZE 1.5
	DISCREPANCY: LACK OF FUSION ON PADDIE AT
0	장 보다 하는 것이 없는 것이 없는 것이 없다면 하는 것이 없는 것이었다면 없어요.
-	HER # A1-216-1-5I-H-330 [epach
	COMMENTS: FURTHER ACTION REQUIRED
	DISPOSITION COMPLETED
	QCUSE
0074	OC CHIEF EXAM. GEN. FOREMAN
	BEDGEN DATESCON CUESCON CONTRACTOR
	BERGEN-PATERSON PIPESUPPORT CORP. NO. A-5
	DISPOSITION TAG DATE 10-26-12
	JOB/LOT NO. 2241 7 80x OTY. 1 SIZE 1.5
	DISCREPANCY: LACK OF FUSION ON PRODLE AT
0	AKEN MARKELL
	NGR # 12-261-1-CH-H-1495
	COMMENTS: FURTHER ACTION REQUIRED
	DISPOSITION COMPLETED
	QCUSE
	CCOSE

BERGEN-PATERSON PIPESUPPORT CORP. NO. A-C
DISPOSITION TAG DATE 10-26-42
JOB/LOT NO. 229/ 14 80% OTY. / SIZE 3
PART NO. 2105 DEPT. SHIPPING INITIATED BY C. HRAN
DISCREPANCY: LACK OF FUSION ON PADDLE AT
AREA MARKED
O HER # 71-286-1-AS-H-400
DREWORK DSCRAP FURTHER ACTION REQUIRED
COMMENTS:
DISPOSITION COMPLETED
QCUSE
GEN. FOREMAN
GEN. FOREMAN
BEDGEN DATERSON DIDECURDORT CORD
BERGEN-PATERSON PIPESUPPORT CORP. NO. 8-9
JOB/LOT NO. 2291 12 BOX TO OTY. / SIZE 20
PART NO. 2001 DEPT. SHIPPING INITIATED BY C. HOAL
DISCREPANCY: LACK OF FULLOW ON PADDLE ENG
where Markod
WER # A3-261-1-MS-H-89 1-02-
LREWORK LISCRAP FURTHER ACTION REQUIRED
COMMENTS:
DISPOSITION COMPLETED
QCUSE
OCT-ME GC CHIEF EXAM. GEN. FOREMAN
BERGEN-PATERSON PIPESUPPORT CORP. NO. A-10
DICROCITION TAG
12 Box
DISCREPANCY: 1 CON DEPT. SHIPPING INITIATED BY C. HEAN
DISCREPANCY: LACK OF FULION ON END ATTACH
J HGR C1-221-1-52-4-474 (CC)
COMMENTS: FURTHER ACTION REQUIRED
DISCOSITION CONT.
DISPOSITION COMPLETED
QCUSE
OCT-00 OC CHIEF EXAM. GEN. FOREMAN

BERGEN-PATERSON PIPESUPPORT CORP. NO. A-13	
DISPOSITION TAG DATE 10-24	-42
JOB/LOT NO. 229/ # 4768 QTY. / SIZE	NA
DISCREPANCY: LACK OF FUSION ON STRUT	
O HER # AS-236-1-5W-H-1649	2_
COMMENTS:	D
DISPOSITION COMPLETEDQC	USE
OC CHIEF EXAM. GEN. FOREMAN	
	7.
BERGEN-PATERSON PIPESUPPORT CORP. NO. R-IF	
DISPOSITION TAG DATE 10-36	. 4.7
JOB/LOT NO. 229/ 12 6007 QTY. / SIZE /	-
PART NO. 2002 DEPT. Shipping INITIATED BY C.A.	
DISCREPANCY: LACK of FOSION ON PADDLE A	CANT
Area Markal	-
O HER # C1-236-1-PD-H-3004 VABREE	
DREWORK DSCRAP FURTHER ACTION REQUIRE	
COMMENTS:	
DISPOSITION COMPLETED	
QC U	25
oct-s QC CHIEF EXAM. GEN. FOREMAN	
BERGEN-PATERSON PIPESUPPORT CORP. NO. A -19	
DISPOSITION TAG DATE 10-26	
JOB/LOT NO. 229/ 1/2 80% QTY. / SIZE /	.5
PART NO. 2001 DEPT. Shipping INITIATED BY	Leart
DISCREPANCY: Excassive UNDERCUT ON PRODU	e
AT Area Marked	7
- HGR # A6-236-1-CS-H-2759 YY-31-	
COMMENTS:	D
HGR #	
DISPOSITION COMPLETED	
oc i	SE
. OCT- OC CHIEF EXAM. GEN. FOREMAN	

	BENGEN-PATERSON PIPESUPPORT CORP. NO. 7-20
	DISPOSITION TAG DATE 10-26-F2
	JOB/LOT NO. 2391 12 80X OTY. / SIZE 1.5
	PART NO. 2002 DEPT. Shipping INITIATED BY C. Beaut
:	DISCREPANCY: IMUFFICIENT Lay on woll Boad
	Marked Send
	O HER # A4-236-1-DW-H-426 resnel
	BREWORK DISCRAP FURTHER ACTION REQUIRED
	COMMENTS:
	DISPOSITION COMPLETED
-	QC USE
	OCT-00 QC CHIEF EXAM. GEN. FOREMAN
- 1	BERGEN-PATERSON PIPESUPPORT CORP. NO. R - 11
-	DISPOSITION TAG
1	JOB/LOT NO. 229/ # 6544 QTY. / SIZE /.5
1	PARTNO SACIL DEST OF
	DISCREPANCY: DEPT. Shoping INITIATED BY C. ARANT
1	DISCREPANCY: LACK OF FUSION ON PRODLE AT
1	
1	HOL # A3-236-1-DW-H-386 Re-
1	COMMENTS: FURTHER ACTION REQUIRED
1	COMMENTS:
1	
i	DISPOSITION COMPLETED
1	QCUSE
!_	OCT- QC CHIEF EXAM. GEN. FOREMAN
	BERGEN-PATERSON PIPESUPPORT CORP. NO. A-26
	DISPOSITION TAG DATE 10-26-F2
	JOB/LOT NO. 229/ # 1720 OTY SIZE 1.5
	PART NO. STEFF DEPT. SHIPPING INITIATED BY C. BRANT
	DISCREPANCY: LACK of FUSION ON WELL Arons
	MARKEL TON ON WELL Areas
	- HER # C1-221-1-FP-H-1663 12 ===================================
	DREWORK DSCRAP FURTHER ACTION SERVICES
	COMMENTS: FURTHER ACTION REQUIRED
	DISPOSITION COMPLETED
	QC USE
	OCT-E OC CHIEF EXAM. GEN. FOREMAN


. .

	BERGEN-PATERSON PIPESUI		NO. #-27
	JOB/LOT NO. 229/ 200		DATE 10-26-\$3
0	DISCREPANCY: LACK of A		
	HGR # C1-236-1-C	S-H- 256 2 _ FURTHER A	CTION REQUIRED
	DISPOSITION COMPLETED		OC USE
007	OC CHIEF EXAM.	GEN. FOREM	AN -

FOR
Parts 2001-15, 2003-15, 72249-15
FOR
BERGEN-PATERSON JOB # 2291

1)6 Comments
100 Comments
100 Comments
11/20/82

### TEST REPORT



Bergen-Paterson Pipesupport Corp. 34 Moulton Street Laconia, NH 03246

REPORT NO TRN	NHTL-1082-321A
OUR JOB NO. NHT	TL-0055
YOUR P.O. NO	N/A
PAGE 1 of 31	PAGE REPOR
	er 18, 1982

DATE OF TEST: September 30, 1982

PERFORMED AT:

New Hampshire Testing Laboratories

34 Moulton Street

Laconia, New Hampshire

TEST SPECIFICATIONS:

Load Rating Test Procedure for NF

Qualification

Procedure No. BP-11-6 Dated August 1, 1980

PREPARED BY: Michael & Tucken	DATE: 10-22-92
REVIEWED BY: Litub Pllis	DATE: 11-19-82
APPROVED BY:	DATE: 11/22/82

secones and Lays: and carefully con all respects.	The information conducted tests and is to	tained in this recom the best of his know	being duly swarm t is the result of complete viedge true and correct in

SUBSCRIBED and swom to before me this ____day of _

... Notary Public in and for the State of New Hampanire at large.

TATE OF NEW HAMPSHIRE

COUNTY OF BELKNAP

My Commission expires ...

New Hampanire Testing Laboratories shall have no liability for damages any kind to person or property, including special or consequential damage resulting from New Hampshire Testing Laboratories providing the service covered by this report.

### TABLE OF CONTENTS

Section		Page Number
1.0 PURPO	OSE	3
2.0 REFE	RENCES	3
3.0 DEFIN	NITIONS	3
4.0 TEST	SPECIMEN DESCRIPTION	3
5.0 MOUNT	TING REQUIREMENTS	4
6.0 SUMM	ARY	4
7.0 TEST	CONDITIONS AND EQUIPMENT	4 - 5
8.0 TEST	REQUIREMENTS AND PROCEDURE	6
9.0 CONCI	LUSIONS	6
APPENDIX I	TEST DATA - PART 2001-1.5	7 - 14
APPENDIX II	TEST DATA - PART 2003-1.5	15 - 21
APPENDIX III	TEST DATA - PART 72249-2.5	22 - 28
APPENDIX IV	EQUIPMENT LIST AND TEST LOG	29 - 31

### 1.0 PURPOSE:

行ののの方

- 1.1 The purpose of this test report is to present the test methods used and the test results obtained during the load rating tests of Bergen-Paterson Pipesupport Corp. Parts 2001-1.5, 2003-1.5, and 72249-1.5 for Shearon Harris Nuclear Power Plant, Bergen-Paterson Job Number 2291.
- 2.0 REFERENCES:
- 2.1 Load Rating Test Procedure for NF Qualification, Procedure Number BP-11-6, dated August 1, 1980.
- 3.0 <u>DEFINITIONS</u>:
- 3.1 LOAD RATING: Maximum load limit for a specified service limit as determined in ASME Boiler and Pressure Vessel Code Section III, NF-3262.4.
- 3.2 LEVEL A SERVICE LIMITS: As defined in ASME Section III, NCA 2142.2, are those loadings to which the component support may be subjected in the performance of its specified service function.
- NCA 2142.2 are those loadings to which the component support may be subjected one time only. Gross general deformations are permitted with some consequent loss of dimensional stability and damage requiring repair, which may require removal of the component support from service.
- 3.4 TEST LOAD: A support load equal to or less than the load under which the component support fails to perform its specified support function.
- 3.5 COMPONENT SUPPORTS: Structural elements whose function include carrying the weight of components or providing them with structural stability.
- 4.0 TEST SPECIMEN DESCRIPTION:
- 4.1 All drawings and revision levels used to manufacture the test specimen were recorded. The documents needed to trace all material used in the test specimen were secured.

#### TEST REPORT NO. TRNHTL-1082-321A

- 5.0 MOUNTING REQUIREMENTS:
- 5.1 The parts 2003-1.5 were welded to four bolt fixture plates as shown in the photograph on page # 16.
- 5.2 The parts 2001-1.5 and 72249-1.5 were load rated using a part 100-1.5 welded to a four bolt test fixture plate as shown in the photograph on page # 9 and 23.
- 6.0 SUMMARY:

---

T. .

15

٧...

12 17 10

- 6.1 The test specimens were all load rated in accordance with Procedure Number BP-11-6 Revision 0.
- 7.0 TEST CONDITIONS AND EQUIPMENT:
- 7.1 Ambient Conditions
- 7.1.1 All measurement and tests were performed at ambient conditions. Ambient Conditions are:

Temperature: 750 + 10\$

Relative Humidity: 90% or less

Atmospheric Pressure: 20 - 32 Inches of Mercury

- 7.2 Measurements and Tolerances
- 7.2.1 The maximum allowable tolerance of test measurements unless otherwise stated was:

Temperature: + 10%

Time: + 5% - 0

Displacement: + 5%

Force: . + 10% - 0 :

- 7.3 Instrumentation Equipment Sheet
- 7.3.1 The Instrumentation Equipment Sheet was maintained for each piece of equipment that participated in the test. A calibration sticker indicating the last calibration, the next calibration due date, and by whom calibrated was affixed to the equipment whenever possible.
- 7.3.2 All equipment calibration was performed with and traceable to U.S. National Bureau of Standards.

### 7.4 System Calibration

in

..

0

00000

(1) (2) (3) (1) (1)

- 7.4.1 Instrumentation system calibration was accomplished immediately prior to testing. Equipment calibration intervals were at least once per year. Actual system tolerances for all static performance measurements were better than + 5%. The recording accuracies for tests were better than + 5%.
- 7.5 Test Fixtures and Set-up
- 7.5.1 The test system was designed and maintained to insure compliance with the testing parameters defined in this specification.
- 7.5.2 The test fixtures and each test set-up was verified and inspected prior to the performance of each test by a Bergen-Paterson representative or his authorized designate.
- 7.5.3 A photograph of a typical test set-up was taken for documentation purposes.
- 7.6 Test Data Documentation
- 7.6.1 Test Data Sheets
- 7.6.1.1 All test data was recorded on Test Data Sheets. See Appendices I thru III.
- 7.6.2 Log Sheets
- 7.6.2.1 A Log Sheet was maintained throughout test. See Appendix IV.
- 7.6.3 Notice of Anomaly
- 7.6.3.1 A Notice of Anomaly (NOA) shall be generated within 24 hours for an out-of-specification occurrence to a specimen and testing halted until disposition of NOA is decided on. No NOA's were generated during the testing of these parts.
- 7.6.4 Photographs
- 7.6.4.1 A photograph of each test specimen was taken after the competion of testing.

### TEST REPORT NO. TRNHTL-1082-321A

- 8.0 TEST REQUIREMENTS AND PROCEDURES
- 8.1 Requirements
- 8.1.1 All parts were tested in tension. The required measurements were permanent set deflections at Level A and at Level D loads. The final test load and mode of failure were also required for load rating calculations.
- 8.2 Procedure

1

[]

0

0

5

...

- 8.2.1 Dial indicators were placed so as to measure deflection over the entire length of the specimen. Test sequence for each specimen was as follows.
- 8.2.2 Level A Service Limits (Design Load)
- 8.2.2.1 An initial load of 10% or 100 lbs., whichever was greater, was applied to the speimen. Load was then increased gradually noting deflection readings at a minimum of five different points. Load was applied until (1.1) x Level A Service Limit was achieved. This load was held for 60 seconds and released to the initial load. The deflection reading at this point was noted as Level A permanent set. Failure criteria was a maximum of 0.005" permanent set.
- 8.2.3 Level D Service Limits (Faulted Load)
- 8.2.3.1 Again, load was increased gradually noting deflection reading at various points. Load was applied until (1.1) x Level D Service Limit was achieved. This load was held for 60 seconds, the deflection noted, and load was released to the initial load. The deflection was noted as Level D permanent set. Failure criteria was amaximum of 0.063" permanent set.
- 8.2.4 Final Test Load
- 8.2.4.1 Load was gradually increased one more time, until the specimens would no longer hold load. Given the final load achieved, the mode of failure, and the material which failed, the maximum load rating of the component support may be calculated.
- 9.0 CONCLUSIONS
- 9.1 All the specimens tested withstood the Level A loads within a maximum of 0.005" permanent set, and Level D loads within a maximum permanent set of 0.063". The specimens also reached sufficient final test loads to verify rated loads.

()


to o o o o o o o o

APPENDIX I
Part 2001-1.5 TEST DATA

(:


000000000000000000

TEST REPORT NO. TRNHTL-1082-321A




TYPICAL SET-UP, PART 2001-1.5

()




SPECIMEN A Part 2001-1.5




SPECIMEN B Part 2001-1.5

0

0000000000



SPECIMEN C Part 2001-1.5



SPECIMEN D Part 2001-1.5


## NEW TESTING LABORATORIE!

# PAGE NO. 11 REPORT NO. TRNHTL-1082-321A DATA SHEET

Customer	Bergen-Paterson				
Specimen _	Strut End				
Part No	2001-1.5	Amb. Temp.	70° F	Job No. 0055	
Spec.	BP-11-6	Photo	Yes	Report No N/A	_
Para		Specimen Temp.	Ambient	Start Date 9/30/82	

st Tide	Load Rating Test
LOAD	DEFLECTIONS
150	0.000
300	0.000
600	0.001
900	0.002
1200	0.0025
1500	0.0025
1650	0.003 1.1 x Level A
150	0.001
300	0.001
- 900	σ.σσz
1200	0.0025
1500	0.0025
2000	0.003
2525	0.0035 1.1 x Level D
150	0.001
	Ultimate test load of 20,000 lbs. when
*	paddle broke on both sides just in front
	of welds.

Specimen Failed	Witness Hele LH Flytter Date: 9/30/82
Specimen Passed	Witness # # 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
netrinW AC	Sheet No
	Approved fitter D. This



See a constant


### PAGE NO. 12 REPORT NO. TRNHTL-1082-321A

### DATA SHEET

Customer	Bergen-Paterson							
Specimen _	Strut End							
Part No.	2001-1.5		Amb. Temp	70°	F	Job No.	0055	
Spec.	BP-11-6		Photo	Yes		Report No.	N/A	
Para			Specimen Tem	a Ambie	nt	Start Dam	9/30/82	

est Tide	Load Rating Test	_
LOAD	DEFLECTIONS	
150	0.000	
300	0.000	
600	0.0005	
900	0.001	
1200	0.001	
1500	0.0015	
1650	0'.0015 1.1 x Level A	
150	0.000	
300	0.000	
900	0.0005	**
1200	0.001	
1500	0.0015	
2000	0.0015	
2525	0.0015 1.1 x Level D	
150	0.0005	
	Ultimate test load of 19,800 lbs. when	
	paddle split at end.	

Speciment Failed	Tested By Soften Come Date: 9/30/82
Specimen Passed	Witness Alfred H State Oate: 8/50/82
NOA Written	Sheet No.
	Approved Letus Ellis



0000

17

. .

+4

6 5

500000

PAGE NO. 13

REPORT NO. TRNHTL-1082-321A

Start Date 9/30/82

DATA SHEET


Part No. 2001 Spec BP-11	Amb. Temp	700	F	Job No.	0055	
	THE RESERVOIR CO. LANSING STREET, SQUARE, SQUA					
Customer Berg Specimen Stru						

Specimen Temp. Ambient

Test Title Load Rating Test

LOAD	DEFLECTIONS
150	0.000
300	0.000
600	0.000
900	0.000
1200	0.000
1500	0.000
1650	0.000 1.1 x Level A
150	0.000
300	0.000
900	0.000
1200	0.000
1500	0.000
2000	0.000
2525	0.000 1.1 x Level D
150	0.000
	Ultimate test load of 20,600 lbs. when
P. D. D. H	paddle split at end.

Specimen Failed	Tested By Logist Tente Date: 9/30/80
Specimen Passed	Witness 4 4 4 1 1 2 Date: 9/30/82
NOA Written	Sheet No qf
	Approved Titi O. Ellis



Second and a

17

2 8

150

0000000

### PAGE NO. 14 REPORT NO. TRNHTL-1082-321A

### DATA SHEET

Para	Specimen Temp	Ambient	Start Date	9/30/82
Spec. BP-11-6	Photo	Yes	Report No	N/A
Part No. 2001-1.5	Amb. Temp	70° F	Job No.	0055
Specimen Strut End				
Customer Bergen-Paterson				

est Tide	Load Rating Test	
LOAD	DEFLECTIONS	
150	0.000	
300	0.000	
600	0.000	
900-	0.000	
1200	0.000	
1500	0.000	
1550	0.000	I.I x Level A
150	0.000	
300	0.000	
900	·- · · · · · · · · · · · · · · · · ·	- 22 ( - 2 )
1200	0.000	
1500	0.000	
2000	0.000	
2525	0.0005	1.1 x Level D

Specimen Failed	Witness But 1 Super Outs: 9/30/82
Specimen Passed	Witness John 14 State Date: 9/8/82
NOA Written	Sheet No of
	Approved Litub Ellis

Ultimate test load of 20,500 lbs. when

paddle split both sides just outside weld.

0.0005

PAGE NO. 15


TEST REPORT NO. TRNHTL-1082-321A

APPENDIX II
Part Z003-1.5 TEST DATA


mannananan

(1

TEST REPORT NO. TRNHTL-1082-321A



SPECIMEN A Part 2003-1.5




SPECIMEN B Part 2003-1.5

TEST REPORT NO. TRNHTL-1082-321A



SPECIMEN C Part 2003-1.5



SPECIMEN D Part 2003-1.5

# NOW HOMODATORIE!

4840

250

PAGE NO. 18 ) REPORT NO. TRNHTL-1082-321A

### DATA SHEET

Customer	Bergen-Paterson	n				
Specimen	End Attachment					
Part No	2003-1.5	Amb. Temp.	70° F	Job No.	NHTL-005	- 2
SpecBP-11-6		Photo	Yes	Report No	N/A	1.
Para.		Specimen Tem	Ambient	· · · · · ·	9/30/82	-

Test Tide	oad Rating Test
LOAD	DEFLECTIONS
250	0.000
500	0.000
1000	0.000
1500	0.000
2000	0.000
2500	0.000
2750	0.000 1.1 x Level A
250	0.000
500	0.000
1000	0.000
2000	0.000
3000	0.000
4000	0.000


Ultimate test load of 28,200 lbs. when pin pulled out spliting one ear at the end and bending the other outwards.

1.1 x Level D

Specimen Failed	Tested By Superal / Lagore 000: 9/20/80
Specimen Passed	Witness Albert No The Cheron 9/20/12
NOA Written	Sheet No.
	Approved fation Ellis

0.000

0.000



# PAGE NO. 19 () REPORT NO. TRNHTL-321A


### DATA SHEET

Customer _	Bergen-Paterson				
Specimen _	End Attachment				
Part No	2003-1.5	Amb. Temp	70° F	Job No. NHTL-005	
Spec.	BP-11-6	Photo	Yes	Report No. N/A	
Para.		Specimen Tem	Ambient	Start Date 9/30/82	

Test Tide Load Rating Test

LOAD	DEFLECTIONS
250	0.000
500	0.000
1000	0.000
1500	0.000
2000	0,0005
2500	0.0005
2750	0.0005 1.1 x Level A
250	0.000
500	0.000
1000	0.000
2000	0.000
3000	0.001
4000	0.001
4840	0.0015 1.1 x Level D
250	0.0005
No. of the last	Ultimate test load of 27,800 lbs. when pin
	pulled out splitting one ear at end and
* 177 4 3 mg to	bending the other outwards.

Specimen Failed	Witness That A State on 9/30/82
Specimen Passed	Witness That A 1/2000 000: 9/80/82
NOA Written	Approved P. T. U. C. Chiles
	Approved TITU C. CLES



### MEPORT NO. TRNHTL-182-321A

### DATA SHEET

Customer Bergen-Paterson

Park No. 2003-1.5

Pari No. 2003-1.5 Spec. BP-11-6

-

8.2

200

17

Para ___

-11-6

Amb. Temp. 70°F Yes

Photo Yes
Specimen Temp. Ambient

Peport No. NHTL - 0055


Report No. N/A

Start Date 9/30/82

Test Tide ____ Load Rating Test

LOAD	DEFLECTIONS
250	0.000
500	0.000
1000	0.000
1500	0.000
2000	0.000
2500	0.000
2750	0.0005 1.1 x Level A
250	0.0005
500	0.0005
1000	0.0005
2000	0.000\$
3000	0.0005
4000	0.0005
4840	0.001 1.1 x Level D
250	0.0005
	Ultimate test load of 29,000 lbs. when
	the pin pulled spliting one ear at the
	end and bending the other outwards.

Specimen Failed	Torus of My March Japanie Don 9/34/10
Specimen Passed	Witness filedel stoffe Out 9/30/82
NOA Written	Short Mr. A
	Approved Litis 6 Elici



### PAGE NO. 21 REPORT NO. TRNHTL-1082-321A

### DATA SHEET

Customer .	Bergen-Paterson					
	rad Assachment		70° F		NHTL-0C55	
Part No	2003-1.5	Amb. Temp		Job No		
Spec.	BP-11-6	Photo		Report No.	9/30/82	_
		Specimen Tem	p. Ambient	Start Date	9/30/82	-

LOAD	DEFLECTIONS	
250	0.000	
500	0.001	
1000	0.001	
1500	0.001	
2000	0.001	
2500	0.001	
2750	0.0015 1.1 x Level A	
250	0.000	
500	0.000	
1000	0.0005	
2000	0.001	
3000	0.001	
4000	0.002	
4840	0.002 1.1 x Level D	
250	0.000	
	Ultimate test load of 28,000 lbs. v	when

	Town By Morpholy Date: 9/20/10
Specimen Failed	Tested By Dogoral States Date: 9/20/32
Specimen Passed	a v of
NOA Written	Approved Peter 15 Ellis


PAGE NO. 22

TEST REPORT NO. TRNHTL-1083-321A


APPENDIX III
Part 72249-2.5 TEST DATA

0


TRNHTL-1082-321A TEST REPORT NO.



TYPICAL SET-UP PART 72249-2.5




SPECIMEN A Part 72249-2.5




SPECIMEN B
Part 72249-2.5

TEST REPORT NO. TRNHTL-1082-321A



SPECIMEN C Part 72249-2.5

כז כז נז נז כז נז כז כז כז



PAGE NO.

26

TRNHTL-1082-321A

### DATA SHEET

Para		Specimen Tem	p.Ambient	Start Date 9/30/82
Spec.	BP-11-6	Photo	Yes	Report No. N/A
Part No	72249-2.5	Amb. Temp	70° F	Job No. NHTL-0055
Specimen _	Strut End			
Customer _	Bergen-Paterson	n		

Test Title Load Rating Test

ロロロロ

80 C3 C3 C3

LOAD	DEFLECTIONS
250	0.000
500	0.0005
1000	0.001
1500	0.001
2000	0.0015
2500	0.002
2750	0.002 1.1 x Level A
250	0.001
500	0.001
1000	0.0015
2000	0.0015
3000	0.002
4000	0.0025
4620	0.0035 1.1 x Level D
250	0.001
	Ultimate test load of 24,200 lbs. when
	paddle split at end.

Specimen Failed	Tested By Nichter Languet Date: 9/32/62
Specimen Passed	Witness Aseld Deplet Date: 9/50/12
NOA Written	Sheet No of
	Approved Petro 10. Pelis



C C C C

60 60


## PAGE NO. 27 REPORT NO. TRNHTL-1082-321A

## DATA SHEET

Customer	Bergen-Paterson				
Specimen	Strut End				
Part No	72249-2.5	Amb. Temp.	70° F	Job No	NHTL-0055
	BP-11-6	Photo	Yes	Report No.	N/A
Para		Specimen Tem	p. Ambient	Start Date.	

LOAD	DEFLECTIONS
250	0.000
500	0.000
1000	0.000
1500	0.0005
2000	0.0005
2500	0.0005
2750	0.0005 1.1 x Level A
250	0.000
500	0.000
1000	0.000
2000	0.0005
3000	0.001
4000	0.001
4620	0.001 1.1 x Level D
250	0.000
	Ultimate test load of 27,200 lbs. when
	paddle split at end.

Specimen Failed	Tested By Suspicion Seems Date: 9/30/82
Specimen Passed	Witness Hat Detto Date: 9/30 82
NOA Written	Sheet No of
	Approved 11th 15 this



## PAGE NO. 28 REPORT NO. TRNHTL-1082-321A

## DATA SHEET

Customer	Bergen-Paterson				
Specimen	Strut End	and the period of the same			
Part No	72249-2.5	Amb. Temp	70° F	Job No. NHTL-0055	
	BP-11-6		Yes	Report No. N/A	
Pers		Specimen Tem	o. Ambient	Start Date 9/30/82	

250	
230	0.000
500	0.0005
1000	0.0015
1500	0.002
2000	0.003
2500	0.003
2750	0.003 1.1 x Level A
250	0.0025
500	0.0025
1000	0.0025
2000	0.003
3000	0.0035
4000	0.004
4620	0.005 1.1 x Level D
250	0.0025
	Ultimate test load of 25,000 lbs. when the

Sansiman Failed	Tested By Nix 11-44 Course: 9/ 50/85
Specimen Failed Specimen Passed	Witness Pebelot At 14 Date: 9/30/82
NOA Written	Sheet No. 2 , , of
	Approved / tuly illi.

APPENDIX IV EQUIPMENT LIST AND TEST LOG

11	ľ			ר:יו	E.3	(	7	t"D	ſ	1	C.3	c)	17.1		r-1	r= 1	- 1	7.1	r-1	n	
	1	一	Now h	lempshire NG LABOR	ATORIES			INS	TRU	ME	ENTAT	TON E	QUIPN	MENT :	SHEET						

## INSTRUMENTATION EQUIPMENT SHEET

Date 9/30/82	Job No.	NHTL-0055	Test Area 25000 Test Stand
Technician R.A. Moore	Customer	Shearon Harris	Type Test Load Rate

No.	Instrument		Model	Serial	NHTL or			Ce	libration
	- minoment	Manufacturer	No.	No.	Gov't No.	Range	Accuracy	On	Due
	Dial Indicator	Starrett, Inc.	25-441J V4Z-200K	N/A	704	,001	for first	7/14/82	10/14/82
	Transducer Load	Transducer, Inc.	10P1	24279	721	0-2001bs	4 078 al	4/18/82	10/18/82
	Strain Gage/Indic	Daytronics, Inc.	3270	2177	639	+ 5V	+ +951 01	9/1/82	3/1/82
	Light Beam Recorder	Soltec Corp.	5L32	8080288	719	0-100y .08-200	+ 21per + 50mm	9/1/82	3/1/82
_									
-									
		AND THE SECOND							
				•					
							i		

Instrument Test Engineer _

PAGE NO. 30

()

PAGE NO. 30 )
REPORT NO. TRNHTL-1082-321A

TIME REMARKS (Include Run Number, Part Changes, Shift Changes, 12:30 PM Specimen A 2003-1.5 Lot Coded Ell 1:45 " Specimen B 2003-1.5 Lot Coded Ell 1:15 " Specimen B 2003-1.5 Lot Coded Ell 1:15 " Specimen B 2001-1.5 Lot Coded CS 2:00 " Specimen A 2001-1.5 Lot Coded CS 2:30 " Specimen B 2001-1.5 Lot Coded CS 2:30 " Specimen B 2001-1.5 Lot Coded CS 3:00 " Specimen B 2201-1.5 Lot Coded ABA 3:15 " Specimen B 72249-1.5 Lot Coded ABA 3:30 " Specimen C 72249-1.5 Lot Coded ABA 3:30 " Specimen C 72249-1.5 Lot Coded ABA	JOB NO.	NIITL-0055	ATTIL NEW HAMPSHINE TESTING LABORATORIES  34 Moulton Street Leconia, NH 03246  LOG SHEET	
12:30 PM Specimen A 12:45 " Specimen B 1:00 " Specimen D 2:00 " Specimen B 2:30 " Specimen B 3:00 " Specimen B 3:15 " Specimen B 3:30 " Specimen C 5:30 " Sp	CUSTOMER	Shearon Ha	Power P	TEST ENGINEER R.A. MOORE
12:30 PM Specimen A 12:45 " Specimen B 1:00 " Specimen C 1:15 " Specimen B 2:00 " Specimen B 2:30 " Specimen B 3:00 " Specimen B 3:15 " Specimen B 3:30 " Specimen C	DATE	TIME		and all other persions date.
" Specimen B 2003-1.5 " Specimen D 2003-1.5 " Specimen A 2001-1.5 " Specimen B 2001-1.5 " Specimen B 2001-1.5 " Specimen B 72249-1.5 " Specimen B 72249-1.5 " Specimen C 72249-1.5	28/05/6	12:30 PM	<	
" Specimen C 2003-1.5 " Specimen B 2001-1.5 " Specimen B 2001-1.5 " Specimen B 2001-1.5 " Specimen B 2001-1.5 " Specimen B 72249-1.5 " Specimen B 72249-1.5 " Specimen C 72249-1.5				
" Specimen B 2001-1.5 " Specimen B 2001-1.5 " Specimen C 2001-1.5 " Specimen B 72249-1.5 " Specimen B 72249-1.5 " Specimen C 72249-1.5		1		
" Specimen A 2001-1.5 " Specimen C 2001-1.5 " Specimen D 2001-1.5 " Specimen A 72249-1.5 " Specimen C 72249-1.5 " Specimen C 72249-1.5				
" Specimen C 2001-1.5 " Specimen D 2001-1.5 " Specimen A 72249-1.5 " Specimen B 72249-1.5 " Specimen C 72249-1.5			2001-1.5	
" Specimen C 2001-1.5 " Specimen A 72249-1.5 " Specimen B 72249-1.5 " Specimen C 72249-1.5			2001-1.5	
" Specimen D 2001-1.5 " Specimen B 72249-1.5 " Specimen C 72249-1.5			2001-1.5	
" Specimen A 72249-1.5 " Specimen B 72249-1.5 " Specimen C 72249-1.5			2001-1.5	
" Specimen B 72249-1.5 " Specimen C 72249-1.5			A 72249-1.5	
" Specimen C 72249-1.5			B 72249-1.5	
	1	- 1	C 72249-1.5	



## TERSON

HOM

LACOMA NEW HAMPSHIRE 03248

J. Newell Ebasco Services Ir--

£

Penetrant inspect

Penetrant examinata after the areas i areas were also e

All areas were cl showed a porosit Procedure 9-5 Su

The following har

HANGER N.

A1-305-1-PL

A2-236-1-57

A5-261-1-C

A1-216-1-S

md Welds for P.O. MY435283.

erformed on eight (8) different hangers ound to remove apparent lack of fusion, th a 51 glass.

apparent lack of fusion, one (1) area /32" diameter. (Acceptable under B/P

examined by Penetrant:

HANGER NUMBER

A1-216-1-5W-H-2790

C1-236-1-SI-H-370

A3-261-1-MS-H-548

C1-236-1-C3-H-1405

L. Hinthorne Ebasco VQAR Please N. J.

P. O. Box 101, New Hill, N. C. 27562' March 21, 1984

Mr. James P. O'Reilly United States Nuclear Regulatory Commission Region II 101 Marietta Street, Northwest (Suite 2900) Atlanta, Georgia 30303

NRC-196

CAROLINA POWER & LIGHT COMPANY
SHEARON HARRIS NUCLEAR POWER PLANT
1986 - 900,000 KW - UNIT 1
SHOP WELDING DEFICIENCIES IN SEISMIC I PIPE HANGERS
SUPPLIED BY BERGEN-PATERSON, ITEM 95
UNDERSIZE SKEWED TEE FILLET WELDS ON SEISMIC I
PIPE HANGERS, ITEM 72

Dear Mr. O'Reilly:

Attached is our third interim report on the subject items which were deemed reportable per the provisions of 10CFR50.55(e) and 10CFR, Part 21, on August 13, 1982 (Item 95) and November 5, 1982 (Item 72). The purpose of this report is to inform you of changes which have occurred since our second interim report dated October 3, 1983. Carolina Power and Light Company is pursuing this matter, and it is currently projected that corrective action and submission of the final report will be accomplished by December 1, 1984.

Thank you for your consideration in this matter.

Yours very truly,

R. M. Parsons

Project General Manager

Shearon Harris Nuclear Power Plant

RMP/sh

Attachment

Messrs. G. Maxwell/R. Prevatte (NRC-SHNPP) Mr. R. C. DeYoung (NRC)

000392

#### CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT

UNIT NO. 1

INTERIM REPORT NO. 3

SHOP WELDING DEFICIENCIES IN SEISMIC I PIPE HANGERS SUPPLIED BY BERGEN-PATERSON ITEM 95

UNDERSIZE SKEWED TEE FILLET WELDS ON SEISMIC I PIPE HANGERS ITEM 72

MARCH 21, 1984

REPORTABLE UNDER 10CFR50.55(e) REPORTABLE UNDER 10CFR21 SUBJECT:

Deficient shop welds on pipe hangers previously accepted by Bergen-Paterson (B-P) and Ebasco Welding Inspectors.

ITEM:

Seismic Pipe Hangers

SUPPLIED BY:

Bergen-Paterson Pipe Support Corporation, Laconia, New Hampshire

#### NATURE OF DEFICIENCY:

- l. Missing and undersized welds
- 2. Cosmetic weld defects
- Undersized skewed tee welds
   Deficient welds accepted by B-P

inspectors and Ebasco Vendor Quality Assurance (VQA) inspectors

DATE PROBLEM OCCURRED:

Prior to October 1, 1982

DATE PROBLEM REPORTED:

On August 13, 1982 CP&L (Mr. N. J. Chiangi) notified the NRC (Mr. A. Hardin) that this item (Item 95) was reportable under 10CFR50.55(e) and 10CFR, Part 21. In our November 5, 1982 letter, CP&L (Mr. R. M. Parsons) notified the NRC (Mr. J. P. O'Reilly) that this item (Item 72) was reportable under 10CFR50.55(e) and 10CFR, Part 21.

SCOPE OF PROBLEM:

Seismic Category I pipe hangers which were inspected at the source of fabrication prior to October 1, 1982.

SAFETY IMPLICATIONS:

Deficient welds could cause a safety-related pipe hanger to fail under seismic conditions. As a result, if not corrected, they could adversely affect the safe operation of this facility. However, no hangers evaluated to date with the above type deficiencies have been found to adversely affect the safe operation of this facility.

## REASON THE DEFICIENCY IS REPORTABLE:

The conditions reported in Item 95 and Item 72 represent breakdowns in B-P and Ebasco QA programs which allowed supports to be shipped with welds which were not in accordance with design criteria. This incident was identified as reportable under 10CFR50.55(e) and 10CFR, Part 21, due to the extensive evaluation required and the breakdown in the QA programs.

## CORRECTIVE ACTION:

- Hangers with shop weld deficiencies were identified during the following processes:
  - A. Receipt Inspection.
  - B. Inspection in the warehouse prior to hanger issuance to the field.
  - C. Inspection in the field of installed hangers which had not been previously inspected by CP&L for shop weld deficiencies (does not include those hangers that were in Reinspection - See D).

# PREVENTIVE MEASURES TAKEN TO AVOID FURTHER NONCOMPLIANCE:

- Field Change Request (FCR) H-979 was developed and issued to provide weld inspection acceptance criteria for both field and shop welds based on the AWS Dl.1 code and B-P design criteria.
- Ebasco VQA began performing in-process inspections and 100% inspection of hanger welds on October 1, 1982. This is to be performed throughout the remainder of the B-P purchase order.
- Ebasco VQA management regularly visits the B-P Laconia facility to confer with the Ebasco VQA representative and to witness the VQA inspector's activities.
- B-P welders and inspectors and Ebasco VQA inspectors have received additional training in weld acceptance criteria.
- 100% shop weld inspections will continue until all shop welds are inspected by our quality control organization.

#### FINAL REPORT:

Corrective action has been completed on all active hangers. Those hangers on engineering hold will be reinspected and reworked when they become active again, or they will be cancelled if they are voided. For this reason, we cannot close this item until December 1, 1984.



#### P. O. Box 101, New Hill, N. C. 27562 March 5, 1984

Mr. James P. O'Reilly United States Nuclear Regulatory Commission Region II 101 Marietta Street, Northwest (Suite 2900) Atlanta, Georgia 30303

NRC-191

CAROLINA POWER & LIGHT COMPANY
SHEARON HARRIS NUCLEAR POWER PLANT
1986 - 900,000 KW - UNIT I
ENGINEERING REVIEW OF COMPLETED PHASE II PIPE HANGERS, ITEM 148

Dear Mr. O'Reilly:

On September 30, 1983, Mr. N. J. Chiangi notified the NRC (Mr. A. Hardin) of a potentially reportable item per the provisions of 10CFR50.55(e). The NRC was informed that of 235 pipe hangers which have been completed and accepted through Phase II, an engineering review of 99 of the pipe hangers completed indicates that various quality characteristics are indeterminate.

As a result of the engineering review, the hanger program has been revised to prevent similar reoccurrences.

The 99 hangers have been reinspected, however the determination for reportability has not been completed. Due to the extensive amount of evaluation involved, we will require until May 7, 1984 for submitting a final report on the reportability of this item.

Thank you for your consideration in this matter.

Yours very truly,

R. M. Parsons

Project General Manager

Shearon Harris Nuclear Power Plant

RMP/dh

Mr. R. C. De Young (NRC)

## P. O. Box 101, New Hill, N. C. 27562 March 9, 1984

Section and the section of the secti

Mr. Ames P. O'Reilly United States Nuclear Regulatory Commission Region II 101 Marietta Street, Northwest (Suite 2900) Atlanta, Georgia 30303

NRC-189

Dear Mr. O'Reilly:

In reference to your letter of February 13, 1984, referring to RII: WPK 50-400/84-03, the attached is Carolina Power and Light Company's reply to the violation identified in Appendix A.

It is considered that the corrective action taken is satisfactory fc: resolution of the item.

Thank you for your consideration in this matter.

Yours very truly,

R. M. Parsons

Project General Manager

Shearon Harris Nuclear Power Plant

RMP/sh

Attachment

cc: Messrs. G. Maxwell/R. Prevatte (NRC-SHNPP)
Mr. B. C. Buckley (NRC)

## Attachment to CP&L Letter of Response to NRC Report RII: WPK 50-400/84-03

#### Reported Violation:

10 CFR 50 Appendix B, Criterion V as implemented by PSAR Section 1.8.5.5 requires activities affecting quality be prescribed by documented procedures and instructions.

Contrary to the above, activities affecting quality were not adequately prescribed by documented procedures in that procedural inadequacies permitted an incorrect heat number to be reported on Weld Data Report for Weld Joint 1-SI-150-FW-536.

This is a Severity Level V Violation (Supplement II).

### Denial or Admission and Reason for the Violation:

The violation is correct as stated.

The pipe weld inspector verified the heat number at the prefit inspection point and entered same on the WDR. When the craft raised the spool piece into position, they turned it around and fitted the opposite end for welding. At the fit-up inspection point, the inspector reverified the piece number but not the heat number. The correct spool l-RC-341-1 was joined; however, the heat number on the WDR was for the opposite end of the spool piece. This caused a problem with documentation only and did not affect the quality of the items being joined or the weld joint.

## Corrective Steps Taken and Results Achieved:

Documentation for 1-SI-150-FW-536 was changed to show the correct heat number (M 2945) for the end of spool 1-RC-134-1 which had been welded. This was verified prior to changing the WDR.

## Corrective Steps Taken to Avoid Further Noncompliance:

QCI-19.1 was changed to require that the pipe weld inspector shall "reverify that heat numbers being joined reconcile with the heat numbers listed on the WDR" during fit-up inspection. Inspectors were instructed by the QA/QC specialist on this requirement.

## Date When Full Compliance Was Achieved:

Full compliance was achieved on January 27, 1984.

Carolina Power & Light Company



REPLY REQUESTED BY 10/10/83

CAROLINA POWER & LIGHT CO. New Hill, North Carolina

September 23, 1983

FILE: SH M-2/1

MEMORANDUM TO: Mr. R. M. Parsons

FROM: N. J. Chiangi

SUBJECT: Pipe Support Installation Program

ROUTE TO INITIALS 3 MOAH 83-264 cons KUH

In the last few months several problems in our hanger installation program have come to light and while individually many of these represent areas not necessarily of great concern, together they indicate the need to seriously evaluate the direction we are heading and perhaps upgrade our system. Please find attached a synopsis of the most significant areas which I feel warrant corrective measures.

While it is recognized that historically pipe supports represent a complex task, we should strive to simplify our program to eliminate as many areas for mistakes as possible.

I feel in all cases we have not accomplished this end result. Implementation of the attached recommendations should help us better control the pipe hanger process.

It is requested that you evaluate the recommendations and respond to this office by October 10, 1983, of your intended action to implement these recommendations.

NJC/mt Attachment

cc: Mr. H. R. Banks W/A

Mr. G. L. Forehand W/A

Mr. P. Foscolo W/A

Mr. L. I. Loflin W/A

Mr. G. Simpson W/A

Mr. M. F. Thompson, Jr. W/A

Mr. M. D. Vernon W/A

Mr. R. A. Watson W/A

Mr. J. L. Willis W/A

File W/AV

Original Signed By

N. J. Chiangi

41-22

#### PIPE SUPPORT CONCERNS AND RECOMMENDATIONS

1. The hanger work package does not provide clear instructions on what work needs to be performed and subsequently inspected. This is especially true when there have been revisions to design and additional field work to the Bergen-Paterson portion of the shop work is required (e.g., addition of structural members, replacement of material, additional welding, etc.). The current method of conveying the necessary information is to include in the package copies of the revised drawing(s) with the changes highlighted. It is then left up to the craft to determine how to implement these changes and to the inspector to determine what the craft actually did and what should have been done to complete the work. (It should be noted that by the use of generic FCR's the latest drawing will not represent a true picture of our as-constructed condition. For example, the generic FCR-H-341 which allows shop welds to be made in the field, and FCR-H-564 that allows for the deletion of the inside welds within the pipe window.) Misapplication of both of these has resulted in recent nonconformances.

The following is offered as a suggested resolution. Hanger work packages should be prepared to clearly state exactly what work is necessary so that both craft and inspection personnel are apprised of the work to be performed in the field. This would eliminate confusion in determining what had already been inspected (i.e., receipt inspection). Any required changes should be incorporated into the drawing prior to work being performed (i.e., changes from shop welds to field welds, addition or deletion of welds, substitution of material by different part number or different size of material). This approach would provide a quality product as subjectivity and interpretation would be eliminated from the craft and inspection personnel. Responsibility for interpretation of requirements and direction would be that of construction engineering.

In conjunction with the work package, additional construction engineering support to craft is needed. Many times when the craft have a question regarding design or procedural requirements, they will go to the most available person which many times turns out to be a CI or QC inspector. Higher visibility in the field by construction engineers would reduce this and provide better input as to what work or material is necessary. Also, increased construction engineering input into work package preparation is needed. Presently, work packages are generated by a clerical staff who have little or no awareness of the technical aspects of the hanger installation. Each package should be reviewed for constructability and accuracy prior to issuance to the field for work.

2. It is felt that some effort should be placed on reviewing the governing work procedure, WP-110, "Installation of Seismic Pipe Hangers and Supports for Seismically Analyzed Pipe", with the intent towards simplifying its requirements. Emphasis should be in the area of geometric tolerances, clearances and building attachment criteria. As previously stated, the use of generic FCR's should be eliminated or at least reduced with construction engineering providing guidance in the work package as to the exact requirements. As previously stated, we recognize that pipe support installation is a complex issue, every effort should be taken to simplify instructions to reduce the possibility of errors.

- 3. Structural components (not catalog parts) are received from Bergen-Paterson and certified as being fabricated to specified revision level of the design document. Reanalysis in some cases necessitates changes in the welding-design for the support which must be implemented either by Bergen-Paterson prior to shipment or by CP&L at the site. Therefore, it is necessary from CP&L's standpoint that we know exactly what revision level the support received on site has been fabricated to so that we can make the necessary changes to comply with the final design. This information is currently presented on the Certificate of Compliance received with each hanger; however, evidence exists which indicates that the Bergen-Paterson program for control of their fabrication is weak in this area. (Note the problems identified on DDR-1794 wherein fillet welds were provided in lieu of the required bevel-flare bevel welds.) It is recommended that HPES strengthen the B-P program in this area.
- 4. In the area of material control, it is felt that a stronger position needs to be developed to alleviate problems arising in the future. Our commitment on Reg. Guide 1.29 stated that ". . . lineage traceability of materials is not required . . ." This does not, however, circumvent the need for material control to assure that acceptable material is used in the proper application. While Deviation Notice No. 4 to Rev. 8 of WP-110 outlines methods to provide proper control from now on, material issued prior to this causes a problem. Presently, inspection groups are required to bring questionable material to the attention of construction engineering for resolution and disposition; please consider that the methods used to determine the acceptability of the material (i.e., color of the coating or size of material if uncoated) should be further supported with an additional technical basis, such as chemical analysis on a sample basis to confirm the actual type of material.

Another area of weakness is in the area of fasceners, particularly bolting and load pins. On bolting, steps should be added to assure that proper bolting, as supplied by Bergen-Paterson or by CP&L, has been used. At present, bolting from Bergen-Paterson contains no identification markings. Load pins represent a situation where they are provided with identification markings but discrepancies exist in the Bergen-Paterson identification references.

#### 5. General

The recent inspection by construction engineering personnel of supports that had been final inspected revealed evidence to support some of the previous issues raised. Our efforts should be to correct these problems and to develop a program such that when we final accept a hanger installation, it is indeed correct and complete as designed.

In this light, we should strive to develop a clear concise program of installation and inspection and should not overlap or combine any of our required inspection with those required by IE Bulletin 79-14. Our construction program should assure compliance with design analysis and our 79-14 effort simply a reconfirmation of these facts and to uncover any construction damage or tampering.

December 15, 1983

MS-12211

Am Pluser

MEMORANDUM TO: Mr. N. J. Chiangi

FROM: Mr. R. M. Parsons

SUBJECT: Shearon Harris Nuclear Power Plant Pipe Support Installation Program

The Hanger Program has undergone major changes in order to eliminate as many areas for error as possible. I feel that we have resolved all the concerns addressed in your letter: SH M-2/1; MQAH 83-264.

office Primar & Linns Councery

I appreciate your recommendations and hope you agree that the changes (attached) are a positive step towards achieving a quality program.

PWH/bk

Attachment

ec: Mr. H. R. Banks W/A

Mr. G. L. Forehand W/A

Mr. P. F. Foscolo W/A

Mr. L. I. Loflin W/A Mr. G. Simpson W/A

Mr. M. F. Thompson, Jr. W/A

Mr. M. D. Vernon W/A

Mr. R. A. Watson W/A

Mr. J. L. Willis W/A

Mr. A. H. Rager W/A

000589

 All hanger work packages will be accompanied by instructions detailing the work activities for the craft.

Required drawing changes will be resolved via Field Mods prior to the work being performed.

Hangers will be installed in accordance with a Field Mod or design drawing. The use of generic FCRs to justify a design deviation is discouraged unless the FCR information has been incorporated into the work procedure. (On exception to this would be FCR-H-286 which allows oversized and extra weld.)

The Hanger Section has been reorganized to provide a Field Engineering Group whose sole task will be to support the craft in the installation of supports. In addition, a Work Package Group has been set up to review the technical requirements of the Work Package. This review will ensure constructibility and accuracy of the design document prior to issuance to the field for work.

- WP-IIO has been revised to simplify the installation requirements. Special emphasis
  has been given to the areas of tolerances, clearances, building attachment criteria,
  and material conformance.
- 3. Although there have been isolated cases in which the Bergen-Paterson Certificate of Compliance identified the wrong revision, the only case in which the problem has been significant involved bevel-flare-bevel Welds. HPES discussed this with both the Ebasco VQA personnel and the Bergen-Paterson shop QA personnel, and the program has been strengthened. HPES reviews the Receiving Inspection Reports and will take additional steps to correct problems as they arise.
- Reference MS-11995 for Pipe Hanger Material Control. Note that Exhibit 4 of WP-110
  was modified in its final form.

As for fasteners, load pins are electro-etched for permanent material grade identification. High strength bolts/nuts, such as 193GR B-7, 194GR 2-H, and A-325, will display the required ASTM markings. Low strength bolts, such as A-307 GR B, will display the vendor markings as required by ASTM.

5. WP-110, WP-139, WP-140, and TP-34 were written and/or revised to revitalize and enhance the Hanger Program. (WP-140 is still preliminary.)

These procedures detail the activities for package preparation, hanger installation and inspection, and final review of the completed package and paperwork.

## CP&L

Carolina Power & Light Company



New Hill, North Carolina October 24, 1983

FILE: SH M-2/1

MQAH 83-321

MEMORANDUM TO: Mr. R. M. Parsons

FROM: N. J. Chiangi

SUBJECT: Pipe Support Installation Program

My memorandum, MQAE 83-264 dated September 23, 1983, noted several areas in our pipe hanger installation program which require corrective measures. One of the main issues surfacing from these concerns pointed to the quality of the installations currently in progress (basic workmanship). Please find attached Surveillance Report No. QASC-83-860 which outlines deficiencies detected in hanger installations prior to being presented for inspections. As you will notice, the reject rate is high (722). I am sure you will agree that the greater the number of problems that exist in an installation being presented for inspection, the higher the probability that the inspection program will not detect all errors. Workmanship is an important aspect of quality that is not always detectable and must be assumed in order to generate a certain degree of confidence in the total process.

It is therefore recommended that a more stringent program to improve the quality of workmenship be implemented. Enforcement of this program would alleviate the need for the crafts to rely on QC/CI to detect and point out errors that should be obvious and corrected prior to releasing work for inspection. In addition, this program should eliminate in many instances the need for rework, reinspection and documentation which in turn will assist in meeting project schedules and derive economic benefits to CP&L.

Original Signed By

N. J. Chiangi

MJC/mt Attachment

Mr. H. R. Banks W/A Mr. G. L. Forehand W/A Mr. R. A. Watson W/A File W/A

000593

41.1

P. O. Box 101, New Hill, N. C. 27562

Date: 10-14-83

MEMORANDUM TO: AL RACER

FROM: D. C. Whitehead

SUBJECT: SURVEILLANCE REPORT NO. GASC-83.860

The QA Surveillance Sub-Unit has recently completed a QA Surveillance of activities within your area of responsibility.

The attached surveillance report is being submitted to you to assist you in evaluating the results of the surveillance.

If you have any questions regarding this surveillance, do please contact me.

DCW: jp

2

Attachment

Mr. G. L. Forehand, W/A via Mr. D. A. McGaw Mr. R. V. Hate', W/A MR. EDNDY HANEY, W/A MR. GEORGESIMPSON. W/A MR. BILL LANGLOIS. W/A MR. CHAN VAN DAWS, WA REV. 1 4/27/83

## CAROLINA POWER AND LIGHT COMPANY CORPORATE QUALITY ASSURANCE DEPARTMENT

GA SURVETLL ANCE REPORT

DATES PERFORMED:

PAGE | CF

EVEILLANCE ACTIVITY/AREA/LOCATION E EVATION: REFERENCE DOCUMENTS: EM ID NO .:_ . SCRIPTION:_ ALITY CLASS:_ PERSONNEL CONTACTED: PHASE (CIRCLE ONE) ONA INSTALLATION INSPECTION RE-INSTALLATION WITNESS & PST-INS WITNESS PST-INS MMARY: PERFORMED BY: DATE 10-7-83 DATE 10-7-83

QA- 65 REV. 0 2/21/83

## CAROLINA POWER AND LIGHT COMPANY CORPORATE QUALITY ASSURANCE DEPARTMENT

0ASC/<del>0ACO 1</del>0.23.

## CONTINUATION SHEET

THE FOLLOWING PIPE HANGES IN THE TOTAL TO ASI  INSTALLED CORRECTIVE - 1-5M-H 3477 8/04, 1-TA-H-700 8/01  I-66-H-1465 8/26, 1-5M-H 3477 8/04, 1-TA-H-700 8/01  I-64-H-2790 8/031  THE FOLLOWING PIPE HANGES INCES INCESSION AND INSTALLABLE IN THE METALLANDON  I-64-H-59 8/031  HANGE WINDOWN 13 7/0" TO SMALL  I-64-H-59 8/031  HANGE WINDOWN 13 7/0" TO SMALL  ITEM # 5 LAP AT EMBED 13 //3" AND THE METALLANDON  I-64-H-2170 8/30  AND VEIT HES IN A"XA" X'" TO BE STORED TO THE METALLANDON  I-64-H-1224 8/031  I-64-H-	THE FOLLOWING PIPE H	WHERE TETERMINED TO BE
The Following Pipe Handers Were Determined To  The Indoor of Indoor of Item #3 12 Approx  I-EA.H. 59 8/031 HANDER WINDOW 13 3/16" TO SMALL  *I-SI-H 1231 8/03 CAP BETWEEN 175M* 5 * EMTREDED THATE  EXCERPS 3/16". TEM #5 10 NOT 12/2    ITEM #5 LAP AT EMBED 13 /8" SHOET  TEOLOGIC PADILIS 13 AT 29/16  AS THAT PADILIS 13 AT 29/16  I-FP-H-2170 8/30 NO VEIT HER IN A "X4" X'E" TUBE 5  AS REQUIRE PER HANDER METTHE TO  GO FROM DESIGNED CRIENTATION  I-SF-H-1224 8/031 THE GAP BETWEEN ITEM #1 28/19/16  I-FP-H 2307 8/04 CRIENTATION OF ITEM #3 12 APPROX  OFF SET  I-FP-H 2307 8/04 LASHERICENT LAP HEM #3 12 APPROX  OFF SET	1-6x-H-2290 8/031	SW-H 3477 8/04, 1-TA-H-700 2/31
HANGER WINDOW 15 3/16" TO SMALL  * 1-51-H 1231 8/00 GAP BETWEEN 17EM*5 EMBEDED THATE  EXCEEPS 3/16". FEM*5 10 NOT LEVEL  ITEM *5 LOP ST EMBEDE 15 /6" SHORT  TESIGN FADILOS 12 47:29/16  AS TOURT PRO HANGER SETTING  1-5F-H-1224 2/031 THE GAP BETWEEN 17EM # 1 EXISTING  EXCEEDS 3/16"  1-FP-H 2307 8/00 CRIENTATION OF ITEM # 3 12 APPROX  OF SET  1-FP-H 2307 8/00 INSUFFICIENT LOP HEM # 3 TO BEDI	THE FOLLOWING PIPE	JAKERS WERE DETERMINED TO
1-FP-H-2307 8/00 PERM DESIGNED CRIENTATION OF ITEM # 3 TO BEAN 12 1/4" TO SHORT		
1-FP-H-2170 8/30 NO VEIT WES IN 4"×4" ×12" TUBE ST AS REQUIRE PER HANGER SETZH  1-62-H-736 8/31 WELDED BEAM ATTACHMENT IS THE GO FROM DESIGNED OF ITEM # 1 EXISTING EXCEEDS 3/16"  1-5F-H-122A 8/031 THE GAP BETWEEN ITEM # 1 EXISTING EXCEEDS 3/16"  1-FP-H 2307 8/04 CRIENTATION OF ITEM # 3 12 APPROX OF SET	* 1-51-H 1231 R/CA CAN EXC 1-72	BETWEEN ITEM # 5 EMBEDED PLATE EEDS 3/6". MEM # 5 IS NOT LEVEL  H 5 LAP AT EMBED IS 18" SHOET
1-62 H-736 R/251 WELDED BEAM ATTACHMENT 15 THE  90° FROM DESIGNED OF ENTATION  EXCEPTS 3/16  1-FP-H 2307 R/OA CRIENTATION OF ITEM #3 15 APPROX  FF SET  1-FP-H 2307 R/OA INSUFFICIENT LAP HEM #3 TO BEAN  15 1/4" TOO SHOPE		
1-5F-H-1224 8/051 THE GIAP PETWEEN ITEM # 1 1201010 F ITEM # 3 12 APPROX OF SET	1-FP-H-2170 8/30 A	O REQUIRE PER HANGER SKETCH
1-5F-H-1224 8/031 THE GIAP PETWEEN ITEM # 1 1201010 F ITEM # 3 13 APPROX OF SET	1-63-4-736 R/231 K	ELDED BEAM ATTACHMENT IS THE
1-FP-H 2207 F/ON INSUFFICIENT LAP HEM * 3 TO BEAN		
13 1/4" TO STORT		
LEILUIS -/- WELD DEED FOR BENE	1-FP-H 2207 R/CA 1	
ITEM# Z Should be Barkled for Full Perl.		LORDET WELD PERP FOR BRAVE  FEMT # Z MOULD BE BRITER FOR FULL PEN  ANGER 12 17/8 OFF OF DESIGN LOCK

' QA- 65 REV. 0 2/21/83

## CAROLINA POWER AND LIGHT COMPANY CORPORATE QUALITY ASSURANCE DEPARTMENT

QASC/QASO 110, 93-41 PAGE 3 OF 4

## . QA SURVEILLANCE REPORT

* 1- SWLH 2002 E/2C	11 SIETINE	FLT LXP 1	TEM # 1 TO ITEM #
T- JOHN ACCES TO THE	10 1/2"	Jaset	T=M #1 TO ITEM #;
	13 /2 3		
			0 1 100
1-5W-H ZOBZ R/ZC	HEM TO	S 12 APPEC	x. 5° out of Plum
1 1-31-4 1231 E/OA	IDENTIFI	cation iter	TEM # 5
	GROUND	CFF CF	TEM #5
1-514-4.378 R/1E		20/00/00	13 KELDED TO
1-2Kt-H-318 KI/E	1	1 1 1/4	THES NITURE
	TEN!	4 NO YEAR	
	STEEL	TEM # 4 + #	<u> </u>
		• • • • • • • • • • • • • • • • • • • •	+1-1-
1- AF-4 245 2/04	AS INST	ALED ITE	T # 1 DIPETTLY
	MIERFE	253 - KITH	WHITE HOND
	WHEEL &	al Valve =	# 3AFV-89-58-1
THE TO THE OWNER	PRINT	TIME	PETULEU THE
INSTALATION AND T		- 122	LETTINI OF
THE TAIL AT ON AND T	1 DESTIN	TIME	
THE DESTRIPE IN			T KIND COLLEGE
EX DESIGNATING PIP	=		POLICY NOPECTO
IN PERFORMULY THE	PRELIM	WARYINE	
	V= BY	DA OF P	- LINTINARY
INSTALLATIONS TESUL	TED IN	A REJECTION	N EXTE IN AXMADIO
EXCESS OF 72%	NE THE	In TORRE	BORATED BY THE
		FROM 6.	I de Followlas
INSTECTION PETECTION			ASBULTELECTION 96
	ACEPT	REJECT	
MAY 83 PHAGE 1	424	273	43 -
PHADET	89	106	0 5
JUNE 83 PLASE I	325	235	27: 4:
FLAGE I	137	138	0 9
The state of the s			/
JULY 23 PLASE T	Z89	311	15
HILY 83 PLASE I			15
· PLACE II	86	リフ	0 /

QA- 65 REV. 0 2/21/83

### CARCLINA POWER AND LIGHT COMPANY CORPORATE QUALITY ASSURANCE DEPARTMENT

PAGE 4 CF 4

GA SURVEILLANCE REPORT

		CONTINUATION	SHEET		
	Coodmissor	Men	Dir.	AS BUT BET	96 PER
PEDIENTER	1	261	177	22	435
- PIERIE	1			-	0
	(FINAL)	9			
	()				
I THE	The whole	-	ALKUST	AND SEPTE	MEER
	2	1	1 1		7=
क् । पड	o no bro	Fin		- TOUR DE	-
PERFOR	MED BY	2.1.			
			,		
			* 1		
the state of the s					
***************************************					



P. O. Box 101, New Hill, N. C. 27562 November 18, 1983

Mr. James P. O'Reilly, Regional Administrator United States Nuclear Regulatory Commission Region II 101 Marietta Street, Northwest (Suite 2900) Atlanta, Georgia 30303

SHEARON HARRIS NUCLEAR POWER PLANT
UNIT NOS. ! AND 2

DOCKET NOS. 50-400 AND 50-401

IE INSPECTION REPORT NOS. 50-400/83-25 AND 50-401/83-25

Dear Mr. O'Reilly:

Carolina Power & Light Company (CP&L) has received Mr. R. C. Lewis' letter dated October 19, 1983 which documents the results of the special Regional Construction Assessment Team inspection conducted by Mr. P. R. Bernis on August 15-26, 1983.

We consider this inspection to be one of the most thorough reviews conducted of our Harris Project Activities, and appreciated the professionalism and high degree of expertise with which it was conducted. The findings and observations noted in the above report, and discussed at the exit critique, are being given management attention as we continue our internal evaluations of program improvements. In addition to the items covered in your letter, we would like to take notice of a number of strengths found by your assessment team and discussed at the critique:

- Project management meetings, such as the project review meeting, are oriented towards the resolution of problems. The meetings focus on the identification of the problems and the agreement of how to attack and resolve the problems. The responsibility to handle the tasks is clearly defined when problems emerge.
- The warehouse storage program is well developed, and the use of operations
  personnel to insure that operations equipment has adequate preventive maintenance
  while in storage is a very positive aspect.
- 3. There is an on-site engineering group Harris Plant Engineering Section which provides design self-sufficiency.
- There is a mechanism to incorporate industry experience feedback into the nuclear power plant design.
- The technical audits conducted by CP&L of the Architect Engineer (Ebasco) are of substance and are over and above the required programmatic audits.

- 6. The electrical construction inspectors are considered to be very knowledgeable and conscientious in their work areas.
- Management is actively involved in getting problems associated with concrete placement addressed and corrected.
- 8. Engineers are extremely responsive in addressing concerns raised by the NRC.

In addition to the strengths noted above, we acknowledge the seven violations that were identified. We herewith submit (Attachment) our responses to violations in accordance with the provisions of 10 CFR 2.201.

We consider that the corrective actions taken are satisfactory for the resolution of the items.

Thank you for the consideration in this matter.

Yours very truly,

R. M. Parsons

Project General Manager Shearon Harris Nuclear Power Plant

RMP/sh

Attachment

Mess: G. Maxwell/R. Prevatte (NRC-SHNPP)
Mr. B. C. Buckley (NRC)

#### ATTACHMENT

Responses to Violation Identified During the Inspection Conducted on August 15-26, 1983 (IE Inspection Report Nos. 50/400/401/83-25)

Carolina Power & Light Company
Shearon Harris Nuclear Power Plant
IE Inspection Report 50-400/401/83-25
Violation A

#### Reported Violation:

10 CFR 50, Appendix B, Criterion X, as implemented by the Carolina Power & Light PSAR Section 1.8.5.10, requires that inspection of activities affecting quality shall be executed to verify conformance with the documented instructions. Construction procedures TP-28 and WP-105 are the Harris site instructions that are used in the installation inspection of safety-related equipment.

Contrary to the above instructions, the installation inspection, which was performed for Motor Control Centers (MCCs) 1A35-SA and 1B35-SB was inadequate in its execution in that inspection failed to identify the following:

- 1. The MCC hold-down fasteners were not tightened.
- 2. The MCC elevation checks were not adequately performed.
- 3. The welding of the MCC mounting sill to embedded plates differed from the requirements on the vendor plan which was referenced on the welding instruction.

This is a Severity Level IV Violation (Supplement II), and is applicable to Unit 1 only.

#### Denial or Admission and Reason for the Violation:

The violation is correct as stated.

- The fasteners were loose because either they were not checked closely enough or they were loosened by others who may have performed work on the MCCs after the inspection by CI.
- 2. Elevations were checked indirectly by CI inspector by verifying previous sign off of pad elevation by Civil CI when pad/embeds were installed.
- 3. The QC Structural Welding inspector inspected the weldments in question as per the vendor drawings minimum weld size 1/4" x 1/4" x 3". Using the 1A4 welding process and a 1/8" E-7018 electrode, an acceptable 1/4" fillet weld was not attained. Therefore, to reach the required weld size, multiple passes were performed. The QC Inspector should have requested clarification before performing the final inspection.

#### Corrective Steps Taken and Results Achieved:

1. All fasteners in MCCs under the scope of Regulatory Guide 1.29 have been reinspected under TP-28. Discrepancies were noted and are being resolved.

- 2. Procedural steps under WP-105 and TP-28 have been initiated to recheck the elevation of all MCCs under the scope of Regulatory Guide 1.29 against vendor, Ebasco, or CP&L approved design documents. This recheck is expected to be complete by December 1, 1983.
- 3. Motor Control Center mounting sill weldments were evaluated by Harris Plant Engineering Section and were found to be structurally sound. FCR-AS-3914 (approved October 27, 1983) was issued to allow for multiple weld passes to attain the required weld size.

#### Corrective Steps Taken to Avoid Further Noncompliance:

- (a) Additional training of inspection personnel involved in inspection of MCCs was conducted by the lead inspector on October 28, 1983 emphasizing closer inspection of MCC fasteners for correct tightness under TP-28.
  - (b) Exhibit 12, WP-105, is now being used to have CI check the results of work performed on equipment that has been disassembled. Exhibit 12, WP-105, is used for special assembly of equipment. This exhibit will be required to be initiated if equipment has to be disassembled to facilitate installation and has to be reassembled after installation.
- 2. Inspection personnel involved with inspection of MCCs received training by the lead inspector on October 28, 1983 on the requirements for elevation checks against vendor, Ebasco, or CP&L approved design documents.
- 3. QC structural welding inspection personnel have been instructed to follow applicable inspection criteria (i.e., FCR's, DCN's, PW's, Vendor and Engineering related drawings). If conflicts arise, inspectors will request clarification of information prior to performing inspection.

#### Date When Full Compliance Will Be Achieved:

- 1. & 2. Full compliance will be achieved on December 1, 1983.
  - 3. Full compliance was achieved on October 28, 1983.

Carolina Power & Light Company Shearon Harris Nuclear Power Plant IE Inspection Report 50-400/401/83-25 Violation B

#### Reported Violation:

10 CFR 50, Appendix B, Criterion V, as implemented by Carolina Power & Light Company PSAR, Section 1.8.5.5, requires that activities affecting quality shall be prescribed by documented instructions, procedures, or drawings and shall be accomplished in accordance with these instructions, procedures, and drawings.

- Pipe support drawing SW-H-456, Revision 4/D, required two piece l's, 4 x 4 tubing, to be welded to a steel tube of support SW-H-366 with a 1/4" fillet welded all around both piece l's.
- 2. Pipe support drawing SW-H-456, Revision 4/D, required a 1/16" clearance between the support and the top and both sides of its pipe.
- 3. WP-110, Revision 8, paragraph 3.4, requires documentation of pipe support stock substitutions. The strut for support SW-H-946 was required to be welded to support SW-H-944.
- 4. Procedure MP-05, Revision 18, paragraph 4.6, required welders to identify their work at the time of fit-ups or before fit-up begins.

#### Contrary to the above,

- One of the support SW-H-456 piece l's was not welded on one of its four sides.
- There was less than 1/32" clearance between support SW-H-456 and the top
  of the pipe it supported.
- 3. The strut for support SW-H-943 was used in support SW-H-946 and welded to support SW-H-944. The strut for support SW-H-942 was used in support SW-H-943. The strut for support SW-H-946 was used in support SW-H-942. The licensee was unable to provide documentation authorizing the above noted material substitutions.
- 4. There was no discernible evidence that the welder(s) had stamped their stencils on field welds C1-255-M-22-FW3, C1-236-1-SI-244-FW-601, and FW-597-598, 599, 600 (tack welds on code plate of SI penetration).

This is a Severity Level V Violation (Supplement II), and is applicable to Unit 1 only.

#### Denial or Admission and Reason for the Violation:

The violation is correct as stated, with the following clarifications:

Pipe hanger SW-H-456 is a box frame hanger attached to a large existing Service Water pipe hanger. It was to have all around 1/4" fillet welds connecting two items #1 (4 x 4 tube steel) to an existing 6 x 6 tube steel member of SW-H-366. The welds were only performed on three sides leaving off the inside welds.

It appears the inspector accepted the joint knowing the welds were deleted, per FCR-H-564. The FCR allows the deletion of the inside window welds for box frame hangers on 12" and smaller pipe when the members require all around fillet welds. Due to the configuration of this hanger, the inspector thought that the FCR was applicable. In the case of the reported joints, the FCR is not applicable.

- 2. Hanger SW-H-456, Rev. 4/D, was inspected to Phase II by the C.I. Inspector (Hanger Q.C. Inspector). It appears that during this inspector's review, he inadvertently failed to detect the specified design clearance requirement violation. It appears that an error occurred in reading or recording the dimension. Therefore, the reason for the violation is considered to be a physical inspection error.
- 3. For hangers SW-H-942, 943 & 946, although a material substitution violation is acknowledged, the violation, as stated, is misleading. The violation stated that "the strut" was substituted in each case without the proper documentation when, in fact, it was not the strut but rather the pipe clamp which was substituted.

WP-110, Rev. 8, paragraph 3.4, requires documentation of pipe support stock substitutions. Apparently, due to the fact that all three (3) hangers (SW-H-942, 943, and 946) require the same type and size pipe clamp, the inspector failed to realize a violation of site procedure had been made. The records suggest that the inspector made a document review error as opposed to a physical inspection error.

4. In reference to the NRC reported violation that on weld joints C1-255-M-22-FW3; C1-236-1-SI-244 FW 601; and the tack welds on the code plate of containment penetration #M-22 reported as FW597, 598, 599, 600, the welder(s) had not stamped their welds; a further investigation into the details has been performed by Welding Engineering.

1S1-244 FW 597, 598, 599, 600, which are socket welds identified on isometric 1S1244, were not welded at the time of the NRC audit and were mistakenly identified by the NRC report as the four (4) tack welds attaching a Code data plate to the containment penetration #M-22. This Code data plate was moved to a new location on the penetration in 1981 for which a WDR was generated which is presently in the Q.A. Records Vault.

On August 26, 1983, Welding Engineering was notified of the NRC Inspector's reported violations on containment penetration weld joint #C1-255-M-22-FW3, 3 diameter pipe weld joint #C1-236-1-SI-244-FW601, and the four (4) tack welds connecting the Code data plate to the containment

penetration #M-22. The Senior Engineer, Metallurgy/Welding, immediately requested a CP&L Q. C. Lead Technician and a Welding Engineering Supervisor to accompany him and assist in investigating the details. Upon arrival at the weld joints, the Welding Engineering Supervisor and the Q.C. Technician located the stencils which had been stamped at the penetration weld joint #Cl-255-M-22 FW3 (stencils #B-79, #C-79) and the stencil which had been stamped at the penetration code plate tack welds (stencils #F-16). It was, however, verified that welder #C-79 had forgotten to stamp pipe weld joint #Cl-236-1-SI-244-FW601; as required by site procedure MP-05. It should be noted, however, that it is not a Code violation.

#### Corrective Steps Taken and Results Achieved:

- After the violation was discovered, the hanger was placed on DDR #1919, Deficiency Report. It was then evaluated by Harris Plant Engineering and the joint was found to be acceptable "as is". The hanger design drawing was revised to reflect the as-built condition.
- The condition was identified and reported for hanger SW-H-456, Rev. 4/D, and documented on DR No. H-273.
  - Hanger SW-H-456, Rev. 4/D, will be reworked to correct the improper pipe to support member clearance.
- 3. Due to the fact that all three (3) hangers involved (SW-H-942, 943, and 946) required by design the identical type and size clamps and the clamps are all standard catalogue parts, the interchange is acceptable "as is".
- 4. DDR 1933 was generated on August 26, 1983 to document the failure of C-79 to stencil pipe weld joint #1SI244 FW601. Working to the Corrective Action Report of the DDR, the pipe weld joint was stamped as required by MP-05.

## Corrective Steps Taken to Avoid Further Noncompliance:

- WP-110 shall be revised to discourage the use of generic FCR's (i.e., FCR-H-564) by the craft or the inspector for installation and inspection.
- 2. For hanger SW-H-456, Rev. 4/D, the C.I. Inspector ceased employment in the Pipe Hanger C.I. Unit (unrelated to this incident) and transferred to a different C.I. discipline. Due to the relatively short time frame from the issuance of the noncompliance report to the inspector's transfer, only a verbal reemphasis of procedures was performed. If the inspector had remained in the group, he would have undergone a documented and formal retraining relative to the noncompliance. Site policy has been reemphasized to all Pipe Hanger C.I. Inspectors to assure that they understand Phase II Inspection procedures and criteria.
- 3. The use of catalog parts shall be in accordance with design. This shall be verified at the point of installation. WP-110 and TP-34 shall be revised to clearly state these requirements.

4. Welder C-79 was issued a written reprimand and reoriented to MP-05 by his supervisor.

### Date When Full Compliance Will Be Achieved:

- 1 3. Full compliance will be achieved on December 15, 1983.
  - 4. Full compliance was achieved on September 2, 1983.

Carolina Power & Light Company
Shearon Harris Nuclear Power Plant
IE Inspection Report 50-400/401/83-25
Violation C

#### Reported Violation

10 CFR 50, Appendix B, Criterion V, requires that procedures written for activities affecting quality be followed, FSAR, Section 1.8, commits to Regulatory Guide 1.28 which endorses ANSI Standard N45.2. Section VI of the standard defines the same requirements as Criterion V. Quality procedures AP-XIII-05, Appendix A, requires that the Senior Lead Engineer will, for each shipment, check for storage requirements from the vendor.

Contrary to the above, as of August 24, 1983, quality procedures were not followed in that the Senior Lead Engineer had not checked the vendor storage requirements for HEPA filters designated for use in safety-related HVAC filtration units. These filters were not stored in accordance with vendor instructions.

This is a Severity Level V Violation (Supplement II).

#### Denial or Admission and Reason for the Violation:

The violation is correct as stated. The vendor storage requirements were not on site.

#### Corrective Steps Taken and Results Achieved:

The HEPA filters have been inspected to insure that no damage occurred because of the previous improper storage. None was found. The filters were restacked to comply with the requirements of ANSI N509-1976. The vendor requirements for storage are not on site, but at the time of the discovery of the violation, the NRC Inspector called the vendor. The vendor said his storage requirements were the same as ANSI N509-1976.

## Corrective Steps Taken to Avoid Further Noncompliance:

The material storage procedure AP-XII-05 was revised to include the specific storage requirements for HEPA filters as described in ANSI N509-1976.

### Date When Full Compliance Will Be Achieved:

Full compliance was achieved on November 10, 1983.

Carolina Power & Light Company Shearon Harris Nuclear Power Plant IE Inspection Report 50-400/401/83-25 Violation D

#### Reported Violation:

10 CFR 50, Appendix B, Criterion V, requires activities affecting quality shall be accomplished in accordance with procedures, drawings, etc. Carolina Power & Light Company procedure CQA-4, Revision 5, QA Records, Attachment 1, identifies radiographs as QA records. Paragraph 7.7.2 requires special process records such as radiographs and microfilms to be packaged and stored to prevent damage due to temperature, humidity, light, etc.

Contrary to the above, radiographic film had been stored in the Superintendent's QA office, outside the vault, for approximately two weeks.

This is a Severity Level V Violation (Supplement II).

#### Denial or Admission and Reason for the Violation:

The violation is correct as stated. The volume of radiographs received on site in a limited period of time exceeded available storage in the QA Records Vault. Timely rearrangement of vault storage was not taken.

#### Corrective Steps Taken and Results Achieved:

Radiographs were transferred to the vault on October 14, 1983. (The vault rearrangement was completed the same day.) The radiographs were removed from the sealed packing crates and placed in the radiograph storage cabinets the next two days and are now stored according to requirements.

#### Corrective Steps Taken to Avoid Further Noncompliance:

Any future receipts of radiographs which exceed QA Records' storage capacity will be stored in the Harris Plant Document Control vault which is the permanent QA Records' storage facility for the plant.

### Date When Full Compliance Will Be Achieved:

Full compliance was achieved on October 14, 1983.

Carolina Power & Light Company
Shearon Harris Nuclear Power Plant
IE Inspection Report 50-400/401/83-25
Violation E

#### Reported Violation:

10 CFR 50, Appendix B, Criterion XVI, requires that measures be established to assure that conditions adverse to quality, such as deficiencies, deviations, and nonconformances are promptly identified and corrected.

Contrary to the above, the Shearon Harris Plant Engineering Organization did not have a procedure for identifying and correcting deficiencies, deviations, and nonconformances. In addition, during re-performance of calculations for pipe support CH-H-1030, the designer noted a violation of AISC requirements in the original calculations. The support was redesigned but the violation was not identified to the original designer (A/E-contractor), nor evaluated for potential generic significance.

This is a Severity Level V Violation (Supplement II).

#### Denial or Admission and Reason for the Violation:

The violation is correct as stated. The Harris Plant Engineering Sections uses departmental and Corporate procedures for identifying and correcting deficiencies, deviations, and nonconformances. NPED procedures, and the procedures applicable to specific design efforts such as on-site hanger design, incorporate the design control requirements of ANSI N45.2-11. NPED procedures for evaluating nonconformances under 10 CFR 50.55(e) and 10 CFR 21 are part of the mandatory training for all design personnel. Criterion XVI, 10 CFR 50, Appendix B, requires that significant conditions adverse to quality be documented and reported, and the NPED procedures reflect this requirement. Also, please note that the specific design question concerning a pipe support, which was identified during this audit, was neither "significant" nor "adverse to quality". If the design had not been revised, the support would have performed the design function.

### Corrective Steps Taken and Results Achieved:

Each applicable HPES employee has been reminded of our procedural commitments (NPED 3.9); however, due to the nature of the specifically identified concern (e.g., not significant), no further specific action for the particular item is deemed appropriate.

### Corrective Steps Taken to Avoid Further Noncompliance:

A Section Instruction is scheduled for issuance by November 30, 1983. The purpose of this Instruction is to more clearly define specific actions to be taken by HPES personnel when nonconformances are identified.

## Date When Full Compliance Will Be Achieved:

Full compliance will be achieved on November 30, 1983.

Carolina Power & Light Company
Shearon Harris Nuclear Power Plant
IE Inspection Report 50-400/401/83-25
Violation F

#### Reported Violation:

10 CFR 50, Appendix B, Criterion V, requires that activities affecting quality be prescribed by and performed in accordance with instructions, procedures, or drawings.

- 1. FSAR, Section 1.8, page 50, commits to compliance with NRC Regulatory Guide 1.38 and ANSI N45.2.2-1972. AP-XIII-05, Revision 12, requires the reactor internals to be stored in accordance with the manufacturer's instructions. The NSSS Component Receiving and Storage Criteria, dated March 1976, states that storage criteria was in accordance with ANSI N45.2.2-1972. During inspection of the storage condition for the upper reactor internals stored in the reactor vessel and an inspection of storage areas in the auxiliary building, the following items were noted:
  - a. ANSI N45.2.2-1982, paragraph 6.2.1, required access control to storage areas.
  - b. ANSI N45.2.2-1972, paragraph 6.2.2, required storage areas to be cleaned to avoid accumulation of trash, discarded packaging materials, and other detrimental soil.
  - c. ANSI N45.2.2-1972, paragraph 6.3.3, prohibits the storage of hazardous chemicals in close proximity to important nuclear items.

#### Contrary to the above:

- a. (1) On July 23, 1983, and twice on July 25, 1983, the materials storage area in the auxiliary building was found unlocked and without an attendant.
  - (2) The storage area for the reactor internals was not posted as a controlled area and unrestricted access to the storage area was observed.
- b. Underneath the reactor upper internals cover and on the upper internals, over six wads of used tape, two rolls of tape, and cleaning cloth were observed. In addition, the RV flange was not protected and numerous cigarette butts were observed on the RV flange grooves.
- c. A can of cutting fluid was observed to be stored on top of the upper reactor internals and underneath its canvas protective cover.
- 2. On August 25, 1983, a craftsman working on the upper internals lifting rig informed the inspector that he had taped over the spray nozzle holes of the upper internals because he was concerned about dropping something into the holes while working above them. He further stated that he determined how deep the holes were by dropping a nut tied to a string into the holes.

Contrary to the above, the craftsman did not have a procedure for determining the depth of the holes and for taping the holes.

This is a Severity Level V Violation (Supplement II), and is applicable to Unit 1 only.

#### Denial or Admission and Reason for the Violation:

The violation is correct as stated with the following exception:

The lower internals cannot be interpreted as being in a stored area with respect to access control. Permanent plant locations are considered storage locations by site policy with the exception of access control. Access control for materials and equipment in its permanent plant location is controlled by procedure on a case-by-case basis. The violation occurred because of failure to implement the policy and the inflexibility of the procedure.

#### Corrective Steps Taken and Results Achieved:

Valve storage areas and the reactor vessel internals storage area are being locked during non-working hours and during times when access to the areas is not required.

Valve storage areas have signs posted at the entrance allowing authorized personnel only to enter the area as well as forbidding the use of tobacco, food or beverages.

The reactor vessel internals have been cleaned of subject debris, and stored in the reactor vessel which is in a relatively isolated area. Polyethylene has been used to seal the internals inside the vessel and a barricade was installed with a lockable door to restrict access. A sign was placed at the entrance designating the area as Zone 4.

The work being done on the vessel internals by the craftsman without a procedure will be eliminated by the new access control for the area. Also, management has reemphasized placing covers over accesses to equipment, piping systems, etc. where the entrance of foreign objects could cause potential problems.

#### Corrective Steps Taken to Avoid Further Noncompliance:

Procedure AP-X-02 has been reviewed and found to be compatible with ANSI standards governing housekeeping requirements. Management has emphasized the importance of compliance with this procedure to all personnel.

#### Date When Full Compliance Will Be Achieved:

Full compliance was achieved on November 10, 1983.

Carolina Power & Light Company
Shearon Harris Nuclear Power Plant
IE Inspection Report 50-400/401/83-25
Violation G

#### Reported Violation:

10 CFR 50, Appendix B, Criterion V, as implemented by Carolina Power & Light Company, PSAR, Section 1.8.5.5, requires in part that activities affecting quality shall be prescribed by documented instructions and procedures of a type appropriate to the circumstances. Contrary to this requirement, the following civil procedure instructions were not appropriate for the circumstances as described below:

- Procedure TP-32, Structural Steel Inspection, requires that extra flat washers be used on oversize holes, but does not provide for instructions or documentation for inspectors to inspect and document oversize holes.
- 2. Procedure WP-28 does not adequately prescribe instructions for the hand methods being used to mix grout in that it does not stress the importance of blending cement and sand before adding water and it prescribes that grout be mixed in a truck or paddle mixer.

This is a Severity Level V Violation (Supplement II).

#### Denial or Admission and Reason for the Violation:

The violation is correct as stated.

- 1. The requirement to inspect for oversize holes was inadvertently omitted from the procedure (TP-32).
- 2. The paragraph of WP-29 which is in question, 3.10.2, concerns dry pack grout, and states grout will be mixed by mixer or by hand. For actual mixing instructions, it references paragraph 3.12.2 which covers controlled shrinkage grout. Paragraph 3.12.2, however, states mixing shall be by paddle mixer or by truck, which contradicts paragraph 3.10.2.

Detailed instructions for hand mixing were not included in 3.10.2 except to require thorough mixing of the ingredients - cement, sand, and water.

#### Corrective Steps Taken and Results Achieved:

Deviation Notice No. 2 was written to TP-32, Rev. 5, establishing procedural requirements for inspection and documentation of bolt holes sizes on August 26, 1983 and is now being used by field inspection personnel. DR-AS-300 was written on September 1, 1983 addressing the possibility that high strength bolts may have been installed in oversized holes without the required hardened washers over the holes. PW-AS-3624 was approved on September 1, 1983 resolving this discrepancy.

2. Procedure WP-29 was revised by Procedure Deviation Notice No. 6 on August 23, 1983 to delete requirement for mixing dry pack grout with a paddle mixer. - Deviation Notice No. 7 was approved on August 25, 1983 adding the requirement for thoroughly blending the sand and cement before water is added.

## Corrective Steps Taken to Avoid Further Noncompliance:

- TP-32, Rev. 6, approved on November 4, 1983, includes inspection for oversized holes in the erection phase and a check during the bolting phase for oversized holes which may result from reaming and drilling.
- Work Procedure revisions. (See Corrective Steps Taken and Results Achieved.)

#### Date When Full Compliance Will Be Achieved:

Full Compliance was achieved on November 4, 1983.

(8515PSA cfr)

#### P. O. Box 101, New Hill, N. C. 27562 February 24, 1984

Mr. James P. O'Reilly United States Nuclear Regulatory Commission Region II 101 Marietta Street, Northwest (Suite 2900) Atlanta, Georgia 30303

NRC-186

CAROLINA POWER & LIGHT COMPANY
SHEARON HARRIS NUCLEAR POWER PLANT
1986 - 900,000 KW - UNIT 1
SHOP WELDING DEFICIENCIES ON SEISMIC CLASS I CABLE TRAY,
CONDUIT, AND HVAC HANGERS, ITEM 77

Dear Mr. O'Reilly:

Attached is our fourth interim report on the subject item which was deemed reportable per 10CFR50.55(e) and 10CFR, Part 21, on August 2, 1982. C?&L is pursuing this matter, and it is currently projected that corrective action and submission of the final report will be accomplished by July 1, 1984.

Thank you for your consideration in this matter.

Yours very truly,

R. M. Parsons

Project General Manager

Shearon Harris Nuclear Power Plant

RMP/sh

Attachment

Mr. R. C. De Young (NRC)

#### CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT

UNIT NO. 1

INTERIM REPORT NO. 4

SHOP WELDING DEFICIENCIES IN SEISMIC CLASS I CABLE TRAY, CONDUIT AND HVAC HANGERS

ITEM 77

**FEBRUARY 22, 1984** 

REPORTABLE UNDER 10CFR50.55(e) AND 10CFR, PART 21

SUBJECT:

Shearon Harris Nuclear Power Plant/Units No. 1 and 2, 10CFR50.55(e) and 10CFR, Part_21, Reportable Deficiency. Shop welding deficiencies in Seismic Class I cable tray, conduit and HVAC hangers.

FTEM:

Shop welding on cable tray, conduit and HVAC hangers is not in accordance with Codes and Standards to which they were procured.

SUPPLIED BY:

Peden Steel Company, Raleigh, N. C.

NATURE OF DEFICIENCY:

Shop welds on cable tray, conduit, and HVAC hangers do not meet AWS Dl.1 code requirements. Undersize welds, overlap, porosity are examples of the types of deficiencies.

DATE PROBLEM WAS CONFIRMED TO EXIST:

March 19, 1982

DATE PROBLEM REPORTED:

On April 2, 1982, Mr. L. E. Jones notified the NRC, Region II (Mr. C. Julian), that the item was potentially reportable. On August 2, 1982, Mr. L. E. Jones notified the NRC, Region II (Mr. A. Hardin), that this item was reportable per the provisions of 10CFR50.55(e).

SCOPE OF PROBLEM:

A large number of cable tray, conduit and HVAC hangers have been installed and accepted by QA/QC personnel. Cable tray, HVAC duct and conduit have been installed in the hangers. Inspection of shop welds is in progress in the containment, reactor auxiliary and reactor auxiliary - common buildings as well as in the warehouse laydown yards. Deficiencies are being found and repaired.

SAFETY IMPLICATIONS:

Cable tray, conduit, and HVAC duct are supported by these hangers. Hangers having unacceptable welding could possibly fail in normal operation or during a seismic event. This in turn could lead to the failure of the items the hangers were supporting. To date, the reinspection has not revealed any problems this severe.

#### REASON DEFICIENCY IS REPORTABLE:

Reportable due to the Quality Assurance
Program breakdowns at Peden Steel Company
and during Ebasco Vendor QA surveillance
activities.

#### CORRECTIVE ACTION:

Since May 14, 1982, all material fabricated by Peden Steel on A/E purchase orders has been receiving a 100 percent primary welding inspection by CP&L Welding QC personnel prior to shipment. A complete reinspection of all cable tray, conduit and HVAC hangers furnished by Peden Steel is in progress. The total number of hangers concerned is approximately 5,200. To date, all but 671 have been found to be acceptable "as-is" or have been repaired and accepted. Of the remaining 671, 664 have portions with welds which are inaccessible for inspection. These 664 hangers have been reported to Engineering on Permanent Waivers (PW's) and approximately 400 of the 664 have been accepted based on engineering evaluation. Engineering is continuing to evaluate the remaining 264 frames. Seven remain to be located.

#### FINAL REPORT:

A final report will be issued when the evaluations, reinspections and subsequent rework have been completed. The date currently projected for submittal of the final report is July 1, 1984.

CONSTRUCTION PROCEDURES MANUAL SHNPP Procedure No. MP-10 As Approved

GENERAL WELDING PROCEDURE

DESCRIPTION REPAIR OF BASE MATERIALS AND WELDMENTS Page 1 of 31

DEC 2 1981 Rev. 4

JUN 5 1981 Rev. 6

DEC 1 8 1980 Rev. 5

MAR 8 1980 Rev. 4

CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT

GENERAL WELDING PROCEDURE
MP-10

AUG 2 9 1978 REV-/

FEB 1 6 1984 Rw. 11 DECUMENT CONTROL

DEC 3 0 1982 Rev. 9 JUN 2 1 1982 Rev. 9

APR 28 10:7 SHEARON HARRIS N. P. P.

* Reviewed by Daniel for Constructability Only

Rev.	Description		Approvals	Date
		Originator	Moledon & Race	4/28
0	Issued for Use	Constructor *	W.D. Hookman	4-28.
	Issued for ose	CP&L	AM Lucy	4-28-
		Originator	malcolm CReist	e/29/7
1	Revised as noted. Revised Exhibit 1.	Constructor *	11/ D. Moodman	8/29/
	Added Exhibit 3.	CP&L	AM Lucar	8/29/1
		Originator	MaldonElase	4/6/7
2	Revised as Noted.	Constructor *	W. D. Gardinan	4-67
-	Revised as Noted.	CP&L	AM Lucay	4-7.7
		Originator	Ray Harford	4/11/
		Constructor *		
3	Revised as Noted.	CP&L	am Luca	4-11-7
		Originator	of Thinger	3/4/4
		Constructor *	al. D. Youdman	3-53
4	Revised as Noted.	CP&L	Amfu	7-8-80



CONSTRUCTION	PROCEDURE	S MANUA		SHNPP .	PROCEI	DURE 10	NO.	DATE As Approved
GENERAL WELD	ING PROCE	DURE			REVISI	ON 11		
DESCRIPTION	REPAIR OF	BASE MATE	ERIALS AND	WELDMENTS	PAGE	2	OF	31

CAROLINA POWER & LIGHT COMPANY
SHEARON HARRIS NUCLEAR POWER PLANT
GENERAL WELDING PROCEDURE
MP-10

* REVIEWED AND APPROVED BY EBASCO SERVICES, INC., FOR CONFORMANCE TO THE REQUIREMENTS OF PARAGRAPH CA-3310 OF ARTICLE CA-3300 OF ASME/AC1 359, SECTION III, DIV. 2, WINTER 1975 ADDENDA.

REV.	DESCRIPTION	DE MANAGE	APPROVALS	DATE
		ORIGINATOR	R. Flanford	12/1/80
	Adopted New Title and	CONSTRUCTOR	VID Dodana)	12/16/8
5	Authorization Sheet. Added Para. 3.6. In-	EBC Q.A.	11/4 /21/	177
	corporated Deviation	CPAL	Ami Luca	12/2/9
	Notice 1.	DES. ENG. *	NA AN	
*	6 Revised Paragraph 3.4.	ORIGINATOR	12 Hapril	6/1/2
6		CONSTRUCTOR	Terti dood unde	121-5
Ĭ		EBC Q.A.	N/A and	
		CPAL	am Luca	6.5-81
		DES. ENG	NA BUS	
		ORIGINATOR	D. Harlis	11/201
7	Revised As Noted.	CONSTRUCT	VII. & Goodman	11-25
		ERC Q.A.	N/A and	
		CPAL	18 M Lun	12-1-81
		DES. ENG. *	MARY	

CONSTRUCTION PROCEDURES MANUAL SHAPP	PROCEDURE NO. DATE MP-10 As Approved			
GENERAL WELDING PROCEDURE	REVISION 11			
DESCRIPTIONREPAIR OF BASE MATERIALS AND WELDMENTS	PAGE 3 OF 31			

CAROLINA POWER & LIGHT COMPANY

SHEARON HARRIS NUCLEAR POWER PLANT

FEB 1 6 1984 Ev. 11

GENERAL WELDING PROCEDURE
MP-10

SEP 21 1983 Rev. 10

DEC 3 0 1982 Rev. 9 DOCUMENT CONTROL

JUN 2 1 1982

Rev.8

SHEARON HARRIS N. P. P.

* REVIEWED AND APPROVED BY EBASCO SERVICES, INC., FOR CONFORMANCE TO THE REQUIREMENTS OF PARAGRAPH CA-3310 OF ARTICLE CA-3300 OF ASME/AC1 359, SECTION III, DIV. 2, WINTER 1975 ADDENDA.

REV.	DESCRIPTION	The state of the	APPROVALS	DATE
8	Revised As Noted.	ORIGINATOR	A. Harful	4/13/2
Incorporated Deviation Notices 1, 2, and 3. Revised Exhibit 1.	CONSTRUCTOR	W. Horder	615	
	EBC Q.A.	NA DH	6/17/5	
	CPAL	R. Herford For A.M. inco	-	
		DES. ENG. *	N/A ELS	6/17/2
9	Revised As Noted.	ORIGINATOR	R. Harbol	674
	Incorporated Deviation Notice 2.	CONSTRUCTOR	W. D. Hoodwa	12.22
		E&C Q.A.	N/A XX	12/20/2
		CPAL	R. Harford FIR HF THOMPSON TR	THE RESERVE AND ADDRESS OF THE PERSON NAMED IN
		DES. ENG. +	N/A PK	14/23/8
		ORIGINATOR		700/6
		CONSTRUCTOR		
		EBC QA		
		CPAL.		
_		DES. ENG. +		

11. 1

FORM NO. 1784-A

CONSTRUCTION PROCEDURES MANUAL SHAPP	PROCEDURE NO. DATE			
GENERAL WELDING PROCEDURE	REVISION 11			
DESCRIPTION REPAIR OF BASE MATERIALS AND WELDMENTS	PAGE 4 OF 31			

## CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT GENERAL WELDING PROCEDURE MP-10

- . REVIEWED BY GA/OC FOR COMPLIANCE WITH THE APPLICABLE GA AND GODE REQUIREMENTS.
  - # REVIEWED AND APPROVED BY EBASCO SERVICES, INC., FOR CONFORMANCE TO THE REQUIREMENTS OF PARAGRAPH CA-3310 OF ARTICLE CA-3100 OF ASME/ACI 359, SECTION III, DIV. 2, WINTER 1975 ADDENDA.

REV.	DESCRIPTION		APPROVALS	DATE
10	Revised As Noted. Incorporated Deviation	ORIGINATOR	A. Harbod,	8/14/5
	Notice 2 and 3 As	CONSTRUCTOR	W. Hordan	6.158
	Applicable. Deviation Notice 1 voided.	QA/QC REVIEW + +	MNIPL	9/10/8
	Deleted Exhibit 1-3. Changed Exhibits 2 and 3	CPAL	P. Harpord For M. F. Manpson &	ahe to
	to 1 and 2 respectively. Added New Exhibit 3.	DES. ENG. *	N/A Det	9/11/2
11	Incorporated Procedure Change Notice 1.	ORIGINATOR	R. Flankel	2/4/4
		CONSTRUCTOR	Ala Marchina	2148
		QA/QC REVIEW .	12-T H. Vu	2/15/8
		CPAL	R. Hamped for M. Thomas n.	The state of the last of the l
		DES. ENG. *	N/A EH	1/11/24
		ORIGINATOR		7 10 10 4
		CONSTRUCTOR		
		QA/QC REVIEW * *		
		CPAL		
		DES. ENG. *		

CONSTRUCTION PROCEDURES MANUAL SHNPP MP-10 As Approved

GENERAL WELDING PROCEDURE

DESCRIPTION REPAIR OF BASE MATERIALS AND WELDMENTS Page 5 of 31

#### 1.0 SCOPE

- 1.1 This specification provides a procedure to be followed for the repair of defects in base material and field welds of components, piping, and structures at the SHNPP Site.
- 1.2 ASME "Code" Classes 1, 2, and 3 are also addressed as Categories 1, 2, and 3, respectively, in this procedure.
- 1.3 This is an ASME Section III Procedure.

#### 2.0 REFERENCES

- 2.1 "ASME Boiler and Pressure Code", Section III, Division I, 1976 Winter Addenda, 1974 Edition
- 2.2 ANSI B31.1 Power Piping Code 1973 Edition, Summer 1973 Addenda
- 2.3 MP-01, Procedure for Qualifying Welding Procedures
- 2.4 MP-02, Procedure for Qualifying Welders
- 2.5 MP-04, Procedure for Heat Treatment
- 2.6 MP-06, General Welding Procedure for Carbon Steel Weldments
- 2.7 MP-07, General Welding Procedure for Stainless Steel Weldments
- 2.8 "ASME Boiler & Pressure Code" Section III, Division 2, 1974 Edition Winter 1975 Addenda.
- 2.9 Site Specification 030, 031, 032, 033 Field Erection Specifications
- 2.10 AWS DL1 Structural Welding Code, 1975 Edition
- 2.11 MP-08, General Welding Procedure For Structural Steel (Seismic and Non-seismic) and Hangers

#### 3.0 GENERAL

- 3.1 Only qualified welding materials and welders using qualified procedures shall perform repair welds with References 2.1, 2.2, 2.3 and 2.10, as appropriate.
- 3.2 Repair weld data reports (RWDR) are required on Code Class 1, 2, 3, MC and seismic 1 items for the following:
  - Weld repairs (repair by welding) on completed weld joints for indications detected by NDE.

R11

中央中心的中心的一个大型工作的。在1000年的中央中心的1000年的1000年的1000年,1000年的1000年的100年的1000年的1000年的1000年

CONSTRUCTION PROCEDURES MANUAL SHNPP	Procedure No. MP-10	Date As Approved	
GENERAL WELDING PROCEDURE	Revision	11	
DESCRIPTION REPAIR OF BASE MATERIALS AND WELDMENTS	Page 6	of	31

- 2. Weld repairs to base metal.
- 3.3 RWDRs are not required on Code Class 1, 2, 3, MC and seismic 1 items for the following:
  - 1. In-Process Repairs

During the welding of pipe joints, it is considered in-process welding for any repairs until welding is complete. This includes any weld defects that are detected visually or by information derived from NDE prior to the completion of welding.

R11

2. Weld Cut-Out

A new Weld Data Report (WDR) shall be written for a pipe weld joint repair which results in cutting the completed weld joint out and reprepping for a new weld. A comment shall be entered in the "Remarks" that "previous weld joint cut and reprepped for welding". The original WDR shall be marked "Superseded" and shall be attached to the back of the new WDR. For seismic Class I structural items and safety related tubing (instrumentation), it shall not be necessary to generate a new WDR and mark the old WDR "Superseded" since weld joint number(s) and hold points may be re-established on the original seismic WDR and/or safety related instrumentation WDR for weld cut-outs.

R11

R11

- 3. For the removal of indications in the completed weld joint or adjacent base metal that were detected by NDE, where removal will not necessitate a weld repair. In this case, the required QC/ANI NDE holdpoints shall be re-established on the original WDR. If it is later determined that removal of these indications has resulted in a violation of minimum wall thickness, a repair WDR shall be generated to facilitate the weld repair.
- 3.4 A weld repair or a repair to base metal that requires a RWDR shall be reported by the welding inspector personnel to the SHNPP Discipline Engineer-Metallurgy/Welding, or his designee, and Quality Assurance who will coordinate the repair procedure with the Discipline Engineer-Metallurgy/Welding, or his designee. It is the responsibility of the

CONSTRUCTION PROCEDURES MANUAL SHNPP

GENERAL WELDING PROCEDURE

DESCRIPTION REPAIR OF BASE MATERIALS AND WELDMENTS

Procedure No. MP-10

Revision

11

Page 7 of 31

(3.4 cont.)

Discipline Engineer-Metallurgy/Welding, or his designee, to effect a resolution of the repair or replacement. The ANI shall be notified by the Director-QA/QC of weld repairs or repair to base metal that requires a RWDR prior to initiation of such repairs. The ANI may establish hold points as deemed necessary. If a RWDR is in progress and a reject occurs due to an inspection hold point necessitating additional grinding, buffing, or welding on the same location, a new RWDR is not required. Additional QC/ANI hold points, as necessary, should be added to repeat inspections until an acceptable inspection is completed. A new RWDR should only be necessary under the following conditions:

- A different repair method is required.
- A repair is required at a new location on an item in an area not previously identified on the discrepancy report and the new repair will be handled as a separate repair.
- 3. If an additional weld repair is at the same location which was previously repaired and has been completed, inspected, and the documentation is completed, the new RWDR would be Number 2, 3, etc.

R11

- 3.5 After the repair is completed the repaired area shall be examined by the same method used to detect the original defect and by any additional NDE as required. For Code Class 1, 2, and 3 base metal repairs, the QA Welding Inspector will prepare a sketch of the repaired area for QA records showing the location and size of the prepared cavity, the welding material identification, the welding procedure, the heat treatment and the examination results of repair welds exceeding in depth the lesser of 3/8 inch or 10% of the section thickness. The RWDR will be maintained as QA records.
- 3.6 The Discipline Engineer-Metallurgy/Welding shall have the authority to assign or remove welders at his discretion.
- 3.7 Welders chosen to perform field welds should be chosen based on the qualification to weld the full thickness of the field joint. The Discipline

WHEN THE PROPERTY OF THE PROPE

R11

Form No. 1784 8					Date
CONSTRUCTION PROCEDURES MANUAL	SHNPP	MP-10	Procedure No.		Approved
하게 하는 마음에서 불가 없어 하면 그 전에 보았다. 이 보통 중에 되고 있어요? 그 집에 가장 이 가장 그는 것이 되었다고 있다. 그 없어 하는 것이 되었다. 나를 모르는데 하다 때 나를		Revision	11		
GENERAL WELDING PROCEDURE DESCRIPTION REPAIR OF BASE MATE	RIALS AND WELDMEN	TS Page	8	of	31

(3.7 cont.)

Engineer-Metallurgy/Welding must be notified to evaluate any situations where this may not be possible to ensure that the actual thickness welded by each welder does not exceed his/her qualification thickness range and permit documentation when deemed necessary.

- 3.3 A welding QC specialist, or his designee, shall be notified by the craft foreman when a QC/ANI holdpoint is reached on the WDR/RWDR.

  Work shall not progress beyond a designated hold point until that hold point has been inspected and signed off. QC/ANI, as applicable, shall be notified in the event work regresses during in-process repair or rework of a fabrication which supersedes a previous hold point which has been signed off by QC/ANI. This will permit the assigning of a new hold point to allow reinspection/reverification of the previous hold point.
  - 3.9 When a RWDR is required by this procedure, the RWDR (QA-30, latest revision) shall be used for pipe (Code Class 1, 2, 3 & MC) components and a Seismic Weld Data Report (SWDR) (QA-34, latest revision) shall be used for structural components. When a SWDR is used for repairs, the word "Repair" shall be added to the SWDR.

#### 4.0 PROCEDURE

- 4.1 Base metal repairs not requiring welding on pressure retaining equipment Category 1-3.
  - 1. Plate
    - Unacceptable surface defects shall be removed by grinding or machining, provided:
      - The remaining thickness of the section is not reduced below that required by the design.
      - The depression, after defect elimination, is blended uniformly into the surrounding surface.
      - After defect elimination the area is reexamined by the magnetic particle method or the liquid penetrant method to assure that the defect has been removed or the indication reduced to an acceptable size.

CONSTRUCTION PROCEDURES MANUAL	SHNPP	Procedure No. MP-10	As	Date Approved
GENERAL WELDING PROCEDURE		Revision 11		
DESCRIPTION REPAIR OF BASE MATE	RIALS AND WELDMENTS	Page 9	of	31

(4.1.1.1 cont.)

- 4. Areas ground to remove oxide scale or other mechanically caused impressions for appearance, or to facilitate proper ultrasonic testing, need not be examined by the magnetic particle or liquid penetrant test method.
- 2. When the elimination of the defect reduces the thickness of the section below the minimum required by the design, the product shall be repaired in accordance with 4.2.1.
- Forgings and Bar Same as Section 4.1.1.
- 3. Wrought Seamless Welded Tubular Products and Fittings (Without Filler Metal)
  - Unacceptable surface defects shall be removed by grinding or machining, provided:
    - The remaining thickness of the section is not reduced below that required by the design.
    - The depression, after defect elimination, is blended uniformly into the surrounding surface.
    - 3. After defect elimination the area is examined by the method which originally disclosed the defect to assure that the defect has been removed or the indication reduced to an acceptable size.
  - If the elimination of the defect reduces the thickness of the section below the minimum required by the design, the product may be repaired in accordance with 4.2.3.
- 4. Tubular Products and Fittings (With Filler Metal)
  - Unacceptable surface defects shall be removed by grinding or machining and, in addition, the requirements of (1), (2), and (3) (below) shall be met.
    - The remaining thickness of the section shall not be reduced below that required by the design.

Form No 1784 B

CONSTRUCTION PROCEDURES MANUALSHNPP			Procedure No. MP-10		Date As Approved		
GENERAL WELDING PRO	CEDURE			Revision	11		
DESCRIPTION REPA	IR OF BASE	MATERIALS AND	WELDMENTS	Page	10	of	31

(4.1.4.1 cont.)

- The depression, after defect elimination, shall be blended uniformly into the surrounding surface.
- 3. After defect elimination the area shall be re-examined by the magnetic particle method or the liquid penetrant method to ensure that the defect has been removed or reduced to an acceptable size. If the area of the defect elimination is in the weld seam, the acceptance standards shall be in accordance with NB-5340 or NB-5350, whichever is applicable.
- If the elimination of the defect reduces the thickness of the section below the minimum required by the design, the product may be repaired in accordance to 4.2.4.
- Statically and Centrifugally Cast Products
   Same as Section 4.1.1.
- 4.2 Base Metal Repairs Requiring Welding on Category 1-3:
  - 1. Plate

Repair by welding may be performed on material from which defects have been removed, provided requirements of the following sub-paragraphs are met.

- 1. The cavity shall be prepared by chipping, grinding, or gouging to sound clean metal. If gouging is used for metal removal, 1/16 inch of the gouged surface shall be removed prior to rewelding. (Whenever thermal cutting methods are used, consideration shall be given to preheat requirements.)

  The cavity shall be sufficiently wide to permit complete fusion and allow adequate manipulation of the electrode.

  The cavity must be liquid penetrant or magnetic particle inspected before welding (to ensure removal of unacceptable indications) as given on the RWDR.
- The manner of depositing the repair weld metal must be in accordance with the original welding procedure specified by the Discipline Engineer-Metallurgy/Welding, or his designee,

CONSTRUCTION PROCEDURES MANUAL SHNPP			Procedure No. MP-10		As Approved	
GENERAL WELDING PROCEDURE		Revision	11			
(1)	TERIALS AND WELDMENTS	Page	11	of	31	

(4.2.1.2 cont.)

which has been approved. All welding shall be done by qualified welders. Original purge requirements must apply if the remaining weld thickness is less than 3/16 inch.

- After repair the surface shall be blended uniformly into the surrounding surface.
- 4. Examination of Weld Repairs Each repair weld for Category 1 and 2 shall be examined by the magnetic particle method or by the liquid penetrant method. In addition, repair cavities, the depth of which exceeds the lesser of 3/8" or 10% of the section thickness, shall be radiographed after repair. Each repair weld for Category 3 shall be examined by the magnetic particle method or by the liquid penetrant method. In addition, repair cavities, the depth of which exceeds the lesser of 3/8" or 10% of the section, shall be radiographed after repair. However, radiography is not required for weld repairs in material used in components, provided that the welds joining materials are not required to be radiographed and the surface area of the repaired area does not exceed 10 square inches. The penetrometer and the acceptance standards for radiographic examination of repair welds shall be based on the section thickness at the repair area.
- Any post weld heat treatment will be in accordance to MP-04.

#### 2. Forgings and Bar

Weld repairs should be done in accordance to 4.2.1, with the following exception. For ferritic steel forgings, the completed repair may be examined by the ultrasonic method in lieu of radiography.

 Seamless and Welded (Without Filler Metal) Tubular Products and Fittings

Weld repairs shall be done in accordance to 4.2.1.

CONSTRUCTION PROCEDURES MANUAL	SHNPP	Procedure MP-10	Procedure No. MP-10		As Approved		
GENERAL WELDING PROCEDURE		Revision	11				
DESCRIPTION REPAIR OF BASE MATE	RIALS AND WELDMENTS	Page	12	of	31		

- (4.2 cont.) 4. Tubular Products and Fittings Welded With Filler Metal
  Repair welding of base material defects shall be in accordance
  with 4.2.1. Repair welding of weld seam defects shall be in
  accordance with 4.4.
  - Statically and Centrifugually Cast Products

    Repair of castings, by welding, may be performed after all unacceptable defects are removed by suitable mechanical cutting or thermal gouging methods to sound metal, or until any defect remaining is within the acceptance standards, provided the cavity is prepared for welding and the following subparagraphs are satisfactorily followed:
    - Qualification of Welding Procedures and Welders
       The welding procedure and welders or welding operators shall be qualified in accordance to References 2.3 and 2.4.
    - Blending of Repaired Areas
       After welding the surface shall be blended uniformly into the surrounding surface.
    - 3. Examination of Repair Welds
      - examined by the magnetic particle method or by the liquid penetrant method. In addition, repair cavities, the depth of which exceeds the lesser of 3/8" or 10% of the section thickness, shall be radiographed after repair. Each repair weld for Category 3 shall be examined by the magnetic particle method or by the liquid penetrant method. In addition, repair cavities, the depth of which exceeds the lesser of 3/8" or 10% of the section, shall be radiographed after repair. However, radiography is not required for weld repairs in material used in components, provided that the welds joining materials are not required to be radiographed and the surface area of the repaired area

CONSTRUCTION	PROCEDURES MANUAL	SHNPP		Procedure No. MP-10		As Approved		
GENERAL WELD	ING PROCEDURE			Revision	11			
DESCRIPTION _	REPAIR OF BASE MAT	ERIALS AND	WELDMENTS	Page	13	of	31	

(4.2.5.3.1 cont.)

- does not exceed 10 square inches. The penetrometer and the acceptance standards for radiographic examination of repair welds shall be based on the section thickness at the repair area.
- 2. Examination of repair welds in P-No. 1 and P-No. 8 on Category 2 and 3 material is not required for pumps and valves with inlet piping connections over 2 inches, up to and including 4 inches, nominal pipe size when a quality factor of 0.70 is applied to the pressure rating of the valve and to the allowable stress values used in the design of the pumps.
- Examination of repair welds in P-No. 1 and P-No. 8
  material is not required for pumps and valves with
  inlet piping connections 2 inches nominal pipe size and
  less.
- 4. Post Weld Heat Treatment After Repairs All PWHT shall be in accordance to MP-04 except that the heating and cooling limitations of paragraph 3.11.1 of MP-04 do not apply.
- 4.3 Repair of Weld Metal Defects
  - Elimination of Surface Defects on Category 1-3
     Weld metal surface defects may be removed by grinding or machining and not repaired by welding, provided that the requirements of (1), (2), and (3) are met.
    - The remaining thickness of the section is not reduced below that required by the design.
    - The depression, after defect elimination, is blended uniformly into the surrounding surface.
    - 3. The area is examined, after blending by a magnetic particle or liquid penetrant method meeting the requirements of Articles 6 and 7 of Section V, to ensure that the defect has been removed or the indication reduced to an acceptable limit.

CONSTRUCTION PROCEDURES MANUAL SHNPP	Procedure MP-1		T.	Date As Approved		
GENERAL WELDING PROCEDURE		Revision 11				
DESCRIPTION REPAIR OF BASE MATERIALS AND WELDMENTS	Page	14	of	31		

#### 2. Defect Removal on Category 1-3

Unacceptable defects shall be removed by mechanical means or by thermal gouging processes. The area prepared for repair shall be magnetic particle or liquid penetrant inspected before welding to ensure removal of unacceptable indications except where the full thickness of the weld is removed and where the backside of the weld joint assembly is not accessible for removal of examination materials. In such cases, ASME Code Case N275 (Exhibit 3) may be invoked. For those welds where Code Case N275 is invoked, it shall be so noted on the RWDR. Partial penetration welds (fillet), such as tube-to-tube sheet welds and those where defect removal essentially removes the full thickness of the weld, need only be examined visually to the satisfaction of the inspector to determine suitability of re-welding. Where purge gas is required by the welding process and the excavation removes metal to a depth where the metal remaining is less than two weld passes or 3/16 inches thick, back purge gas will be used during the weld repair until the required minimum root thickness has been re-established.

- The weld repair shall be made by qualified welders using qualified procedures.
- 4. Repair welds on Category 4-8 materials shall be made in accordance with the same procedure used for original welds or by another welding process if it is a part of a qualified procedure, recognizing that the cavity to be repaired may differ in contour and dimensions from the original joint.
- After repair the surface shall be blended uniformly into the surrounding surface.
- Examination of Weld Repairs on Category 1-3
  - The examination of weld repairs shall be repeated as required for the original weld except that repair of defects originally detected by magnetic particle or liquid penetrant

R11

(4.3.6.1 cont.)

methods need only be reexamined by a magnetic particle or liquid penetrant method when the repair cavities do not exceed the lesser of 3/8 inch or 10% of the thickness.

- When repairs to weld joining P-No. 1 and P-No. 3 materials require examination by radiography as required in (1) above, but construction assembly prevents meaningful radiographic examination, ultrasonic examination may be substituted provided:
  - The weld had been previously radiographed and met the applicable acceptance standards.
  - The ultrasonic examination is performed using a procedure in accordance with Article 5 of Section V to the acceptance standards of NB-5330.
  - 3. The substitution is limited to Category A and B welds in vessels and similar type welds in other items (see Exhibit 1). The absence of suitable radiographic equipment is not justification for the substitution.
- The types, extent and method of examination and limits of imperfections of repair welds shall be the same as for the original welds on Category 4-8 materials.
- The area shall be heat treated in accordance to MP-04 and the applicable welding procedure specifications.
- 9. Weld Repairs Without Required Postweld Heat Treatment
  Limited weld repairs to P-1 and P-3 materials and A-1 or A-2 (in
  addition, A-10 and A-11 for Category 3) weld filler metal (Table
  QW-442 of Section IX) may be made without PWHT, provided the
  requirements of the following subparagraphs are met.
  - Before repair, the area shall be examined by either
    magnetic particle or liquid penetrant methods to ensure
    elimination of unacceptable indications.
  - The depth of the repair shall not be greater than 3/8 inch or 10% of the base thickness for Category 1 material and 1/2

R11

さいませい からまかいて、アフトは、これは、これできていいっていること

Form No. 1784 B	Procedure No.	Date
CONSTRUCTION PROCEDURES MANUALSHNPP	MP-10	As Approved
GENERAL WELDING PROCEDURE REPAIR OF BASE MATERIALS AND WELDMENTS	Page 1	6 of 31

(4.3.9.2 cont.)

- inch or 50% of base thickness or weld thickness, whichever is less, for Category 2 and 3, and the individual area shall not be greater than 10 square inches.
- 3. The welding procedure and welder qualification shall meet all of the requirements of References 2.3 and 2.4 and the additional requirements of this article. The Welding Procedure Specification shall include the requirements of (1) through (8) below.
  - The area to be repaired shall be suitably prepared for welding in accordance with a written procedure.
  - The weld metal shall be deposited by the manual shielded metal arc process using low-hydrogen type electrode. The maximum bead width shall be four times the electrode core diameter.
  - The low-hydrogen covered electrodes shall be baked and otherwise cared for as required by (1) and (2) below.
    - covered electrodes before use at a temperature of 800°F (+ 25°F) for 30 minutes to one hour. The temperature of the oven shall not exceed 300°F when the electrodes are placed in the oven for baking. During the baking cycle, the temperature shall not be raised more than 300°F/hr. when oven temperatures are above 500°F and the total time above 500°F, including the holding time, shall not exceed five hours. After baking and before the electrodes are allowed to cool below 150°F, they shall be transferred to holding ovens operating in temperature ranges of 225° to 300°F.

Form No. 1784 B

CONSTRUCTION PROCEDURES MANUAL	SHNPP	Procedure MP-10	No.	As	Approved
GENERAL WELDING PROCEDURE		Revision	11_		
DESCRIPTION REPAIR OF BASE MATE	RIALS AND WELDMENTS	Page	17	of	31

(4.3.9.3.3 cont.)

- 2. Suitable heated portable containers shall be used at 225-300°F. Electrodes turned in after exposure shall be returned to the holding ovens and held at temperatures given in (1) above for a period of not less than eight hours before reissue. Electrodes shall not be rebaked more than once, except if tests establish that the electrodes, after multiple rebakings, meet all specification requirements.
- 4. The weld area shall be preheated and maintained at a minimum temperature of 350°F during welding. The maximum interpass temperature shall be 450°F.
- 5. The initial layer of weld metal shall be deposited over the entire area with 1/8 inch maximum diameter electrode. Approximately one-half the thickness of this layer shall be removed by grinding before depositing subsequent layers. Subsequent layers shall be deposited with a 5/32 inch maximum diameter electrode in a manner to ensure tempering of the prior heads and their heat affected zones.
- Heat input shall be controlled within a specified range of welding current and voltage.
- 7. The weld area shall be maintained at a temperature of 400-500°F for a minimum period of 2 hours after completion of the weld repair.
- The performance of the repair welding shall be witnessed by the ANI if he wishes.
- 9. The qualification test plate shall be the minimum thickness of base metal at the area to be repaired but need not be greater than 4 inches (102 mm) thick and shall be of the same nominal composition as the material to be repaired. The qualification test plate

		Date .
	Procedure No. MP-10	As Approved
Form No. 1784 B SHNPP	Revision	
CONSTRUCTION PROCEDURES MANUAL	-	of 31
GENERAL WELDING PROCEDURE REPAIR OF BASE MATERIALS AND WELDMENTS	Pege 18	
DESCRIPTIONREPAIR OF BASE MATERIAL		

(4.3.9.3.9 cont.)

assembly shall be prepared and tested in accordance to NB-4642 4-1.

- The completed welds shall have the weld reinforcement, including the final layer, removed substantially flush with the surface prior to performing the required nondestructive examination. The nondestructive examination shall be performed after the completed weld has been at ambient temperature for a minimum period of 48 hours to determine the presence of possible delayed cracking of the weldments. The nondestructive examination of the repair welded region shall include both ultrasonic examination and a surface examination.
  - SHNPP Quality Assurance group shall maintain records including dimensions and location of the weld repairs. 5.
- Repair Welds to Cladding After Final Post Weld Heat Treatment Non-post weld heat treated weld repairs may be made to P-8 or 10. P-43 cladding of P-1 and P-3 material after final PWHT, provided it is impossible or impractical to PWHT the area after repair, and provided the requirements of the following subparagraphs are met.

#### Maximum Extent of Repair ١.

The base metal shall not be exposed to a depth greater than 3/32 inch or 13% of the base metal thickness, whichever is the lesser, nor to any individual area greater than 10 square inches.

#### Repair Welding Procedure 2.

The welding procedure and welder qualifications shall meet all of the requirements of ASME Code Section IX and the additional requirements of 1 through 6 below.

The repairs shall be made using A-No. 8 weld metal (QW-442 of ASME Code Section IX) for P-No. 8 cladding or F-No. 43 weld metal (QW-432 of ASME Code Section IX) for either P-No. 8 or P-No. 43 cladding.

	Procedure No MP-10		As	Approved
CONSTRUCTION PROCEDURES MANUAL SHNPP	Revision	11		
GENERAL WELDING PROCEDURE REPAIR OF BASE MATERIALS AND WELDMENTS	Page	19	of	31

(4.3.10.2 cont.)

- The manual shielded metal arc process shall be used for welding with a bead width not to exceed four times the electrode core diameter.
- The weld area shall be preheated and maintained at a minimum temperature of 350°F during welding. The maximum interpass temperature shall be 450°F.
- 4. All areas of the base material on which weld metal is to be deposited shall be covered with a single layer of weld deposit using 3/32 inch diameter electrodes, followed by a minimum of one layer of weld deposit using 1/8 inch diameter electrodes. Part of the first layer shall be removed by grinding and any removal of weld metal between layers shall be described and duplicated in the procedure qualification.
- The heat input shall be controlled within a specified range of welding current, voltage, and speed of travel.
- After completion of welding, the weld area shall be maintained at a temperature of 400-500°F for a period of one hour minimum.

## Qualification Test Assembly

The qualification test assembly shall consist of a 3 inch minimum thickness plate of the same nominal composition as the base material that is to be clad. The qualification test plate assembly shall be prepared and tested in accordance with the requirements of Section IX.

## 4. Examination of Repair Welds

The completed weld shall be nondestructively examined in accordance with paragraph 4.3.1.6 of this procedure.

## Records of Repair Welds

Appropriate records and actual dimensions of weld repairs shall be documented and made a part of the Manufacturer's Data Report form.

4.4 Arc strikes which are considered defects shall be removed by grinding and visually inspected with 5X magnification to ensure complete removal and soundness of metal in affected area. In addition, the area shall also be examined by MT or PT on all Category 1 and 2 piping and Category 4 and 5 mainsteam/feedwater piping.

# 4.5 Field Repair to Piping Butt Joint End Preparation Existing piping butt joint end preparations shall not be remachined, filed, ground, or otherwise changed without prior approval of the Discipline Welding Engineer or his designee, except as follows:

- Light grinding of the groove face is permitted during interpass bead cleaning of weld metal deposited in field welds.
- Grinding as required to restore groove faces after removal of fitup spacer blocks.
- 3. Local spot repair of weld end preparation by welding, grinding or filing to restore the end prep to the required design configuration (whether due to damage that occurred at the site or prior to delivery) provided such welding repair is made in accordance with a procedure approved by the Discipline Welding Engineer or his designee.
- 4. End preps with sharp roughness (feels tacky to finger rub) shall be smoothed with emery cloth or sanding disks. Such roughness is a frequent cause of porosity due to cutting oil trapped in the rough lay of the machined surface.
- 4.6 Repairs to be made on Category 4-8 items shall be in accordance to the following:

## l. Weld Defect Repairs

- All defects in welds requiring repair shall be removed by flame or arc gouging, chipping or machining.
- Repair welds shall be made in accordance with the same procedure used for original welds or by another welding process if it is a part of a qualified procedure, recognizing that the cavity to be repaired may differ in contour and

de monte de la latera establisha de la latera

Form No. 1784 B SHNPP	Procedure MP-10	NO.	As	Approved
CONSTRUCTION PROCEDURES MANUAL SHAFF	Revision	11		
GENERAL WELDING PROCEDURE REPAIR OF BASE MATERIALS AND WELDMENTS	Page	21	of	31
DESCRIPTION REPAIR OF BASE 1		100		

(4.6.1.2 cont.)

- dimensions from the original joint. The types, extent and method of examination and limits of imperfections of repair welds shall be the same as for the original weld.
- Preheating may be required for flame-gouging or arc-gougng 3. on certain alloy materials of the air hardening type in order to prevent surface checking or cracking adjacent to the flame or arc-gouged surface.
- Any cracks, blowholes or other defects that appear on the 4. surface of the weld beads shall be removed by chipping or grinding before the next covering weld bead is deposited. Stagger all stops and starts. Stops and starts shall be examined by the welder and all defects removed before continuing to weld. Repairs shall be checked per the original NDE.
- Arc strikes produced by welding electrodes or magnetic particle inspection shall not be purposely made on base metal surfaces outside of the weld groove area or other areas not to be covered by weld metal. Where inadvertent arc strikes on the base metal surface occur outside the weld area or on the final weld leaves a defect condition, the surface shall be ground to the bottom of the depression and inspected visually. (For Category 4 and 5 mainstream and feedwater piping the ground depression shall be liquid penetrant inspected.) If the design material thickness has been violated the arc strike shall be repair welded.

#### Repair of Base Material Defects 3.

- Approval is required from the Discipline Engineer-Metallurgy/Welding, or designee, for repair of base material defects after final heat treatment or hydrotest. Repair welding of defects in base material shall be accomplished in accordance with the applicable code(s).
  - The shape of the excavated repair area shall be adequate for 2. access of the welding arc. The ends of the cavity shall fair

R11

A STATE OF THE PROPERTY OF THE PARTY OF THE

Form No 1784 8 SHNPP		Procedure No. MP-10	As Approved
CONSTRUCTION PROCEDURES MANUAL		Revision 11	
GENERAL WELDING PROCEDURE DESCRIPTION REPAIR OF BASE MATE	RIALS AND WELDMENTS	Page 22	of 31

(4.6.3.2 cont.) neatly into the existing weld or base metal without abrupt offsets or pockets.

3. Repair welding of defects in base material (piping, castings, plates) shall be accomplished in accordance with the applicable ASME-SA, ASTM-A specifications, except that welding procedures, qualifications and welder performance qualifications shall be in accordance with MP-01 and MP-02 respectively.

4.7 Repairs made on seismic Class I structures shall be made in accordance to the following:

Repair Welding of Base Metal Defects
 Documented evidence shall be provided showing that the joint preparation has been visually inspected and is acceptable in accordance to the following sub-paragraphs:

- 1. Surfaces and edges to be welded shall be smooth, uniform, and free from fins, tears, cracks, and other discontinuities which would adversely affect the quality or strength of the weld. Surfaces to be welded and surfaces adjacent to a weld shall also be free from loose or thick scale, slag, rust, moisture, grease and other foreign material that would prevent proper welding or produce objectionable fumes.

  Mill scale that can withstand vigorous wire brushing, a thin rust-inhibitive coating, or anti-spatter compound may remain with the following exception. For girders, all mill scale shall be removed from the surfaces on which flange-to-web welds are to be made by submerged arc welding or by shielded metal arc welding with low hydrogen electrodes.
  - 2. In all oxygen cutting, the cutting flame shall be so adjusted and manipulated as to avoid cutting beyond (inside) the prescribed lines. The roughness of oxygen cut surfaces shall be no greater than that defined by the American National Standards Institute - a surface roughness value of 1000u

| R11

CONSTRUCTION PROCEDURES MANUAL SHNPP Procedure No. MP-10 As Approved

GENERAL WELDING PROCEDURE

DESCRIPTION REPAIR OF BASE MATERIALS AND WELDMENTS Page 23 of 31

(4.7.1.2 cont.)

inches (25 um) for material up to 4 inches (102 mm) thick and 2000u inches (50 um) for material 4 inches to 8 inches (203 mm) thick, with the following exception. The ends of members not subject to calculated stress at the ends shall meet the surface roughness value of 2000u inches. Roughness exceeding these values and occasional notches or gouges no more than 3/16 inch (4.8 mm) deep, on otherwise satisfactory surfaces, shall be removed by machining or grinding. Cut surfaces and edges shall be left free of slag. Correction of discontinuities shall be faired to the oxygen cut surfaces with a slope not exceeding one in ten. In oxygen cut edges, occasional notches or gouges less than 7/16 inch (11.1 mm) deep in material up to 4 inches thick, or less than 5/8 inch (15.9 mm) deep in material over 4 inches thick may, with the approval of the Engineer, be repaired by welding. Other discontinuities in oxygen cut shall not be repaired by welding. Any approved weld repairs shall be made by (1) suitably preparing the discontinuity, (2) welding with low hydrogen electrodes not exceeding 5/32 inch 4.0 mm) diameter, (3) observing the applicable requirements of this Code and (4) grinding the completed weld smooth and flush with the adjacent surface to produce a workmanlike finish.

- 3. Visual Inspection and Repair of Plate Cut Edges
  - 1. In the repair and determination of limits of internal discontinuities visually observed on sheared or oxygen cut edges and caused by entrapped slag or refractory inclusions, deoxidation products, gas pockets, or blow holes, the amount of metal removed shall be the minimum necessary to remove the discontinuity or to determine that the permissible limit is not exceeded. Plate edges may exist at any angle with respect to the

orm No 1784 B	Procedure MP-10	No.	As	Approved
CONSTRUCTION PROCEDURES MANUALSHIPP	Revision	11		
GENERAL WELDING PROCEDURE  REPAIR OF BASE MATERIALS AND WELDMENTS	Page	24	of	31

(4.7.3.1 cont.)

- rolling direction. All repairs of discontinuities by welding shall conform to the applicable provisions of this code.
- 2. The limits of acceptability and the repair of visually observed edge discontinuities shall be in accordance with Table A, in which the length of discontinuity is the visible long dimension on the plate cut edge and the depth is the distance that the discontinuity extends into the plate from the cut edge.
- 3. For discontinuities over 1 inch (25.4 mm) in length with depth greater than 1 inch, discovered by visual inspection of plate cut edges before welding or during examination of welded joints by radiographic or ultrasonic testing, the following procedures should be followed.
- 4. Where discontinuities such as (W), (X), or (Y) in Exhibit 2 are observed prior to completing the joint, the size and shape of the discontinuity shall be determined by ultrasonic testing. The area of the discontinuity shall be determined as the area of total loss of back reflection, when tested in accordance with the procedure of ASTM A435.
- 5. For acceptance, the area of the discontinuity (or the aggregate area of multiple discontinuities) shall not exceed 4% of the plate area (plate length x plate width) with the following exception. If the length of the discontinuity, or the aggregate width of discontinuities on any transverse section, as measured perpendicular to the plate length, exceeds 20% of the plate width, the 4% plate area shall be reduced by the percentage amount of the width exceeding 20%. (For example, if a discontinuity is 30% of the plate width,

THE PROPERTY OF THE PARTY OF TH

Form No. 1784 B		Procedure	No.		Date
CONSTRUCTION PROCEDURES MANUAL SHNPP		MP-10 Revision		As	s Approved
[6] 사람들의 경우를 가는데 학교 전문을 받는데 하게 되었다면 보면 되었다면 하는데 하는데 하는데 하다 되었다면 하는데		Revision	11		
GENERAL WELDING PROCEDURE REPAIR OF BASE MATERIALS AND	WELDMENTS	Page	25	of	31

(4.7.3.5 cont.)

the area of discontinuity cannot exceed 3.6% of the plate area.) The discontinuity on the cut edge of the plate shall be gouged out to a depth of 1 inch (25.4 mm) beyond its intersection with the surface by chipping, air carbon are gouging, or grinding, and blocked off by welding with the shielded metal are process in layers not exceeding 1/8 inch (3.2 mm) in thickness.

- in 4.7.1.3.3.2 is discovered after the joint has been completed and it is determined to be I inch (25.4 mm) or more away from the face of the weld as measured on the plate surface, no repair of the discontinuity is required. If the discontinuity (Z) is less than I inch away from the face of the weld, it shall be gouged out to a distance of I inch from the fusion zone of the weld by chipping, air carbon are gouging, or grinding. It shall then be blocked off by welding with the shielded metal are process for at least four layers, not exceeding 1/8 inch (3.2 mm) in thickness per layer. Submerged are or other welding process may be used for the remaining layers.
- 7. If the area of the discontinuity (W), (X), (Y), or (Z) exceeds the allowable in 4.7.3.3.2, the plate or subcomponent shall be rejected and replaced or repaired at the discretion of the engineer.
- The aggregate length of weld repair shall not exceed 20% of the length of the plate edge without approval of the Engineer.

Form No. 1784 B

CONSTRUCTION PROCEDURES MANUAL	SHNPP	Procedure MP-10	Procedure No. MP-10		Date Approved
GENERAL WELDING PROCEDURE		Revision	11		
DESCRIPTION REPAIR OF BASE MATE	RIALS AND WELDMENTS	Page	26	of	31

(4.7.3 cont.)

- All repairs shall be in accordance with this code.
   Gouging of the discontinuity may be done from either plate surface or edge.
- 10. Reentrant corners, except for the corners of weld access cope holes adjacent to a flange, shall be filleted to a radius of no less than 1/2 inch (12.7 mm) for buildings and tubular structures and 3/4 inch (19.0 mm) for bridges. The fillet and its adjacent cuts shall meet without offset or cutting past the point of tangency.
- Machining, air carbon are cutting, oxygen cutting, oxygen gouging, chipping, or grinding may be used for joint preparation, back gouging, or the removal of unacceptable work or metal except that oxygen gouging shall not be used on quenched and tempered steel.
- 12. Edges of built-up beam and girder webs shall be cut to the prescribed camber with suitable allowance for shrinkage due to cutting and welding. However, moderate variation from the specified camber tolerance may be corrected by a carefully supervised application of heat.
- Corrections of errors in camber of quenched and tempered steel must be given prior approval by the engineer.

CONSTRUCTION PROCEDURES MANUAL SHNPP	Procedure No. MP-10		As Approved	
GENERAL WELDING PROCEDURE		Revision 11		
DESCRIPTION REPAIR OF BASE MATERIALS AND WELDMENTS	Page	27	of	31

#### TABLE A

Limits on Acceptability and the Repair of Cut-Edge Discontinuities of Plate

Description of Discontinuity	None-need not be explored  None, but the depth should be explored	
Any discontinuity 1 in. (25.4 mm) in length or less		
Any discontinuity over 1 in:(25.4 mm) in length and 1/8 in. (3.2 mm) maximum depth		
Any discontinuity over 1 in. (25.4 mm) in length with depth over 1/8 in. (3.2 mm) but not greater than 1/4 in. (6.4 mm)	Remove, need not weld	
Any discontinuity over 1 in. (25.4 mm) in length with depth over 1/4 in. (6.4 mm) but not greater than 1 in.	Completely remove and weld. Aggregate length of welding shal not exceed 20 percent of the length of the plate edge being repaired	
Any discontinuity over 1 in. (25.4 mm) in length with depth greater than 1 in.	See 4.7.1.3.3	

A spot check of ten percent of the discontinuities on the oxygen-cut edge in question should be explored by grinding to determine depth. If the depth of any one of the discontinuities explored exceeds 1/8 in. (3.2 mm) then all of the discontinuities remaining on that edge shall be explored by grinding to determine depth. If none of the discontinuities explored in the ten percent spot check have a depth exceeding 1/8 in. (3.2 mm) then the remainder of the discontinuities on that edge need not be explored.

## 2. Repair of Weld Metal Defects

Repair of weld shall be made in accordance with the following requirements:

 If after an unacceptable weld has been made, work is performed which has rendered that weld inaccessible, or has created new conditions that make correction of the unacceptable weld dangerous or ineffectual, then the original conditions shall be restored by removing welds or (4.7.2 cont.)

- members, or both, before the corrections are made. If this is not done the deficiency shall be compensated for by additional work performed according to an approved revised design.
- may be done by machining, grinding, chipping, oxygen gouging, or air carbon arc gouging. It shall be done in such a manner that the remaining weld metal or base metal is not nicked or undercut. Oxygen gouging shall not be used in quenched and tempered steel. Unacceptable portions of the weld shall be removed without substantial removal of the base metal. Additional weld metal to compensate for any deficiency in size shall be deposited using an electrode preferably smaller than that used for making the original weld, and preferably not more than 5/32 inch (4.0 mm) in diameter. The surfaces shall be cleaned thoroughly before welding.
- 3. The contractor has the option of either repairing an unacceptable weld or removing and replacing the entire weld. The repaired or replaced weld shall be retested by the method originally used and the same technique and quality acceptance criteria shall be applied. If the contractor elects to repair the weld it shall be corrected as follows:
  - Overlap or Excessive Convexity Remove excess weld metal.
  - Excessive Concavity of Weld or Crater, Undersize Welds, Undercutting Prepare surfaces and deposit additional weld metal.
  - Excessive Weld Porosity, Excessive Slag Inclusions, Incomplete Fusion
     Remove unacceptable portions and reweld.
  - 4. Cracks in Weld or Base Metal

Form No. 1784 B CONSTRUCTION PROCEDURES MANUAL SHNPP As Approved Revision GENERAL WELDING PROCEDURE 11 REPAIR OF BASE MATERIALS AND WELDMENTS

(4.7.2 cont.)

DESCRIPTION

Ascertain the extent of the crack by use of acid etching, magnetic particle inspection, or other equally positive means. Remove the crack and sound metal 2 inches (50.8 mm) beyond each end of the crack and reweld.

29

31

- Members distorted by welding shall be straightened by mechanical means or by carefully supervised application of a limited amount of localized heat. Any material listed in AWS DLI may be heated to a temperature in the heated areas, as measured by approved methods, to a temperature which shall not exceed 1100°F (590°C) for quenched and tempered steel nor 1200°F (650°C) (a dull red color) for other steels. Any material not listed in AWS Dl.1 shall not be heated for straightening unless instructed in writing by the design specification or Welding Engineering. The part to be heated for straightening shall be substantially free of stress and from external forces. except those stesses resulting from the mechanical straightening method used in conjunction with the application of heat.
- Approval shall be obtained for such corrections as 6. repairs to base metal (other than those required by 4.7.1), repair of delayed cracks, straightening of members distorted by welding, or for a revised design to compensate for deficiencies.
- 7. The engineer shall be notified before improperly fitted and welded members are cut apart.

#### 3. Arc Strikes

Arc strikes produced by welding electrodes of magnetic particle inspection shall not be purposely made on base metal surfaces outside of the weld groove area or other areas not to be covered by weld metal. For Seismic Class I structures where inadvertent

CONSTRUCTION PRO	CEDURES	MA	NUAL	SI	INPP		Procedure I	No.	As	Date Approved
WORK PROCEDURE							Revision	11		- Approximation
DESCRIPTION	REPAIR	OF	BASE	MATERIALS	AND	WELDMENTS	Page	30	of	31

(4.7.2.3 cont.) arc strikes on the base metal surface occur outside the weld area or on the final weld, the surface shall be ground to the bottom of the depression and visually inspected.

#### 4. Defects

Any cracks, blowholes or other defects that appear on the surface of the weld beads shall be removed by chipping or grinding before the next covering weld bead is deposited. Stagger all stops and starts. Stops and starts shall be examined by the welder and all defects removed.

### 5. Welding of Drilled Holes

When welding to fill drilled holes in plate or structural shapes it will not be necessary to perform a visual inspection of the hole prior to welding. Drilled holes whose diameter is in excess of 5/16" shall be welded with the use of a backing plate or bar of material compatible with the base material. These welds will be accomplished with the use of Seismic I Weld Data Reports (for Seismic I items) originated by the Discipline Engineer and signed by the Metallurgy/Welding Engineer or his designee. If required by the Discipline Engineer, the backing shall be removed.

#### 4.8 Deviations

- The requirements of this specification shall be complied with during field welding except that waivers on specific sections of this document can be granted only in writing by the SHNPP Discipline Engineer-Metallurgy/Welding and then only when such waivers do not violate ASME "Code" or requirements of Reference 2.9.
- In the situation where the requirements of this procedure and the "Code" conflict, the "Code" requirement shall be complied with.
- Any conflicts or needs for changes during the course of welding a
  joint using this specification shall be resolved by the Discipline
  Engineer-Metallurgy/Welding or his designee.

Form No. 1784 B

CONSTRUCTION PROCEDURES MANU	JAL SHNPP	Procedure No. MP-10	As Approved
GENERAL WELDING PROCEDURE		Revision 11	
DESCRIPTION REPAIR OF BA	SE MATERIALS AND WELDMENTS	Page 31	of 31

### 5.0 EXHIBITS AND APPENDICES

- 5.1 Exhibit 1 Illustration of Welded Joint Locations Typical of Categories A, B, C, and D (Rev. 3-7/83)
- 5.2 Exhibit 2 Edge Discontinuities in Cut Plate (Rev. 3-7/83)
- 5.3 Exhibit 3 ASME Code Case N-275 (Rev. 0-7/83)

ILLUSTRATION OF WELDED JOINT LOCATIONS TYPICAL OF CATEGORIES A, B, C, AND D





Exhibit 2 MP-10

EDGE DISCONTINUITIES IN CUT PLATE



### CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT ASME CODE CASE N-275

CASES OF ASME BOILER AND PRESSURE VESSEL CODE

Meeting of March 7, 1980 Approved by Council, May 15, 1980

Case N-275
Repair of Welds
Section III, Division 1

Inquiry: What attendative rules may be used for the examination of the area orepared for repair of welds in lieu of the requirements of NB/NC/ND/NE/NF/NG-4453 for Section III, Division I construction where the full thickness of the weld is removed and where the back side of the weld joint assembly is not accessible for removal of examination materials?

Reply:

It is the pinton of the Committee that the following rules for the elamination of the area prepared for repair of welds may be used in lieu of the requirements of NB/NC/ND/NE/NF/NG-4453 for Section III, Division 1 construction:

- 1. Unacceptable indications shall be removed by mechanical means of by mechanic gonging methods.
- 2. The area prepared for repair shall be examined by the liquid penetran or magnetic particle method in accordance with NB/NC/ND/NE/NF/NG-5110 and shall meet the acceptance standards of NB/NC/ND/NE/NF/NG-5300 except that the examination is not required where the full thickness of the well is removed and where the back side of the weld is int assembly is not accessible for removal of examination materials.
- The completed weld repair shall be exhipted in accordance with NB/NC/ND/NE/NF/NG-4534.

m

CP&L. SHNPP
METALLURGY / WELDING UNIT

PERFORMANCE ON	SAT.	SAT.	GOOD	EXC	OUT STANDING	LIN
IG-IF ( DRING EVALUATED )						T T T T T T T T T T T T T T T T T T T
2G - 2F			V			
3G-3F			V			
<u>4</u> G -4F 5G ⋅6G	-		-			
LARE BEVEL GROOVE			*			
UTO STUD WELDING			X			HILL.
KEWED T JOINTS						1
ESTRICTED ACCESS					But Man	~
LEAN UP OF WELDS						~
OLLOWS PROCEDURE			-			
ERFORMANCE VS			-			
APABILITY		,	./			
TTITUDE			-	-		
		-		1		
			-			
ELDERS COMMENTS:	2/4	20	1			
		riec	ices, r	ce c	comme	6-1
ELDING SUPERVISORS	COM	MENTS	* 7La	ue 1	January 1	relie
an local in un l	ut ha	o no	t we	wied	anga	us
the Hickory Clang	/ /					

WELDING SUPERVISORS SIGNATURE S.N. Wurken

### WELDER EVALUATION REPORT CP&L - SHNPP METALLURGY / WELDING UNIT

ERFORMANCE ON	UN SAT.	SAT.	GOOD	WPS N	OUT	TUN
G-IF ( DRING EVALUATED )					O IAI VOIVO	INIVEVVIV
2G - (2F)		V				
1G (4B)		V				
G-6G		V				
ARE BEVEL GROOVE						
UTO STUD WELDING						-
KEWED T JOINTS						1
ESTRICTED ACCESS  LEAN UP OF WELDS						V
DLLOWS PROCEDURE		1				
ERFORMANCE VS		-	-			
APABILITY		1				
TITUDE		~				
	-					
LDERS COMMENTS:	120			7		
NO Problem with this	COMN	ENTS:	th	w 7	Line	
	1.1 .	1.00	5/			

000643

DATE 12-16-83

### WELDER EVALUATION REPORT CP&L . SHNPP METALLURGY / WELDING UNIT

OUT	UN
STANDING	KNCW
-	
-	
	2
	2000 Pa

DATE 11-2-82

000647

# WELDER EVALUATION REPORT CP&L SHAPP METALLURGY / WELDING UNIT

	UN SAT.	SAT.	GOOD	EXC	OUT	\$ Fy 3 + 1
IG-IF ( CINCLE POSITION(S)	)				SIANDING	KNOW
2G - (2F) 3G - (3F)			ALC: U	1,		
4G - (F)	-			V		
5G-6G				V		
LARE BEVEL GROOVE						
UTO STUD WELDING				V		
KEWED T JOINTS				-/		V
ESTRICTED ACCESS				V		
EAN UP OF WELDS				1		
ERFORMANCE VS				11		
APABILITY VS						
TITUDE				1		
				V		
		-				
		-	-			
				-		
ELDERS COMMENTS:	NA	Carro	me	4		
LDING SUPERVISORS	COMM	ENITE:				
	COIVIIVI	المالي				
fter and oh CH - 32 we he coult that is work I have	resec	lean	1	0.0	11 -	

WELDING SUPERVISORS SIGNATURE Bary Hofand

000643

### WELDER EVALUATION REPORT CP&L SHINPP METALLURCY / WELDING UNIT

PERFORMANCE ON	UN SAT.	SAT.	GOOD	EXC	OUT	UN
IG-IE ( SINCLE POSITION(8))	10011			<u> </u>	PIANDING	KNOWN
2G-2F	-		-	-		
3G - 3F)						
4G-4F)			-	-		
5G-6G						
FLARE BEVEL GROOVE						
AUTO STUD WELDING			~			
SKEWED T JOINTS						-
RESTRICTED ACCESS						
CLEAN UP OF WELDS						
FOLLOWS PROCEDURE						
PERFORMANCE VS						
CAPABILITY						
ATTITUDE						
STITIOUE .						nibit.
WELDERS COMMENTS:						
WELDING SUPERVISORS	COM	MENITE		/	12 -	
	COIVI	MENIS	. 0000	we	14-5	

000849

# WELDER EVALUATION REPORT CP&L SHIPP METALLURGY / WELDING UNIT

PERFORMANCE ON	UN	CAT			10. 12 4	
	SAT.	SAT.	GOOD	EXC	OUT	KNOW
IG-IF ( SEING EVALUATED )						
3G -3F			L			
4G -4F			L			
5G-6G			L	THE !		
LARE BEVEL GROOVE						
AUTO STUD WELDING			-			
SKEWED T JOINTS						r
RESTRICTED ACCESS		-	1			RE L
LEAN UP OF WELDS	-					
OLLOWS PROCEDURE!	-	-	ı			
ERFORMANCE VS	-	-	-			
APABILITY						
TTITUDE		-	-			
	-		-	441		
			-			
			-			
ELDERS COMMENTS:	1					
					· Cern	
ELDING SUPERVISORS	COMM	ENTS:	form.		in in	

# WELDER EVALUATION REPORT CP&L SHIPP METALLURGY / WELDING UNIT

PERFORMANCE ON	UN SAT.	SAT.	GOOD	EXC	OUT	UN
IG-IF ( CHACLE POSITION(3)	OAT.				STANDING	KNOW
2G-2F)			V			
3G-3E		De M				
4G (4.5) 5G-6G						
LARE BEVEL GROOVE			Times.			
LUTO STUD WELDING			V			
SKEWED T JOINTS						V
ESTRICTED ACCESS			~			
LEAN UP OF WELDS		-	/			
OLLOWS PROCEDURE		-	/			
ERFORMANCE VS		-	-		*	Day 14
APABILITY			-			
TTITUDE						
				-		
ELDERS COMMENTS:	2/.1	1.	11-	wa /	7.	
	vu		nas ,	wa	enne	-
LDING SUPERVISORS	COMM	ENTC:		. 0		
ELDING SUPERVISORS	COMM	ENTS:	Wat	Lee	has he	.0

WELDING SUPERVISORS SIGNATURE Auchan
DATE 7-8-8-8

CP&L - SHNPP
METALLURGY / WELDING UNIT

IG-IF (SINCE POSITION(S))  2G-ZF)  3G-SE)  4G-SF)  5G-SG  FLARE BEVEL GROOVE  AUTO STUD WELDING  SKEWED T JOINTS  RESTRICTED ACCESS  CLEAN UP OF WELDS  FOLLOWS PROCEDURE  PERFORMANCE VS.  CAPABILITY  ATTITUDE		100	C STAND	UN KNOW
3G-6F) 5G-6G FLARE BEVEL GROOVE AUTO STUD WELDING SKEWED T JOINTS RESTRICTED ACCESS CLEAN UP OF WELDS FOLLOWS PROCEDURE PERFORMANCE VS. CAPABILITY	( DEING EVALUATED )			
AG-GF)  5G-6G  FLARE BEVEL GROOVE  AUTO STUD WELDING  SKEWED T JOINTS  RESTRICTED ACCESS  CLEAN UP OF WELDS  FOLLOWS PROCEDURE  PERFORMANCE VS,  CAPABILITY		/		
SG-6G  FLARE BEVEL GROOVE AUTO STUD WELDING SKEWED T JOINTS RESTRICTED ACCESS CLEAN UP OF WELDS FOLLOWS PROCEDURE CAPABILITY				
AUTO STUD WELDING  SKEWED T JOINTS  CLEAN UP OF WELDS  COLLOWS PROCEDURE  CAPABILITY				
AUTO STUD WELDING  SKEWED T JOINTS  CLEAN UP OF WELDS  FOLLOWS PROCEDURE  CERFORMANCE VS,  CAPABILITY	EVEL GROOVE	_	N. Internal	
RESTRICTED ACCESS CLEAN UP OF WELDS FOLLOWS PROCEDURE PERFORMANCE VS. APABILITY	UD WELDING			
CLEAN UP OF WELDS COLLOWS PROCEDURE PERFORMANCE VS. APABILITY	T JOINTS	_		1
CLLOWS PROCEDURE  PERFORMANCE VS.  APABILITY	TED ACCESS			
PERFORMANCE VS. APABILITY	P OF WELDS	-		
APABILITY	PROCEDURE			
	IANCE VS.			
		1		
VELDERS COMMENTS: Wilder has no comment	COMMENTE			

WELDING SUPERVISORS SIGNATURE of No Lon home DATE 11-4-83

WELDER EVALUATION REPORT CP&L - SHNPP METALLURGY / WELDING UNIT

PERFORMANCE ON	UN SAT.	SAT.			OUT STANDING	
IG-IF (SING EVALUATED)  2G) 2F  36-3F  4G-4F  5G-6G  FLARE BEVEL GROOVE  AUTO STUD WELDING						
SKEWED T JOINTS RESTRICTED ACCESS CLEAN UP OF WELDS FOLLOWS PROCEDURE PERFORMANCE VS CAPABILITY ATTITUDE			VVV			
WELDERS COMMENTS:						
ELDING SUPERVISORS				tiofae	tog	

DATE _ 7- 20-02

000853

## WELDER EVALUATION REPORT CP & L . SHNPP METALLURGY / WELDING UNIT

PERFORMANCE ON	UN SAT.	SAT.	GOOD	MPS N	OUT	UN
IG-IF ( SKING EVALUATED )					DIANDING	T
2G-2F			1			MA
3G - 3F						NA
4G -4F			/			NA
5G)-6G V						1
LARE BEVEL GROOVE UTO STUD WELDING						NA
KEWED T JOINTS						NA
ESTRICTED ACCESS						110
LEAN UP OF WELDS						NA
OLLOWS PROCEDURE		-	~			
ERFORMANCE VS			/			
APABILITY			/			
TTITUDE			-			
		-+	-			
		-				
			-			
ELDERS COMMENTS:	NO C	U m A e	1245.			
ELDING SUPERVISORS ROBJENS WITL WILL S WORK	COMN	ENTS:	FORM	ive T	ins NO	

DATE 6-16-83

### WELDER EVALUATION REPORT CP&L SHIPP METALLURGY / WELDING UNIT

ERFORMANCE ON	UN SAT.	SAT.	GOOD	EXC	OUT	UN
IG-IF ( SAME SALE ASER)						
2G (2D) 3G - (SD)			-		Alfalat.	
4G · 🗭			1			
5G-6G						
LARE BEVEL GROOVE			V			
UTO STUD WELDING						V
KEWED T JOINTS ESTRICTED ACCESS			V			
LEAN UP OF WELDS						
OLLOWS PROCEDURE			/			
ERFORMANCE VS						
APABILITY			V			
TTITUDE			VI			
The restarts are	e m	nn	14,	ult In a	is om	with.
FORMAN Haw Fillet	of a	Res o	best.	a r	eders	

# WELDER EVALUATION REPORT CP&L SHIPP METALLURGY / WELDING UNIT

PERFORMANCE ON	UN SAT.	SAT.	GOOD	EXC	OUT STANDING	UN
IG-IF ( CENG EVALUATED )					BIANDING	KNOW
2G - (2F) 3G (3F)				11		
4G (4E)			Barry	V		
5G 6G		7111	BEST SERVICE	V		
LARE BEVEL GROOVE					The same	
UTO STUD WELDING				V		
KEWED T JOINTS						1
ESTRICTED ACCESS		-		~		
LEAN UP OF WELDS				0		
OLLOWS PROCEDURE				-		
ERFORMANCE VS						
APABILITY				~		
TITOUE				-		
	-					
	-					
ELDERS COMMENTS: -						7177
			7	no Ca	me	
LDING SUPERVISORS ( Droblems with weller has her	COMM file	ENTS:	Forma perf	an le	as No	

### WELDER EVALUATION REPORT CP&L SHINPP METALLURGY / WELDING UNIT

NAME J. D. PRICE WORK ASSIGNMENT PER FOREMAN J. MAR	IT, Fh	1. m3	1	AREA	AD. ITA	
PERFORMANCE ON	UN SAT.				OUT STANDING	
IG-IF ( CENG EVALUETED )				In the second		DIA
2G (2F)			V			
3G - 3F						N/A
4G-4F (5G)-6G						N/A
FLARE BEVEL GROOVE			~			- 11
AUTO STUD WELDING						N/A
SKEWED T JOINTS						NA
RESTRICTED ACCESS						MA
CLEAN UP OF WELDS			V			
FOLLOWS PROCEDURE			V			
PERFORMANCE VS						
CAPABILITY		45.5	1			
ATTITUDE						
WELDERS COMMENTS:						
NO.	NE					
WELDING SUPERVISORS KNOLEDGE OF WELL NIS WORK, VERY	DING	AND	TAKES			

WELDING SUPERVISORS SIGNATURE 71. Janelle DATE 7-26-82 000857

# WELDER EVALUATION REPORT CP&L - SHIPP METALLURGY / WELDING UNIT

PERFORMANCE ON	UN SAT.	SAT.			OUT STANDING	
IG-IF ( DEING EVALUATED )					CIAIUM	TRIVOVI
2G 72F 3G -3F			V			
4G -4F			V			
5G-6G			V			
LARE BEVEL GROOVE						
AUTO STUD WELDING						-
SKEWED T JOINTS						V
RESTRICTED ACCESS			V			V
LEAN UP OF WELDS			V			-
CLLOWS PROCEDURE			~			
ERFORMANCE VS						
APABILITY TTITUDE			V			
TITIODE				1		
	-					200
	-					
FI DEDG COMMENTO						
ELDERS COMMENTS:				700	CEM	cent
Droblem with	COMM	ENTS:	For Dei	four	las ?	w

# WELDER EVALUATION REPORT CP & L - SHNPP METALLURGY / WELDING UNIT

PERFORMANCE ON	UN SAT.	SAT.	GOOD	EXC	OUT STANDING	UN
2G-EF ( SEING EVALUATED )						2
3G (3F)			4			
4G (4E)			1			
5G-6G						
ARE BEVEL GROOVE						1
UTO STUD WELDING						-
KEWED T JOINTS						
STRICTED ACCESS			-			
EAN UP OF WELDS						
REFORMANCE VS			~			
PABILITY			,_			
TITUDE		-				
		-				
		-				
				-		
			-	-		
ELDERS COMMENTS:						
LDING SUPERVISORS all positions. We done without difference very severe.	COMM Colo u	ENTS:	Wells restrice	ted a	of good custilis	Prolity

CONSTRUCTION PROCEDURES MANUAL SHAPP	PROCE	DURE	NO. A	As Approved
GENERAL WELDING PROCEDURE (SEISMIC, NON-SEISMIC) AND HANGERS	REVISION 8			
DESCRIPTION	PAGE	1	OF	26

APR 2 7 1984 Rev. 8 JAN 3 0 1984 Rev. 7 AUG 0 9 1983 Rev. 6

GENERAL WELDING PROCEDURE

MP-08

APR 2 2 1982 Rev. 5

JUL 2 8 1981-Rev. 4

MAR 3 1 1981-Rev. 5

FEB 1 0 1981-Rev. 2

AUG 2 6 1980-Rev. 1

NOV 9 1979
SHEARON HARRIS N. P. P.

Rev. o

REVIEWED AND APPROVED BY EBASCO SERVICES, INC., FOR CONFORMANCE TO THE REQUIREMENTS OF PARAGRAPH CA-3310 OF ARTICLE CA-3300 OF ASME/AC1 359, SECTION III, DIV. 2, WINTER 1975 ADDENDA.

REV.	DESCRIPTION		APPROVALS	DATE
		ORIGINATOR	P. Harford	11/6/19
		CONSTRUCTOR	W. E. Brodman	11-9-74
0	Issued for Use.	EBC Q.A.	N/A and	
		CPAL	amLuc	11-9-79
		DES. ENG. *	N/O QM	
		ORIGINATOR	P. Hasford	deste.
		CONSTRUCTOR	Merk for use	8-25-8
1	Revised as Noted. Incorporated Deviation	E&C Q.A.	N/A AN	
	No. 1 and 2. Added Exhibit 2.	CPAL	AmLus	8-26-80°
		DES. ENG	NIP BY	
		ORIGINATOR	R. Harford	2/5/5
2	Revised as Noted.	CONSTRUCTOR	W. D. Goodinas	2-06,8
	Incorporated Deviation No.'s 4 and 5.	E&C Q.A.	1.14 1411	
	Deviation No.s 1-3	CPAL	Am Lun	2.027
	were torono.	DES. ENG. #	1.12 67:	

CONSTRUCTION PROCEDURES M.	ANUAL	PROCEDURE	NO.	DATE As Approved
GENERAL WELDING PROCEDURE	CENERAL WELLIAM INCOLUCTION	REVISION 8		
DESCRIPTION	AND HANGERS	PAGE 2	OF	26

GENERAL WELDING PROCEDURE
MP-08

* REVIEWED AND APPROVED BY EBASCO SERVICES, INC., FOR CONFORMANCE TO THE REQUIREMENTS OF PARAGRAPH CA-3310 OF ARTICLE CA-3300 OF ASME/ACL 359, SECTION III, DIV. 2, WINTER 1975 ADDENDA.

REV.	DESCRIPTION		APPROVALS	DATE
		ORIGINATOR	R. Harfiel	3/2/4
3	Revised As Noted.	CONSTRUCTOR	11 A Godwan	3.27.8
	Incorporated Deviation	EBC Q.A.	NA GAS	
	No. 1.	CPAL	am Luc	3-31-81
		DES. ENG. *	1/18 AN	
		ORIGINATOR	R. Harford by F. Shail	7/23/81
4	Revised As Noted.	CONSTRUCTOR	1 / Lacing de	1-12-8
		EAC Q.A.	N/A BH	
		CPAL	am Luc	7-27
		DES. ENG. &	Ma an	
5	Revised As Noted.	ORIGINATOR	Affection!	4/16/8
	Incorporated Deviation Notices 1, 2, and 3.	CONSTRUCTOR	11/2- Mostaclan	0.6
		EBC Q.A.	NIA WES 16, AND	4/2/18
		CPAL	PER A. LUCAS	Micia
		DES. ENG. *	NIA WES for AIN	1/2/8

	PROCEDURE	NO.	DATE As Approve
GENERAL WELDING PROCEDURE (SEISMIC, NON-SEISMIC)	REVISION	4 7	8
DESCRIPTIONAND HANGERS	PAGE 3	OF	26

WELDING PROCEDURE
MP-08

* REVIEWED AND APPROVED BY EBASCO SERVICES, INC., FOR CONFORMANCE TO THE REQUIREMENTS OF PARAGRAPH CA-3310 OF ARTICLE CA-3300 OF ASME/AC1 359, SECTION III, DIV. 2, WINTER 1975 ADDENDA.

REV.	DESCRIPTION		APPROVALS	DATE
6	Revised As Noted.	ORIGINATOR	A fachol	93/87
0	Incorporated Deviation Notices 2, 3, 4, & 5.	CONSTRUCTOR	11. D. Mordenan	813,8
	Added Appendices A and		N/A EU	8/1/6
	B and Exhibits 3, 4, & 5.	CP&L	FOR ME THEMPSON TH	8/5/
		DES. ENG. *	N/A els	8/5-14
<		ORIGINATOR		/
30 : 10 M		CONSTRUCTOR		
		EBC Q.A.		
		CPAL		
		DES. ENG.		
		ORIGINATOR		
		CONSTRUCTOR		
		EBC Q.A.		
		CPAL		
/		DES. ENG. *		

FORM NO. 1784-A		
LEONSTRUCTION PROCEDURES MAINUAL	PROCEDURE	NO. DATE As Approved
GENERAL WELDING PROCEDURE FOR STRUCTURAL STEEL (SEISMIC NON-SEISMIC) AND HANGERS	REVISION	8
DESCRIPTION	PAGE 4	OF 26

WELDING PROCEDURE

MP-08

- . REVIEWED BY QA/QC FOR COMPLIANCE WITH THE APPLICABLE QA AND CODE REQUIREMENTS.
  - * REVIEWED AND APPROVED BY EBASCO SERVICES, INC., FOR CONFORMANCE TO THE REQUIREMENTS OF PARAGRAPH CA-3310 OF ARTICLE CA-3100 OF ASME/ACI 359, SECTION III, DIV. 2, WINTER 1975 ADDENDA.

REV.	DESCRIPTION		APPROVALS	DATE
7	Revised As Noted. Incorporated Procedure	ORIGINATOR	Thathe,	1/19/84
	Change Notices 2, 3, and 4. Revised Table	CONSTRUCTOR	12/ Ho Boocheller	1.20.3
	B. Added Exhibits 6	QA/QC REVIEW * *	M. M. Fush	1/2/84
	and 7.	CPAL	A. Hanbrd	1/26/58
		DES. ENG. #	NIA BH	1/20/89
8	Added Paragraph	ORIGINATOR	R. Blakford	4/18/00
	4.5.3.8.5. Incorporated PCN-1.	CONSTRUCTOR	W. D. Hordwan	4.48
		QA/QC REVIEW * *	A.T. M. Puch	9/20/8
		CPAL	1 1 / O FOR:	on on 4/29/64
		DES. ENG. *	NIA RH	4/29/8
		ORIGINATOR		
		CONSTRUCTOR		
		QA/QC REVIEW + +		
		CPAL		
		DES. ENG. *	Access to the second	

CONSTRUCTION PROCEDURES MANUAL SHNPP Procedure No. MP-08 As Approved

GENERAL WELDING PROCEDURE STRUCTURAL STEEL (SEISMIC,

NON-SEISMIC) AND HANGERS Page 5 of 26

### 1.0 SCOPE

The purpose of this procedure is to define general welding requirements for welding of structural steel (seismic and non-seismic), hangers, and other steel construction. It does not apply to attachment welds to pressure containing components under the jurisdiction of ASME or ANSI codes.

### 2.0 REFERENCES

- 2.1 Site Specification 033, Structural Welding for Permanent Plant Construction, Latest Revision
- 2.2 Site Specification 034, NDE, Visual Inspection and Testing Requirements for Code Class 1, 2, 3, BOP Piping Systems and Nonseismic Structures for Permanent Plant Construction, Latest Revision
- 2.3 MP-01, Qualification of Welding Procedures
- 2.4 MP-02, Procedure for Qualifying Welders and Welding Operators
- 2.5 MP-03, Welding Material Control
- 2.6 MP-05, Procedure for Stamping of Weldments
- 2.7 MP-09, Procedure for Welding Equipment Control
- 2.8 Site Specification 021, Purchasing of Welding Materials
- 2.9 MP-10, Procedure for Repair of Base Metal and Weldments
- 2.10 WP-18, Miscellaneous Steel Fabrication
- 2.11 MP-04, Procedure for Heat Treatment
- 2.12 WP-30, Erection of Structural Steel, Latest Revision
- 2.13 WP-110, Installation of Safety Related or Seismic Class I Pipe Hangers
- 2.14 WP-203, Installation of Seismic Class I Electrical Cable Tray, Tray Supports, Conduit and Conduit Supports
- · 2.15 WP-105, Installation and Inspection of Equipment (Safety-Related Seismic Class I and NNS)

### 3.0 GENERAL

- 3.1 All welders shall be qualified in accordance with Reference 2.4.
- 3.2 All welding procedures shall be qualified in accordance with References2.3 and 2.1. Welders and welding procedures shall either be qualified toASME Section IX or AWS Dl.l, as applicable.

Form No. 1784 B Date Procedure No. SHNPP Approved CONSTRUCTION PROCEDURES MANUAL MP-08 GENERAL WELDING PROCEDURE FOR Revision 8 GENERAL WELDING PROCEDURE STRUCTURAL STEEL (SEISMIC, of NON-SEISMIC) AND HANGERS Page DESCRIPTION Welds shall be stamped in accordance with Reference 2.6. 3.3 Welding materials shall be controlled in accordance with Reference 2.5. 3.4 Welding equipment shall be controlled in accordance with Reference 3.5 2.7. All weld repairs and base metal repair shall be performed in accordance 3.6 with References 2.1 and 2.9. In case of conflict between this procedure and the AWS Code, the 3.7 ASME or AWS Code, as applicable, shall govern. Any conflict shall be brought to the attention of the Discipline Engineer-Metallurgy/Welding. When a QA or Welding Inspector hold point is reached, the Welding QA 3.8 Specialist, or his designee, or the Metallurgy/Welding Engineering representative shall be notified. The Discipline Engineer-Metallurgy/Welding shall have the authority to 3.9 assign or remove welders and welding operators at his discretion. The choice of welders to perform field welds should be based on the 3.10 R7 qualification to weld the full thickness of the field joint. The Discipline Engineer-Metallurgy/Welding must be notified to evaluate any situations where this may not be possible to ensure that the actual thickness welded by each welder does not exceed his/her qualification thickness range and permit documentation when deemed necessary. 4.0 PROCEDURE Weld Joint Preparation | R7 Weld joint configuration shall be as specified on the design 1. drawing and/or the welding procedure specification. For prequalified weld joints for full penetration and partial

penetration joints, the joint design shall be as detailed in AWS Dl.1

Weld joint preparations for welding against a backing bar shall be

joints requiring metallic backing, the root opening should be 3/16 inch optimum. Root openings less than 3/16 inch or greater than

R7

in Figures 2.9.1 and 2.10.1, along with the legend in Table A.

in accordance with the welding procedure specification. For

CONSTRUCTION PROCEDURES MAN	NUAL SHNPP	Procedure No.	As Approved	
GENERAL WELDING PROCEDURE	GENERAL WELDING PROCEDURE FOR STRUCTURAL STEEL (SEISMIC,	Revision	8	
DESCRIPTION	NON-SEISMIC) AND HANGERS	Page 7	of 26	

(4.1.2. cont'd.)

1/2 inch are not permitted (unless allowed by WPS) without written approval from Metallurgy/Welding Engineering.

- 4.2 Weld joint preparation of the base metals shall be accomplished by machining, grinding, oxygen-fuel cutting or air-arc cutting. Thermal processes shall be followed by grinding or machining of at least 1/16 inch.
  - 1. Surfaces to be welded and surfaces adjacent to a weld (within 1/4 inch of where the toe of the weld will be) shall be free from loose or thick scale, slag, rust, moisture, grease and other foreign material that would prevent proper welding or produce objectionable fumes. Mill scale that can withstand vigorous wire brushing, a thin rust-inhibitive coating (such as deoxaluminate paint), or anti-spatter compound may remain with the following exception. For girders, all mill scale shall be removed from the surfaces on which flange-to-web welds are to be made by submerged arc welding or by shielded metal arc welding with low hydrogen electrodes.
  - 2. The surface of base metal approximately one inch adjacent to the weld joint, in the plane of welding, need only be cleaned of those loose materials which may fall into the molten weld metal and coatings which, due to fumes caused by heating or burning, could leave a harmful residue in the weld. Tightly adhering rust which has been cleaned with a hand wire brush shall be permissible.
  - 3. Deoxaluminate paint can remain on the base metal and the prepped edges and surfaces to be welded. If rust appears where deoxaluminate paint has been applied to the prepped edges and surfaces to be joined by welding, it should be removed; however, if rusting appears on the base metal within the area one inch from the weld prepped edges, only wire brushing of these areas is necessary to remove any loose particles which could fall into the molten weld metal during welding of the joint. Due to corrosion, surfaces on the base metal may contain pitting. Wire brushing of

R7

Procedure No. Approved SHNPP CONSTRUCTION PROCEDURES MANUAL . GENERAL WELDING PROCEDURE FOR Revision GENERAL WELDING PROCEDURE STRUCTURAL STEEL (SEISMIC, of Page NON-SEISMIC) AND HANGERS DESCRIPTION

(4.2.3. cont'd.)

these surfaces is adequate to remove loose rust scale without removing tightly adhering rust oxide film from the pits.

- The cleaning shall be done by wire brushing, grinding, abrasive 4. blasting using angular aluminum or silicon carbon grit, or the use of an approved solvent. All grinding shall be done using only rubber or resin bonded aluminum oxide or silicon carbide grinding wheels or tungsten carbide burrs. Tools used for grinding or cleaning carbon steel shall not be used on stainless steel or nickel base material.
- Prior to weld joint inspection, any coatings that will prevent 5. visual or non-destructive inspection of the weld and heat-affected zone shall be removed (approximately 1/2 inch from the toe of the weld, where accessible).

#### Weld Joint Tolerances and Fit-Up 4.3

The parts to be joined shall be placed into as close contact as practical. When a gap exists between the parts to be welded, the gap shall not exceed the tolerances as follows:

#### Fillet Fit-Up 1.

If the weld gap is 1/16 inch or greater, up to a maximum of 3/16 inch, the leg of the fillet weld shall be increased in increments of 1/16 inch, 1/8 inch or 3/16 inch such that the increase in leg size is equal to or greater than the actual fit-up gap. (Example: Fillet weld fit-up gap is 3/32 inch and the drawing calls for a 1/4 inch fillet weld - the actual weld should be a 3/8 inch fillet weld.) A total of 5/16 inch is allowed when a backing or seal weld is used to prevent melt-thru and the thickness of the sections is three inches or greater.

#### Partial Penetration Groove Welds Tolerance 2.

The weld gap shall not exceed 3/16 inch maximum; however, a maximum of 5/16 inch gap is allowed in cases involving rolled shapes or plates 3 inches or greater in thickness, provided a backing or seal weld is used to prevent melt-thru and the final R7

CONSTRUCTION PROCEDURES MAN	IUAL S	HNPP	Procedure ! MP-08	No.		As Approved
	GENERAL WELDING			-	8	
GENERAL WELDING PROCEDURE DESCRIPTION	STRUCTURAL STEE		Page	9	of	26

(4.3.2. cont'd.)

weld meets the requirement for effective throat as described below. Partial joint penetration groove welds made by shielded metal arc welding, gas metal arc welding (except short circuiting transfer), or flux cored arc welding in butt, corner, and T-joints which may be used without performing the joint welding procedure qualification tests, are subject to the limitations specified in 4.3.2.3.

- 1. Definition
  - Groove welds without steel backing, welded from one side, and groove welds welded from both sides but without back gouging, are considered partial joint penetration groove welds.
- All partial joint penetration groove welds made by short circuiting transfer gas metal arc welding (see Appendix D) shall be qualified by the joint welding procedure qualification test.
- 3. Dimensional Tolerance

Dimensions of groove welds specified on design or detailed drawings may vary from the dimensions shown in AWS Dl.1 Figure 2.10.1, only within the following limits:

- The groove angle is minimum. It may be detailed to exceed the dimensions shown by no more than 10 degrees.
- The radius of the J-grooves and U-grooves is minimum. It may be detailed to exceed the dimensions shown by no more than 1/8 inch (3 mm). Ugrooves may be prepared before or after fit-up.
- Double-groove welds may have grooves of unequal depth, providing the weld deposit on each side of the joint conforms to the limitations of Figure 2.10.1.
- 4. The minimum root face of the joints shall be 1/8 inch (3mm), except that the minimum root face for joints

R7

orm No. 1784 B	SHNPP Procedur	8		As Approved
ONSTRUCTION PROCEDURES MANUAL GENERAL	TOTHE PROCEDURE FOR Revision		8	
WELDING PROCEDURE STRUCTUR	STEEL (SEISMIC,	10	of	26

(4.3.2.3.4. cont'd.)

to be welded by submerged are welding shall be 1/4 inch (6mm).

- The effective throat of partial joint penetration square-, 4. single- or double-V-, bevel-, j-, and U-groove welds shall be as shown in Table 2.10.3. Shop or working drawings shall specifiy the groove depths (S) applicable for the effective throat (E) required for the welding process and position of welding to be used.
- Groove preparations detailed for prequalified shielded metal 5. arc welded joints may be used for prequalified gas metal arc or flux cored arc welding.
- Corner Joints For corner joints the outside groove preparation may be in either or both members, provided the basic groove configuration is not changed and adequate edge distance is maintained to support the welding operations without excessive melting.

**TABLE 2.10.3** Minimum Effective Throat for Partial Joint Penetration Groove Welds

Base Metal Thicker Par	Thickness of Joined	Minimum Effective Throat**	
Inch	mm	Inch	mm
To 1/4 (6.4) 1/4 (6.4) to Over 1/2 (12 Over 3/4 (1 Over 1-1/2)	1/2 (12.7) incl. 2.7) to 3/4 (19.0) incl. 9.0) to 11/2 (38.1) incl. (38.1) to 2-1/4 (57.1) incl. (57.1) to 6 (152) incl.	1/8* 3/16 1/4 5/16 3/8 1/2 5/8	3 Over 5 6 8 10 13 16

^{*}Minimum size for bridge applications is 3/16 inch.

^{**}Except the effective throat need not exceed the thickness of the thinner part.

CONSTRUCTION PROCEDURES MAN	IUAL SHNPP	Procedure N	10.		Date As Approved
GENERAL WELDING PROCEDURE	GENERAL WELDING PROCEDURE FOR	Revision		8	3
DESCRIPTION	NON-SEISMIC) AND HANGERS	Page	11	of	26


(4.3.)

### 3. Butt Weld, Full Penetration

 With the exception of 4.3.3.2 for root openings in excess of those permitted in the table below and illustrated in Figure 3.3.4, the dimensions of the cross section of the groovewelded joints which vary from those shown on the detail drawings by more than the following tolerances shall be referred to the Welding Engineer for approval or correction.


		Goug	-	Goug	ed
		Inch	mm	Inch	mm
(1)	Root face of joint	<u>+</u> 1/16	1.6	Not limit	ted
(2)	Root opening of joints without steel backing	<del>+</del> 1/16	1.6	+1/16 =1/8	1.6
	Root opening of joints	+1/6	6.4	Not Appl	
(3)	with steel backing Groove angle of joint	-1/16 +10 deg. -5 deg.	1.6	Not Appl +10 deg. -5 deg.	icable
*0-	- 10 10 11 /0\ 6 4-1	and.		o ace.	

*See 10.13.1.1 (3) for tolerances for complete joint penetration tubular groove welds made from one side without backing in AWS Dl.1.



(A) Groove weld without backing - root not gouged

(B) Groove weld with backing - root not gouged



(C) Groove weld without backing root gouged

#### Notes

- 1. a groove angle
- 2. R · root opening.
- 3. f root face.
- 4. The groove configurations shown are for illustration only.

Fig. 3.3.4—Workmanship tolerances in assembly of groove welded butt joints

CONSTRUCTION PROCEDURES MA	NUAL SHNPP	Procedure	No.	As	Approved
	GENERAL WELDING PROCEDURE FOR STRUCTURAL STEEL (SEISMIC,	Revision		8	
DESCRIPTION	NON-SEISMIC) AND HANGERS	Page ]	12	of	26

(4.3.3. cont'd.)

- 2. Root openings wider than those permitted in 4.3.3.1, but not greater than twice the thickness of the thinner part or 3/4 inch (19 mm), whichever is less, may be corrected by welding to acceptable dimensions prior to joining the parts by welding. Root openings larger than the above may be corrected by welding only with the approval of the Welding Engineer.
- 3. Fillet welding in the transverse direction across a gap between two embed plates in concrete during erection of a structural member or across a hole in the embed is acceptable, provided the gap or hole does not exceed 3/16 inch. Where the gap or hole diameter exceeds 3/16 inch, but not in excess of 5/16 inch, the fillet weld leg size shall be increased by 1/8 inch minimum over the length of the weld with the gap appearing at any location along the length. Where the weld length is in excess of six inches, the increased leg size may be limited to a maximum of six inches of length closest to the gap location. Where a hole in the embed plate exists, an acceptable alternate is to plug weld the hole prior to making the fillet weld across it.

### 4.4 Weld Cleaning

1. Any cracks, blowholes, coarse ripples, grooves, overlaps, abrupt ridges or valleys, or other defects that appear on the surface of the weld beads, shall be removed by chipping or grinding before depositing the next successive bead of welding. Defects in stops and starts shall be removed by grinding. All slag or flux remaining on any bead or pass of welding shall be removed before placing the next successive bead or pass. The finished pass shall be cleaned thoroughly of all flux by first lightly chipping and then wire brushing the weld for final cleaning. Excessive porosity, entrapped slag, or crater cracks shall be ground out and blended

CONSTRUCTION PROCEDURES MANUAL SHNPP Procedure No. MP-08 As Approved

GENERAL WELDING PROCEDURE STRUCTURAL STEEL (SEISMIC,
NON-SEISMIC) AND HANGERS Page 13 of 26

(4.4.1. cont'd.)

into the weld pass. Additional weld metal shall be added when necessary to restore the weld pass configuration, using the same welding procedure as used for depositing the weld pass.

2. Grinding

All grinding shall be done using only approved rubber or resin bonded aluminum oxide or silicone carbide grinding wheels. Tungsten carbide deburring may be performed. Care shall be exercised not to remove excessive amounts of base metal. Concerns about the removal of excessive base metal shall be brought to the attention of the Discipline Engineer-Metallurgy/Welding, or his designee.

### 4.5 Welding

- Welding is prohibited where the weld joints and adjacent surfaces are wet or damp. When necessary to prevent condensation, the weld joint areas shall be preheated until it is warm to hand touch.
- 2. Tack welds used to secure alignment shall be removed completely when they have served their purpose or shall be prepared by grinding or other suitable means so that they may be satisfactorily incorporated into the root pass weld. Tack welds shall be made by qualified welders using qualified welding procedures. Tack welds shall be visually examined when they are to become part of the finished weld and defective tack welds shall be removed or repaired.
- Welding of temporary attachments and clips shall be welded in accordance with the procedure applicable to the assembly and as outlined below.
  - Welding is prohibited where the weld joints and adjacent surfaces are wet or damp. When necessary to prevent condensation, the weld joint areas shall be preheated until it is warm to hand touch.
  - Tack welds used to secure alignment shall be removed completely when they have served their purpose or shall be

Form No 1784 B

Date Procedure No. SHNPP Approved As CONSTRUCTION PROCEDURES MANUAL GENERAL WELDING PROCEDURE FOR Revision 8 GENERAL WELDING PROCEDURE STRUCTURAL STEEL (SEISMIC, NON-SEISMIC) AND HANGERS 26 Page DESCRIPTION

(4.5.3.2. cont'd.)

prepared by grinding or other suitable means so that they may be satisfactorily incorporated into the root pass weld. Tack welds shall be made by qualified welders using qualified welding procedures. Tack welds shall be visually examined when they are to become part of the finished weld and defective tack welds shall be removed or repaired.

- Welding of temporary attachments and clips shall be welded 3. in accordance with the procedure applicable to the assembly and as outlined below.
  - The material must be suitable for welding and be 1. compatible with the component material to which it is attached, but need not be certified material.
  - Weld material must be compatible with the base 2. material and certified in accordance with Reference 2.8.
  - The welder and the procedure shall be qualified in 3. accordance with References 2.4 and 2.3, respectively.
  - The temporary attachment, when required, shall be 4. removed by cutting, grinding, or air-arc gouging and the area shall be ground and blended into base metal. Care shall be exercised not to remove excessive base material. Temporary attachments shall not be removed by hammer blows.
  - "After removing temporary attachments from seismic 5. and non-seismic structural components, craft personnel shall request, in writing, using Exhibit 6, that Metallurgy/Welding personnel examine the area to determine that the surface has been made flush with the original surface as required by AWS Dl.l, paragraph 9.24. The area of removal of permanent plant structure' items due to design changes, mislocations, atc., shall be subjected to the same

m No 1784 B SHNPP	Procedure No. MP-08	As Approved
PROCEDURES MANUAL TIPLDING PROCEDURE	FOR Revision	8
ENERAL WELDING PROCEDURE STRUCTURAL STEEL (SEISMIC, NON-SEISMIC) AND HANGERS	A STATE OF THE PARTY OF THE PAR	of 26

(4.5.3.3. cont'd.)

inspection criteria as temporary attachments and shall be handled as noted above. If additional examination (such as a D-Meter) or a base metal weld repair is required, a Welding Engineering Hold Tag (see Exhibit 7) shall be placed on the area of concern until such examination and/or repairs are initiated. Base metal repairs shall be handled in accordance with Reference 2.9."

## 6. Backing Strips

Backing strips, or spacer blocks, where permitted, shall be compatible with the base materials for similar base material welds. For dissimilar metal welds the higher alloy material shall be used. Groove welds with backing shall conform to AWS Dl.l, Figures 2.9.1 or 2.10.1, or applicable WPS.

## 7. Tack Welds

All tack welds shall be made in accordance with an approved welding procedure by a qualified welder. Cracked or broken tack welding shall be removed. Tack welds shall blend smoothly at both ends and shall be even in size with no abrupt change in contour thus allowing proper inclusion into the weld. Multiple-pass tack welds shall have cascaded ends.

8. For the purpose of welding at SHNPP, "weave bead method" is defined as a transverse oscillation width of not more than four times the electrode core wire diameter, or 5/8 inch, whichever is less, for carbon steel material. For stainless steel, weave bead width shall not be more than three times the electrode diameter, or 1/2 inch, whichever is less. The deposited weld bead width due to weave shall not exceed the limits of Appendix A for carbon steel and Appendix B for stainless steel.

R7

R7

Form No 1784 B Procedure No. Date SHNPP CONSTRUCTION PROCEDURES MANUAL MP-08 As Approved GENERAL WELDING PROCEDURE FOR Revision 8 GENERAL WELDING PROCEDURE STRUCTURAL STEEL (SEISMIC, of NON-SEISMIC) AND HANGERS Page 26 16 DESCRIPTION

(4.5.3.)

- 4. Controlled peening may be performed to minimize distortion when allowed by the WPS. However, peening shall not be used on the initial layer or root of the weld metal nor on the final layer in order to eliminate cracking.
- 5. Before applying weld metal to the second side to be welded, the root of double welded joints shall be prepared by suitable methods, such as chipping, grinding or thermal gouging, except for those processes of welding by which proper fusion and penetration are otherwise obtained and demonstrated to be satisfactory by welding procedure qualification.
- 6. Welded surfaces are permitted. However, the surface of welds shall be sufficiently free from coarse ripples, grooves, overlaps, and abrupt ridges and valleys to meet the following requirements. The surface condition of the finished weld shall be suitable for the proper interpretation of radiographic and other required nondestructive examinations of the welds. In those cases where there is a question regarding the surface condition on the interpretation of a radiographic film, the film shall be compared to the actual weld surface for interpretation and determination of acceptability.
- 7. Groove Weld Termination

  Extension bars, or run-off plates, shall be removed upon completion and cooling of the weld, and the ends of the welds shall be made smooth and flush with the edges of the

8. Welding Procedure Specification (WPS) for Site Welding

abutting parts.

Prequalified WPS for Carbon and Low Alloy Steels
 A prequalified WPS listed in Table B may be used for fillet and butt welds, provided the weld joint detail meets the design details of one of those listed in AWS Dl.l, Figures

R7

R7

CONSTRUCTION PROCEDURES MAN	JAL SHNPP GENERAL WELDING PROCEDURE FOR	MP-08	No.	A	Date as Approved
GENERAL WELDING PROCEDURE	STRUCTURAL STEEL (SEISMIC,	Revision		8	
DESCRIPTION	NON-SEISMIC) AND HANGERS	Page	17	of	26

(4.5.3.8.1. cont'd.)

2.9.1 or 2.10.1 (attached), and the material is ASTM A36 or a Group II (AWS D1-1) as listed below:

## GROUP II

ASTM A36		ASTM A570	All
			Grades
ASTM A53	Grade B	ASTM A572	Grades
			42,45,50
ASTM A106	Grades A,B,C,	ASTM A573	Grade
	0.000 11,2,0,		65
ASTM A131	Candon A B C	ASTM A588	03
ASIM MISI	Grades A,B,C,		
	CS,D,E	ASTM A595	Grades
			A,B,C
	AH 32 & 36	ASTM A606	
	DH 32 & 36	ASTM A607	Grades
			45,50,55
	EH 32 & 36	*ASTM A618	
ASTM A139	Grade B	ASTM A633	Grades
			A.B
*ASTM A242			Grades
ADIM METE			
ASTM A381	C 1- VIO.	40004 4000	C,D
A51 W A381	Grade Y35	ASTM A709	Grades
			36,50,50W
ASTM A441		API 5L	Grade
			В
ASTM A500	Grade A	API 5LX	Grade
			42
	Grade B	API Spec, 2H	
ASTM A501	Oldde D	ABS	Grades
			AH 32
ASTM A516	Grades 55 & 60		& 36
AST IN ASTO	Grades 33 & 60		DH 32
			& 36
	65 & 70		EH 32
			& 36
ASTM A524	Grades I & II	ABS	Grades
			A,B,D
ASTM A529			CS, DS
ASTM A537	Classes 1 & 2		Grade
			E
			_

^{*}Do not weld without Welding Engineering's permission because of special AWS Dl.l requirements.

CONSTRUCTION PROCEDURES MANUAL SHNPP

GENERAL WELDING PROCEDURE STRUCTURAL STEEL (SEISMIC, NON-SEISMIC) AND HANGERS

Procedure No. MP-08 As Approved

Revision 8

Pege 18 of 26

(4.5.3.8. cont'd.)

DESCRIPTION

- Qualified WPS for Carbon, Low Alloy Steels and Stainless Steels A qualified WPS must be used when the material or prequalification requirements are not met as required by 4.5.8.1. For materials in Table C (attached), the welding of the joints shall be in accordance with a WPS listed in Table B. Also for dissimilar weld joints between P-l materials and 304 stainless steel (P-8), the WPS shall be as listed in Table B.
- 3. WPS (Qualified) Assigned by Metallurgy/Welding (Seismic Class I)
  Seismic Class I structural steel and hangers of P-1 material, such as
  ASTM A-36 requiring weld joints which are butt (partial and full
  penetration) or fillet welds of two components in which the thickest
  member (measured at the weld joint) is over 1-1/2" thick, shall not be
  welded without written instructions on welding and required hold points
  from the Discipline Engineer, Metallurgy/Welding. The written
  instructions shall be on drawings issued in accordance with Reference
  2.12 or a WDR in accordance with References 2.13 or 2.14. These
  instructions shall contain the WPS, filler metal, preheat, post weld heat
  treatment, and required NDE hold points, as applicable. The written
  instructions and the WDR shall be approved by the Discipline Engineer,
  Metallurgy/Welding.
- WPS assigned by Metallurgy/Welding for balance of plant (BOP) shall be by Exhibit 2 when deemed necessary by the Welding Engineer or Area Engineer.
- 5. For completed structural components which have been field welded but for which the SWDR is not available, the following shall apply:
  - A notation shall be made on the "recreated" SWDR for the WPS and filler metal for fillet welds that the welds were welded "In accordance with (IAW) MP-08". This is based on the fact that site welding requirements for structural welding are performed in accordance with MP-08 and the guidelines for WPS and filler metal selection are per Table B. Filler metal for field use is controlled in accordance with MP-03.
  - 2. For groove welds contact Metallurgy/Welding Engineering.

R8

- 9. When welding on seismic structures, the welder or his supervisor shall be responsible for recording the welder's symbol and the WPS revision number on the Seismic 1 Weld Data Report. Each welder performing welds to the WDR shall have his or her symbol written on the Seismic 1 Weld Data Report.
- 10. Welding of equipment (Reference 2.15) shall be in accordance with the requirements of this procedure and the following.
  - Fillet welds and plug welds for joining switchgear (ASTM A569 and/or AISI 1015 to 1020) and/or motor control centers
     (A-36) to embedded steel (A-36) shall be accomplished using WPS 1A4, latest revision.
  - Welds not covered in paragraph 4.5.10.1 (including groove welds) shall be brought to the attention of the Mechanical Engineer and the Welding Engineer prior to the initiation of field welding.

#### ll. Plug Welds

The technique used to make plug welds when using shielded metal are welding, gas metal arc welding (except short circuiting transfer), and flux cored arc welding processes shall be as follows.

- 1. For welds to be made in the flat position, each bead shall be deposited around the root of the joint and then deposited along a spiral path to the center of the hole, fusing and depositing a layer of weld metal in the root and bottom of the joint. The arc is then carried to the periphery of the hole and the procedure repeated, fusing and depositing a layer of weld metal in the root and bottom of the joint. The arc is then carried to the periphery of the hole and the procedure repeated, fusing and depositing successive layers to fill the hole to the required depth. The slag covering the weld metal should be kept molten until the weld is finished. If the arc is broken or the slag is allowed to cool, the slag must be completely removed before restarting the weld.
- For welds to be made in the vertical position, the arc is started at the root of the joint at the lower side of the hole

CONSTRUCTION PROCEDURES MAN	UAL SHNPP	Procedo MP-	n a	As	Date Approved
GENERAL WELDING PROCEDURE	GENERAL WELDING PROCED	Revisio	n	8	
DESCRIPTION	NON-SEISMIC) AND HANGE	Page	20	of	26

(4.5.3.11.2. cont'd.)

and is carried upward, fusing into the face of the inner plate and to the side of the hole. The arc is stopped at the top of the hole, the slag is cleaned off, and the process is repeated on the opposite side of the hole. After cleaning slag from the weld, other layers should be similarly deposited to fill the hole to the required depth.

3. For welds to be made in the overhead position, the procedure is the same as for the flat position, except that the slag should be allowed to cool and should be completely removed after depositing each successive bead until the hole is filled to the required depth.

#### 12. Slot Welds

Slot welds shall be made using techniques similar to those specified in 4.5.ll for plug welds, except that if the length of the slot exceeds three times the width, or if the slot extends to the edge of the part, the technique requirements of 4.5.ll.3 shall apply.

#### 4.6 Weld Profiles

- Weld profiles shall be in accordance with the following.
  - Size of fillets and partial penetration welds shall be in accordance with drawing, symbols and dimensions.
  - 2. The faces of fillet welds may be slightly convex, flat or slightly concave as shown in Exhibit 1, A, B, and C, with none of the acceptable profiles shown in Exhibit 1D. Except at outside corner joints, the convexity shall not exceed the value of 0.1S plus 0.03 inch where S is the actual size of the fillet weld in inches (see Exhibit 1C). When the fillet weld gap between parts to be jointed equals or exceeds 1/16 inch, up to 3/16 inch maximum, the leg of the fillet weld shall be increased, as a minimum, by the total amount of the gap. A total of 5/16 inch is allowed when a backing strip is used and the thickness of the sections is 3 inches or greater.

(4.6.1. cont'd)

DESCRIPTION

- Groove welds shall preferably be made with slight or 3. minimum reinforcement except as may be otherwise provided. In the case of butt and corner joints, the reinforcement shall not exceed 1/8 inch (3.2 mm) in height and shall have gradual transition to the plane of the base metal surface (Exhibit 1E). They shall be free of discontinuities shown for butt joints in Exhibit IF.
- Surfaces of butt joints required to be flush shall be finished so as not to reduce the thickness of the thinner base metal or weld metal by more than 1/32 inch (0.8 mm) or five percent of the thickness, whichever is smaller, or leave reinforcement that exceeds 1/32 inch. However, all reinforcement must be removed where the weld forms part of a faying or contact surface. Any reinforcement must blend smoothly into the plate surfaces with transition areas free from edge weld undercut. Chipping may be used provided it is followed by grinding.
  - Undercut shall be no more than 0.01 inch (0.25 mm) deep 5. when the weld is transverse to the primary stress in the part that is undercut. Undercut shall be not more than 1/32 inch (0.8 mm) deep when the weld is parallel to the primary stress in the part that is undercut.
  - Welds shall be free from overlap. 6.
  - Care shall be exercised to avoid arc-strike on the base metal outside of the joint groove. The arc-strikes shall be removed by grinding and shall be visually inspected.
- Pipe hanger field and shop weld profiles (seismic and non-seismic) 2. shall be in accordance with the following.
  - The area to be examined shall be sufficiently free from 1. foreign matter to allow for examination of the weld area.

Form No. 1784 B			CONTRACTOR ASSESSMENT
CONSTRUCTION PROCEDURES MAN	UAL SHNPP	Procedure No.	As Approved
GENERAL WELDING PROCEDURE	GENERAL WELDING PROCEDURE FOR	Revision	8
DESCRIPTION	STRUCTURAL STEEL (SEISMIC, NON-SEISMIC) AND HANGERS	Page 22	of 26

(4.6. cont'd)

- Surfaces and edges to be welded shall be smooth, uniform, and free from fins, tears, cracks, and other discontinuities which would adversely affect the quality or strength of the weld.
- 3. Check to assure the weld has no cracks.
- 4. Check to assure that complete fusion exists between weld and base metal and adjacent layers of weld metal. Incomplete (lack of) fusion shall be considered acceptable if 1/16 inch or less in length.
- Check to assure that all craters are filled to the full cross section of the weld.
- Confirm the weld profiles are in accordance with the illustrations outlined on Exhibit 3.
- 7. A fillet weld in any single continuous weld shall be permitted to underrun the nominal fillet weld size required by 1/16 inch without correction, provided that the cumulative length of undersize weld does not exceed 10% of the length of the weld. On web-to-flange welds on girders, no underrun is permitted at the ends for a length equal to twice the width of the flange.
- Check to assure that any conditions of undercut do not exceed 1/32 inch in depth.
- 9. Surface porosity shall be less than 1/16 inch in size of greatest dimension. The sum of the greatest dimensions of porosity shall not exceed 3/8 inch in any linear inch of weld. Piping porosity in fillet welds shall not exceed one in four inches of weld length and the maximum diameter shall not exceed 3/32 inch in size.
- 10. Skewed tee fillets and flare bevel groove welds shall be measured in accordance with the outlined illustration in Exhibit 4.

CONSTRUCTION PROCEDURES MAN		Procedure No.		As Approved
	GENERAL WELDING PROCEDURE FOR		8	3
GENERAL WELDING PROCEDURE	STRUCTURAL STEEL (SEISMIC, NON-SEISMIC) AND HANGERS	Page 23	of	26

(4.6.2. cont'd)

- 11. When the toe of a fillet extends into the radius of a tube steel member and that leg is determined to be undersized, a check shall be made to confirm that the undersized leg is equal to the theoretical effective throat. The entire profile of the weld shall be equal to or greater than the theoretical effective throat (see Exhibit 5).
- 12. Tightly adhering weld spatter is acceptable.
- 13. Arc strikes 1/16 inch or less shall be considered acceptable provided the base metal or deposited metal is not cracked and there is no bimetallic inclusion (copper, stainless steel filler metal).
- 14. Non-structural end cap welds shall meet the above acceptance criteria except that indications less than 3/16 inch in length, per one inch of weld length, shall be considered non-relevant.

#### 4.7 Shielding

The shielding gas and flow rate shall be as specified by the assigned WPS. The shielding gas shall be welding grade argon (99.95%), helium, mixture of argon and carbon dioxide, or argon and helium.

## 4.8 Control of Preheat and Interpass Temperature

Preheating techniques and preheat and interpass temperature measurement shall be such as to ensure that the full thickness of the weld joint preparation and adjacent base metal is at the specified temperatures required by AWS Dl.l of Table 4.2, or applicable WPS. When flame heating is used, only a neutral flame shall be employed. Temperature shall be determined by either contact pyrometers, thermocouples or temperature indicating crayons.

## 4.9 Dissimilar Butt Weld and Fillet Weld Joints

 Any carbon or low alloy steel weld prep requiring post weld heat treatment (PWHT) which is to be welded to stainless steel (dissimilar joint) shall be buttered with type Ni-Cr-Fe (F No. 43) Form No 1784 B

CONSTRUCTION PROCEDURES MANUAL SHNPP

GENERAL WELDING PROCEDURE FOR
GENERAL WELDING PROCEDURESTRUCTURAL STEEL (SEISMIC,
NON-SEISMIC) AND HANGERS

Page

24

Procedure No. MP-08
As Approved
Revision

8

(4.9.1. cont'd)

filler metal and post weld heat treated after buttering. The minimum thickness of the buttered area after end preparation shall be sufficient to keep the temperature of the carbon or low alloy steel below its critical temperature during welding. The joint shall then be welded with Ni-Cr-Fe (F No. 43) material. The completed joint shall not be subjected to PWHT.

2. Dissimilar butt joints made of carbon/low alloy steels that do not require PWHT may be welded, without buttering, using type 309 (F6 or F5) or Ni-Cr-Fe (F No. 43) filler metal for the entire joint. The completed joint shall not be post weld heat treated.

#### 4.10 Deviations

- The requirements of this specification shall be complied with during field welding except that waivers on specific sections of this document can be granted, only in writing, by the SHNPP Discipline Engineer-Metallurgy/Welding and then only when such waivers do not violate AWS Code or the requirements of References 2.1 thru 2.4.
- In the situation where the requirements of this procedure and the Code conflict, the Code requirement shall be complied with.
- Any conflicts or needs for changes during the course of welding a
  joint using this specification shall be resolved by the Discipline
  Engineer-Metallurgy/Welding, or his designee.

#### 4.11 Post Weld Heat Treatment

When required by field construction drawings, or specifications, PWHT will be accomplished in accordance with the requirements of Reference 2.ll for welded steel greater than 1-1/2 inches in thickness at the welded joint. A sufficient number of thermocouples shall be provided to assure an adequate temperature history. Stress relief of welded assemblies shall be performed when an assembly is under restraint during welding, when high shrinkage stresses are a result of welding, when

CONSTRUCTION PROCEDURES MAN	SHNPP	Procedure No MP-08	).	As	Date Approved
GENERAL WELDING PROCEDURE	GENERAL WELDING PROCEDURE FOR	Revision		8	
DESCRIPTION	NON-SEISMIC) AND HANGERS	Page	25	of	26

(4.11.1. cont'd)

weldments are of a complex design configuration, or when machining close tolerances requires it.

- For Seismic Class I structures, heat treatment charts and data sheets shall be identified as to component(s) and processed. When dated and signed they become part of the documentation record.
- Marking fluid, chalk, tape, tags and other materials deleterious to components during thermal treatments shall be removed with suitable solvents.

#### 4.12 Inspection and Tests

NDE and visual inspection shall be performed and evaluated, when required, by using qualified personnel and procedures meeting the requirements of Reference 2.2. Non-seismic items will be inspected by a Welding Supervisor, Metallurgy/Welding. For seismic items, a QA Welding Specialist or his designee shall perform the inspection.

#### 4.13 Repairs to Base Materials and Welds

Repairs to base materials and welds shall be done in accordance with AWS Dl.l and MP-10.

## 4.14 Quality Assurance

#### Seismic Class 1

Field weld data for full penetration welds shall be forwarded to the QA record for storage and shall include:

- Seismic Class I structural welding shall be subjected to the requirements of CP&L's corporate QA Program, Part I.
- Welding materials shall be identified and controlled so that they can be traced to each welded section of structural steel, or else a controlled procedure shall be employed which ensures that the specified materials are used.

## 2. Seismic l Records

Field weld data for all full penetration welds shall include:

- 1. Identification of the welding procedure used.
- 2. Welder or welders performing the welding operation.

Form No 1784 B

CONSTRUCTION PROCEDURES MANUAL SHNPP	Procedure No. MP-08	As Approved
GENERAL WELDING PROCEDURE STRUCTURAL STEEL (SEIS		8
DESCRIPTIONNON-SEISMIC) AND HANGE		of 26

(4.14.2. cont'd)

- 3. Filler metal.
- 4. PWHT data.
- 5. NDE results and repair weld data NDE inspection.
- 4.15 To protect permanent plant equipment and cable trays in the area from damage prior to the initiation of the welding, cutting, burning or are gouging operation, precautions shall be taken by the welder or fitter. Protection shall be in the form of an approved fire resistant or fire retardant material. If equipment is located over openings in the floor which permit hot metal to drop through to the equipment underneath, the same precautions apply.

#### 5.0 EXHIBITS AND APPENDICES

- 5.1 Exhibit 1 Acceptable and Unacceptable Weld Profiles (Rev. 0-9/79)
- 5.2 Exhibit 2 Welding Inspection Assignment (Rev. 0-7/80)
- 5.3 Exhibit 3 Illustrations of Weld Profiles For Pipe Hangers (Rev. 0-7/83)
- 5.4 Exhibit 4 Measurement of Skewed Tee Fillets and Flare Bevel Groove Welds on Pipe Hangers (Rev. 0-7/83)
- 5.5 Exhibit 5 Measurement of Fillet Welds at Tube Steel Radius on Pipe Hangers (Rev. 0-7/83)
- 5.6 Exhibit 6 Inspection Request For Damaged/Ground Area (Rev. 0-9/83)
- 5.7 Exhibit 7 Welding Engineering Hold Tag (Rev. 0-9/83)
- 5.8 Appendix A Bead Width For Carbon Steel (Rev. 0-7/83)
- 5.9 Appendix B Bead Width For Stainless Steel (Rev. 0-7/83)

Note: Below is a list of the attachments referenced.

- 1. AWS Dl.1, Figure 2.9.1 (pages 9-23)
- 2. AWS Dl.1, Figure 2.10.1 (pages 25-33)
- 3. Table A
- 4. Table B (Rev. 1-8/83)
- 5. Table C
- 6. Appendix D

R7

R7



# CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT




Exhibit 1 -Acceptable and unacceptable weld profiles.

SHEARON HARRIS NUCLEAR POWER PLANT

Welding/Inspection Assignment

WELDING POR REV. NO	
PWHT PROC. + REV	
FILL METAL TYPE.	COMPLETE
INSPECTION REQ. CHECK EQUIRED	
VISUALLY INSPECT. FINAL WELD	·
FINAL NDE RT-MT-PT-UT	
PWHT MDE RT-MT-PT-UT-VT.	O
REMARKS:	A

Exhibit 2 - Welding/Inspection Assignment Instructions for welding seismic structures and hangers.

#### - CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT

#### ILLUSTRATIONS OF WELD PROFILES FOR PIPE HANGERS




Exhibit 4

#### CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLLANT

# MEASUREMENT OF SKEWED TEE FILLETS AND FLARE BEVEL GROOVE WELDS ON PIPE HANGERS





Exhibit 5 MP-08

MEASUREMENT OF FILLET WELDS AT TUBE STEEL RADIUS ON PIPE HANGERS



	INSPECTION	N REQUEST FOR DAMAGED/GROUND AREA	
Seis	smic	Non-Seismic	
Mate	erial Type:		المستثرينا التنجيب عثا
		RFT NO.	
Proc		eel, W shape, etc.):	
Draw	wing/Rev.:		
		bed, piece no. etc.):	
Bldg		Elevation	
		Location	
Othe	er Info:		
	7((1)		
Regu	uested By:	Title	Date
	(Signature)		
-			
		7Acceptable .	
Vis	ual Inenection Recults.		
1		Further Investigation Requir	ed
-		^	
	Thickness (D-Meter) check	required	
1	Min. Wall Criteria	inch(	es)
	Actual Results (Min.)	Inch(	es) Acceptable
			Not Acceptable
-	Hold Tag Applied		
Wel	d Repair Required: Ye	s No Not Recommended (	See Comments)
-	ments (attach sketch, as	needed):	
Com	ments tarrach skerch, as	needed/:	<u> </u>
-			
-			
		13	
_			
			(1)
	**************************************		111
			-
5	THE PARTY OF THE PARTY OF		
Meration 97 merang			
2	spected by:	Title	Date
IIIS	(Signature)		

Exhibit 7 MP-08

### WELDING ENGINEERING HOLD TAG

No
WELDING ENGINEERING HOLD
DO NOT WELD
Hold Authorized By Date Removal Authorized By Date
12
Deficient Item Identification
Reason for Hold
☐ WELD to be cut out for repair ☐ Base Metal Repair ☐ Hold for repair instructions ☐ Repair without removal from installation
Inspector Date

Rev. 0 7/83

## CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT

## BEAD WIDTH FOR CARBON STEEL

SMAW Size Electrodes	Maximum Weld Bead Width
1/16"	1/2"
3/32"	3/4"
1/8"	1"
5/32"	1"
GTAW Filler Materials (Manual)	Maximum Weld Bead Width
*0.035"	3/4"
*0.045"	3/4"
1/16"	1/4"
3/32"	3/8"

## WEAVE TECHNIQUE (TRANSVERSE OSCILLATION) - MAXIMUM ALLOWABLE BEAD WIDTH

*Bare wire used in Automatic Welding

1/2"

## CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT

A STATE OF THE STA

3/32"


1/8"


### BEAD WIDTH FOR STAINLESS STEEL

SMAW Size Electrodes	Maximum Weld Bead Width
1/16"	3/8"
3/32"	1/2"
1/8"	3/4"
5/32"	3/4"
GTAW Filler Materials (Manual)	Maximum Weld Bead Width
*0.035	5/8"
*0.045	5/8"
1/16"	1/4"
3/32"	3/8"

WEAVE TECHNIQUE (TRANSVERSE OSCILLATION) - MAXIMUM ALLOWABLE BEAD WIDTH

*Bare wire used in Automatic Welding





Note A: Not prequalified for gas metal arc welding using short circuiting transfer. Refer to Appendix D.


Note C: Gouge root before welding other side.

Note D: Welds must be centered on joint.

Fig. 2.9.1-Prequalified complete joint penetration groove welded joints

**The above references appear in AWS D1-1, See notes AA, for details.

#### 10 / DESIGN OF WELDED CONNECTIONS



Single V are	ove weld (2)						Tolerances '	4.0%
butt joint (E				L	4	As detail (see 2.9	A STATE OF THE PARTY OF THE PAR	it up 3.4.4)
			Г			R = +1/1	6,-0 +1/4,	-1/16
			5	11 11 5	Т1	a = +10°	-	,-5°
M = steel	(see 8.2.4, 9.2.5	Base metal thick	ness	Groove pr	reparation	Permitted	Gas shielding	
Welding	Joint	(U = unlim	ited)	Root	Groove	welding	for	Note
process	designation	T ₁	T ₂	opening	angle	positions*	(FCAW)	Noti
				R = 1/4	a = 45°	All	-	-
SMAW	B-U2a	U	1 - [	R = 3/8	a = 30°	F,OH	-	-
				R = 1/2	a = 20°	F,OH	-	-
				R = 3/16	α = 30°	F,V,OH	Required	A
GMAW	B-U2+GF	U	1-1	R = 3/8	a = 30°	F	Not req.	A
FCAW				R = 1/4	a = 30°	V,OH	Not req.	A
		1/2 max	1-1	R = 1/4	a = 30°	F	-	-
SAW	B-L2a-S	1/2 max					The second district of the second	-

Note A: Not prequalified for gas metal arc welding using short circuiting transfer. Refer to Appendix D.

Note C: Gouge root before welding other side.

Note J: If fillet welds are used in buildings to reinforce groove welds in corner and T-joints, they shall be equal to 1/4 T₁ but need not exceed 3/8 in. The reinforcement of groove welds in corner joints, when required, and T-joints in bridges shall be made with fillet welds equal to 1/4 T₁, but need not exceed 3/8 in.


Fig. 2.9.1 (continued)-Prequalified complete joint penetration groove welded joints

**The above references appear in AWS D1.1. See Note AA, attached, for details.

^{*}F = Flat, OH = Overhead.

Rev. 0 1/81

Details of Welded Joints | 11



Single-V-groo Butt joint (B	ve weld (2)			_		<del></del>			
		Base	7	Gr	pove preparation			Gas	
		metal thickness	1	Root opening	Tolera	nces ***	Permitted	shielding	
Welding	Joint	(U = unlimited)		Root face	As detailed	As fit up (see 3.3.4)	welding positions	for FCAW	Note
process	designation	Т1	T ₂	Groove angle	(see 2.9.2)		positions		
SMAW	B-U2	U	-	R = 0 to 1/8 f = 0 to 1/8 a = 60°	+1/16,-0 +1/16,-0 +10°,-0°	+1/16,-1/8 Not limited +10°,-5°	All	-	С
GMAW FCAW	B-U2-GF	U	-	R = 0 to 1/8 f = 0 to 1/8 a = 60°	+1/16,-0 +1/16,-0 +10°,-0°	+1/16,-1/8 Not limited +10°,-5°	All	Not required	A,C
SAW	B-L25-S	Over 1/2 to 1 inclusive	-	R = 0 f = 1/4 max α = 60°	±0 +0,-1/4 +10°,-0°	+1/16,-0 ±1/16 +10°,-5°	Flat	-	K
		Over 1/2 to 1	-	R = 0, a = 60° f = 1/4 max					
SAW	B-L2c-S	Over 1 to 1-1/2	-	R = 0, a = 60° f = 1/2 max	R = ±0 f = +0,-f a = +10°,-0°	+1/16,-0 ±1/16 +10°,-5°	Flat	-	C

Note A: Not prequalified for gas metal arc welding using short circuiting transfer. Refer to Appendix D.

R = 0. a = 60°

f = 5/8 max

Note C: Gouge root before welding other side.


Note K: Weld root after welding at least one pass on arrow side.

Over 1-1/2 to 2


Fig. 2.9.1 (continued)-Prequalified complete joint penetration groove welded joints

**The references below appear in AWS D1.1. See Note AA attached for details.

#### 12 / DESIGN OF WELDED CONNECTIONS



		Base		Gro	ove preparation				
		metal thickn	ess	Root opening	Tole	rances **	Permitted	Gas shielding	
Welding	Joint	(U = unlimite	ed)	Root face	As detailed	As fit up	welding	for FCAW	Notes
process	designation	Tı	T ₂	Groove angle	(see 2.9.2)	(see 3.3.4)	positions	FCAW	Notes
SMAW	C-U2	U	U	R = 0 to 1/8 f = 0 to 1/8 a = 60°	+1/16,-0 +1/16,-0 f10°,-0°	+1/16,-1/8 Not limited +10°,-5°	All	-	۲٥
GMAW FCAW	C-U2-GF	U	U	R = 0 to 1/8 f = 0 to 1/8 a = 60°	+1/16,-0 +1/16,-0 +10°,-0°	+1/16,-1/8 Not limited +10°,-5°	All	Not required	A,C,
SAW	C-L2b-S	1 max	U	R = 0 f = 1/4 max a = 60°	±0 +01/4 +10°,-0°	+1/16,-0 ±1/16 +10°,-5°	Fiat	-	J,K



	Base metal thickne		etal thickness . Groove preparation		Permitted Shieldin				
Welding process	Joint designation	(U = unlimited	T ₂	Root opening	Root face	Groove angle	welding positions*	for FCAW	Notes
		U, preferably 5/8 or thicker – Spacer = 1/8 x R		R = 1/4	f = 0 to 1/8	a = 45°	All	-	
SMAW	₩-U3a		- [	R = 3/8	f = 0 to 1/8	a = 30°	F,OH	-	C,M
				R = 1/2	f = 0 to 1/8	a = 20°	F,OH	-	
SAW	B-U3a-S	U Spacer = 1/4 x R	-	R = 5/8	f = 0 to 1/4	a = 20°	F	-	м

- Note A: Not prequalified for gas metal arc welding using short circuiting transfer. Refer to Appendix D.
- Note C: Gouge root before welding other side.
- Note J: If fillet welds are used in buildings to reinforce groove welds in corner and T-joints, they shall be equal to 1/4 T₁ but need not exceed 3/5 in. The reinforcement of groove welds in corner joints, when required, and T-joints in bridges shall be made with fillet welds equal to 1/4 T₁, but need not exceed 3/8 in.
- Note K: Weld root after welding at least one pass on arrow side.
- Note M: Double-groove welds may have grooves of unequal depth, but the depth of the shallower groove shall be no less than one-fourth of the thickness of the thinner part joined.
  - *F = Flat, OH = Overhead.

Fig. 2.9.1 (continued)-Prequalified complete joint penetration groove welded joints

							For	B-U3c-S onl	Y
ouble V-groc	ove weld (3)			_				T ₁	Sı
rtt joint (B)			_		\$ 51 1 1 52 1 -	± Tı T	Over 2 2-1/2 3 3-5/8 4 4-3/4 5-1/2	10 2-1/2 3 3-5/8 4 4-3/4 5-1/2 6-1/4	2-3/1
M = Stee	(see 8.2.4, 9.2.		_	Groove pr	eneration		For T ₁	> 6-1/4, or = 2/3 (T ₁ -1	T1 < /4)
	1	Base metal thickne	ss l		THE RESERVE OF THE PARTY OF THE	ences **	Permitted	Gas shielding	
Welding	Joint	(U = unlimite	d)	Root opening Root face Groove angle	As detailed (see 2.9.2)	As fit up (see 3.3.4)	welding positions	(FCAW)	Note
process	designation	T ₁	T ₂		+1/160	+1/161/8	All	-	C,I
SMAW	B-U3b B-U3-GF	U, preferably 5/8 or larger	-	R = 0 to 1/8 1 = 0 to 1/8 α = β = 60°	+1/16,-0 +10°,-0	Not limited +10°,-5°	All	Not required	A,C
SAW	B-U3b-S	1-1/8 min	-	R = 1/8 f = 0 e = \$ = 60° S ₁ = 2/3 T ₁ , S ₂ = 3/8 min	+1/16,-0 +1/16,-0 +10°,-0°	+1/16,-1/8 Not limited +10°,-5°	Fiat	-	M, I
SAW	B-L3-S	1-1/2 max	-	R = 0 f = 1/4  max $\alpha = 60^{\circ}; \beta = 80^{\circ}$ $S_1 = 2/3 (T_1 - 1/4), S_2 = 1$	±0 +0,-1/4 +10°,-0°	+1/16,-0 Not limited +10°,-5°	Fist	-	M,
SAW	B-U3c-S	U	-	R = 0 f = 1/4 max	±0 +0,-1/4 +10°,-0°	+1/16,-0 Not limited +10°,-5°	Fiat	-	M

Note A: Not prequalified for gas metal arc welding using short circuiting transfer. Refer to Appendix D.

Note C: Gouge root before welding other side.

Note K: Weld root after welding at least one pass on arrow side.

Note M: Double-groove welds may have grooves of unequal depth, but the depth of the shallower groove shall be no less than one-fourth of the thickness of the thinner part joined.


Note P: Weld S2 first with shielded metal arc low-hydrogen electrodes. Root of this weld shall be back gouged. Weld S1 with single- or multiple-pass subjnerged arc weld in flat position after manual arc welding is completed on other side.

Note X: It is permissible for the groove opening to vary from 0-1/8 in., in which case, weld as follows: Weld the S₁ groove first with shielded metal arc using low hydrogen electrodes; complete the weld with submerged arc welding. The root of the SMAW weld shall be back gouged. Weld the S2 groove with shielded metal arc using low hydrogen electrode or by submerged arc welding.

Fig. 2.9.1 (continued) - Prequalified complete joint penetration groove welded joints

**The references above appear in AWS D1.1. See Note AA attached for details.

#### 14 / DESIGN OF WELDED CONNECTIONS



Single herel	groove-weid (4)						Tolerances ³	रक्र
T-joint (T) Corner joint				- THE	Note V	As detai (see 2.9	The second secon	
				<u></u>		R = +1/1	6,-0 +1/4,-	-1/16
M = steel (s	** ee 8.2.4, 9.2.5, 1	0.2.4)		Note J		a = +10°	',-0° +10°,	-5°
Welding	Joint	Base metal thick	kness	Groove p	reparation Groove	Permitted welding	Gas shielding for	
process	designation	T1	T ₂	opening	angle	positions*	(FCAW)	Notes
				R = 1/4	a = 45°	All	-	J,V
		41	111	N = 1/4	0-45			
SMAW	TC-U4c	U	U	R = 3/8	a = 30°	F, OH	-	J,V
SMAW	TC-U4c	U	U			F, OH	- Required	-
GMAW	TC-U4c TC-U4c-GF	U	U	R = 3/8	a = 30°			A, J, V
			+	R = 3/8 R = 3/16	a = 30° a = 30° = 30° = 45°	All	Required	A, J, V
GMAW			+	R = 3/8 R = 3/16 R = 3/8	a = 30°	All Flat	Required Not req.	J,V A, J, V A, J, V A, J, V

Note A: Not prequalified for gas metal arc welding using short circuiting transfer. Refer to Appendix D.


Note Br: Bridge application limits the use of these joints to the horizontal position

Note J: If fillet welds are used in buildings to reinforce groove welds in corner and T-joints, they shall be equal to 1/4 T₁ but need not exceed 3/8 in. The reinforcement of groove welds in corner joints, when required, and T-joints in bridges shall be made with fillet welds equal to 1/4 T1, but need not exceed 3/8 in.

Note V: For corner joints, the outside groove preparation may be in either or both members, provided the basic greene configuration is not changed and adequate edge distance is maintained to support the welding operations within excessive edge melting.

*F = Flat, OH = Overhead.

Fig. 2.9.1 (continued)-Prequalified complete joint penetration groove welded joints



Single-bevel- T-joint (T) Corner joint	groove weld (4)			1-17	->		Note V		
		Base		-T2-R	Note Y Preparation		Note J		
		metal thick	ness	Root opening	_	rances ***	Permitted	Gas	
Welding	Joint	(U = unlim	ited)	Root face	As detailed	As fit up	welding	shielding for	
process	designation	T1	T ₂	Groove angle	(see 2.9.2)	(see 3.3.4)	positions	FCAW	Notes
SMAW	TC-U4a	U	U	R = 0 to 1/8	+1/16,-0	+1/16,-1/8	All	-	C,J,V
GMAW FCAW	TC-U4a-GF	U	U	f = 0 to 1/8 α = 45°	+1/16,-0 +10°,-0°	Not limited +10°,-5°	All	Not req.	A,C,J,
SAW	TC-L4a-S	3/4 max	U	R = 0 f = 1/8 max α = 60°	±0 +0,-1/8 +10°,-0°	+1/4,-0 ±1/16 +10°,-5°	Flat	-	J,V,Y

Note A: Not prequalified for gas metal arc welding using short circuiting transfer. Refer to Appendix D.

Note C: Gouge root of joint before welding the other side.

Note J: If fillet welds are used in buildings to reinforce groove welds in corner and T-joints, they shall be equal to 1/4 T₁ but need not exceed 3/8 in. The reinforcement of groove welds in corner joints, when required, and T-joints in bridges shall be made with fillet welds equal to 1/4 T₁, but need not exceed 3/8 in.

Note V: For corner joints, the outside groove preparation may be in either or both members, provided the basic groove configuration is not changed and adequate edge distance is maintained to support the welding operations without excessive edge melting.


Note Y: Shielded metal arc or submerged arc backing fillet weld required.


## Fig. 2.9.1 (continued)-Prequalified complete joint penetration groove welded joints

**The references above appear in AWS D1.1. See Note AA attached for details.

1/81 **The references below appear in AWS D1.1. See Note AA attached for details.

#### 16 / DESIGN OF WELDED CONNECTIONS





- Note A: Not prequalified for gas metal arc welding using short circuiting transfer. Refer to Appendix D.
- Note C: Gouge root of joint before welding the other side.
- Note J: If fillet welds are used in buildings to reinforce groove welds in corner and T-joints, they shall be equal to 1/4 T₁ but need not exceed 3/8 in. The reinforcement of groove welds in corner joints, when required, and T-joints in bridges shall be made with fillet welds equal to 1/4 T₁, but need not exceed 3/8 in.
- Note V: For comer joints, the outside groove preparation may be in either or both members, provided the basic groove configuration is not changed and adequate edge distance is maintained to support the welding operations without excessive edge melting.
- Note Y: Shielded metal arc or submerged arc backing weld required.
  - *F = Flat, OH = Overhead.

The state of the s

Fig. 2.9.1 (continued)-Prequalified complete joint penetration groove welded joints

Double-bev	ei-groove weld (	5)		~	A H	·		Tolerances	22
Butt joint ( T-joint (T)	B)		?	XX	X	See Note	'As deta		fit up 2.3.4)
Corner join			Ī				R = :	10 +1/	/16,-0
			+-	-لحننها-	R		f =+1/1	160 ±1	/16
	7c 7c		5		5 +2		a =+10	°,-0° +11	0°,-5°
	see 8.2.4, 9.2.5,		L		الله الله		Spacer	-+0 +1	/16,-0
Note: Sam	ne steel as base r	metal		- T1 -				10110	
		Base metal thickness			Groove preparation		Permitted	Gas shielding	
Welding	Joint	(U = unlimited)	-	Root	Root	Groove	welding positions*	(FCAW)	Notes
process	designation	Т1	T ₂	opening	1000	angic	positions	Tr CATT	NOTES
	B-U5b	U, preferably 5/8 or thicker Spacer = 1/8 X R	-	R - 1/4	f = 0 to 1/8	e - 45°	All	-	Br, C,
SMAW		U, preferably		R = 1/4	f = 0 to 1/8	a = 45°	All		C, J, M, V
	TC-U5a	5/8 or thicker Spacer = 1/8 X R	4	R = 3/8	f = 0 to 1/8	e = 30°	F, OH		C, J, M, V

Note Br: Bridge application limits the use of these joints to the horizontal position

Note C: Gouge root of joint before welding the other side.

Note J: If fillet welds are used in buildings to reinforce groove welds in corner and T-joints, they shall be equal to 1/4 T₁ but need not exceed 3/8 in. The reinforcement of groove welds in corner joints, when required, and T-joints in bridges shall be made with fillet welds equal to 1/4 T₁, but need not exceed 3/8 in.

Note M: Double-groove welds may have grooves of unequal depth, but the depth of the shallower groove shall be no less than one-fourth of the thickness of the thinner part joined.

Note V: For corner joints, the outside groove preparation may be in either or both members, provided the basic groove configuration is not changed and adequate edge distance is maintained to support the welding operations without excessive edge melting.

*F = Flat, OH = Overhead.

Fig. 2.9.1 (continued) - Prequalified complete joint penetration groove welded joints

**The references above appear in AWS D1.1. See Note AA attached for details.

GMAW

FCAW

GMAW

FCAW

SAW

B-U5-GF

#### Limitations Double-bevel-groove weld (5) Butt joint (B) Bridge applications limited to horizontal position Note Z TI Groove preparation Base Gas Tolerances *** Permitted metal thickness shielding Root opening As fit up welding (U = unlimited) As detailed for Root face Joint Welding FCAW Notes (see 3.3.4) positions Groove angles (see 2.9.2) process designation T, T2 +1/16,-1/8 +1/16.-0 R = 0 to 1/8 U. C. M. Not limited +1/16,-0 f = 0 to 1/8 preferably All a + f. +10 B-U5a SMAW Z a + \$, +10 a = 45° 5/8 or thicker

+1/16.-0

+1/16,-0

+10°,-0°

±0°

+10°,-0°

+0,-3/16

+10°,-0°

:0

+1/16.-1/8

Not limited

+10° .-5°

+10°,-5°

+1/16.-0

+10° .-5°

±1/16

All

Not req

Not

required

All

Flat

A. C.

J. M. V

J. M. V

A. C.

M

8 = 0° to 15°

R = 0 to 1/8

f = 0 to 1/8

a - 45°

6 = 0°

U.

preferably

5/8 or thicker

Double-beve T-joint(T) Corner joint	el-groove weld (5	0			× ×		Hote V		
		Base metal thickn	229.1	T ₂ -R	roove preparation		Note J	Gas	
	F 4 7 2 1			Root opening	Tole	rancesitate	Permitted	shielding	Mil.
Welding	Joint	(U = unlimit	ed)	Root face	As detailed	As fit up	welding	for	
process	designation	T ₁	T ₂	Groove angle	(see 2.9.2)	(see 3.3.4)	positions	FCAW	Note
SMAW	TC-U5b	U, preferably 5/8 or thicker	U	R = 0 to 1/8	+1/16,-0	+1/16,-1/8	All	-	C. J
			-	f = 0 to 1/8	+1/16,-0	Not limited		Not	

Note A: Not prequalified for gas metal arc welding using short circuiting transfer. Refer to Appendix D.

U

a = 45°

R = 0

a = 60°

f = 3/16 max

Gouge root of joint before welding the other side. Note C:

TC-U5-GF

TC-U5-S

If fillet welds are used in buildings to reinforce groove welds in corner and T-joints, they shall be equal to 1/4 T₁ but need not exceed 3/8 in. The reinforcement of groove welds in corner joints, when required, and T-joints in bridges shall be made with fillet welds equal to 1/4 T1, but need not exceed 3/8 in.

Note M: Double-groove welds may have grooves of unequal depth, but the depth of the shallower groove shall be no less than one-fourth of the thickness of the thinner part joined.

Note V: For corner joints, the outside groove preparation may be in either or both members, provided the basic groove configuration is not changed and adequate edge distance is maintained to support the welding operations without excessive edge melting.

Note Z: When lower plate is beveled, make the first root pass on this side.


U.


preferably

5/8 or thicker

Fig. 2.9.1 (continued)-Prequalified complete joint penetration groove welded joints

1





Gouge root of joint before welding the other side. Note C:


If fillet welds are used in buildings to reinforce groove welds in corner and T-joints, they shall be equal to 1/4 T₁ but need not exceed 3/8 in. The reinforcement of groove welds in corner joints, when required, and T-joints in bridges shall be made with Note J: fillet welds equal to 1/4 T₁, but need not exceed 3/8 in.

Double-groove welds may have grooves of unequal depth, but the depth of the shallower groove shall be no less than one-fourth of the thickness of the thinner part joined.

Note V: For corner joints, the outside groove preparation may be in either or both members, provided the basic groove configuration is not changed and adequate edge distance is maintained to support the welding operations without excessive edge melting.

## Fig. 2.9.1 (continued)-Prequalified complete joint penetration groove welded joints

**The references above appear in AWS D1.1. See Note AA attached for details.



Note A: Not prequalified for gas metal arc welding using short circuiting transfer. Refer to Appendix D.

Note C: Gouge root of joint before welding the other side.

Note J: If fillet welds are used in buildings to reinforce groove welds in corner and T-joints, they shall be equal to 1/4 T₁, but need not exceed 3/8 in. The reinforcement of groove welds in corner joints, when required, and T-joints in bridges shall be made with fillet welds equal to 1/4 T₁. These fillet welds need not exceed 3/8 in.

Note M: Double-groove welds may have grooves of unequal depth, but the depth of the shallower groove shall be no less than one-fourth of the thickness of the thinner part joined.

*F = Flat, OH = Overhead.

Fig. 2.9.1 (continued)-Prequalified complete joint penetration groove welded joints

#### Details of Welded Joints / 21

Butt joint (	pove weld (8)				- T1-				Toleran	ces **
butt joint (	101			17	1-1-			As det		As fit up see 3.3.4)
				12				R = +1/	16,-0	+1/16,-1/8
				X				a = +10	0°,-0°	+10°,-5°
				,	-30-	L		f =+1/	16,-0	Not limited
				1	-	_		r =+1/	4,-0	±1/16
		L			~- 1	R				
		Base metal thick	kness	G	roove prepare	etion .		Permitted	Gas	
Welding	Joint	metal thick	kness nited)	Root	Groove	Root	Groove	welding	shieldi	ng
process	designation	metal thick (U = unlin	kness	Root opening	_		Groove		shieldi	ng
		metal thick	kness nited)	Root	Groove	Root		welding	shieldi	ng

	ove weld (8)								Tolerano	es XX
T-jóint (T) Corner join	t (C)			~ . '	,	Note V		As deta (see 2.		s fit up ee 3.3.4)
				ST.	I		2	R = +1/1	16,-0 +	/16,-1/8
			1	7	"	0	7	a = +10	°,-0° +	10°,-5°
				1	_	4		f = +1/1	6,-0 N	ot limited
			-T ₂ -	-R 1		Note	,	r = +1/4	,-0	±1/16
		Base metal thickness								
					Groove p	reparation		Permitted	Gas	
Welding	Joint	metal thick	nited)	Root	Groove p	Root	Groove	Permitted welding	Gas shielding for	9
Welding process	Joint designation			Root opening		_	Groove		shieldin	1
process	designation	(U = unlin	nited)		Groove	Root		welding	shieldin for	Notes
		(U = unlin	nited)	opening	Groove angle	Root face	radius	welding positions*	shieldin for FCAW	1

Note A: Not prequalified for gas metal arc welding using short circuiting transfer. Refer to Appendix D.

Note Br: Bridge application limits the use of these joints to the horizontal position

Note C: Gouge root before welding other side.

Note J: If fillet welds are used in buildings to reinforce groove welds in corner and T-joints, they shall be equal to 1/4 T₁ but need not exceed 3/8 in. Groove welds in corner and T-joints of bridges shall be reinforced with fillet welds equal to 1/4 T₁ but not more than 3/8 in.

Note V: For corner joints, the outside groove preparation may be in either or both members, provided the basic groove configuration is not changed and adequate edge distance is maintained to support the welding operations without excessive edge melting.

*F = Flat, OH = Overhead.

Fig. 2.9.1 (continued)-Prequalified complete joint penetration groove welded joints

**The references above appear in AWS D1.1. See Note AA attached for details.

Rev. 0 1/81 22 / DESIGN OF WELDED CONNECTIONS

MP-08

	oove weld (8)			L /2	_				Tolerar	ncestric
T-joint (T) Corner join	ot (C)		[-^-	[ X	N	lote V		As det		As fit up (see 3.3.4)
				X	L	1		R = +1/	16,-0	+1/16,-1/8
		+	-	ージン	1	11	>	a = +10	°,-0°	+10",-5"
		1		EX ST		· He	5	f = +1/1	16,-0	Not limited
			-T2-	- X	_	Note J		r = +1/4	4,-0	1/16
		Base		45° to 90°			*			
		Base metal thic			Groove prep	aration		Permitted	Gas	
Welding	Joint	No. of the last of	kness nited)		Groove prep	aration	Groove	Permitted welding	Gas shieldi for	ng
	Joint designation	metal thic	kness			,	Groove radius		shieldi	ng
process	designation	metal thic	kness nited)	Root	Groove	Root		welding	shieldi for	ng
		metal thic	kness nited)	Root opening	Groove angle	Root face	radius	welding positions*	shieldi for FCAV	Note

	oove weld (9)			T1	1	,			Tolerances	र्जन प्रत
Butt joint (	B)			- S ₁  -	_ /	5		As deta (see 2.		fit up 3.3.4)
				1-11-1	1			R = +1/	16,-0 +1/	16,-1/8
				M	1			a = +10	°,-0° +10	0°,-5°
				· AHA	119			f = +1/	16,-0 Not	limited
				i V	R			r = +1/	4,-0 +1/1	6
		Base		السال	1					
	7.77	metal thickness		Groove preparation			Permitted	Gas shielding		
Welding		(U = unlimit	-	Root	Groove	Root	Groove	welding	for	1.7
process	designation	T ₁	T ₂	opening	angle	face	radius	positions	(FCAW)	Notes
SMAW	B-U9	U, preferably 5/8 or thicker	-	R = 0 to 1/8	α = 45°	f = 1/8	r = 3/8	All	1-1	Br. C
GMAW FCAW	B-U9-GF	U, preferably 5/8 or thicker	-	R = 0 to 1/8	a = 30°	f = 1/8	r = 3/8	All	Not required	A, B

Note A: Not prequalified for gas metal arc welding using short circuiting transfer. Refer to Appendix D.

Note Br: Bridge application limits the use of these joints to the horizontal position

Note C: Gouge root before welding other side.

Note J: If fillet welds are used in buildings to reinforce groove welds in corner and T-joints, they shall be equal to 1/4 T₁ but need not exceed 3/8 in. The reinforcement of groove welds in corner joints, when required, and T-joints in bridges shall be made with fillet welds equal to 1/4 T₁, but need not exceed 3/8 in.

Note M: Double-groove welds may have grooves of unequal depth, but the depth of the shallower groove shall be no less than one-fourth of the thickness of the thinner part joined.

Note V: For corner joints, the outside groove preparation may be in either or both members, provided the basic groove configuration is not changed and adequate edge distance is maintained to support the welding operations without excessive edge melting.

* F = Flat, OH = Overhead.

Fig. 2.9.1 (continued)-Prequalified complete joint penetration groove welded joints

**The references below appear in AWS D1.1. See Note AA attached for details.

#### Details of Welded Joints | 23

									Tolerances	36.36
-joint (T)	ove weld (9)		•+	X				As deta (see 2.5		fit up 3.3.4)
corner joint	107		-			lote V		R = +1/1	16,-0 +1/1	6,-1/8
			T	97	-	5112		a = +10	°,-0° +10	0°,-5°
			1	12 1		12		f = +1/1	160 Not	limited
			. +	1		Note .		r = +1/	4,-0 ±	1/16
		Base	T2 - F						Gas	
			-	-	Groove pr	reparation		Permitted	Gas shielding	
Welding	Joint	Base metal thickno	ess ed)	Root	Groove	Root	Groove	Permitted welding positions		Note
Welding process	Joint designation	Base metal thicknown (U = unlimits	ess	Root	_	AND RESIDENCE OF PERSONS ASSESSED.	Groove radius	welding	shielding for	Note C, J, M, V
		Base metal thickno	ess ed)	Root	Groove angle	Root face	radius	welding positions	shielding for	Note C, J,

1	(O) blanca							1 10	SIEL BUILDES	
Couble-J-gro Comer joint	(C)	r	->-	1-02	<del>-</del>	Note V		As detail		fit up 3.3.4)
		17				100		R=+1/16	5,-0 +1/1	6,-1/8
		-				25	>	a =+10°	-0° +10	*,-5°
		1		TAIN ()		6 1	15	f =+1/16	5,-0 Not I	imited
		1-	~	TO THE		-	3	r =+1/4	,-0 ±1/	16
Welding	Joint	Base metal thickn	ness		Groove prepi	aration		Permitted	Gas shielding	14
Welding	Joint	(U = unlim	-	Root	Groove	Root	Groove	welding positions*	(FCAW)	Notes
Welding process	Joint designation	(U = unlim	T ₂	Root opening	Groove angle	Root face	radius	positions*	The second secon	Notes
		T ₁	T ₂			With the second second		and the second second second	The second secon	C. J.
		T ₁	-	opening	angle	face	radius	positions*	The second secon	C, J, M, V

Note A: Not prequalified for gas metal arc welding using short circuiting transfer. Refer to Appendix D.

Note C: Gouge root before welding other side.

If fillet welds are used in buildings to reinforce groove welds in corner and T-joints, they shall be equal to 1/4 T₁ but need not exceed 3/8 in. The reinforcement of groove welds in corner joints, when required, and T-joints in bridges shall be made with fillet welds equal to 1/4 T₁, but need not exceed 3/8 in.

Note M: Double-groove welds may have grooves of unequal depth, but the depth of the shallower groove shall be no less than one-fourth of the thickness of the thinner part joined.


Note V: For corner joints, the outside groove preparation may be in either or both members, provided the basic groove configuration is not changed and adequate edge distance is maintained to support the welding operations without excessive edge melting.

* F = Flat, OH = Overhead.

(

Fig. 2.9.1 (continued)-Prequalified complete joint penetration groove welded joints

Square-groo Butt joint (I	ve weld (1)		/	Their	nforcement 1/32 to	o 1/8, no toleran	ce		
		Base metal thick			T ₁	1			
			Tolerances ***		Permitted	Effective			
Walding		(O - Ommin			As detailed	As fit up	welding	throat	
Welding process	designation	T ₁	T ₂	Root opening	(see 2.10.2)	(see 3.3.4)	positions	(E)	Note
		T ₁	T ₂	Root opening R = 0 to 1/16	(see 2.10.2) +1/16,-0	(see 3.3.4) ± 1/16	positions	(E) T,	Note




Note B: Joints welded from one side. These welds are not applicable to bridges.

Note C2: Root need not be gouged before welding second side. This weld is not applicable to bridges.

Fig. 2.10.1-Prequalified partial joint penetration groove welded joints

**The references above appear in AWS D1.1. See Note AA attached for details.

# 26 / DESIGN OF WELDED CONNECTIONS



Note A: Not prequalified for gas metal arc welding using short circuiting transfer. Refer to Appendix D.

Joint is welded from one side only.

Note E: Minimum effective throat (E) as shown in Table 2.10.3; S as specified on drawings. **


Note L: Butt and T-joints are not prequalified for bridges.


Fig. 2.10.1 (continued)-Prequalified partial joint penetration groove welded joints

**The references above appear in AWS D1.1. See Note AA attached for details.

**The references below appear in AWS D1.1. See Note AA attached for details.

Details of Welded Joints 1 27





Note A: Not prequalified for gas metal arc welding using short circuiting transfer. Refer to Appendix D.

Note B: Joint is welded from one side only.

Note E: Minimum effective throat (E) as shown in Table 2.10.3; S as specified on drawings. Hot

Note L: Butt and T-joints are not prequalified for bridges.

Note Mp: Double groove welds may have grooves of unequal depth, provided they conform to the limitations of Note E. Also. the effective throat (E), less any reduction, applies individually to each groove.

Ngte W: Unbeveled face is the lower edge for horizontal position.

# Fit-up tolerance, SAW: see 3.3.2; for rolled shapes R may be 5/16 inches in thick plates if backing is provided.

Fig. 2.10.1 (continued) - Prequalified partial joint penetration groove welded joints

.. .

#### 28 / DESIGN OF WELDED CONNECTIONS

Single-beve Butt joint ( T-joint(T) Corner join					S 1,	Note V	}		
		Base		Gr	oove preparation		J		
1		metal thickness		Root opening	Tolerances **		Permitted	Effective	
Welding process	Joint /	(U = unlimit	T ₂	Root face Groove angle	As detailed (see 2.10.2)	As fit up (see 3.3.4)	welding positions*	throat (E)	Notes
SMAW	BTC-P4	7/16 min (for bridges 1/2 min)	U	R = 0 f = 1/8 min a = 45°	+1/16,-0 -0 +10°,-0°	±1/16 ±1/16 +10°,-5°	All	S -1/8	E, L, \
GMAW	BTC-P4-GF	1/4 min (for bridges 5/16 min)	U	R = 0 f = 1/8 min	+1/16,-0	±1/16 ±1/16	F,H	s	A, E,
FCAW		7/16 min		a = 45°	+10°,-0°	+10°,-5°	V,ОН	S-1/8	L. V
SAW	TC-P4-S	7/16 min (for bridges 1/2 min)	υ	R = 0 f = 1/4 min a = 60°	±0 -0 +10°,-0°	+3/16,-0: ±1/16 +10°,-5°	Flat	s	E, L, V

Note A: Not prequalified for gas metal arc welding using short circuiting transfer. Refer to Appendix D.

Note E: Minimum effective throat (E) as shown in Table 2.10.3; S as specified on drawings. **

Note L. Butt and T-joints are not prequalified for bridges.


Note V: For comer joints, the outside groove preparation may be in either or both members, provided the basic groove configuration is not changed and adequate edge distance is maintained to support the welding operations without excessive edge melting.

# Fit-up tolerance, SAW: see 3.3.2; for rolled shapes R may be 5/16 inches in thick plates if backing is provided.

* F = Flat, H = Horizontal, V = Vertical, OH = Ovorhead.

Fig. 2.10.1 (continued) - Prequalified partial joint penetration groove welded joints

**The references above appear in AWS D1.1. See Note AA, attached, for details.



Note A: Not prequalified for gas metal arc welding using short circuiting transfer. Refer to Appendix D.

Note E: Minimum effective throat (E) as shown in Table 2.10.3; S as specified on drawings. **

Note L: Butt and T-joints are not prequalified for bridges.

Note Mp: Double-groove welds may have grooves of unequal depth, provided they conform to the limitations of Note E. Also, the effective throat (E), less any reduction, applies individually to each groove.

Note V: For comer joints, the outside groove preparation may be in either or both members, provided the basic groove configuration is not changed and adequate edge distance is maintained to support the welding operations without excessive edge melting.


# Fit-up tolerance, SAW: see 3.3.2; for rolled shapes R may be 5/16 inches in thick plates if backing is provided.

Fig. 2.10.1 (continued)-Prequalified partial joint penetration groove welded joints

**The references above appear in AWS Dl.1. See Note AA, attached, for details.

^{*} F = Flat, H = Horizontal, V = Vertical, OH = Overhead.

#### 30 / DESIGN OF WELDED CONNECTIONS



Note A: Not prequalified for gas metal arc welding using short circuiting transfer. Refer to Appendix D.

Note E: Minimum effective throat (E) as shown in Table 2.10.3; S as specified on drawings. **

Note L: Butt and T-joints are not prequalified for bridges.

* Fit-up tolerance, SAW: see 3.3.2; for rolled shapes R may be 5/16 inches in thick plates if backing is provided.

Fig. 2.10.1 (continued)-Prequalified partial joint penetration groove welded joints

**The references above appear in AWS Dl.1. See Note AA, attached, for details.

Double V-gr Butt joint (B	oove weld (7)			-7		S ₂ -J			
		Base metal thickr			Groove preparation		-		
Welding Joint		(U = unlimited)		Root opening Root face Groove radius	Tolerances **  As detailed As fit up		Permitted welding	Effective throat	
process	designation	T ₁	T ₂	Groove angle	(see 2.10.2)	(see 3.3.4)	positions	(E)	Notes
SMAW	B-P7	1/2 min (for bridges 5/8 min)	-	R = 0 to 1/8 f = 1/8 min r = 1/4 a = 45	+1/160 -0 +1/40 +10°0°	±1/16 ±1/16 ±1/16 +10°,-5°	All	S	E, L, Mp
GMAW FCAW	B-P7-GF	1/2 min (for bridges 5/8 min)	-	R = 0 f = 1/8 min r = 1/4 a = 20°	+1/16,-0 -0 +1/4,-0 +10°,-0°	±1/16 ±1/16 ±1/16 +10°,-5°	All	s -	A, E L, Mr
SAW	B-P7-S	3/4 min (for bridges 7/8 min)	-	R = 0 f = 1/4 min r = 1/4 α = 20°	±0 -0 +1/4,-0 +10°,-0°	+3/15,-0* ±1/16 ±1/16 +10°,-5°	Flat	s	E, L,

Note A: Not prequalified for gas metal arc welding using short circuiting transfer. Refer to Appendix D.

Note E: Minimum effective throat (E) as shown in Table 2.10.3; S as specified on drawings. **

Note L: Butt and T-joints are not prequalified for bridges.


Note Mp: Double-groove welds may have grooves of unequal depth, provided they conform to the limitations of Note E. Also, the effective throat (E), less any reduction, applies individually to each groove.

# Fit-up tolerance, SAW: see 3.3.2; for rolled shapes R may be 5/16 inches in thick plates if backing is provided.

Fig. 2.10.1 (continued)-Prequalified partial joint penetration groove welded joints

**The references above appear in AWS D1.1. See Note AA, attached, for details.

### 32 / DESIGN OF WELDED CONNECTIONS



Note A: Not prequalified for gas metal arc welding using short circuiting transfer. Refer to Appendix D.

Note E: Minimum effective throat (E) as shown in Table 2.10.3; S as specified on drawings. **


Note L: Butt and T-joints are not prequalified for bridges.

Note V: For corner joints, the outside groove preparation may be in either or both members, provided the basic groove configuration is not changed and adequate edge distance is maintained to support the welding operations without excessive edge melting.

Fit-up tolerance, SAW: see 3.3.2; for rolled shapes R may be 5/15 inches in thick plates if backing is provided.

Fig. 2.10.1 (continued)-Prequalified partial joint penetration groove welded joints

**The references above in AWS Dl.1. See Note AA, attached, for details.



Note A: Not prequalified for gas metal arc welding using short circuiting transfer. Refer to Appendix D.

Note E: Minimum effective throat (E) as shown in Table 2.10.3; S as specified on drawings. **

Note J: If fillet welds are used in buildings to reinforce groove welds in corner and T-joints, they shall be equal to 1/4 T₁ but need not exceed 3/8 in. The reinforcement of groove welds in corner joints, when required, and T-joints in bridges shall be made with fillet welds equal to 1/4 T₁, but need not exceed 3/8 in.

Note L: Butt and T-joints are not prequalified for bridges.

1

Note Mp: Double-groove welds may have grooves of unequal depth, provided they conform to the limitations of Note E. Also, the effective throat (E), less any reduction, applies individually to each groove.

Note V: For corner joints, the outside groove preparation may be in either or both members, provided the basic groove configuration is not changed and adequate edge distance is maintained to support the welding operations without excessive edge melting.

t Fit-up tolerance, SAW: see 3.3.2; for rolled shapes R may be 5/16 inches in thick plates if backing is provided.

Fig. 2.10.1 (continued)-Prequalified partial joint penetration groove welded joints

**The references above appear in AWS Dl.1. See Note AA, attached, for details.

#### NOTE AA

The following references as listed in AWS D1.1 are as follows:

- Reference 9.2.5 When material is ASTM A242 or A618, Grade 1, its weldability must be investigated by the welding engineer, Metallurgy/Welding prior to welding.
- Reference 2.9.2 Dimensional Tolerances. Dimensions of groove welds specified on design or detailed drawings may vary from the dimensions shown in Fig. 2.9.1 only within the following limits.
  - The specified thickness of base metal or weld effective throat is the maximum nominal thickness that may be used.
  - The groove angle is minimum; it may be detailed to exceed the dimensions shown by no more than 10 degrees.
  - 3. The radius of J-grooves and U-grooves is minimum. It may be detailed to exceed the dimensions shown by no more than 1/8 in. (3 mm). U-grooves may be prepared before or after fit-up.
  - 4. Double-groove welds may have grooves of unequal depth, but the depth of the shallower groove shall be no less than 1/4 of the thickness of the thinner part joined, unless otherwise designated in Fig. 2.9.1.
  - 5. The root face of the joint shall be as dimensioned in Fig. 2.9.1 with the following variations permitted:
    - (1) For SMAW, GMAW, or FCAW it may be detailed to exceed the specified dimension by no more than 1/16 in. (2 mm). It may not be detailed less than the specified dimension.


Reference 3.3.4


With the exclusion of electroslag and electrogas welding, and with the exception of 3.3.4.1 for root openings in excess of those permitted in the table below and illustrated in Fig. 3.3.4, the dimensions of the cross section of the groove-welded joints which vary from those shown on the detail drawings by more than the following tolerances shall be referred to the Engineer for approval or correction.

		Root n gouged		Root gouged
		in.	mm	in. mm
(1) (2)	Root face of joint Root opening of joints without steel backing root opening of joints	+ 1/16 + 1/16 +1/4	1.6 1.6 6.4	Not limited + 1/16 1.6 - 1/8 3.2 Not
(3)	with steel backing Groove angle of joint	-1/16 +10 deg - 5 deg	1.6	applicable +10 deg - 5 deg

^{*}See 10.13.1.1 (3) for tolerances for complete joint penetration tubular groove welds made from one side without backing, see AWS D1.1.

3.3.4.1 Root openings wider than those permitted in 3.3.4, but not greater than twice the thickness of the thinner part of 3/4 in. (19 mm), whichever is less, may be corrected by welding to acceptable dimensions prior to joining the parts by welding. Root openings larger than the above may be corrected by welding only with the approval of the Engineer.





(C) Groove weld without backing root gouged

#### Notes:

- 1. α · groove angle.
- 2. R root opening.
- 3. f root face.
- 4. The groove configurations shown are for illustration only.

Fig. 3.3.4—Workmanship tolerances in assembly of groove welded butt joints

#### Reference 2.10.2 and Table 2.10.3

- 2.10.1 Partial joint penetration groove welds made by shielded metal arch welding, submerged arc welding, gas metal arc welding (except short circuiting transfer), or flux cored arc welding in butt, corner, and T-joints which may be used without performing the joint welding procedure qualification tests prescribed in 5.2 are detailed in Fig. 2.10.1 and are subject to the limitations specified in 2.10.2.
  - 2.10.1.1 Definition. Except as provided in 10.13.1.1., groove welds without steel backing, welded from one side, and groove welds welded from both sides but without back gouging are considered partial joint penetration groove welds.

- 2.10.1.2 All partial joint penetration groove welds made by short circuiting transfer gas metal arc welding (see Appendix D) shall be qualified by the joint welding procedure qualification test prescribed in 5.2.
- 2.10.2 Dimensional tolerances. Dimensions of groove welds specified on design or detailed drawings may vary from the dimensions shown in Fig. 2.10.1 only within the following limits.
  - 2.10.2.1 The groove angle is minimum; it may be detailed to exceed the dimensions shown by no more than 10 degrees.
  - 2.10.2.2 The radius of the J-grooves and U-grooves is minimum. Let may be detailed to exceed the dimensions shown by no more than 1/8 in. (3 mm). U-grooves may be prepared before or after fit-up.
  - 2.10.2.3 Double-groove welds may have grooves of unequal depth, providing the weld deposit on each side of the joint conforms to the limitations of Fig. 2.10.1.
  - 2.10.2.4 The minimum root face of the joints shall be 1/8 in. (3 mm), except that the minimum root face for joints to be welded by submerged arc welding shall be 1/4 in. (6 mm).

- 2.10.3 The effective throat of partial joint penetration square-, single- or double-V-, bevel-, J-, and U-groove welds shall be as shown in Table 2.10.3.
  - 2.10.3.1 Shop or working drawings shall specify the groove depths (S) applicable for the effective throat (E) required for the welding process and position of welding to be used.
- 2.10.4 Groove preparations detailed for prequalified shielded metal arc welded joints may be used for prequalified gas metal arc or flux cored arc welding.
- 2.10.5 Corner Joints. For corner joints the outside groove preparation may be in either or both members, provided the basic groove configuration is not changed and adequate edge distance is maintained to support the welding operations without excessive melting.

Table 2.10.3
Minimum effective throat for partial joint penetration groove welds

Base metal thickness of thicker part joined	Minimum effective throat**		
in. mm	in.	mm	
To 1/4 (6.4) incl.	1/8*	3	
Over 1/4 (6.4) to 1/2 (12.7) incl.	3/16	5	
Over 1/2 (12.7) to 3/4 (19.0) incl.	1/4	6	
Over 3/4 (19.0) to 1-1/2 (38.1) incl.	5/16	8	
Over 1-1/2 (38.1) to 2-1/4 (57.1) incl.	3/8	10	
Over 2-1/4 (57.1) to 6 (152) incl.	1/2	13	
Over 6 (152)	5/8	16	

^{*}Minimum size for bridge applications is 3/16 in.

^{**}Except the effective throat need not exceed the thickness of the thinner part.

#### TABLE A

#### Symbols for joint types

B - butt joint

C - corner joint

T - T joint

BC - butt or corner joint

TC - T or corner joint

BTC - butt, T, or corner joint

# Symbols for base metal thickness and penetration

L - limited thickness - complete joint penetration

U - unlimited thickness - complete joint penetration

P - partial joint penetration

# Symbols for weld types

1 - square-groove

2 - single-V-groove

3 - double-V-groove

4 - single-bevel-groove

5 - double-bevel-groove

6 - single-U-groove

7 - double-U-groove

8 - single-J-groove

9 - double-J-groove

# Symbol for welding processes, if not shielded metal arc

S - submerged arc welding

G - gas metal arc welding

F - flux cored arc welding

# TABLE B

# WPS for Structural & Hangers for Seismic & Non-Seismic Welds

Type Joint	Joint Size	WPS (Qualification)	Weld Process Filler	Preheat* (min.)
Carbon Steels	& Low Alloy Ste	els (Group II)		
Fillet	ALL	AW-1 (Prequalified)	SMAW - E7018	**None (thickness thru 3/4" 50°F (over 3/4" thru 1½") 150°F (over 1½" thru 2½") 225°F (over 2½")
Groove	See Figures 2.9.1 & 2.10.1	"	"	"
Carbon Steels	s & Low Alloy Ste	els (Group II or P	I, See Table C)	
Fillet	ALL	1Al or 1A4 (Qualified)	SMAW E7018	**None (thickness thru 3/4" 50°F (over 3/4" thru 1½") 150°F (over 1½" thru 2½") 225°F (over 2½")
Fillet	ALL	1F1 (Qualified)	FCAW E71T-1	**None (thickness thru 3/4" 50°F (over 3/4"thru 1½") 150°F (over 1½" thru 2½") 225°F (over 2½")
Fillet	ALL	1F3 (Qualified)	FCAW E71T-1	100°F (thickness up to 1½") 150°F (over 1½" thru 2½") 225°F (over 2½")
Fillet	thickness	1M1 (Qualified)	GMAW ER70S-2	50°F (thickness thru ½")
Groove (With Backing)	Thru 1½"	1A4 (Qualified)	SMAW E-7018	Same As 1A4 table above
Groove (With Backing)	Thru 1½"	1F1 (Qualified)	FCAW E71T-1	Same as 1F1 table above
Groove (With Backing)	Thru 1½"	1F3 (Qualified)	FCAW E71T-1	Same as 1F3 table above
Groove (Without Backing)	(Contact Weld	ding Engineer, Meta	llurgy/Welding)	

Over 3/8" (Contact Welding Engineer, Metallurgy/Welding)

MP-08 Table B Page 2 of 2

# Carbon & Low Alloy Steel to 304 Stainless Steel (or other P-8)

Fillet ALL 1-8A1 SMAW 50°F

(Qualified) E304

Groove 3/16 (.1875) " " "

(With thru 3/8 (.3750)

Backing)

Groove (with or without backing)

*Thickness at the weld joint of the thickest member **If the temperature is below 32°F, preheat to 70°F and maintain during welding

max. T)

TABLE C

# Carbon Steel and Low Alloy Steels (P-1) as Listed in ASME Section IX

# Material Specification

	Mat	erial specifica		
	SA-234 Marking WPA		SA-105	SA-537 Class 1
SA-31 Grade A		SA-515 Grade 55		
Grade B		Grade 60	SA-106 Grade C	\$A-541 Class 1
		Grade 65		2-n/ Class 1A "
SA-36	SA-234 Marking WPB		SA-155 Grade KC70	
	an-an marking tire	SA-516 Grade 55	Grade KCF70	SA-556 Grade C2
SA-53 Acid Bessemer		Grade 60		
Open Hearth		Grade 65	SA-181 Class 70	:SA-557 Grade C
Grade A	SA-266 Class 1	The last and the l	20-101-0-0-	
Grade B		SA-524 Grade 1	SA-210 Grade C	
	SA-283 Grade A	Grade II	. 30-210 0:00: 0	"SA-660 Grade WCB
	Grade B			Grade WCC
SA-106 Grade A	Grade C	SA-556 Grade A2	SA-216 Grade WCB	
Grade B	Grade D	Grade B2	Grade WCC	SA-662 Grade C
			Grade mod	
SA-134	SA-285 Grade A	SA-557 Grade A	SA-234 Marking WPC	SA-671 Grade CB70
	Grade B		SA-234 Marking Hrv	Grade CC70
SA-135 Grade A	Grade C	Grade B	SA-266 Class 2	Grade CD70
			Class 4	Grade CK75
Grade 8	SA-333 Grade 1		Citiss 4	
		SA-587		SA-672 Grade 870
	Grade 6	10.00	£4.100	Grade C70
SA-155 Grade 745		SA-660 Grade WCA	SA-299	Grade D70
		-	SA-350 Grade LF2	Grade N75
SA-155 Grade C50	SA-334 Grade 1	SA-662 Grade A	SA-350 Grade LF2	
Grade C55	20.000.000.0	Grade B	SA-352 Grade LCC	SA-675 Grade 70
Grade KC55	Grade 6		SA-352 Grade LCC	
Grade KCF55		SA-671 Grade CA55	6	SA-691 Grade CMSH-70
		Grade CE55	SA-372 Type II	The second secon
SA-155 Grade KC60	SA-350 Grade LF1		** ****	Grade CMS-75
Grade KCF60	an-330 diage Er I	SA-671 Grade CB60	SA-414 Grade F	
Grade KC65	SA-352 Grade LCA	Grade CC60	Grade G	
Grade KCF65	Grade LCB	Grade CE60		SA-695 Type B Grade 40
7.00	Grade CCO	Grade CB65	SA-420 Grade WPL6	***************************************
SA-178 Grade A	SA-369 Grade FPA	Grade CC65		SA-696 Grade C
Grade C	SW-307 GIRUT FFM		SA-455 Type I	
	SA-372 Type 1	SA-672 Grade A45	Type II	SA-737 Grade B
SA-179	3M-3/2 ()pe (	ald and all delice in the		
***************************************	SA-414 Grade A	SA-672 Grade A50	SA-487 Class AQ	SA-738
	Grade B	Grade A55	Class D and Dir	***************************************
SA-181 Class 60	Grade C	Grade 855	Class C and CN	Dr. Marson St.
	Grade D	Grade C55	** *** *	SA-487 Class BQ
SA-192	Grade E	Grade E35	SA-500 Class 1	Class CQ
	Grade C		Class 1A	
SA-210 Grade A-1	SA-420 Grade WPL6		** *** ***	SA-537 Class 2
	Switch diege Marie	SA-672 Grade B60	SA-515 Grade 70	
SA-214	SA-442 Grade 55	Grade C60		SA-671 Grade CD80
		Grade E60	SA-516 Grade 70	
	Grade 60	Grade 865		SA-672 Grade D80
SA-216 Grade WCA		Grade C65		
SW-ETG GLEGE ALCV	SA-487 Class A and AN			SA-691 Grade CMSH-80
SA-226		SA-675 Grade 45		
		Grade 50		
		Grade 55		SA-737 Grade C
		Grade 60		
		Grade 65		
		SA-695 Type B Grade 35		SA-724 Grade A (% in.
				max. T)
		SA-696 Grade B		Grade B (% in.
				max, T)

SA-727 .

# Appendix D: Short Circuiting Transfer

Short circuiting transfer is a type of metal transfer in gas metal arc welding in which melted material from a consumable electrode is deposited during repeated short circuits. For additional information, see Section 2 of the Sixth Edition of the WELDING HANDBOOK, page 23.24.

Typical current ranges for short circuiting transfer gas metal arc welding of steel

		Weld	ling current, Ampere	5*			
Electrode diam		Flat position		Vertical and overhead positions			
	11.1	min	max	min	max		
in. mm 0.030 0.8 0.035 0.9 0.045 1.2		50 75 100	150 175 225	50 75 100	125 150 175		

^{*}Electrode positive.

File: SH P-1/2

QA/QC Harris Plant Personnel Training

Date: 4/5/84
Training Period: 3.00 - 4 4/105
Class Title: Non-Con for man = Control
Procedure and Revision: CQA-3 Rev-3
summary: Explained entire procedure - Discussed with inspector
how won conformance flow works - Discussed recent
revision changes - defined subordinate Num conformance
The following personnel attended the above described training: (Print name, followed by signature.)
11- //-
Jim Storey Im Clay
Gerald W. GLASS Shull Willand
Rex Green indicate auni
Steven & Rake Stewn R. Thake
Jerry Smith Juny Smith
Douglas M. Brown Phuslas M. Burney
Steven T. Russell Heatheril
MIKE STEPHENS MIL ROLL.

Note: Procedure revisions must be recorded before gransmitting to CA Records.

Instructor: Nie 3

018000

File: SH P-1/2

QA/QC Harris Plant

Personnel Training

Date: 4/3/84
Training Period: 3:30 /n 4 4:50 /at
Class Title: 45 4 GET 17.5 Res-+ * see Summary
Procedure and Revision: QCI-19.5 Rev-1
Summary:
* Identification and documentation of base metal
deficiencies outside of the weld aren of interest,
Procedure defined the "aven of interest" and what
to do when indications are * solishy discovered:
1) Asno Sect. III class 1, 2, 3, and mc items
Asme sect VIII tanks i vessels
Flasco Catagory 455 mainsteam & Fredwater systems
Radwaste and fire protection systems
Quel Pool Liner Plates
2) Scismic Class I items
The following personnel attended the above described training:
(Print rame, followed by signature.)
PKK Grason Dal Roman - AJAMES Workers OR WOLLD
Sherman Cotham Shemon Coham Mark Stouts June This
Gerald W. GLASS Hull W. Hless KM KENYON & In Leun
MIKE Stephens Mit Alas
Steven R. Ruhe Steven R. Boly
JERRY Smith Aug Smith
Stevent Russell Harring
Dong'sell Prouse Donglas MI Brank
CABL WEAST CAN WORK
Note: Procedure revisions must be recorded before transmitting to CA Records.

LTTE: DU L-1/5

# QA/QC Harris Plant

Personnel Training

	129/84		11:0000	
raining Pér	10d: 3,30 F	m to	4:00 PM	Idan to
rocedure an	Repair of and Revision:	MP-10	Per 1 - 11	(cemen) 3
ummary:		411 /0 /		
	See' Attach	-1 0	+1.10	
	see Affair	ea ou	INE	
Carlo Park Inc.				
he followin	g personnel attended t	the above desc	cribed training	
Print name,	followed by signature	•.)		
JERRY UN	with Finy mut	£		
Serold W.	GLASS Sullastle	u.		
	Russell HenRun	11		
	-			
teren R.	11 11			
Km Keny	ON Km hou	2/		
Jim Sta	over 1 Im Store	<u> </u>		1873.14
Pick GAR	RISON X	/ .		
	Brown Dondas M.	P.		
Man Of	to 2 Mongas III.	In milk		
Mark Pto	uts mul I four			
Note: Proce	edure revisions must b	e recorded be	efore transmitt	ing to CA Record
			1000 AIL	

March 30, 1984

MEMORANDUM TO: R. Hanford

FROM: D. Timberlake

SUBJECT: MP-10 Rev. 11 Training Class (Structural Welding)

On March 29, 1984, I conducted a 1/2 hour training class on the above subject for QC-Welding personnel. Attached is a copy of the training outline and attendance sheet.

Did sall

DRT: cag

cc: Mr. P. Foscolo (w/o att)

Mr. W. Mercer (w/att)

Mr. M. Taylor (w/att)

Met./Welding File T-4d (w/att)

## MP-10 Rev. 11 Training Class (Structural Welding)

## I. General (Repairs)

- A. RSWDR's are required for:
  - 1. Rejectable indications detected by MT, PT, UT and RT
  - 2. Base metal repairs
- B. Any weld defects that are detected visually or by info NDE DO NOT REQUIRE AN RSWDR. This is considered in-process welding.
- C. After the repair is completed the repaired area shall be examined by the same method used to detect the original defect and by additional NDE as required.

## II. Repairs made on Seismic I Structures

- A. Repair welding of base metal defects
  - 1. Visual inspection of area prior to welding is required
  - 2. Flame cut edges
    - a. Notches and gauges
    - Internal Discontinuities
       Table A for acceptance limits
- B. Repair of weld metal defects
- C. Repair of misdrilled holes

# DANIEL CONSTRUCTION COMPANY SHEARON HARRIS NUCLEAR POWER PLANT

### TRAINING RECORD

DATE MARCH 29, 1984 TIME 3:30 P LENGTH OF CLA	SS T HOUR
COURSE & TITLE MP-10 REPAR OF BASE MATERIALS	MO WOLDMONTS (STRUCK
INSTRUCTOR DAVID TIMBERLAKE	SHIFT
PERSONS IN ATTENDANCE	
NAME	BADGE NO.
1. TOM ASHIEY Ofom lichly	254
2. G. Hort A. Do Barros Gellit A. Dobres	113
3. Robert L Phumler Robert L. Rumley	486
4. CHRISTOPHERM CASE Mustopher Max	107
5. JERRY O. TRAMMELL Jerry D. Frammell	576
6. Melvin Corepenter Melan Cargita	85
7. Thomas B. LEMBO Lond Lalo	124
8. Stever M Douglas Str M. Dangle	//5
9. Sand Dowell Lavel Dowell	573
10. TELLO ANGGLINA TELLO Cenceline	262
11. HROLD L. POSTANT Hould'S Dinest	159
12. Mula ORB Michael Royd	823
13. KM KENTON KM Kom	400
14. ALLEONARD and some	144
15. Mark Pfouts mul Pfoute	452
16. Stevent Bussell Her Bussell	502
17. Steven R. Rahe Thun To Take	451
18. JERRY A. Snith Juny Smith	450
19- Jin Storey Jan Story	177
20. Jahr CADDEN John Colle	364
21. Gerali W. GLASS Studie W. Slass	3002

# QA/QC Harris Plant Personnel Training

Date: March 27,1984
Training Period: 3130 pm +ill 4'00 pm
Class Title: miscellaneous theil Fatrication
Procedure and Revision: WP-18 Rev. 15
Summary: Llass consisted of proper application and
Filling out of the MP-18 form Acr. 9. What OA/AC
should be aware of concerning the amount of information
that is needed on the form and who is responsible for
initiating, ruleusing, and review of the WP-12. Also how
the form relates with attached documents such as
drawings, QA-37 Forms, and SWDB's.
The following personnel attended the above described training:
(Print name, followed by signature.)
SARL WEAST Nor Monthsont Jeery Crith Genjatante
Red GARRISON ISE - Shermin Cotton Delinen Cotto
Mark Pfouts mail Pfour
11 8
A. James Wark v3 af wall
MIKE Stephen Mater Acolo
1 1 1 - 60
Stevent Rissell thentensel
KEVIN M. KENYON K TH Komm
Davides M. Brown Douglas M. Brown
Total Contract Contract

Note: Procedure revisions must be recorded before transmitting to 24 Records.

Instructor: Etun 2. Rahe Steen & Rahe

# QA/QC Harris Flant Personnel Training

Date: 3/22/84 Training Period: 3:	30 Pm to 4;	00Pm	
Class Title: NOE Req	urrements for Se	lignic Pipe H	inges and Structural.
Procedure and Revision:	Site Spec.	- 034	RW-12
Summary:	Conference of the	Property of the second	
	jerovenia uzomiti.	titististis et ale	
The of a man of the first of	AND LINE SOFT AND	the side of the same of	
	Committee of		
		1	
See	attaches	t outly	ve.
	<b>4</b> /2		
	· 10- 10-	este a transfer	
	THE RESERVE OF THE PERSON NAMED IN COLUMN 2 IS NOT THE PERSON NAME	Strate Constitution	
	· West	entered to the second	
The following personnel at	tended the above	described tra	ining:
(Print name, followed by s	ignature.)	/	000
Tin Storey Um	Plon	Joseph J.	Zysk Myna
Mark Prouts mul 7	81	og men a mendy-max salam men	T X D
		erlike Stee	hows Mix State
Steven Rahe Sum	7. Fale		
Matt Brown Matt	Brown or		
- 11 01 -	NO. 10		
Steven Russel Min	Janey		
Pick Greenin 12	Com		
Gerald W. GLASS Du	Maddley		
( )	14		
JERRY Smith guy	1 Ometho		
James Warkins to	un file		
Note: Procedure revisions	must be record	2 .	
	Instruct	or: 12-30	1111



Company Correspondence

March 26, 1984

MEMORANDUM TO: Ray Hanford

FROM: David Timberlake

SUBJECT: Site Spec. 034 Training Class

On Thursday, March 22, 1984 I conducted a 1 hour training class on the requirements of Site Spec. 034 Rev. 12 relative to structural and hanger welding for QC inspection personnel. Attached is an outline and attendance sheet for this class. the rull

DRT: cag

c: Mr. P. Foscolo (w/o att.)

Mr. M. Taylor (w/att.)

Met./Welding File T4-d (w/att.)

# SITE SPEC. 034 REV. 12 TRAINING CLASS

I PIPE HANGERS

A-NDE IN ACCORDANCE WITH TABLE 1 ( ZOMY

ATTACHED) FOR SEISMIC I HANGERS

SUPPORTING ASME CLASS 1, 2 AND 3 PIPE


B-NOE IN ACCORDANCE WITH TABLE 3 (LOFY
ATTACHED) FOR SEISMIC I HAMINGLE SUPPORTING
CATEGORY 4-8 PIPE

II. STRUCTURAL STEEL

A- NOE IN ACCORDANCE WITH TABLE 4 ( rory

ATTACHED)

B- DOUBLE INCLOSED TOL JOINS



TIT. PIPE RESTRAINTS / LARGE FRAMES (EXHIBIT NO. 1)

A-BERGEN - PATERSON CONTRACTS - NOE PER

SITE SPEC 034 TABLES 183 (AS APPLICABLE)

B-PBI (ET AL.) CONTICACIO - 1/CE 1-CT SITE
SECO 034 TABLE -

# EXHIBIT No. 1

CODE (AWS DI.I)

Language

Total

Table 1 & 3.

Total

Tot

51+c5,034

Time 4 Size Spi 034

......

____

. . . . .

----



A. Carbon Steels (Cont'd)	CLAS	THE THE	RT	PT	нт	UT	VT	NOTES	ACCEPTANCE CRITERIA
6. Pipe Hangers								10100	CRITERIA
	1	-	1000	_	-				AWS D1.1
a. Full Penetration	2	-	1002	-			1002	2.6.9	Per Ref. 2.14, 9.25
Butt Welds	3	1		-			1002	2,9	Per Ref. 2.14, 5.25.
b. Full Penetration Tee	1	1			-		1002	2,9	Per Ref. 2.14, 9.25.
Welds	1,2,3						1002	9	
	1	Throath			1002		100%		Per Ref. 2.14, 9.25.
c. Partial Penetration and Fillet Welds	1	Zi inch Thtoat			(Fillete only)			2,7	Per Ref. 2.14, 9.25.
Fillet welds	2	MISSE		-		-	100%		Per Ref. 2.14
	3						100%		Per Ref. 2.14
							100%		Per Ref. 2.14
									Property of the second
			. erlet	2000					
					-				
			-						
			-	-					
		-	-						
	-		-						
	-+		_						
			_						
			_						
	-		_						
						•			
,									

# NDE AND VISUAL INSPECTION SPECIFICATION

#### Notes for Table 1

- For either PT or MT, the external and accessible internal weld surfaces and adjacent base metal for at least 1/2 inch on each side of the weld shall be 100% examined.
- PT is an acceptable alternate in lieu of MT. PT should be used on nominal pipe sizes 2 inches and less.

RIO

- Acceptance criteria for material adjacent to the weld shall be per NB-2500.
- Acceptance standards for material adjacent to the welds shall be per NC-2500.
- Acceptance standards for materials adjacent to the welds shall be per ND-2500.
- All full penetration butt joints in members designed to carry loads under any postulated load condition (primary members) shall be radiographed.
- 7. All fillet welds in members designed to carry loads under any postulated load condition (primary members) that have a throat dimension greater than 1 inch shall be examined by either the magentic particle or liquid penetrant method.
- Applicable acceptance criteria.
- 9. Full penetration open butt weld joints shall receive a root pass inspection by either magnetic particle or liquid penetrant inspection when welded using the SMAW process. Full penetration open butt weld joints welded using the GTAW process for the root pass shall not require any root NDE.
- 10. ASME Code Case N-127(1755-1) (Reference 2.13) is invoked for alternate NDE requirements on those tube welds where automated welding machines are employed and the nominal tube size does not exceed 2 inches and the thickness does not exceed 0.20 inches.

RIO

	SYSTEMS/COMPONENTS/ITEMS	Cat. Pipe	THK.	RT	PT	нт	UT	VT	NOTES	CRITERIA
١.	Carbon Steel								3	B31.1 (Nonboil external pipir
	Fillet and Socket Welds	4	all			120%		1002	1	DATE STREET
		5	all					100%	Marie .	
_		6, 7, 8	all					100%		- V
4.	Pipe Hangers Partial and Full Penetration Butt Welds and Fillet Welds	4	all					100%		Per Ref. 2.14
		5	all					100%		
_		6, 7, 8	all					100%		1/
	Stud Welds	4.5.6.7.	8 All					100%		B31-1 (Non-Bo1
_				TITLE			Ref grade			External Pipin
	Structural Attachment Welds	4	all				reate	100%		
	between metaciment werds	5	all					100%		
-	· · · · · · · · · · · · · · · · · · ·	6,7,8	all				l en	100%		V
		-								
		-		-						

# NDE AND VISUAL INSPECTION SPECIFICATION

# Notes for Tables 2 and 3

- 1. PT is an acceptable alternate in lieu of MT.
- For lube oil pipe other than that governed by Westinghouse Specification requirements, a visual inspection only is required. (An example is lube oil pipe supplied by Southwest Fabricators.)
- 3. For Category 4 through 8, base metal defects shall be evaluated per the base metal specification, not by the requirements for the weld. For base metal quality requirements, refer to Purchase Order and applicable ASTM or ASME Material Specification when evaluating defects (cracks or linear indications only to be evaluated) located more than 1/4" from the toe of the weld. Any cracks or linear indications which exceed 1/16" in length and which are located within 1/4" of the toe of the weld shall be repaired.

R12

TABLE 4
SUMMARY OF NDE INSPECTION REQUIREMENTS
STRUCTURAL STEEL (SEISMIC CLASS 1 AND NONSEISMIC)

	RT	PT	ти	UT	VT	NOTES	ACCEPTANCE CRITERIA
Butt Welds Full Penetrations	Note 5 100%			1	100%	1	Per Reference 2.
Partial Penetrations				!	100%	1	AWS D1.1 9.25.2
Tee Welds			1002	Note 5 1002	1002	1,2,4	Per Ref. 2.14
Partial Penetrations					1002	1	AWS D1.1 9.25.2 and 9.25.3
Fillet Welds		See Note 3	See Note 3		100%	1,3	Per Ref. 2.14 AWS D1.1 9.25.2
Stud Welds							AWS D1.1, para. 4.30 for shear connectors
Cable Tray and Supports - Conduit Hangers - Fillet Welds					1002	1	Per Reference 2.1
leating, Ventilating & Air Condition-				,	1002	1	Per Reference 2.1

#### TABLE 4

# NDE AND VISUAL INSPECTION SPECIFICATION

#### Notes to Table 4

- Peening of welds is prohibited on Seismic Class 1. Peening of root and final pass is prohibited on nonseismic structural welds.
- 100% MT or PT (if MT is not practical) of root pass and final weld layers.
- Where noted on design drawings, filler welds will be either MT or PT inspected.
- The root inspection for double-welded joints shall be performed after back gouging.
- For Seismic Class 1 only except when drawing explicitly deletes this requirement.

KL

#### DANIEL CONSTRUCTION COMPANY

### SHEARCH HARRIS MUCLEAR POWER PLANT

#### TRAINING RECORD

TATALIO RECOLD	
DATE 3-22-84 TIME 3:30- LENGTH OF	CLASS
COURSE & TITLE SITE SPEC. 034 REV. 12	
INSTRUCTOR DAVID TIMBERLAKE	SHIFT 1 ST 4 Z ND
PERSONS IN ATTENDANCE	
NAME	BADGE NO.
1. P. acott	3015
2. I Watk. NS low Trect	3024
3. Robert L. Alumber Robert I llumber	486
4. Tom Ashley Ofom leaking	572
5.5 Douglas Ste M Daugla	115
6. AL LEONARD Q'Y Remaid	144
7. Shanow Gibson Shapor Gibson	129
8. Melvin Conserter Melin Carpenter	85
9. HOROLD O'SSINT Was WX O'Sunt	159
10. Thomas B. Lombo Moner & Londo	724
11. David Dove // David Dowell	573
12. Marka PRoge Michael R Boyd	823
13. Rek 5 Garrison Dekami	453
14. Gerald W. GLASS Qualit W & loss	3002
15. JERRY SMITH Jung Smith	450
16 Toseph J. Zysk JE Doych	362
17. MIKE Stephers Mil Stych	1271
18. In Storey Jan Story	177
19. Mark Prouts man Plant	452
20. Steven R. Raha Thum n. Rahe	451
21. Dangles M. Boren Donato M. Rioux	86

### PERSONS IN ATTENDANCE

	NAME •		BADGE NO.	
22.	Steven T Bussell	Herolly	self 502	
23				
25				
30				
31				
32				
33				
34				
35				t the July
36				The same same
37				
39				
44				
45				
46				
.7				
.8.				

# QA/QC Harris Flant Personnel Training

Date: March 20 84	
Training Feriod: 230 250	2 801
Class Title: Q.C.Y- (c.	3. Cented of A.36 Steel Stamps
Procedure and Revision: (2.C.	7 6.3. Rev. 3
Summary: River of Du	upos scape general and Intent
Covering design of A-3	storp and control and receipt
consolia.	
The following personnel attended	the above described training:
(Print name, followed by signatur	'e.)
Exx 5 mensor De Stan	and the skind of the state of
Jense Rhide in Dane	
Jim Storey Jan Mar	us
KNIKENYON Ken fens	1
Stere & Robe tun 7 Test	
Not Preuin Mott Brown	
Gerald W.GLASS Dustilles	the
TORPHIZYSK ORGAN	
Mark Prouts Mark Pfores	
Note: Encoders	
Note: Frocedure revisions must b	
	Instructor: Michael Len Stophens

# QA/QC Harris Plant Personnel Training

Date: 3-14-84	
Training Period: 3145 to 475	
Class Title: Weld Control	
Procedure and Revision: CQ. (	
Summary: Reining of Cac 19	descurre duties of an ac
summary: Revaus of Cac 19	with Sumi (AA-24) inspections
- 0 0	
The following personnel attended the abov (Print name, followed by signature.)  Steven R Rohr Llun Th. Thake  Mirk Stouts Brank Short  Joseph J. Zysk Solve	0 1 - /
Tim HANKINS Smith	
Jin Storey In Story	
KM KENYON KANGER	
JERRY SMITH Jung Vmito	
Dagles Abthen Brown Longhol M. Porch	
Note: Procedure revisions must be record	ded before transmitting to CA Records.
Instruct	tor: Michael Lin Stephens

QA/QC Harris Plant Personnel Training

Date: 3-8-84
Training Period: 3:30pm - 4:00pm
Class Title: QA-37 RW 3 NDE Documentetion
Procedure and Revision: OA 59 Rev. 3
summary: Completion of QA-37 / Nondestructive
Examination Request) correctly
The following personnel attended the above described training: (Print name, followed by signature.)
0.0.14-
JERRY Smith Juny Smith nork Hors much Popul
Donno Sanda Barrillands Rick GARRISON DE
MATT Brown Watt Brown
Steven Russell Han Russel
13-44 Kann K.M KENTON
MIKE Stophows Mikes & stephon
Jagan J. Zin Boly
In storey Jam Story
/ //
Strenk Rahe Steen R. Flesh

Note: Procedure revisions must be recorded before transmitting to IA Records.

Instructor: Lugs. Brown

# CORPORATE QA/QC SECTION PERSONNEL TRAINING

Instructor: Douglas M Brown	Date: 3-6-84
Training Period: 4:00 - 4:15	
Class Title: CQC-7	
(General Topics) I. Marking \$ 7	Aggins
(Specific Topics) A. Materials	
. B. Identification	nasking Control
c. Marking Typ	=5
II. Tagging - TA	g Types & Labels
A	' /'
B	
c	
III.	
Α	
. Б.	
c	
The sollowing personnel accended one a	
Matt Brown MATT Brown (Instructor)	Jerry Rhodes & Ploal
Sherman Cotham Kanen Cohan	Stever Russell And Currell
Kevin Kenyon Manager	Don Sands Sand Souls
Rick Garrison	Jerry Smith Juny Junto
Cameron Lucas	Mike Stephens Mike Atephan
Ward Mercer	Jim Storey
Mark Pfouts Fresh Pfort	Carl Whatley
Steve Rane Steam 2. Role	Carl Weast G f ( Sont
Tim HANKIN'S Jankar	uctor: Douder M Brown

# CORPORATE CA/OC SECTION PERSONNEL TRAINING

Instructor: KEVIN M. K	ENYON . Date: 2/29/84	
Training Period: 2/29	/84	
Class Title: SITE SPEC	033- STRUCTURAL WELDING FOR PERMANENT PLANT CONSTRUCTION	
(General Topics) I.	SCOPE AND GENERAL SECTION	
(Specific Topics) A.	DEFINITIONS	
, B.	SYMBOLS	
c	CODES AND STANDARDS	
II. DETAILED WELDING REQUIREMENTS		
Α.	WELDING QUALIFICATIONS & WELDING PROCESSES	
В.	FILLER METALS, FIELD DRAWINGS, AND WELDING REQUIREMENTS	
с.	CONTROL OF PREHEAT & INTERPASS TEMP., PWHT, AND REPAIRS	
	QUALITY ASSURANCE	
<b>A.</b> _	SEISMIC CLASS1 RECORDS	
ъ.		
The tollowing personnel	attended the above described training:	
Matt Brown Act Show	Jerry Rhodes In Phoel	
Sherman Cotham Shanen	Chen StevenRussell Hand Surell	
Kevin Kenyon See Be	low Don Sands N/A	
Rick Garrison	Saure Jerry Smith This Country	
Cameron Lucas NA	Mike Stephens Mike. Hechoma	
Ward Mercer N/94	Jim Storey N/A	
Mark Prouts grad Pla	carl Whatley of Chiller	
Steve Rahe Run 2	Role Carl Weast Con Wood	
in HANKINS A.	will Val	

# QA/QC Harris Plant

Personnel Training

Training Period: 3:30 Pm to	
	THE RESERVE THE PROPERTY OF TH
Class Title: Basics of Nuc	lear rower
Procedure and Revision:	
Summary:	
The instructor gave	a brief synopsis of the.
"Powe Train" of a Pressuriz	
elaborated somewhat on how	
	internals, control and drive mechanism.
	generators (and how they are put
together), and her it ultimate	
/ .	He then explained the nethed
	Nuclear fuel is handled (ie;
loading and unlanding from	the season vessel so
No. 6-33	
he following personnel attended the at Print name, followed by signature.)	pove described training:
Print name, followed by signature.)	pove described training:
Jerry Swith gruy Swith	DONALD GAING Spaces Udans
Print name, followed by signature.)	DONALD SAINS Special donds
Jerry Swith gray Smith  Jerry Rhodes Jay Marky	DONALD SAINS Special donds
Jerry Smith gray Smith  Jerry Rhodes Jay Rhodes  Matt Brown Matt Brown	DONALD SAINS Special donds
Jerry Smith gray Smith  Jerry Rhodes Jay Block  Matt Brown  KM Kenten KM Kenten	DONALD SAINS Secold don's  MINE STEPHEN Mile Stephens  AND ARONS Sin Stephens  Tim Arons Sin Signed
Jerry Swith gray Justs  Jerry Rhodes Jay Bally  Mott Brown Matt Brown  K.M. Kenten K.M. Eng.	DONALD SAINS Secret Souls
Jerry Smith gray Smith  Jerry Smith gray Smith  Jerry Rhodes Jay Rhode  Matt Brown  KM Kenton KM Kong  M. Houts mal Hour	DONALD SAINS Secold don's  MINE STEPHEN Mile Stephens  AND ARONS Sin Stephens  Tim Arons Sin Signed
Jerry Smith gruy Juito  Jerry Rhodes Jet Room  Matt Brown  KM Kenten KM Kong  M. Houts Mal Hour  CK GARRISON Jet au	DONALD SAINS Secold don's  MINE STEPHEN Mile Stephens  AND ARONS Sin Stephens  Tim Arons Sin Signed
Jerry Smith gray Smith  Jerry Smith gray Smith  Jerry Rhodes Jah Brown  Matt Brown  Matt Brown  M. Houts mul Hour  Sex Grerison Decan  Stevent Finssell Store	DONALD SAINS Secold don's  MINE STEPHEN Mile Stephens  AND ARONS Sin Stephens  Tim Arons Sin Signed
Matt Brown Matt Brown  Matt Brown  M. Menten H m Horn  M. Houts mul Hour  Cake Greenson Delan  Stevent Finsell Stevely  Steven R. Raha Mun J. Role	DONALD SAINS Secold don's  MINE STEPHEN Mile Stephens  AND ARONS Sin Stephens  Tim Arons Sin Signed
Jerry Smith gray Junto  Jerry Smith gray Junto  Jerry Rhode Jay Brown  Matt Brown  Matt Brown  M. Houts mul Hour  Stevent Fussell Stevent  Stevent Fussell Stevent  Stevent R. Rahe Steven R. Rale	DONALD GAINS Secret don's  MINE STEEDERS Mile Stephens  AND ARONS Sin Stephens  Tim Arons Sin Sign Sign Sign Sign Sign Sign Sign
Jerry Smith gray Smith  Jerry Smith gray Smith  Jerry Rhode Jay Brown  Matt Brown  Matt Brown  M. Monton  M. M	DONALD GAINS SECULIANS  MILE STEPHENS MILE Stephens  AND ARON'S Sin Stephens  S. A. Storen Jun About

# CORPORATE QA/QC SECTION PERSONNEL TRAINING

Training Period: 300 Pm 315 Pm  Class Title: MPNR FAMR DF WURC DUCT 50  (General Topics) I. X FAMR  (Specific Topics) A. SCOPE-  C. FIT-UP  II. CLEMNING  A. GRINDING  B.
(Specific Topics) A. SCOPE.  (Specific Topics) A. SCOPE.  (B. PROCEDURE  C. FIT-UP  II. CLEMNING  A. GRINDING
(Specific Topics) A. SCOPE.  (Specific Topics) A. SCOPE.  (B. PROCEDURE  C. FIT-UP  II. CLEMNING  A. GRINDING
II. CLEMNING  A. GRINDING
II. CLEANING A. GRINDING
II. CLEANING A. GRINDING
A. Glinding
A. Glinding
c.
III. WED PROFIES
A. SHIEDING
B. COPTINGS
c. DEVIRKONS
The collowing personnel attended the above described training.
Matt Brown Max Brown Jerry Rhodes On Phoale
Sherman Cotham MA Steven Russell Sussell
Kevin Kenyon N/A Don Sands Schands
Rick Garrison is Comment Jerry Smith Juny Vonto
Cameron Lucas NA Mike Stephens NA
Ward Mercer N/4 Jim Storey N/4
Mark Pfouts Mail Ofour Carl Whatley N/A
Steve Rahe N/A Carl Weast N/A
Im Hadkins Instructor

# CORPORATE CA/OC SECTION PERSONNEL TRAINING

Instructor:	FASIM SHAIKH	Date: 2/16/84
	1 HR.	
Class Title:	QUALIFICATION O	A MUDER & WIRDING APPRATORS
(General Topics)	I	
(Specific Topics)	A	
	B. 9,0	
	c. 0	هور
1	II	•
	A	
	в	
	c	
11	ī	
	A	
	В.	
	C	
		we described training.
Matt Brown Mall	Bow	Jerry Rhodes Jan Pholle
Sherman Cotham	WA	Steven Russell Azar Rusell
Kevin Kenyon	mount	Don Şands N/A
Rick Garrison		Jerry Smith Juny Omto
Cameron Lucas	Eliado for	_Mike Stephens Mike Stephens
Ward Mercer	MA	Jim Storey N/A
Mark Pfouts mail	Pfort	Carl Whatley (ex) father.
Steve Rahe Klum	2 Rah	Carl Weast
I'M HANKINS	Gen No	sor: Fail Ala !!



Company Correspondence

February 7, 1984

WE-754

MEMORANDUM TO: R. Hanford/G. Forehand

FROM: F. Shaikh

SUBJECT: Training of Q.C. Inspectors on Qualification of Welding

Procedures and Welders

# A. Welding Procedure Qualification

Welding procedures and brazing procedures used for the SHNPP code work are qualified inaccordance with applicable site specification. The two most used codes are ASME Section IX and AWS D1.1. Section IX is utilized for piping category 1 thru 8. AWS D1.1 code is employed for structural welding and hangers.

Carolina Power & Light Co. is the Nuclear Stamp holder hence all the welding procedures are qualified by CP&L personnel. Discipline Engineer, Metallurgy/Welding is responsible for qualifying all welding procedures for SHNPP and all other ruclear power plancs.

- Welding procedure specification (WPS) is a written document prepared to provide direction to the welder while making production welds. A welding procedure specification (WPS) describes in detail all of the variables which are essential, supplementary essential, and non-essential variable to the welding process. Details of actual welding procedure specification test requirements are given in general welding procedure, MP-01.
- Procedure Qualification: The act of qualifying a welding procedure specification by actual welding of test coupons, the testing of specimens as required by the code, and the recording of the welding data and test results in a document called Procedure Qualification Record (PQR).

### 4. Procedure Qualification Record POR

This form documents the essential variables of the specific welding process and actual variables such as amps, volts, preheat, etc. are recorded along with the test results of tensile tests, bend tests, impact tests as applicable.

### 5. Groove Weld & Fillet Welds

The groove weld tests qualifies the WPS for use with groove welds within the range of essential variables. Groove weld test shall also qualify for use with fillet welds in all thicknesses of metal, sizes of fillet welds and diameters of pipe within other essential variables.

#### 6. Stud Welding

Our stud welding procedure is not qualified to ASME Section IX.

### B. Welding Performance Qualification

 All welders including tack welders are qualified by CP&L inaccordance with general welding procedure MP-02.

The welder qualification is limited by the essential variables given for each process.

#### 2. Tests

The performance qualification test are intended to determine the ability of welders and welding operators to make sound welds.

Each company is required to qualify each welder for each welding process to be used in production welding.

Performance qualification is performed inaccordance with one of the qualified welding procedure. When performance qualification is done inaccordance with a WPS that requires post weld heat treatment, this post weld heat treatment is not required for welder qualification.

### 3. Renewal of Qualification

The performance qualification of a welder is affected under the following conditions:

- (a) When the welder has not welded with a process during a period of 3 months or more, his qualification for that process will be expired; except when he is welding with another process, the period is extended once to 6 months.
  - (b) When he has not welded with any process during a period of 3 months, all his/her qualifications will be expired.
  - (c) When there is a specific reason to question welder's ability to

Fail Stall

# 4. Welder's Qualification Status Report

Welder qualification status report is published every two weeks which lists all the welders who are qualified to weld on a WPS. The limitations of the welder qualification such as diameter, thickness range etc. is shown on the status report. A cross qualification of the welder qualification is also attached with the status report. Status report will be discussed in detail.

FAS: cag

# CORPORATE CA/CC SECTION

PERSONNEL TRAINING

Instructor:	Joney with Date: 2-14-84
Training Period:	3/30 to 4:00 PM
	ention criteria CAR-2165-ADO3 A/4
(General Topics) I.	- Scope
(Specific Topics) A.	
, в.	
c.	
II.	Acceptance criteria
Α.	
В.	
c.	
III.	
Α.	
В.	
c.	
The following personne	el attended the above described training.
Matt Brown	A Terry Rhades Cay Males
Sherman Cotham	Steven Russell Haren Blassell
Kevin Kenyon	Bores Don Sands N/A
Rick Garrison	Jerry Smith MA
Cameron Lucas	Mike Stephens Min XIII
Ward Mercer MA	Jim Storey Om Jon
Mark Pfouts Freel P	Carl Whatley NA
Steve Rahe	Carl Weast
Jim HAKINS &	Instructor: Jany Smith

# CORPORATE QA/QC SECTION PERSONNEL TRAINING

Instructor: tash	Shaikh . Date: 2/9/84
Training Period:	3:30 Pm to 4:20 Pm
Class Title: <u>Wel</u>	d Procedure Specifications
(General Topics) I.	See attached outline
(Specific Topics) A.	
, в.	
II	
Α.	
B	
c.	
III	
A	
ъ.	
c	
The rollowing personnel	attended the above described training:
Matt Brown Matt Brown	on rein Rhodes my Phopler
Sherman Cotham	
Kevin Kenyon	Don Sands W/A
Rick Garrison	Jerry Smith Juny Dunth
Cameron Lucas	A Mike Stephens Mike Stychen
Ward Mercer . W/	A Jim Storey Con Store
Mark Pfouts . N/	Carl Whatley Calestin
Steve Rahe Thum Th.	Roh Carl Weast INIA
JIM HAN	Kins Instructor: Sail Stall



Company Correspondence

February 7, 1984

WE-754

MEMORANDUM TO: R. Hanford/G. Forehand

FROM: F. Shaikh

SUBJECT: Training of Q.C. Inspectors on Qualification of Welding

Procedures and Welders

# A. Welding Procedure Qualification

Welding procedures and brazing procedures used for the SHNPP code work are qualified inaccordance with applicable site specification. The two most used codes are ASME Section IX and AWS D1.1. Section IX is utilized for piping category 1 thru 8. AWS D1.1 code is employed for structural welding and hangers.

Carolina Power & Light Co. is the Nuclear Stamp holder hence all the welding procedures are qualified by CP&L personnel. Discipline Engineer, Metallurgy/Welding is responsible for qualifying all welding procedures for SHNPP and all other nuclear power piants.

- 2. Welding procedure specification (WPS) is a written document prepared to provide direction to the welder while making production welds. A welding procedure specification (WPS) describes in detail all of the variables which are essential, supplementary essential, and non-essential variable to the welding process. Details of actual welding procedure specification test requirements are given in general welding procedure, MP-01.
- 3. Procedure Qualification: The act of qualifying a welding procedure specification by actual welding of test coupons, the testing of specimens as required by the code, and the recording of the welding data and test results in a document called Procedure Qualification Record (PQR).

# 4. Procedure Qualification Record PQR

This form documents the essential variables of the specific welding process and actual variables such as amps, volts, proheat, etc. are recorded along with the test results of tensile tests, bend tests, impact tests as applicable.

### 5. Groove Weld & Fillet Welds

The groove weld tests qualifies the WPS for use with groove welds within the range of essential variables. Groove weld test shall also qualify for use with fillet welds in all thicknesses of metal, sizes of fillet welds and diameters of pipe within other essential variables.

### 6. Stud Welding

Our stud welding procedure is not qualified to ASME Section IX.

### B. Welding Performance Qualification

- All welders including tack welders are qualified by CP&L inaccordance with general welding procedure MP-02.
- The welder qualification is limited by the essential variables given for each process.

#### . 2. Tests

The performance qualification test are intended to determine the ability of welders and welding operators to make sound welds.

Each company is required to qualify each welder for each welding process to be used in production welding.

Performance qualification is performed inaccordance with one of the qualified welding procedure. When performance qualification is done inaccordance with a WPS that requires post weld heat treatment, this post weld heat treatment is not required for welder qualification.

# 3. Renewal of Qualification

The performance qualification of a welder is affected under the following conditions:

- (a) When the welder has not welded with a process during a period of 3 months or more, his qualification for that process will be expired; except when he is welding with another process, the period is
  - (b) When he has not welded with any process during a period of 3 months, all his/her qualifications will be expired.
  - (c) When there is a specific reason to question welder's ability to

Fasil Stall

# 4. Welder's Qualification Status Report

Welder qualification status report is published every two weeks which lists all the welders who are qualified to weld on a WPS. The limitations of the welder qualification such as diameter, thickness range etc. is shown on the status report. A cross qualification of the welder qualification is also attached with the status report. Status report will be discussed in detail.

FAS: cag

# CORPORATE QA/QC SECTION PERSONNEL TRAINING

Instructor: WArd	Mercer . Date: 2-7-84
Training Period: 4	:00 pm To 5:00 pm
Class Title: Find	Beview of Hanger Packages
(General Topics) I.	
(Specific Topics) A.	SWDB Review (PA-34)
, в.	Traveler Review (Exhibits)
c.	Drawing Rev. & Mods.
II.	material Status
Α.	Engineering Insterial Status (Exhibit 4)
	QC material Status (QA:34)
c.	
III.	use of "n/A"
Α.	Line thru of unused blocks on SWAR
В.	
c.	
The totlowing personne	attended the above described training.
Matt Brown	MA Jerry Rhades In Moder
Sherman Cotham	N/A StevenRussell & Busell
Kevin Kenyon	N/A Don Sands N/A
Rick Garrison	Jerry Smith Juny Courts
Cameron Lucas	N/A Mike Stephens / N/A
Ward Mercer	MA Jim Storey NA
Mark Pfouts ,	N/A Carl Whatley N/A
Steve Rahe	N/A Carl Weast N/A
II.  A.  B.  C.  III.  A.  B.  C.  III.  A.  B.  C.  The rollowing personne Matt Brown  Sherman Cotham  Kevin Kenyon  Rick Garrison  Cameron Lucas  Ward Mercer  Mark Pfouts	Drawing Rev. & Mods.  Material Status  Engineering Instance Status (Exhibit 4)  O.C. material Status (OA:34)  Use of "n/A"  Line thru of unused blacks on SWOR  Statushed the above described training.  N/A  StevenRussell Status Status  N/A  Don Sands  N/A  Jerry Smith  Mike Stephens  N/A  Jim Storey  N/A  Jim Storey  N/A  Carl Whatley  N/A

Instructor: Wal Main

# CORPORATE QA/QC SECTION PERSONNEL TRAINING

Instructor: Eugene	Moitin Date: 2/2/84 30 Pm to 4:30 Pm
Training Period: 3:3	opm to 4:30 pm
Class Title: _ Start-	17 Manual - Section II
(General Topics) I.	
(Specific Topics) A.	
, в	
Α	
B	
c	
III	
A	
ъ	
c	
The tollowing personnel atten	ded the above described training.
Matt Brown N/A	Rhodes & Tholes
Sherman Cotham N/A	Stever Russell Herrell
Kevin Kenyon	Don Sands N/A
Rick Garrison Delice	Jerry Smith Trung Smith
Cameron Lucas NYA	Mike Stephens Mil Stephen
Ward Mercer N/A	Jim Storey N/A
Mark Pfouts NA	Carl Whatley MillaThe
steve Rahe Hay 2. 7864	Carl Weast NIA
	6/ 11/

# CORPORATE QA/QC SECTION PERSONNEL TRAINING

Instructor: Dullah	+ Estes Date: 1-26-84
The state of the s	30 Pm to 4:00 Pm
Class Title: Radiation	Sately
(General Topics) I.	· / · · · · · · · · · · · · · · · · · ·
(Specific Topics) A.	
, в	
c.	
II	- X
A	1/1/
э	1.
c.	
ш	
Α	
в.	
· c	
The tollowing personnel atten	nded the above described training.
Matt Brown NA	Terry Bhodes Jumy Holie.
Sherman Cotham	S
Kevin Kenyon 9 M An	1/1 2
A CONTRACTOR OF THE PARTY OF TH	Don Sands NA
Rick Garrison W	Jerry Smith Juny Onto
Cameron Lucas WA	Mike Stephens
Ward Mercer NA	Jim Storey C. Alexandre
Mark Pfouts	7
7/01	Carl Whatley Che hotter
Steve Rahe flum & Rale	Carl Weast NA
	00 110.

Instructor: Q. Euroft Esta

# CORPORATE QA/QC SECTION PERSONNEL TRAINING

Instructor:	0/42 Lowe Date: 1-19-84
	3:30 pm to 4:00 pm
Class Title: 24	A. Sonic Testing
c.	
II.	
Α.	
В.	
c.	
III.	
Α.	
В.	
c.	1 · · · · · · · · · · · · · · · · · · ·
	el attended the above described training.
Matt Brown	A Jerry Bhodes Jug Malle
Sherman Cotham N	A SteverRussell Hen Russell
Kevin Kenyon	modern Don Sands N/A )
Rick Garrison	Jerry Smith Yory Inutt
Cameron Lucas	N/A Mike Stephens Mike Heatens
Ward Mercer	N/A Jim Storey Jan Story
Mark Pfouts	N/A Carl Whatley whatless
Steve Rahe Mun	2. Fishe Carl Weast N/A
	Instructor: 0 D

# CORPORATE QA/QC SECTION PERSONNEL TRAINING

Instructor: Michael In De	shus Date: 1-17-84
Training Period: 30 min.	
Class Title:	
(General Topics) I. Clean	ung .
(Specific Topics) A. TYPE	<i>-</i>
, B. Meth	ods
c. Inspe	ction
II. Weldin	· g
A. Root openin	us & BACKING FINSS
B. Fit up.	FFINAL Weld
c. NOE	
III. How MP-	06 DIFFERS FROM Hanger Criteria
	elds fritup
B. FINALS	
C. Inspect.	ON & NOE
The rollowing personnel attended the	above described training.
Matt Brown WA	Jerry Bhodes Jany Blides 1
Sherman Cotham N/A	StevenRussell Som Rensell
Kevin Kenyon Dair M. Teng	Don Sands MA
Rick Garrison 2-	Jerry Smith Jung Junto
Cameron Lucas N/A	Mike Stephens
Ward Mercer NATED MBL	Jim Storey Jan Story
Mark Pfouts MA	Carl Whatley WA
Steve Rahe Town R. Role	Carl Weast MA

Instructor: Mickey lan Stepher

AJS TRAINING 2165-A-003 REU 5

Michael Stephens Michael Stephens KM. KENTON

Handlusel S.T. Russell Chilathy

James & Jacken JAMES G. JACKSON

ad Leonard A.L. LEONARD Hawley Dowant

Robert L. Clumba Roberi L. PLUMIEE

munies Skoules MINNES SKANES

AL TITLE

Thereor Gover Sheldow Gibson

JERRY SMITH

Bill Perc

CARL WEAST

Sherman Cotham

Mark Pfouts Thomas B. Lembo

C. WHATLEY

Harold L. OBRIANT

al Titel

John Pere

Carl WassT

Shenon Cothan mail offort

Frenco B. Lenh

1-17-84 AFTERNOON CLASS

I hove CLASS

INSTRUCTON: LEE WALIAMS

AWS Training 2165-A-003 REUS

Jum Story JIM STOREY Rota Tingan PETE TINGEN Lacky A. Buchne JACKY L. BUCKNER Christophic M Case CHRISTOPHER M CASE P. D. Bodie P. H. BODINE Was Men WARD MERCER Melvin Cayata MElvin CARPENTER Jume ENLE JEROME EVERS the M Dangle STEVEN M. DOUGLAS Tom askly Tom ASHIEY Vatter D. Dowell Watter D. Dowell Tello angelina TELLO ANGELINA Tuling June Douglas M. Brown Storm De Rake Steren R. Raha Gillet A. Dyk-s Gilbert A. DeRarros Jany Rhoells BOB Ne Consider Bed me Connece Day Lung Doug. Lucas Conaldand DONALD SANDS RICK - GARRISON C. F. Sovier C.E. GOINS Frank Jore F. GORE P. TAYLOR Folat Park

Some Thech

TESSE NITHO

MIKE KING MAKY

The intent of this design document is to provide the CP&L QA program with acceptance criteria that satisfies the design requirements and thereby allowing clarification from strict code interpretation during receipt inspection, reinspection, and field welding inspection. This criteria is applicable to both primary (first inspection, uncoated) and secondary inspections (receipt inspection included with quality release or reinspection, coated) for structural weldments designed to AWS Dl.1 requirements. Secondary inspections may be performed through coatings. Primary inspections shall not be allowed through coatings unless allowed by the engineer. Any item not specifically covered in this criteria shall refer back to AWS Dl.1.

This criteria covers joints which provide framing for components, such as cable tray, HVAC, conduit supports, instrument racks, ducting air control dampers, doors, hatch covers, pipe supports, etc. This is to include any item welded to AWS Dl.1 standards.

This criteria is applicable to any weld joint where these imperfections are to be visually inspected per AWS Dl.1.

As per AWS D1.1, welds with acceptable imperfections in combination shall be acceptable.

Based on the QA programs for acceptance prior to vendor release (or acceptance of field welds), any defects not identified during primary inspection and subsequently covered by coatings are not considered significant.

Visual inspection of welds shall be in accordance with AWS D1.1 except as modified below:

surface distance of no more than 24 inches, the inspector position within an angular region of 30 to 90 of the examination surface by personnel possessing 20/20 visual acuity. Visual aids which do not enhance 1% capability, such as mirrors, may be used. Visual inspection shall be used unless otherwise noted on design documents.

### 2.0 ACCEPTABILITY CRITERIA

### 2.1 Oversize Fillet Welds

Either or both fillet weld legs may exceed design size. Welds may be longer than specified. Continuous welds may be used in lieu of intermittent welds.

### 2.2 Undersize Fillet Welds

The leg of 1/4" and larger fillet welds may be 1/16" less than the required weld size for a continuous span of 2", provided there is no less than a 6" separation between each undersize increment. For welds less than 8" long, a continuous undersize span of 25% of the total weld run length will also apply. All 1/16" undersize increments less than 1/2" in length will be acceptable. For intermittent welds, 1/16" less than that size will be accepted provided the undersize condition the more than 40% of the weld length.

The leg of 3/16" fillet welds may be 1/32" less than the required according to the above provisions.

It is to be understood that the thickness of coatings on secondary inspections are not considered detrimental and the weld size criteria shall not be adjusted. Any unique application of coatings (excessive thickness, putty) shall be brought to

#### 2.3 Porosity

Pores between 1/16" and 1/8" dismeter shall be acceptable when separated by a minimum of one inch. Isolated pores less than 1/16" dismeter shall be disregarded. Clustered porosity including all sizes to 0.030" contained within up to a 3/8" diameter circle shall be acceptable. Linear, in-line pores shall be considered as clustered porosity. It is to be understood that porosity not visible through coatings on secondary inspection are not considered significant.

#### 2.4 Weld Profile

Fillet and butt weld convexity can be accepted without limit.

#### 2.5 Craters

Welds may have underfilled craters provided underfill depth does not exceed 1/16" and the crater has a smooth contour blending gradually with the adjacent weld and base metal with no evidence of cracking.

### 2.6 Undercut

Steels 5/16" or thicker which were produced to a maximum specified tensile strength of 60,000 psi may contain weld undercut up to 1/16" in depth for a continuous span of 2" provided its surface width is less than 0.100" and there is no less than a 6" separation between each undercut increment.

Weld runs less than 8" long may contain a continuous undercut span of 25% of the total weld length. All undercut less than 1/2" in length will be accepted provided the above width limit is adhered to. Undercut up to 1/32" depth is acceptable in all steels and all thicknesses.

#### 2.7 Cracks

Cracks are unacceptable. It is to be understood that secondary inspections are intended to identify cracks that result from shipping damage or stress relief and, if relevant, would appear through the coating.

#### 2.8 Arc Strikes

Arc strikes in high-strength, low-alloy steels (minimum specified tensile strength greater than 60,000 psi), shall be removed by grinding. The ground area shall be visually inspected to assure complete removal of the arc strike.

For other maximum specified 60,000 psi tensile steels, arc strikes shall be visually examined and accepted if no cracking is evident. If cracking is evident, the repair shall conform with Section 3.10 of AWS-Dl.1. Arc strike regions in these lower strength steels shall not require power brushing or grinding before visual examination. It is to be understood that cracks in arc strikes not visible through coatings on secondary inspections are not considered significant.

### 2.9 Fusion

Lack of fusion which does not exceed 1/4" in length when measured transverse or along the weld and each increment separated by 6" is acceptable.

Criteria for lack of fusion in transverse direction is applicable only in start/stop location.

Criteria for lack of fusion shall apply to overlap. : It

is to be understood that lack of fusion not visible through

exactings on secondary inspections is not considered significant.

Any unique application of coatings (excessive thickness, putty)

shall be brought to the attention of QA management for resolution.

# CORPORATE QA/QC SECTION

Var

# PERSONNEL TRAINING

Instructor: Alex Laws	Date: 1/12/84
Class Title: Magnetic Pant	ich : Vaccum Box Presentation
(General Topics) I.	
(Specific Topics) A.	
The totlowing personnel attended	
Matt Brown Leader M. Proce	A Shall
Sherman Cotham	Steven Russell Again Lungel
Kevin Kenyon B. All Hann	Don Sands
Rick Garrison Trion	Jerry Smith Owny Junt
Cameron Lucas (qui tron Luco	Mike Stephens 772 Strokew
Ward Mercer	Jim Storey
Mark Pfouts	Carl Whatley Collatte
teve Rahe Stern R. Rake	Carl Weast
	Instructor: QQ_D.Q

Hand

# CORPORATE QA/QC SECTION PERSONNEL TRAINING

Instructor: RICK GARES	ON Date: 1-16-6-
Training Feriod: 12:30	PM to 1 PM
Class Title: WP-18	REV-14
(General Topics) I. Docs	MENTATION
(Specific Topics) A. Sign	CFE BLOCKS
. B	IAL REVIEW
c. N/A.	BLANK BLOCKS
II.	
Α	
В.	
с.	
III.	
Α.	
в.	
c.	
The totlowing personnel attended the	above described training
Matt Brown	Terry Rhodes Jerry Allodie
Sherman Cotham	StevenRussell Hent Buryelf
Kevin Kenyon & M Your	Don Sands
Rick Garrison	Jerry Smith Juny Smith
Cameron Lucas	Mike Stephens
Ward Mercer	Jim Storey
Mark Pfouts	Carl Whatley Chilletin
Steve Rahe Kan & Fale	Carl Weast
Inst	Tuctor: [26] : Totour

# Word

# CORPORATE CA/QC SECTION

# PERSONNEL TRAINING

Instructor: Jenry 1	Phodes Date: 1/5/84
Class Title: WP 13	9 - WORK PACKAGE PREPARATIO
(General Topics) I.	
(Specific Topics) A.	
, в	
A	
B	
A	
c	
The collowing personnel accend	ed the above described training.
Matt Brown Donder 11 Brown	Jaim Phodes Jung Alody
Sherman Cotham	Stever Russell Herr Bussell
Kevin Kenyon Jour din	Don Sands
Rick Garrison Dal	Jerry Smith of my Smith
Cameron Lycas Qui cos K	4. Mike Stephens while Him
Ward Mercer	Jim Storey Jan Story
Mark Pfouts	Carl Whatley
Steve Rahe Mon 72. Poly	Carl Weast
	0.000

4/0-00

# CORPORATE QA/QC SECTION PERSONNEL TRAINING

Instructor: Steven T. Russell Date: 17/29/83
Training Period: 4:00Pm to 4:15Pm
class Title: MP-03 Wold Miterial Control
(General Topics) I. Scope / References
(Specific Topics) A. Estiblish guidelines for welding material
B. describes control required for weld mitt.
c. For use with Asms, safety related & BOR
II. General
A. controlled wiese To storages areas
B. wield Insterial Issue Station requirements
c
III. Procedure
A. Insterial Supervisor D. Welling operator
B. Receiving Despector E Weld Zeene Station
c. Discipline Engineer attendant
The rollowing personnel attended the above described training.
May 2. Rule Steven R. Rahe
Filed Colver Fixo aito
Horey Om Story
KENYON St. M. Form
Jepry Photes an Rhods
iney Smith gray Smith
Columber Collette
CH DE THE THE THE THE THE THE THE THE THE TH
H 187 11
Instructor: Men Okenel

# CORPORATE 24,20 SECTION PERSONNEL TRAINING

Instructor:	Mark Pfouts	Date:/	2-21-83
Training Pe	riod: 4:00 11 40	4:25911	
Class Title	= QCI6.3 Royal	QCI7.1 Rev 6	
		A36 steel stamps	
		1 string log.	
	В.		
	c.		
	II. DA Zasas	ction status identificat	ria
		nd tagging	
	В.		
	c.		
	Α.		
	ъ.	The state of the	
	c.		
. The tollow		e above described training	4
	1.	- This n Role	
	0 000	32 1/25	- 1
JERRY Rho	des-yen Klader		C. WEAST
Krawn-1	Langles III. Mour		
mila - Juny	O. fr		
Storey-	W 0+ 101) 16		
3. 1. 17 uss	et Man Sunely		
Mike Staf	MUS MIKE STOP	hew-	
WHATLEY	Certatley		
,	/ In	structor: grad for	- 11 -
			- /704/5

11100

Instructor: Ward Mercer Date: 12/14/83
Training Period: 4:00Pm to 4:20Pm
class Ittle: Documentation & Non-Conformance Reportin
(General Topics) I. Documentation
(Specific Topics) A. making ontry/s on SWDR's
B. Requiements of pot 1913
II. Non-Conformance Reporting
A. How and when to initiate NCR's
B. REPARTING IN A TIMELY MANNER
c.
m.
Α.
В.
. c.
The Policining personnel estanced the above described training:
teplens Michael In Staphin cellatter - Whatley
Pake Stone 2 Roll Prown - Dandas M Brown
wrison ST Russell - Steven Russell.
'cryon Low Storey - Join Story
Veast Sail Vent Smith - Some Swith
TRETAR Davell V. Stuton GR. F.H Bally
Hodes am Rhan
The state of the s
ucas Ruholo C. Avia
Instructor: Estal Moun

Word

## CORPORTE QA/QC SECTI

W.--

M	D C 1611
	D. Griffith Date: 12/6/83
	3:50 PM to 4:25 PM
Class Title: CAR-	2165- A-003 Rw-4 - Weld Inspection Crite
	acceptance Criteria
(Specific Topics) A.	discontinuity limits
В.	
c.	
II.	Allowed Visual Aids
A.	
В.	
c.	
III.	
/ A.	
В.	
с.	
ine following personne	attended the diove described training:
Junes Bhooles	Ca) father
R. Tale	Quest Court
DA	Of Stown
Sten & Ru	nell Jan
Fil. Oct.	,
Jana MX E	24
M S S	
The Stephens	
1 our 119-1100	

File: SH P-1/2

생물하고 있는데 이 과 가 보고 있다면 하고 있다. 이 나를 하고 있는데 아니라 아니라 아니라 아니라 아니라 하는데 아니라
Instructor: Douglas M. Brown Date: 11-29-83
Training Period: 3:45 To 4:05
Class Title: Site Specification 033
(General Topics) I. Detailer Welding Requirements
(Specific Topics) A. Welding Processes
B. Field Drawings
c
II. Welding Requirements
A. Prep. + Cleaning
B. Packing Strips on Rings
c. PEENing
III. Tempora, ATTachment welds
A. Tack welds / Defects
B. Arc STrikes Preheating
c. Supace defects Post weld Heat Treatment
The following personnel attended the above described training:
Missing.
Danel V. stating
Jany Vm 46
HAN Som
Jun Blocker
Civilate
mil Atrah
the Selverell
- Total State of the state of t

On Tuesday, November 29th, there will be a training class held for the latest revision to WP-110. It will be held at the Daniel's Training Annex.

10:00 Am

1:00 Pm

Brown Stephens Garison Russell Streter Griffith Kenyon

Storey Lucis Pfonts Whatley Rhodes Snith File: SH P-1/2

lind

File: SH P-1/2

Ward

Instructor: Keuin M Kenion Date: 11/15/83
Training Period: 4:00 - 4:30 Pm 11/15/83
class Title: MP 04 Accoderce for POST WELL TRATMENT
(General Topics) I. General Section
(Specific Topics) A. Nominal Thickness of welds
B. HEATING METHODS, 40 HING TIME & TEMP
C. HEMING & COOLING RATES
II. Procedyre
A. Local PWHT
B. Templostrol
c. Joint preparation for PWHT
III.
A
В
c. i
Mike Alekens
Vondo 4 Bro 02
Had Bund
Juny Smith
mail fout
Danell V. Stuton

#### CORPORATE QA/QC SECTION

PERSONNEL TRAINING

Instructor: Jim Storey Date: 11/8/83
Training Period:
Class Title: MP-05 Perment Marky of Ste MA+1/5 & Conone
(General Topics) I. Me Hods of Marking Rev. 18
(Specific Topics) A. Description
B. thickness limitations
c.
II. Requirements for making
A. Welder Symbol
B. ID Transfering
c. weld ID
III.
A
В.
c. <u> </u>
The rollowing personnel attended the above described cruining:
mul Pfour Davell V. Streton
Kein M. Kown Whatly
Steven R. Rohe Cook Weat
The Sligher Jony mutto
Donald Light Extends
Tolur Jan Story
Unda DX Brown
man all the

File: SH P-1/7

Instructor: CARL	WEAST. Date: 11-2-83
Training Period: 4:0	10 pm To 4:30 pm.
Class Title: MP-10	BEV. 10 - WELD REPAIR OF BASE METAL AND WELDMENTS
(General Topics) I.	HE HERE THE SELECTION OF A SECURITION OF A
(Specific Topics) A.	REPAIR WOR - WHEN BEQUIRED - WHEN NOT BEQUIRED
в	INITIATION OF BERAIR WOR
c	
п	INVOLVED CODES
A	ASME
В	AWS.
с	MODIFICATION OF AWS CODE BY CAR-2165-A-003
ш	WELD BERAIRS -
A	BASE METAL BEPAIRS
в	WELD BERAIRS
c	
The real parts of the	get suits to the above of separate testains:
modely	- Would Soul
Juny Smith	
Steen R. Male	
Mex Blassel	
must y fout	
Kuin on Keny	
mile Station	
Ralas Church	
1	

Word

File: SH P-1/2

#### CORPORATE QA/QC SECTION PERSONNEL TRAINING

Date: 11/2/83		
Training Period: 11/2/8	-3	
Topic:	Rev. 10	
•		
Instructor CARL	WEAST	4/4
	tended the above described training:	
Mike Stephens	2000	
Steven R. Rahe	RCAucas 1	
They Sints		
Sould church		
Well I fout		

Carl Wear Instructor

File: SH P-1/2

Word

Date:
Training Period:
Topic: NDEP-605 REV. 1
CAR - 2165 A - 003 REV. 2
Visual EXAMINATION OF SEISMIC I, STRUCTURAL AND HANGER
WELDS SHEARON HARRIS NUCLEAR POWER PIANT
Instructor Danell V. Stretan:
The following personnel attended the above described training:
Steven D. Rake Sevir on Jean
sing Chilles O. Story
mail of fout of Lang Smith
ttotsusel dollar
Evald Sould Dongs M. From
Whe Tyshow Elas Man Dowell V set
The State Instructor

#### DANCL CONSTRUCTION COMPANY

SHEARON HARRIS NUCLEAR POWER PLANT

TRAINING RECORD

	A STATE OF THE STA	in the second of the second
		GTH OF CLASS ONE HOUR
DURSE & TITLE MP- C8 R.	ev. 6 PIN #3+2 AND	MP-10 (Bise Metsi Repair)-
INSTRUCTOR DAVID TIN	ABERLAKE-	SHIFT 1 ST
THE WILL SAN TO SE	The state of the s	HIMATON BOOK
3	PERSONS IN ATTENDANCE	· · · · · · · · · · · · · · · · · · ·
Be for pyropia and the same of		
RANE		BADGE NO.
1. Rt Lading		CP\$L 801
2. CO/200		752 1204
3. Al Tint		T32 357
4. FCFfun		CPEC 319
5. Phurtophin MCa.	u i	CP2 L 882
6. Roberth Chumler		TSL 128
7. 18llo Angelin	A way in	CPSL
8. Mike Stephers		CP\$1 343
3. donin B. Lemlo		TSL VISITIE 03
o. Danill V Stretas		561
1. A Coling		ts L 1197
2. gray Unito	1.	TSL 578
3. Ranky Cooper		TSL 1209
4. Son 2 ( Elatis)		TSL 225
5. Molluself		T.S.L. 564
6 Mail I four		136 991
1. States D. Pole		T32 494
8. 11 8 11 11 11 11 11	から	156-458/4-4
9. (V. A. Brill		NAL 893
1 W WILL AS		G. PC 848
" UL. 1.11 A.R. +		10#1 837

#### PERSONS IN ATTENDANCE

NAME	BADGE NO.
2. On Ston	c P's 2 - 347
. Wetter Dowell	504
M. Skours	586
5. Tom askly	254
6. the Money	287
7. Hein m Down	CP:1309
s. An Sond	TSC 573
9. Tim HANKINS	CFEL 81-9
0	
1	
2	
3•	
4	
5	
6	
7-	
ß •	<del></del>
9	
0	
1	
2	
3	
4	
5	
6	
7	

October 24, 1983

MEMORANDUM TO: Ray Hanford

FROM: David Timberlake

SUBJECT: Training Class for QC-Welding (Structural and Pipe Hangers)

Inspectors

On Thursday October 20, 1983 I conducted a one (1) hour training class in the large conference room. An outline and attendance sheet are attached.

this riell

DRT:cag

cc: Mr. Ralph Bodine

Mr. Ward Mercers Mr. Vic Safarian Mr. Fasih Shaikh Mr. M. F. Thompson, Jr.

Mr. Jim Trammel

Metallurgy/Welding File T-4d

#### MP-08 Rev. 6, PCN #2 and PCN #3 and MP-10 (Structural Base Metal Repair)

- 1. MP-08 Rev. 6
  - A. Procedure Change Notice #2 (copy attached)
  - B. Procedure Change Notice #3 Partial (copy attached)
    - 1. Paragraph 4.5.3.5
    - 2. Exhibit 6
- II. MP-10 Structural Base Metal Repairs
  - A. Minimum wall criteria
    - 1. Based on ASTM material specification
    - 2. Example of ASTM A6
  - B. Structural significance of areas of base metal reduction
    - For DDR reportability handled on a case by case basis based on load and "as-built" condition.
    - Damage to systems/components that have not been turned over on an RFT the situation will be handled as an in process repair (not structurally significant).

Procedure No. MP-08

# CAROLINA POWER & LIGHT COMPANY

The state of the s	
SHEARON HARRIS NUCLEAR POWER PLANT	Page 1 of
PROCEDURE CHANGE NOTICE	

Applicable -	FCR's: N/A DCN's: N/A
Affected Paragraphs	Description of Change
4.2.2	Change to Read:
	The surface of base metal approximately one inch adjacent to the weld
	joint, in the plane of welding, need only be cleaned of those loose
	materials which may fall into the molten weld metal and coatings which,
	due to fumes caused by heating or burning, could leave a harmful residue
•	in the weld. Tightly adhering rust which has been cleaned with a hand
1	wire brush shall be permissible.
4.2.5	Change to Read:
	Prior to weld joint inspection, any coatings that will prevent visual or
	non-destructive inspection of the weld and heat-affected zone shall be
	removed. (approximately 1/2 inch from the toe of the weld, where
	accessible).
	DOCUMENT CONTROL
	111
The approval to the extent	of this Procedure Change Notice authorizes deviation from the named procedure described above.  SHEARON HARRIS N. P. P.

procedure revision is in effect.

	APPROVALS	DATE
ORIGINATOR	Comy Upckusch &	04 9/27/83
QA/QC REVIEW	M. M. Hear	10/3/83
CP&L	P. Horgard Fol. M. F. THOM	Sal m 10/3/82

Page 1 of 2

# CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT PROCEDURE CHANGE NOTICE

Dux #30/63

Procedure No. MP-08	Revision No 6	Change No.	23
Procedure Title GEN	ERAL WELDIN	a PROCEDURE	FOR
STRUCTURAL STE	FEL (SEISMIC, )	NON- SEISMIC) AND	O HANGERS
Applicable - FCR's:	V/A	DCN's: N/A	

Affected Paragraphs	Description of Change
4.5.3.5	CHANGE TO READ
	"AFTER REMOVING TEMPORARY ATTACHMENTS FROM
	SEISMIC AND NON-SEISMIC STRUCTURAL COMPO-
	NENTS CRAFT PERSONNEL SHALL REQUEST IN
	WRITING, USING EXHIBIT 6, THAT METALLURGY
	WELDING PERSONNEL EXAMINE THE AREA TO PETER-
	MINE THAT THE SURFACE HAS BEEN MADE PLUSH
	WITH THE ORIGINAL SURFACE AS REQUIRED BY
	AWS DI. 1, PARAGRAPH 9.24. THE AREA OF RE-
	MOVAL OF PERMANENT PLANT STRUCTURAL ITEMS DUE
	TO DESIGN CHANGES, MISLOCATIONS ETC. SHALL BE
	SUBJECTED TO THE SAME INSPECTION CRITERIA AS
	TEMPORARY ATTACHMENTS AND SHALL BE HANDLED
	AS NOTED ABOVE. IF ADDITIONAL EXAMINATION (SUCH
	AS A D-METER) OR A BASE METAL WELD REVAIL
	IS REQUIRED, A WELDING ENGINEERING HOLD TAG

The approval of this Procedure Change Notice authorizes deviation from the named procedure to the extent described above.

The holder of the affected procedure shall retain this notice with the procedure until the next

QA/QC REVIEW M.M. Fuel 10-3-83

CP&L 2. Harford FOR M.F. THOMPSON 2 10/3/6-3

# CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT Page 2 of 2 PROCEDURE CHANGE NOTICE CONTINUATION SHEET

Paragraphs	Description of Change
SEE EXHB	IT 7) SHALL BE PLACED ON THE AREA OF
ZONCERN U	WILL SUCH EXAMINATION AND/OR REPAIRS ARE
ACLARDANE	BASE METAL REPAIRS SHALL BE HANDLED IN WITH REPORTULE 2.9."
- COULDANCE	WITH REPERENCE 2.7.
5.0 ADD	THE FOLLOWING:
	EXHIBIT 6- INSPECTION REQUEST FOR
ALL VALUE AND ARCHE	DAMAGED / GROUND AREA (REV. 0 - 9/83)
5.9	EXHIBIT 7 - WELDING ENGINEERING HOLD
	TAG (REV. 0-9/83)
	TABLE B (REV. 1 - 8/83)
JUSTIFICA	TION: CLARIFICATION OF INSPECTION OF TEMPORAL
ATTACHMENT	REMOVAL AREAS AND ADDITION OF WPSIS TO
TABLE B.	THE PROPERTY OF WESTS TO

The holder of the affected procedure shall retain this notice with the procedure until the next procedure revision is in effect.

	INSPECTION REQUEST FOR DAMAGED/GROUND AREA
	Seismic Non-Seismic
	Material Type:
- 1	Material Thickness: RET NO.:.
	Product Form (plate, tube steel, W shape, etc.):
•	Drawing/Rev.:
	Component Identification (embed, piece no. etc.):
1	Bldg. Elevation Zone
	Actual Elevation Location
	Other Info:
	0(0)
	(0)
	Requested By: Title Date
	(Signature)
	Visual Inspection Results:urther Investigation Required
	Thickness (D-Meter) check required
	Min. Wall Criteria Inch(es)
	Actual Results (Min.) Inch(es) Acceptable
	Not Acceptable
	Hold Tag Applied
	Weld Repair Required: Yes No Not Recommend (See Comments)
	Comments (attach sketch, as needed):
	//:
n	
,	
;	
215	
Meret tury/ merening	

## CORPORATE QA/QC SECTION PERSONNEL TRAINING

Date: October 18; 1983	
Training Period: October 18, 1983	
Topic: QCI 19.4 PREPARATION AND SUBMITTAL OF SEISMIC WE	LD DATA REPORT
Rev. 4	
	-
Instructor KEVIN M. KENYON	
INSTRUCTOR ADVIN M. RENION	
The following personnel attended the above described training:	· ·
Danell V. Stretes 1/ Chang of flat	* 1.0°
Daniel V. Stieter / Juny H. Kholin	
Med Range & Taline	-
male dinto	
my of the man	
The Septem Walfiller -	
and for Cellatter	
Jun Storing The Och who	
1 = 3 mil	
Jakem P. Jews.	

Jewi m Kenni Instructor File: SH P-1/2

Da	e: 10/11/83	
Tr	ining Period: 7:30 Am to 8:00 Am	
· To	ic: QCI-19.3 Pw-5	
_		•
_		• • • • • • • • • • • • • • • • • • • •
_		
-		- 25,4.5
. In	tructor Jerry Snith	
Th	following personnel attended the above described training:	
nike	Stephens Eval Men	
anell	Stephens Eval Meur	
	Durself Jones Phoeles	N.
0	Atom Callette	
19	and the day only	L
Mo	Defent Mail Mount Instructor	
Mou	2. Rah	
-63	- 505 - 10/11/23	

Date: 3-22-83		
Training Period:	10 minutes	
Topic: Base me	tal reduction in pipe hangers and structural steel. In	spec-
tors were reins	tructed to observe for base metal reductions outside th	e weld
area and reques	t Weld Engineering evaluation in cases where acceptabil	ity
cannot be deter	mined by the inspector.	
Instructor E.	W. Mercer	
The following per TSL	connel attended the above described training:	
Rick Garrison	Kevin Kenyon	
Mike King	Jane Martin Wayne Martin	
Mark PFouts Carl Weast	George Carpenter	
Al Tittle	Gil DeBarros Matt Brown	
Jerry Smith Dave Jarvis	Place Di Owli	
Ron Mays		
Chuck Goins James Jackson	0,50 00	
	Instructor	

, File: SH P-1/2

Date: 1-27-83	
Training Period:	15 minutes .
Topic: Base me	etal reduction in pipe hangers and structural steel. Inspector
were instructed t	to observe for base metal reductions outside the normal weld
area. If areas a	are noted and acceptability cannot be determined by the
inspectors, Weld	Engineering is to be notified via a 3 part memo for evalua-
tion. Areas that	are found to be unacceptable will be identified as a
nonconformance.	
Instructor F W	I Mercer
	connel attended the above described training:
TSL	<u>CP&amp;L</u>
Mike King	Kevin Kenyon  Jane Martin
Carl Weast	Wayne Martin
Al Tittle	George Carpenter
Jerry Smith Dave Jarvis	Gilbert DeBarros
Ron Mays	Matt Brown
Chuck Goins	
James Jackson	
	Ello Man
	Instructor

December 9, 1980

Memo To: R. Hanford

From: D. Timberlake

Subject: Welder Craft Training - Bimonthly Update

A two and one half hour training class was held on November 24, 25, 26, Dec. 3, and 9, 1980, for all welders and welding foremen. The following is an outline of what was covered in each class:

- .. A review of welding symbols including a clarification of the flare bevel symbol that is used on hangers.
- 2. The meaning and application of preheat and interpass temperatures . were discussed. Also a preheat demonstration was given to class members in the training school after the conclusion of the classroom training to show how to preheat and measure preheat temperatures.
- A review of Welding Procedure Specification No. AW-1 was included with a discussion of the various prequalified joint designations that are incorporated in this WPS.
- 4. A review of MP-03, Welding Material Control (see attached Handout) which included the reading of B. Isom's letter on MP-03.
- A review of MP-08, General Welding Procedure for Structural Steel (Seismic, Non-Seismic) and Hangers.

Training records are on file in Met./Welding Engineering.

David Timberlake

DT:bb

CC: F. Shaikh

A. Lucas

G. Forehand

J. Givens

3.79 DOCUMENT CONTROL CAROLINA POWER AND LIGHT COMPANY AP-IX-04 SHEARON HARRIS NUCLEAR POWER PLANT Exhibit 1 Page 1 of 2 OCT 2 2 1980 REST FOR CLARIFICATION OF INFORMATION (BCI) MI - E - 010 PARON HARRIS N.-P CAR-2168-G-7047 REV. 4 Reference Documents: 1364- 41845 RO CONTE HVAC & CABLE TRAY RESTRAINT STRUCTURES Description: TYPICAL CONNECTION DETAILS WELDING SYMBOLS PLEASE CLARIFY THE LOCATIONS OF WELDS FOR THE Inquiry: FOLLOWING TYPICAL CONNECTIONS AND WELD SYMBOLS USED ON EBASCO AND PEDEN STEEL HANGER DRAWINGS . CASE 1 (3 SIDES ( C.S. Hunnant Recid 5- Elect 10-21-80 Resid . Eng. - Elect 10-21-80 Originator Response: THE CORRECT WELD LOCATIONS ARE SHOWN BY HASH MARKS ON THE FOLLOWING SKETCHES ALONG WITH MORE DEFINITIVE WELD SYMBOLS FOR SOME CASES. (THESE RESPONSES HAVE BEEN DISCUSSED WITH EBASCO AND ARE NUMBERED THE SAME AS THE INQUIRY SKETCHES ABOVE.) CASE 1 000495 C.S. Humant Revid Eng-Elect 10-21-80 Response Signature Title Date Date Approval Title GARY ROGERS ROSIE ROHLETTER "Need-to-Know" A.M. LUCAS RAY HANFURD Distribution Scotty HINNANT JIM BELL

the major that the party of the

Charles and Charles

#### DOCUMENT CONTROL

#### CAROLINA POWER AND LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT

OCT 23 1980

REQUEST FOR CLARIFICATION OF INFORMATION (RCI)

BCT - E - SHEARON HARRIS N. F Please Reply By: ASAP Reference Documents: PEDEN STOCK CONFORT # C-3986-N SH E21 (1364-16292) Connection Details and Symbol related only to the above reference document Inquiry: alarity the locations of weeps for the following: reference dwg C056 1 Ose 2 Typ Cont start innent Read Fra- Fleat 10-23-80 Response: The correct weld locations are shown by slash marks on the statches shown below. These weld locations have been discussed with Peden Steel and are selected typicals and unique only to the above reference document and assicuted days 000497 SHinnert Reid Eng-Elect. 10-23-80 proval Thele Date Need-to-Know" Cline Distribution

#### CAROLINA POWER AND LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT

AP-IX-04 Exhibit 1

REQUEST FOR CLARIFICATION OF INFORMATION (RCI)

Please Reply By: ASAP	Please Reply By: ASAP RCI - W - 035	
Reference Documents:	NY 435076	DOCUMENT CONTROL
DESCRIPTION: DETAIL R - BRACE FOR TURB		DEGETTURE
Inquiry:	<del></del>	SHEARON HARRIS N. P.
IS THIS WELDING SYMBOL CO SHOULD IT BE LIKE THE FOLLS	ORRECT FOR THIS D.	STAIL ? OR
Nauel Rizero Eng 10-3- Originator Title Date Response:		Title Date
THE WELDING SYMBOL DETAIL R. THE PLATE SHOW	IS CORRECT AS S	HOWN ON
ENDS ONLY AND NOT ALL INFORMATION WAS VERIFIED BY COMPANY.	THE WAY AS	T
1		000498
Response Signature Title Date	1. 80 CS Hemia T Ra	Title Date
"Need-to- ROZIE ROHLETTER  Enow"  GREG MESHAW  Distribution		

旅海

#### REQUEST FOR CLARIFICATION OF INFORMATION (RCI)

Please Reply By: ASAP RCI -	W - 039
Reference Documents:	and the control of the control of
1364-A1845 RO .	
TURBING BLDGT UNIT # 1	
GENERAL SHEET OF DETAILS FOR DUCT SUPPORT	76
Inquiry:	
	WELD ALL AROUND
BUTTAG ARROW POINTS TO JUST THE BACK S	IDE OF CGORLANA
SHOULD THE PIECE BE WELDED ALL AROUND O	ON THE FRONT
DIDE :	DOUMENT CONTROL
	recurred
IN IN	OCT 1 3 1980
	7(2) 1 ( P)
Originagor Title Date Approved	TIEVE Date
Response:	
THE PIECE, EITHER CG OR LAXA, SHOULD B	BE WELDED ALLTHE
THE FRONT AND BACK	, AS PER
PAUL HAYES OF PEDEN STEEL (DIS	CUSSED IN TELECON
BETWEEN PAUL HAYES AND GARY ROGERS OF	N 10-10-50)
14 ( )	000499
Response Signature Title Date Approval	Title Date
"Need-to- GARY ROGERS	
Bierribusian GREG MESHAW	
Part = 10 - 11 - 12 - 12 - 12 - 12 - 12 - 12 -	

#### REQUEST FOR CLARIFICATION OF INFORMATION (RCI)

Please Reply By:	BCI - W - 040
Reference Documents:	
1364-41842 RO	
TURBINE BLOG UNIT#1	
GENERAL SHEET OF DETAILS	S FOR DUCT SUPPORTS
SECTS SHOWS A BRACE B	BEING WELDED TO THE FIEAM.
WHICH WELDING DETAIL DO W	
	DOCUMENT CONTROL
	MEGENTIEM
	OCT 1 4 1980
Aug / Kegers ENG. 10-13-80	CS Henrout Resid . Eng- Elect 10-13-80
Originator Title Date	Approved Title Date
Response:	. THE BRACE SHOULD BE WELDED
TO THE HANGER, PIECE # 15B6	, USING VETAILD.
THIS LAVERE MATION ARTHURS BY	Y TELCON BETWEEN PAUL HAYES
CEDEN) AND DAN HARSHBARGER	
O E DE 70 7 FIND DAIN MAKEMENT LA	
	000500
Haw Regers ENG 10-13-80	CS Hinrat Read Eno-Elect 10-13-80 Approval Title Date
"Need-to- GARY ROGERS	,
Know" GREG MESHAW	
Blatribution	

# Other for Welder Training Class.

I Introduction

A. HAND-out on weld symbols given to each

B. Reason men brought to class. Attendance Taken

NRO


NRO

HANGEN FIOLE


I Weld Symbols

A. Reference line:

Size & Type weld And finish information
given above & below reference line.



B. Arrow : designates where preparation and weld will be performed.



Broken Arrow Shows which piece will be prepared. example on

000501

example:

Tresped bevel show in red.

c. <u>Supplementry</u> <u>Symbol</u>:

ex. This should not be confused with the weld and which means which means fillet weld on both sides yet no all around.

2. Field Weld symbol: old symbol .

New AWS symbol 1

D. TAil:

Used to specify welding process or

specification or other supplements 502
information. Often omitted.

ex. small

是自己的

....

when "TYP." is specified, sometimes drawing is not clear. welder should get with forman to contact mechanical Engineers on Weld Engineer for clarification, when this is not clear.

E. Typical weld Symbols seen on Berg. Patterson Draws.


1. Fillet weld

a) size of fillet weld Always should be specified on drawing in front of fillet symbol.


ex.

6.) measure fillets:
size is measure of leg length.


ex.



Excess a concarry on converty of the



#### 2. Flare Weld



Example: Tube steel on plate




Note: This is Not A fill
penetration weld.
Sometimes weld symbol on
drawings calls for fillet weld
rather than flare. This mistake
should be brought to Atlention
of mechanical Engineering.

## 3. Bevel

______

without backing should not be welded with WPS IAI. Welder should be qualified for open root welding with WPS IAB WPS IAB Prior to attempting these welds.


ex.




Applicable procedures (wos, mx

F. Combination Weld Symbols

1. Bevel with Fillet




#### 2. Flare with Fillet



#### III Discussion of Misunderstood Procedures 1 +

A. StaniFing - MP-05
1. Changes to MP-OS to help prevent
excessive stamping on Hanger Welds  2. Request that All welders obtain
2. Request that All welders obtain
"Nissen" Pipe markers to use for
for welder identification. 000506
for welder identification.
HONG 아니네 주에 HONG NOT NOT HONG NOT HONG OF LOT HONG NOT H
ex. SH 19 62 BOX IN



MAN HATTERS

MUNICATION



Form 16-99-3 (9-78)

#### INTER-OFFICE COMMUNICATION

SHEARON HARRIS NUCLEAR POWER PLANT NEW HILL, N.C. 27562

TO: ALL WELDING SUPERVISION

DATE: November 11, 1980

FROM: B. B. Isom

SUBJECT: Control of Welding Material

We are experiencing difficulty in following the rules on welding material control as required by the Site Procedure MP-03. Several NCR's and Memos have been written as well as meetings being held to cause those people, associated with welding, to be aware of the correct methods of welding material control. Violations have continued to occur and a disregard for following Procedure MP-03 is being demonstrated; therefore more stringent corrective action must be applied whereby welders will recognize the seriousness of controlling welding material.

ind become familiar with the pertinent parts regarding material control whereby this information may be relayed to the welders and same may be observed for compliance. The following rules must be strictly enforced by all personnel:

- 1. Coated welding electrodes MUST NOT BE REMOVED from a heated caddy oven and layed down in the welding work area. While welding is in progress, a welder is perattied to store a few electrodes (approximately 12 maximum) in a leather pouch at his work location. If welding is stopped, the electrodes should be returned to the heated caddy.
- 2. Coated Welding Electrodes must not be exposed to moisture or rain. Scrap any electrodes exposed to moisture as required by Procedure MP-03.
- 3. All Heated Caddy Ovens Must be connected to an electrical outlet in the work location. Check the light on the caddy oven frequently to ensure the electricity
- 4. Any Electrode Caddy een found cold must be returned immediately to the Weld Issue Station with a new Weld Material Requisition to obtain another.
- 5. Unauthorized personnel found unplugging a welder's heated electrode oven will be subject to disciplinary action by management.

Violators should receive written reprimands and if a person continues to disregard the rules and procedures which control site welding, such individual must be terminated.

Please lend your assistance in correcting this problem.

B. B. Isom

BBI/RHM/jal

cc: J. Poythress

G. A. Rabb

J. P. Kirk

R. Rohletter

D. B. Turner

R. A. Rydarowski

R. H. McMillan

W. Rodgers

H. O. Ford

000509

#### WELDER CRAFT TRAINING

## Highlights of MP-03-Welding Material Control


- 1. Exposure time is considered to be the period of time hygroscopic material is not contained in a holding oven or heated portable rod
- 2. Rebaked electrodes shall not be used on Code Class work. These electrodes are painted red on their tips.
- 3. No welder shall pass welding filler materials, issued to him, to another welder for use with the exception of a welding operator for automatic
- 4. Issue time limit for heated containers and the welding electrodes contained therein is one shift or twelve hours.
- 5. Any welding stubs or scrap welding material (including wet material) should be discarded by the welder or welding supervisor in proper containers marked scrap. Failure to do so can result in disciplinary action.
- 6. In filling out a WMR, a Welding Foreman shall ensure that the following information is included: electrode size and classification, welders symbol, WPS and revision, job description, drawing or isometric number and revision, joint number, amount of electrodes requested, signature of the supervisor and
- 7. A welders responsibilities shall include the following:
  - a. Have a container for placing used electrode stubs and shall bend all scrapped material and place it in the container with stubs to be discarded.
  - b. Return all undamaged and unused material to the Weld Material Issue Room
  - c. A copy of the WMR shall be maintained by the welder at his work station until he has used all the materials issued or returned with the unused portion and his copy of WMR to the Weld Material Issue Room.
- 8. Change in E70S-2 designation to ER70S-2.

### Highlights of MP-08-General Welding Procedure For Structural Steel (Seismic, Nonseismic) and Hangers

- 1. Weld joint configuration shall be as specified on the design drawing. Where no joint configuration is specified by design, the joint configuration shall be essentially as shown on the welding procedure specification.
- 2. Any defects that appear on the surface of the weld beads shall be removed by chipping or grinding before depositing the next successive bead of welding.

Name:		 	 
Stencil	Number:_		_
Date:			


1. Explain the three parts of the following welding symbol by matching the correct answer with the corresponding letter.




- 2. The temperature at which the base metal of a weld joint must be maintained before the initiation of welding is called the predeat temperature. The temperature that the base metal adjacent to the weld must not exceed prior to the initiation of each weld pass is called the interperature.
- 3. T or F Rebaked electrodes, which have their tips painted red, shall not be used on Code Class work. (Circle correct answer)
- 4. The designation for E70S-6 bare carbon steel wire has been changed to _____
- T or F When it is necessary to preheat a weld joint to prevent condensation, the weld joint area shall be preheated until it is warm to hand touch. (Circle correct answer)
- 6. T or F Temporary attachments may be removed by hammer blows. (Circle correct enswer)

#### PREQUALIFIED JOINT WELDING PROCEDURE PROCEDURE SPECIFICATION

	process	Manual			
	of weiding				
	etal specific	SUCH COMPANY	5.1		
	etal classific	ation	010		
- X	etal grade*	N/A			
	ig gas	N/A			Flow rate N/A
	r multiple p	Mult			
	r multiple a	rc Sing			
	Reve		ct Current		
arity		Vant	ical Upward		
	progression eatment	N/A			
heat	and interpa	ss temperature .	Preheat:	See Be	low** Interpass: 500 F max.
_	t treatment	STATE OF THE PERSON NAMED IN COLUMN	Imlimited	Per Jo	int Details.*
Lei	mess -	Printed G			
			WE	LDING PE	ROCEDURE
		Weiding	aurrent .	T	
200	Electrode			Travel	Joint detail *
NO.	8424	Amperes	Volts	-	
11	3/32"-	65-120	19-25	-	This procedure is applicable to
	1/8"	75-160	20-25	-	partial penetration & full penetration
	5/32	120-200	20-28		joint designs as given in Fig. 2.9.1 &
4.					Fig. 2.10.1 and fillet welds in
					accordance with Figure 2.7.1. (See
					Attached Figures)
	1-11-1	7 66	4		DOCUMENT CONTRO
			rolle	11 0	
	Inc	nnt	ralla		LONV III
	MILL	WILL	UIIC	U U	NOV 5 1980
	EC	D INFO	RMATIO	N ON	
	L	IL HALO	VIAIVIO	1	HEARON HAR IS N. P.
			-		
			belostion samus	-	pass size, etc., within the limitation of variables given in 48
s pr	ocedure may	1 Serveniral W	felding Code. (1)	980 Edi	tion)
		AW-1	randing coos. ( 2	,,,,	Manufacturer or constructor Carolina Power & Lig
ced	ure no.		7 P1-1-4 No	.1	Manufacturer or cood actor
		3			Authorized by Hearford
	n no				Authorized by
risio					Date
rtsic					© 1978 by American Welding Society. All rights reserved
	hest.				
Pre	heat:	thickest p	art I		
Pre	mess of	thickest p	Min	imm Te	emperature
Pre	mess of		Min	imm Te	emperature f base metal is below 32°F, preheat to 7
Pre	oint of v		Min	imm Te. (I:	f base metal is below 32°F, preheat to 7



Klaximum size of fillet weld alone edges





Skewed T-joints

Note:  $t_{(n)}$ ,  $t'_{(n)}$  = effective throats dependent on magnitude of gap  $(g_n)$ . See 3.3.1. Subscript (n) represents 1, 2, 3, or 4.

*Angles smaller than 60 degrees are permitted; however, in such cases, the weld is considered to be a partial joint penetration groove weld.

Fig. 2.7.1-Details for prequalified fillet welds







Note C: Gauge root before welding other side.

Note D: Welds must be centered on joint.

Fig. 2.9.1-Prequalified complete joint penetration groove welded joints






Note C: Gauge root before welding other side.

Note D: Welds must be centered on joint.

Fig. 2.9.1-Prequalified complete joint penetration groove welded joints



Single-V-gro	ove weld (2)						Tolerances	
Butt joint (I	8)			1	₹.	As deta (see 2.9		fit up 3.4.4)
			Г			R = +1/1	6,-0 +1/4	,-1/16
			7	11 17	Т1		,-0° +10°	-
M - steel	(see 8.2.4, 9.2.5	Base metal thick	nes	Groove pr	T	T	Gas	
Welding	mioL	(U = unlim	ited)	Root	Groove	Permitted	shielding	1
process	designation	Т1	T ₂	opening	angle	positions*	(FCAW)	Note
				R = 1/4	a = 45°	All	-	-
SMAW	8-U2a	U	I - [	R = 3/8	a = 30°	F,OH	-	-
				R = 1/2	e = 20°	F,OH	-	-
				R = 3/16	e = 30°	F,V,OH	Required	A
FCAW	8-U2+GF	U	1 - [	R = 3/8	a = 30°	F	Not req.	A
PLAN				R = 1/4	a = 30°	V,OH	Not req.	A
SAW	8-L2+5	1/2 mux	-	R = 1/4	a = 30°	F	-	-
	8-U2-S	U		R = 5/8	a = 20°			-

Note C: Gouge root before welding other side.

Note J: If fillet welds are used in buildings to reinforce groove welds in corner and T-joints, they shall be equal to 1/4 T₁ but need not exceed 3/8 in. The reinforcement of groove welds in corner joints, when required, and T-joints in bridges shall be made with fillet welds equal to 1/4 T₁, but need not exceed 3/8 in.

*F = Flat, OH = Overhead.


Fig. 2.9.1 (continued) - Prequalified complete joint penetration groove welded joints


M = stani (	ove weld (2) (8)	10.2.4)			7,		As detail (see 2.9 R = +1/1 a = +10°	1.2) (see 3	-1/16
		Base metal thickness	T	Gr	oove preparation		Permitted	Gas shielding	
Weiding	Joint	U = unlimited	二	Root		iroove	swelding positions	(FCAWI)	Notes
process	designation	T ₁ T	2	opening R = 1/4	THE RESERVE TO THE PERSON NAMED IN	= 45°	All	-	11-1
SMAW	C-U2s	U 1	, -	R = 3/8		- 30,	F,OH	-	-
			+	R = 1/2	THE RESERVE AND ADDRESS OF THE PARTY OF THE	- 20"	F,OH	-	-
			1	R = 3/16		- 30"	F,V,OH	Required	A
GMAW FCAW	C-U2s-GF	0 0	4	R = 3/8	STREET, SQUARE OF STREET, SQUARE STR	= 30°	F	Not req.	A
			ı	R = 1/4		= 30"	V,C:"	Not req.	A
SAW	C-L2s-S	1/2 max	U	R = 1/4		- 30"	F	-	-
SAW	C-U2-S	U	U	R = 5/8	THE PERSON	- 20"	F	-	-
	ove weld (2) B)			_		<del>-</del>			
ingle-V-gra utt jaint (		Base meral thickness	. 1		poove preparation	<del>-</del>	-	Ges	
waiding	Joint	metal thickness (U = unlimited)		Root opening Root face		As fit up (see 3.3.4)	Permitted welding positions	Gas shielding for FCAW	Note
utt joint (	8)	metal thickness	- 1	Root opening	Tolers As detailed	As fit up	welding	shielding for	
Waiding process	Joint designation	metal thickness (U = unlimited) T ₁		Root opening Root face Groove angle R = 0 to 1/8 f = 0 to 1/8	Tolera As detailed (see 2.9.2) +1/16,-0 +1/16,-0	As fit up (see 3.3.4) +1/16,-1/8 Not limited	welding positions	shielding for	Note
Waiding process SMAW	Joint designation	metal thickness (U = unlimited) T1 U .	T2 -	Root opening Root face Groove angle R = 0 to 1/8 f = 0 to 1/8 e = 60° R = 0 to 1/8 f = 0 to 1/8	As detailed (see 2.9.2) +1/16,-0 +1/16,-0 +1/16,-0 +1/16,-0 +1/16,-0	As fit up (see 3.3.4) +1/16,-1/8 Not limited +10°,-5° +1/16,-1/8 Not limited	welding positions All	shielding for FCAW	Note
Walding process SMAW GMAW FCAW	Joint designation 8-U2	metal thickness (U = unlimited) T1 U .	T ₂	Root opening Root face Groove angle R = 0 to 1/8 f = 0 to 1/8 e = 60° R = 0 to 1/8 e = 60° R = 0 to 1/8 e = 60°	Tolera As detailed (see 2.9.2) +1/16,-0 +1/16,-0 +10°,-0° +1/16,-0 +10°,-0°	As fit up (see 3.3.4) +1/16,-1/8 Not limited +10°,-5° +1/16,-1/8 Not limited +10°,-5° +1/16,-0 ±1/16 +10°,-5°	welding positions All	shielding for FCAW  -  Not required	C A,C
Walding process SMAW GMAW FCAW	Joint designation 8-U2	metal thickness (U = unlimited) T1 U . U Over 1/2 to 1 inclusive	T2 -	Root opening Root face Groove angle R = 0 to 1/8 f = 0 to 1/8 e = 60° R = 0 to 1/8 e = 60° R = 0 to 1/8 e = 60° R = 0 to 1/8 e = 60°	Tolers As detailed (see 2.9.2) +1/16,-0 +1/16,-0 +10°,-0° +1/16,-0 +10°,-0°	As fit up (see 3.3.4) +1/16,-1/8 Not limited +10°,-5° +1/16,-1/8 Not limited +10°,-5° +1/16,-0 ±1/16	welding positions All	shielding for FCAW  -  Not required	C A,C

Note C: Gauge root before welding other side.

Note K: Weld root after welding at least one pass on arrow side.

Fig. 2.9.1 (continued)—Prequalified complete joint penetration groove welded joints





Note C: Gauge root before welding other side.

Note J: If fillet welds are used in buildings to reinforce groove welds in corner and T-joints, they shall be equal to 1/4 T₁ but need not exceed 3/8 in. The reinforcement of groove welds in corner joints, when required, and T-joints in bridges shall be made with fillet welds equal to 1/4 T₁, but need not exceed 3/8 in.

Note K: Weld root after welding at least one pass on arrow side.

Note M: Double-groove welds may have grooves of unequal depth, but the depth of the shallower groove shall be no less than one-fourth of the thickness of the thinner part joined.

*F = Flat, OH = Overhead.

Fig. 2.9.1 (continued)-Prequalified complete joint penetration groove welded joints

Double V.	sore weld (3)							For	8-U3c-S on	ly
Butt joint (8				<u></u>	_				T ₁	Sı
			{		) \$1	<u> </u>		Over 2 2-1/2 3 3-5/8 4 4-3/4 5-1/2		1-3/- 2-1/1 2-3/- 2-3/- 3-1/- 3-3/-
M - Stee	ol (see 8.2.4, 9.2.	3, 10.25)		\( \tag{\chi}				For T ₁	> 6-1/4, or = 2/3 (T ₁ -1)	/4)
		Base		Groove pr	reparation				Gas	
Welding Joint process designation	metal thickness		Root opening	Tolerances			hetrin	shielding		
		d) T ₂	Root face Groove angle	As detailed (see 2.9)	As fit up (see 3.3.4)	welding positions		for (FCAW)	Notes	
SMAW	8-U3b	U.	٦	R = 0 to 1/8	+1/160	1 - 1/16,-1/8	-	All	-	C,N
GMAW FCAW	8-U3-GF	preferably 5/8 or larger	-	f = 0 to 1/8 a = g = 60°	+1/16,-0 +10°,-0	Not limited +10°,-5°	,	MI	Not required	A,C,
SAW	8-U3b-S	1-1/8 min	-	R = 1/8 f = 0 e = \$ = 60° S ₁ = 2/3 T ₁ , S ₂ = 3/8 min	+1/16,-0 +1/16,-0 +10°,-0	+1/16,-1/8 Not limited +10°,-5°		Flat	-	M, P
SAW	8-13-5	1-1/2 max	-	R = 0 1 = 1/4 max e = 80°; s = 80° S ₁ = 2/3 (T ₁ -1/4), S ₂ = 1	±0 +0,-1/4 +10°,-0° /3 (T ₁ -1/4)	+1/16,-0 Not limited +10°,-5°		Flat	•	M, N
SAW	8-U3e-S	U	-	R = 0 f = 1/4 max a = g = 80°	.±0 +0,-1/4 +10°,-0°	+1/16,-0 Not limited +10°,-5°		Flat		м, с
				To find S ₁ see table above	1: 52 - T1 -(S	+ 1/4)				

Note C: Gauge root before welding other side.


Note K: Weld root after welding at least one pass on arrow side.

Note M: Double-groove welds may have grooves of unequal depth, but the depth of the shallower groove shall be no less than one-fourth of the thickness of the thinner part joined.

Note P: Weld S₂ first with shielded metal arc low-hydrogen electrodes. Root of this weld shall be back gouged. Weld S₁ with single- or multiple-pass submerged arc weld in flat position after manual arc welding is completed on other side.

Note X: It is permissible for the groove opening to vary from 0-1/8 in., in which case, weld as follows: Weld the S₁ groove first with shielded metal arc using low hydrogen electrodes; complete the weld with submerged arc welding. The root of the SMAW weld shall be back gouged. Weld the S₂ groove with shielded metal arc using low hydrogen electrode or by submerged arc welding.

Fig. 2.9.1 (continued)-Prequalified complete joint penetration groove welded joints



T-joint (T)	-groove-weld (4)			- W		As deta	Tolerances	it up
Corner join	t (C)		P	7"	Note V	(see 2.5	9.2) (see	3.3.4)
			-			R = +1/1	60 +1/4	-1/16
M = stooi (s	<b>8.2.4, 9.2.5,</b> 1	0.2.4)	1	Note J		a =+10	-,-0" +10"	5*
Welding Joint		Base metal thickness (U = untimited)		Groove p	Permitted	Gas shielding		
process	designation	T ₁	T ₂	opening	Groove angle	welding positions*	(FCAW)	Notes
SMAW	TC-U4e	U	l u	R = 1/4	a = 45°	All	-	J.V
				R = 3/8	e = 30°	F, OH	-	J,V
				R = 3/16	a = 30°	All	Required	A. J. V
******			1 1	R = 3/8	4 = 30"	Flat		
GMAW FCAW	TC-U4c-GF	U	U	n = 3/0	e = 30	Plat	Not req.	A. J. V
GMAW FCAW	TC-U4e-GF	U	1"	R = 1/4	0 = 45"	All	Not req.	A, J, V
	TC-U4e-GF	U	"					


Note Br: Bridge application limits the use of these joints to the horizontal position (see 9.12.1.5).


Note J: If fillet welds are used in buildings to reinforce groove welds in corner and T-joints, they shall be equal to 1/4 T₁ but need not exceed 3/8 in. The reinforcement of groove welds in corner joints, when required, and T-joints in bridges shall be made with fillet welds equal to 1/4 T₁, but need not exceed 3/8 in.

Note V: For corner joints, the outside groove preparation may be in either or both members, provided the basic groove configuration is not changed and adequate edge distance is maintained to support the welding operations without accessive edge melting.

*F = Flat, OH = Overhead.


Fig. 2.9.1 (continued)-Prequalified complete joint penetration groove welded joints






- Note A: Not prequalified for ges metal arc welding-using short circuiting transfer. Refer to Appendix D.
- Note C: Gauge root of joint before welding the other side.
- Note J: If fillet welds are used in buildings to reinforce groove welds in corner and T-joints, they shall be equal to 1/4 T₁ but need not exceed 3/8 in. The reinforcement of groove welds in corner joints, when required, and T-joints in bridges shall be made with fillet welds equal to 1/4 T₁, but need not exceed 3/8 in.
- Note V: For corner joints, the outside groove preparation may be in either or both members, provided the basic groove configuration is not changed and adequate edge distance is maintained to support the welding operations without excessive edge melting.
- Note Y: Shielded metal arc or submerged arc backing fillet weld required.


Fig. 2.9.1 (continued) - Prequalified complete joint penetration groove welded joints





- Note A: Not prequalified for gas metal arc welding using short circuiting transfer. Refer to Appendix D.
- Note C: Gauge root of joint before welding the other side.
- Note J: If fillet welds are used in buildings to reinforce groove welds in corner and T-joints, they shall be equal to 1/4 Tq but need not xceed 3/8 in. The reinforcement of groove welds in corner joints, when required, and T-joints in bridges shall be made with fillet welds equal to 1/4 T₁, but need not exceed 3/8 in.
- Note V: For corner joints, the outside groove preparation may be in either or both members, provided the basic groove configuration is not changed and adequate edge distance is maintained to support the welding operations without excessive edge melting.
- Note Y: Shielded metal arc or submerged arc backing weld required.

Fig. 2.9.1 (continued)-Prequalified complete joint penetration groove welded joints



Note Br: Bridge application limits the use of these joints to the horizontal position (see 9.12.1.5).

Note C: Gauge root of joint before welding the other side.


Note J: If fillet welds are used in buildings to reinforce groovs welds in corner and T-joints, they shall be equal to 1/4 T₁ but need not exceed 3/8 in. The reinforcement of groove welds in corner joints, when required, and T-joints in bridges shall be made with fillet welds equal to 1/4 T₁, but need not exceed 3/8 in.

Note M: Double-groove welds may have grooves of unequal depth, but the depth of the shallower groove shall be no less than one-fourth of the thickness of the thinner part joined.

Note V: For corner joints, the outside groove preparation may be in either or both members, provided the basic groove configuration is not changed and adequate edge distance is maintained to support the welding operations without excessive edge melting.


*F = Flat, OH = Overhead.


Fig. 2.9.1 (continued)-Prequalified complete joint penetration groove welded joints



- Not prequalified for gas metal arc welding using short circuiting transfer. Refer to Appendix D.
- Gauge root of joint before welding the other side. Note C:
- If fillet welds are used in buildings to reinforce groove welds in corner and T-joints, they shall be equal to 1/4 T₁ but need not exceed 3/8 in. The reinforcement of gronve welds in corner joints, when required, and T-joints in bridges shall be made with fillet welds equal to 1/4 T₃, but need not exceed 3/8 in.
- Note M: Double-groove welds may have grooves of unequal depth, but the depth of the shallower groove shall be no less than one-fourth of the thickness of the thinner part joined.
- Note V: For corner joints, the autaide groove preparation may be in either or both members, provided the basic groove configuration is not changed and adequate edge distance is maintained to support the welding operations without excessive edge melting.
- Note Z: When lower place is beveled, make the first root pass on this side.


Fig. 2.9.1 (continued)-Prequalified complete joint penetration groove welded joints





- Gauge root of joint before welding the other side.
- Note J: If fillet worlds are used in buildings to reinforce groove welds in corner and T-joints, they shall be equal to 1/4 T1 but need not succeed 3/8 in. The reinforcement of groove welds in corner joints, when required, and T-joints in bridges shall be made with fillet welds equal to 1/4 T₁, but need not exceed 3/8 in.
- Note M: Double-groove welds may have grooves of unequal depth, but the depth of the shallower groove shall be no less than one fourth of the thickness of the thinner part joined.
- Note V: For corner joints, the outside groove preparation may be in either or both members, provided the basic groove configuration is not changed and adequate edge distance is maintained to support the welding operations without excessive edge melting.

Fig. 2.9.1 (continued)-Prequalified complete joint penetration groove welded joints



Note A: Not prequalified for gas metal arc welding using short circuiting transfer. Refer to Appendix D.

Fig. 2.9.1 (continued) - Prequalified complete joint penetration groove welded joints


Note C: Gauge root of joint before welding the other side.


Note J: If fillet welds are used in buildings to reinforce groove welds in corner and T-joints, they shall be equal to 1/4 T₁, but need not exceed 3/8 in. The reinforcement of groove welds in corner joints, when required, and T-joints in bridges shall be made with fillet welds equal to 1/4 T₂.

These fillet welds need not exceed 3/8 in.

Note M: Double-groove welds may have grooves of unequal depth, but the depth of the shallower groove shall be no less than one-fourth of the thickness of the thinner part joined.


^{*}F = Flat, OH = Overhead.






- Note A: Not prequalified for gas metal arc welding using short circulting transfer. Hefer to Appendix D.
- Note Br: Bridge application limits the use of these joints to the horizontal position (see 3.12.1.5).
- Note C: Gauge root before welding other side.
- Note J: If filler welds are used in buildings to reinforce groove welds in corner and T-joints, they shall be equal to 1/4 T₁ but need not exceed 3/8 in. Groove welds in corner and T-joints of bridges shall be reinforced with filler welds equal to 1/4 T₁ but not more than 3/8 in.
- Mote V: For corner joints, the outside groove preparation may be in either or both members, provided the basic groove configuration is not changed and adequate edge distance is maintained to support the welding operations without excessive edge melting.
  - *F = Fist, OH = Overhead.

Fig. 2.9.1 (continued)-Prequalified complete joint penetration groove welded joints





- Note A: Not prequalified for gas metal arc welding using short circuiting transfer. Refer to Appendix D.
- Note Br: Bridge application limits the use of these joints to the horizontal position (see 9.12.1.5).
- Gauge root before welding other side.
- If filler welds are used in buildings to reinforce groovs welds in corner and T-joints, they shall be equal to 1/4 Tq but need not exceed 3/8 in. The reinforcement of groove welds in corner joints, when required, and T-joints in bridges shall be made with Note C: fillet welds equal to 1/4 T₁, but need not exceed 3/8 in.
- Note M: Dauble-groove welds may have grooves of unequal depth, but the depth of the shallower groove shall be no less than one-fourth of the thickness of the thinner part joined.
- Note V: For corner joints, the outside groove preparation may be in either or both members, provided the basic groove configuration is not changed and adequate adge distance is maintained to support the welding operations without excessive edge melting.
  - * F . Flat, OH . Overhead.


Fig. 2.9.1 (continued) - Prequalified complete joint penetration groove welded joints


Double J-gri	pove weld (9)			V					Tolerances	
T-joint (T) Corner joint		-	*	24.1				As deta		fit up 3.3.4)
		_	_	-1-		Note V		R = +1/1	160 +1/	161/8
			li	7 4	1.	Sils		a = +10	r0° +1	0",-5"
			V	12	1	0		1 =+1/1	6,-0 Not	limited
		L	L,	1	_	Note.		r =+1/	4,-0 1	1/16
		metal thickne			Groove pr	reperation		Permitted	Gas	
Welding	Joint designation	(U = unlimit	Tz	Root	Groove	Root	Groove	welding positions	FCAW	Note
burness	nearly serious	Tı	12	Opening	an right					
		U.		R = 0 to 1/8	e=45°	f= 1/8	r= 3/8	.All	-	C. J.
SMAW	TC-US	-	U					F,OH	-	C. J.

	cove weld (9)		1		,			T	olerances	
T-joint(T) Corner join	t (C)		~	129	-	Note V		As deta		fit up 3.3.4)
		17			Г	100		R=+1/1	50 +1/1	6,-1/8
		7		1		7 1	)	e =+10°	,-0° +10	7,-5"
				A1724	'	6	12	f =+1/1	6,-0 Not	limited
				IR-X	L	~	ote J	r =+1/4	4,-0 11	/16
		metal thicks		- 4 -	Greave prep	eration		Permitted	Gas shielding	
	The state of the s	The second contract of								
Welding	Joint designation	(U = unlim	T ₂	Root	Groove angle	Root	Groove	positions*	for (FCAW)	Notes
process	designation	T ₁	Τ2							Notes C, J,
	The second secon	T ₁		opening	angle	fece	radius	positions*		

- Nute A: Not prequalified for gas metal arc welding using short circuiting transfer. Refer to Appendix D.
- Note C: Goige root before welding other side.
- Note J: If fillet welds are used in buildings to reinforce groove welds in corner and T-joints, they shall be equal to 1/4 T₁ but need not exceed 3/8 in. The reinforcement of groove welds in corner joints, when required, and T-joints in bridges shall be made with fillet welds equal to 1/4 T₁, but need not exceed 3/8 in.
- Note M: Double-groove welds may have grooves of unequal depth, but the depth of the shallower groove shall be no less than one-fourth of the thickness of the thinner part joined.
- Note: V: For corner joints, the outside groove preparation may be in either or both members, provided the basic groove configuration is not changed and adequate edge distance is maintained to support the welding operations without accessive edge melting.
  - * F = Flat, OH = Overhead.

Fig. 2.9.1 (continued) - Prequalified complete joint penetration groove welded joints






Note 8: Joints welded from one side. These welds are not applicable to bridges.

Note C2: Root need not be gouged before welding second side. This weld is not applicable to bridges.

Fig. 2.10.1-Prequalified partial joint penetration groove welded joints





Note B: Joint is welded from one side only.

Note E: Minimum effective throat (E) as shown in Table 2.10.3; S as specified on drawings.

Note L: Butt and T-joints are not prequalified for bridges.

Fig. 2.10.1 (continued) - Prequalified partial joint penetration groove welded joints





Note 8: Joint is kelded from one side only.

Note E: Minimum effective throat (E) as shown in Table 2.10.3; S as specified on drawings.

Note L: Butt and T-joints are not prequalified for bridges.

Note Mp: Double-groove welds may have grooves of unsqual depth, provided they conform to the limitations of Note E. Also. the effective throat (E), less any reduction, applies individually to each groovs.

Note W: Unbeveled face is the lower edge for horizontal position.

# Fit-up tolerance, SAW: see 3.3.2; for rolled shapes R may be 5/16 inches in thick plates if backing is provided.

Fig. 2.10.1 (continued)-Prequalified partial joint penetration groove welded joints

bevel-groov pirk (8) vt(T)			Г	1	1	193			1
er joint (C)	_		1	-	7-4-				_
			_	Groo	re preparation		Permitted	Effective	
T		Base metal thickness	1	Root opening	Toleran	As fit up	welding positions	throat (E)	Notes
veiding	Joint designation	(U = untimited)		Root face Groove angle R = 0	+1/16 -0	(see 3.3.4) ±1/16 ±1/16	All	S-1/8	E. L.
process		7/16 min (for bridges	.	1 = 1/8 min	+100	+10"5"		1	-
SMAW	STC.P4	1/2 min)				21/16	F,H	s	AL
GMAW	STCP4-GF	1/4 min (for bridges 5/16 min)	υ	R = 0 f = 1/8 min = -45°	+1/16,-0	±1/16 +10°,-5°	V,0H	S-1/8	
FCAW		7/16 min			1.0	+3/16,-0+	Flat	5	E.
SAW	TC.P45	7/16 min (for bridges 1/2 min)	U	R = 0 f = 1/4 min e = 60°	+10,-0	±1/16 +10°,-5°		1	1

- Note E: Minimum effective throat (E) as shown in Table 2.10.3; S as specified on drawings.
- Note V: For corner joints, the outside groove preparation may be in either or both members, provided the basic groove sonfiguration is not changed and adequate edge distance is maintained to support the welding operations without expensive arise meltins. Note L. Butt and T-joints are not prequalified for bridges.
  - # Fit-up tolerance, SAW: see 3.3.2; for rolled shapes R may be 5/16 inches in thick plates if backing is provided.

Fig. 2.10.1 (continued)-Prequalified partial joint penetration groove welded joints * F = Flat, H = Horizontal, V = Vertical, OH = Overhead.

ouble bavel urt joint (B) -joint (T) corner joint (				31 1			3		
		Base Enetal thickne			pove preparation			Etterrine	
Welding Joint		(U = unlimite		Root opening Root face Groove angle	As detailed	As fit up (see 3.3.4)	Permitted welding positions*	Effective throat (E)	Notes
SMAW	designation STC-P5	3/4 min (for bridges 1/2 min)	U	R = 0 f = 1/8 min e = 45°	+17.6,-0	±1/16 ±1/16 +10°,-5°	All	S-1/8	E, L. Mp. V
		1/2 min		8-0	+1/16,-0	±1/16	F,H	s	A. E.
GMAW FCAW	STC-PS-GF	(for bridges 5/8 min)	U	f = 1/8 min	+10",-0"	£1/16 +10°,-5°	V,OH	S-1/8	Mp.
run.		3/4 min					-	-	$\vdash$
SAW	TC-P5-S	3/4 min (for bridges 7/8 min)	U	R = 0 f = 1/4 min e = 60°	±0 -0 +10°,-0°	+3/16,-0+ ±1/16 +10°,-5°	Fiat	s	E. L.

Note E: Minimum effective throat (E) as shown in Table 2.10.3; S as specified on drawings.

Note L: Butt and T-joints are not prequalified for bridges.

Note Mp: Double-groove walds may have grooves of unequal depth, provided they conform to the limitations of Note E. Also, the effective throat (E), less any reduction, applies individually to each groove.

Note V: Fox corner joints, the outside groove preparation may be in either or both members, provided the basic groove configuration is not changed and adequate edge distance is maintained to support the welding operations without successive edge melting.

e Fit-up tolerance, SAW: see 3.3.2; for rolled shapes R may be 5/16 inches in thick plates if backing is provided.

* # = Flet, H = Horizontal, V = Vertical, OH = Overbead.

Fig. 2.10.1 (continued)-Prequalified partial joint penetration groove welded joints

Single-U-grad Butt joint (B Corner joint		[]	7	7					
		Base metal thickn	-T2-	G Root opening	rgove preparation			Effective	
Welding	Joint designation	(U = unilmit	ed)	Root face Groove radius Groove angle	As detailed (see 2.10.2)	As fit up (see 3.3.4)	Permitted welding positions	throat (E)	Notes
SMAW	BC-P6	1/4 min (for bridges 5/16 min)	U	: = 0 to 1/8 f = 1/8 min r = 1/4 e = 45°	+1/16,-0 -0 +1/4,-0 +10°,-0°	±1/16 ±1/16 ±1/16 +10°,-5°	All	s	E, L
GMAW FCAW	BC-P6-GF	1/4 min (for bridges 5/16 min)	U	R = 0 f = 1/8 min r = 1/4 a = 20°	+1/16,-0 -0 +1/4,-0 +10°,-0°	±1/16 ±1/16 ±1/16 +10°,-5°	All	s	ĄE
SAW	8C.76.S	7/16 min (for bridges 1/2 min)	U	R = 0 f = 1/4 min r = 1/4 e = 20°	±0 -0 +1/4,-0 +10°,-0°	+3/16,-0+ ±1/16 ±1/16 +10°,-5°	Flat	s	E, 1

Note E: Minimum effective throat (E) as shown in Table 2.10.3; S as specified on drawings.

Note L: Butt and Y-joints are not prequalified for bridges.

# Fit-up tolerance, SAW: see 3.3.2; for rolled shapes R may be 5/16 inches in thick plates if backing is provided.

Fig. 2.10.1 (continued) - Prequalified partial joint penetration groove welded joints

Jouble V-gro lutt joint (8	oove weld (7)			7		× 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1				
		Base metal thickn		Root opening	groove preparatio	on ances		1		
Welding		Joint designation	(U = unlimit	T ₂	Root face Groove radics Groove angle	As detailed (see 2.10.2)	As fit up (see 3.3.4)	Permitted welding positions	Effective throat (E)	Notes
SMAW	8-97	1/2 min (for bridges 5/8 min)	-	R = 0 to 1/8 f = 1/8 min r = 1/4 e = 45°	+1/16,-0 -0 +1/4,-0 +10°,-0°	±1/16 ±1/16 ±1/16 ±1/16 +10°,-5°	All	S	E. L.	
GMAW FCAW	8-P7-GF	1/2 mi (for bridges 5/8 min)	-	R = 0 f = 1/8 min r = 1/4 e = 20°	+1/16,-0 -0 +1/4,-0 +10°,-0°	±1/16 ±1/16 ±1/16 +10°,-5°	All	s	A, I	
SAW	8- <b>P</b> 7-S	3/4 min (for bridges 7/8 min)	-	R = 0 f = 1/4 min r = 1/4 e = 20°	±0 -0 +1/4,-0 +10°,-0°	+3/16,-0+ ±1/16 ±1/16 +10*,-5*	Flat	s	E, L	

Note E: Minimum effective throat (E) as shown in Table 2.10.3; S as specified on drawings.

Note L: Butt and T-joints are not prequalified for bridges.

Note Mp: Double-groove welds may have grooves of unequal depth, provided they conform to the limitations of Note E. Also, the effective throat (E), less any reduction, applies individually to each groove.

. Fit-up tolerance, SAW: see 3.3.2; for rolled shapes R may be 5/16 inches in thick plates if backing is provided.

Fig. 2.10.1 (continued)-Prequalified partial joint penetration groove welded joints

Single J grad Butt joint (II T-joint (T) Corner joint					-	<b>Y</b>	3		
		- Base		Groove preparation					
Welding	Joint designation	metal thickness (U = unlimited)		Root opening Root face Groove radius	Tolarences		Permitted	Effective	
					As detailed	As fit up	welding	throat	Notes
		Tı	T ₂	Groove angle	(see 2.10.2)	(see 3.3,4)	positions	(E)	NOUS
		1/4 min (for bridges U 5/16 min)		e = 45°	+10",-0"	+10°,-5°	All	s	E.L.
SMAW	STC-PE		U	R = 0 to 1/8 f = 1/8 min r = 3/8	+1/16,-0	±1/16 ±1/16 ±1/16			
GMAW. FCAW	BTC-P8-GF	1/4 min (for bridges 5/16 min)	U		+1/4,-0		All	s	A.E.
				30"	+10",-0"	+10",-5"			
		7/16 mic		e = 20°	+10",-0"	+10",-5"			
SAW	CP8-S	(for bridges U	R=0 f=1/4 min		+3/16,-0+	Flat	S	E, V	
SAW	T-PB-S	7/16 min	U	r = 1/2	+1/4,-0	± 1/16	Flat	s	E, L
				45	+10",-0"	+10",-5"			


Note E: Minimum effective throat (E) as shown in Table 2.10.3; S as specified on drawings.

Note L: Butt and T-joints are not prequalified for bridges.

Note V: For corner joints, the outside groove preparation may be in either or both members, provided the basic groove configuration is not changed and adequate edge distance is maintained to support the welding operations without excessive edge melting.

e Fit-up tolerance, SAW: see 3.3.2; for rolled shapes R may be 5/16 inches in thick plates if backing is provided.

Fig. 2.10.1 (continued) - Prequalified partial joint penetration groove welded joints



- Note A: Not prequalified for gas metal are welding using short circuiting transfer. Refer to Appendix D.
- Note E: Minimum effective throat (E) as shown in Table 2.10.3; S as specified on drawings.
- Note J: If fillet welds are used in buildings to reinforce groove welds in corner and T-joints, they shall be equal to 1/4 T₁ but need not exceed 3/8 in. The reinforcement of groove welds in corner joints, when required, and T-joints in bridges shall be made with fillet welds equal to 1/4 T₁, but need not exceed 3/8 in.
- Note L: Butt and T-joints are not prequalified for bridges.
- Note Mp: Double-groove welds may have grooves of unequal depth, provided they conform to the limitations of Note E. Also, the effective throat (E), less any reduction, applies individually to each groove.
- Note V: For corner joints, the outside groove preparation may be in either or both members, provided the basic groove configuration is not changed and adequate edge distance is maintained to support the welding operations without excessive edge melting.
  - a Fit-up tolerance, SAW: see 3.3.2; for rolled shapes R may be 5/16 inches in thick plates if backing is provided.

Fig. 2.10.1 (continued)-Prequalified partial joint penetration groove welded joints

Corrective Action & Disposition of Hanger Reinspection	on Hacked
Hanger No. 7021-EC2357	IN a CT NUS
Hanger Ispection Report # 150	po attached  report nos
Detail rework required listed below:	
1. Correct undersize weld- See detail	
(B) of the attached report	QA Accept
	QA Accept
2.	
	QA Accept
3.	
	QA Accept
4.	
	QA Accept
5.	
	QA Accept
6.	
	QA Accept
7.	
	QA Accept
8	
	QA Accept
X814 Meluin 32/68 1 128/81	
Date //	10/1
Issued To Date OA Acce	1 1 281.81 epted By Date
Date Qx Acce	epted by Date

P. O. Box 101, New Hill, N. C. 27562 March 31, 1983

in the second of the second of

Mr. James P. O'Reilly United States Nuclear Regulatory Commission Region II 101 Marietta Street, Northwest (Suite 3100) Atlanta, Georgia 30303 NRC-52

CAROLINA POWER & LIGHT COMPANY
SHEARON HARRIS NUCLEAR POWER FLANT
1986-90 - 900,000 KW - UNITS 1 & 2
SEISMIC CLASS 1 ELECTRICAL, HVAC AND CONDUIT
SUPPORTS INSTALLED AND ACCEPTED THAT WERE NOT
IN ACCORDANCE WITH DESIGN, ITEM 119

Dear Mr. O'Reilly:

On March 3, 1983, Mr. N. J. Chiangi notified the NRC (Mr. A. Hardin) of a potentially reportable item per the provisions of 10CFR50.55(e). The NRC was informed that Seismic Class 1 Electrical, HVAC and Conduit Supports were fabricated and installed on site and accepted by a Quality Control inspector, no longer with CP&L, that were not in accordance with design documents. There are approximately 900 items which are suspect. This item is still being evaluated for reportability and to determine acceptability or extent of corrective action required. These evaluations are expected to be complete by May 16, 1983. For this reason, we request an extension until June 1, 1983 for submitting a report on the reportability of this item.

Thank you for your consideration in this matter.

Yours very truly,

R. M. Parsons

Project General Manager

Shearon Harris Nuclear Power Plant

RMP/sh

cc: Mr. G. Maxwell (NRC-SHNPP)

Mr. V. Stello (NRC)

bcc: Mr. H. R. Banks

Mr. G. L. Forehand

Mr. N. J. Chiangi

Mr. C. H. Moseley

Mr. W. J. Hurford

Mr. S. Hinnant

Mr. A. B. Cutter

Dr. T. S. Elleman

Mr. L. I. Loflin

Mr. M. F. Thompson

Mr. M. A. McDuffie

Mr. J. Nevill

Mr. R. M. Parsons


Mr. H. W. Bowles

Mr. Sheldon D. Swith

Dr. J. D. E. Jeffries

# CP&L Carolina Power & Light Company

GOPY



File: SH N-2/18 Item 72

Mr. James P. O'Reilly
United States Nuclear Regulatory Commission
Region II
101 Marietta Street, Northwest
Atlanta, Georgia 30303

SREARON HARRIS NUCLEAR POWER PLANT UNIT 1

DOCKET NO. 50-400
UNIDERSIZED SKEWED TES FILLET WELDS ON SEISMIC I PIPE HANGERS

Dear Mr. O'Reilly:

On February 24, 1982, the MRC (Mr. T. Landis) was notified by Carolina Power & Light Company (Mr. N. J. Chiangi) of an item considered potentially reportable per the provisions of 10CFR50.55(e) and 10CFR21. The NRC was informed that certain skewed tee welds on previously accepted Seismic I pipe hangers were subsequently found to be rejectable due to undersize welds.

The intent of this letter is to inform you that Carolina Power & Light Company has not beer able to complete its evaluation corcerning this matter since all reinspections have not been completed to determine the scope of the problem. Bergen-Paterson and CP&L QC inspectors have been made aware of the correct method of measuring skewed tee welds and Ebasco vendor surveillance and site receiving QA inspectors have been alerted to this problem.

Due to the amount of reinspection involved, it is now anticipated that the completion of the reportability evaluation will be accomplished by November 15, 1982, at which time, the NRC will be informed of the results. Completion of corrective action will depend on the results of the evaluations and extent of corrective action required. Once the item is deemed reportable, the NRC will be so notified and the projected date of completion of corrective action and final report provided through submittal of an interim letter.

Thank you for your consideration in this matter.

CLM/mt

Yours very truly,

# Original Signed By

N. J. Chiangi N. J. Chiangi - Manager

N. J. Chiangi - Manager Engineering & Construction Quality Assurance/Quality Control

CLM/mt

cc: Mr. G. Maxwell Mr. V. Stello (2)


bcc: Mr. H. R. Banks
Mr. N. J. Chiangi
Mr. A. B. Cutter
Mr. C. R. Dietz
Dr. T. S. Elleman
Mr. G. L. Forehand
Mr. T. L. Harrington
Mr. E. Harris
Mr. S. Hinnant

Mr. P. W. Howe
Mr. L. I. Loflin
Mr. A. M. Lucas
Mr. M. A. McDuffie
Mr. C. H. Moseley
Mr. R. M. Parsons
Mr. Sheldon D. Smith
Mr. R. B. Starkey



Raleigh, N. C. 27602

September 13, 1982



Mr. James ?. O'Reilly United States Nuclear Regulatory Commission Region II 101 Marietta Street, Northwest Atlanta, Georgia 30303

> SHEARON HARRIS NUCLEAR POWER PLANT DOCKET NO. 50-400 SEISMIC PIPE HANGERS PREVIOUSLY ACCEPTED BY OC WELDING INSPECTOR

Dear Mr. O'Reilly:

Attached is an interim report on the subject item which was deemed reportable per the provisions of 10CFR50.55(e) on August 13, 1982. CP&L is pursuing this matter, and it is currently projected that corrective action and submission of the final report will be accomplished by July 1, 1983.

Thank you for your consideration in this matter.

Yours very truly, Original Signed By N. J. Chiangi

N. J. Chiangi - Manager Engineering & Construction Quality Assurance/Quality Control

NJC/gea (212) Attachment

cc: Mr. G. Maxwell W/A Mr. V. Stello

bcc: Mr. H. R. Banks W/A

Mr. D. L. Bensinger/HI/A-2D W/A

Mr. A. B. Cutter W/A

Mr. C. R. Dietz W/A

Dr. T. S. Elleman W/A

Mr. G. L. Forehand (2) W/A

Mr. T. L. Harrington W/A

Mr. E. Harris W/A

Mr. S. Hinnant W/A

Mr. P. W. Howe W/A

Mr. L. I. Loflin W/A

Mr. A. M. Lucas W/A


Mr. M. A. McDuffie W/A

Mr. C. H. Moseley, Jr. W/A

Mr. R. M. Parsons W/A

Mr. Sheldon D. Smith W/A

Mr. R. B. Starkey, Jr. W/A



## CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT

UNIT NO. 1

PIPE HANGERS PREVIOUSLY ACCEPTED BY QC WELDING INSPECTORS

Interim Report September 8, 1982

Reportable Under 10CFR50.55(e)

SUBJECT:

Deficient field welds on pipe hangers previously accepted by QC welding inspectors.

ITEMS:

Seismic pipe hangers.

SUPPLIED BY:

N/A - Hangers furnished by Bergen-Paterson, but problem deals with field welds.

NATURE OF DEFICIENCY:

- 1. Missing and undersized welds
- 2. Cosmetic weld defects
- 3. Inaccurate and incomplete QC documentation
- QC inspections performed by personnel whose work was suspect
- 5. Poor workmanship

DATE PROBLEM OCCURRED:

Prior to July 29, 1982

DATE PROBLEM REPORTED:

August 13, 1982 - CP&L (N. J. Chiangi) notified the NRC (A. Hardin) that this item was reportable under the provisions of 10CFR50.55(e).

SCOPE OF PROBLEM:

Pipe hangers having field welds were found to be unacceptable. Per the letter submitted on August 13, 1982, 38 hangers were identified as being unacceptable. Since that time approximately 140 additional hangers have been identified as having weld deficiencies. As a result of the increase in problems it is thought that the hanger program needs extensive evaluation. For this reason, approximately 4000 seismic pipe hangers must be reinspected to ensure all identified problems are corrected.

## Note

The scope of the reinspection will include undersized skewed-tee welds which were found to be potentially reportable (see CQAD 82-519 dated 3/24/82) and the deficient shop welds which were reportable (see NPED-821332 dated 8/10/82).

SAFETY IMPLICATION:

Deficient welds could cause a pipe hander supporting a safety-related pipe to fail under seismic conditions. As a result, this could adversely affect the safe operation of this facility.

REASON THE DEFICIENCY IS REPORTABLE:

The deficiencies represent a breakdown in the QA program as well as deficiencies in construction.

CORRECTIVE ACTION:

- Have prepared a pipe hanger inspection/ documentation procedure (QCI 19.3).
- Continuing to hold training classes with both craft and inspection personnel.
- NDEP-601 is being revised so that visual inspection criteria for pipe hangers will comply with AWS D.1.1.
- 4. Have begun routine surveys performed by QC Supervisor on each QC inspector's field work to ensure that the inspector complies with the QC procedures.
- Each inspector's paper work is being reviewed on a routine basis.
- 6. Documentation has been reviewed identifying hangers requiring reinspection. Preparations are in precess for hanger reinspection, reworking - if required, and correctly documenting all affected seismic pipe hangers.


FINAL REPORT:

A final report will be issued once the corrective action described above has been completed. It is projected that the submittal date is July, 1983.

FCR etc 41-3(e)

000E	SHEARCH HARRIS NUCLEAR POWER PLANT FIELD CHANGE REQUEST/PERMANENT WALVER  PW - 380  PW - 380
Type of Request:	See Recommended Action Non-ASME CASME Section III Division 2
Identification of An	rea and Item: Augle Iron Connections for Cable tray, Condait, and Q non-Q
	Conflict/Condition
Honger And Hauger	or Attachment All structural steel HUAC, Conduit and cable tray suggest Drawings (ATTACHMENT A)
EBASCO structus  CN Angle iron cons  on the two posselle  There are cases in  sides and the side	ral connection details typically call for three sides to be welded vections. Typically the drawings will call for a certain size weld I sides and the end (see attachment A sheet lof 2 for Definitions) the field when the constructor has welded the two parallel opposite the end.
Recommended Action:	☐ Please Investigate and Resolve ☑ Please Resolve as Follows
IN such coses with the proper size the end loscalled the length of the	where the parallel sides and the side opposite the end are welded weld required by the drawing and when the iength of the weld on the side opposite the end is equal to or greater than weld on the end is equal to or greater than weld on the end is equal to or greater than weld on the end is equal to or greater than
the drawings), All	Uncontrolled Copy
	- > FOR INFORMATION ONLY
Justification: [By E	BASCOT ; PROPOSED RECOMMENDED ACTION WILL NOT JEOPARDIZE THE INTEGRITY OF THE STRUCTURE.
Requested by:  hades face  Discipline Enginee	Site Approval:    1/3/8/ C. Henried 1-11-81   Date DOCUMENT CONTROL    Date DOCUMENT CONTROL
First Distribution:	MERENDAR (COOV) Vie Satarion

Definitions of sides to be welded	
	Parallel sides Attachment A  Sht. 1 of 2
	Arrow Indicates  End
	Side apposite of End
- Attachment A .ch	leet 1+2



1/0,00 FIELD CHA	NA POWER & LIGH HARRIS NUCLEAR/ NGE REQUEST/PER	POWER PLANT	Page 1 of 200
	mended Action	Non-ASME □ ASME Sec	tion III Division 1
	Conflict/Condit	ion	
UNEUN	trollec	Copy	
	FORMATION ched cons	N UNLY finaction sheet	
MA			
DO NOT USE FOR C	CONSTRUCTION	☐ Please Investigate ☐ Please Resolve as	
SEE EBASCO COM		pg. 2054	MAR 1 0 1981 SHEARON HARRIS N. P. P.
Justification: Recommended structual intogrity of	the sup	Most compromi By Ebesco	se the
Requested by:  Discipline Engineer  First Distribution:	/13/8/ Date	Senior Resident Eng	
(Original) Design Organization (Copy) Churk Franch		(Copy) (Copy)	Chletter 0

Children and Children Library and the Company of the second and the contract of the contract o

(17 1/13/61 OY____UATE ____ POWER PLANT CONSTRUCTION SHEET 3 OF 34 LHKD. BY____DATE ____ COMPUTATION SHEET DEPT. ____ FCK-15-3728211 SUEJECT____ FORM NO. 1630 Conthet / Condition Thre exist in the field conditions where the embed design drawings call for specific lengths of embedded states. In a majority of cases, the total lengths of the embadded states are obtained by using a combination of shorter plates and to and. Using this type of construction pracbetween the embedded plates. In Certain areas, in lacating the gusset plates to the embed plates to attach a support hanger, the gusset plates needs to be welded across the gap between the two adjoining embedded plates What is the minimum space allowed between the embedded plates before it becomes necessary to use a bridging plate, and what is the maximum distance betwear the embedded plates allowed before a bridging plate is no longer permissible? recommended Action (OPTION #1) Allow the field to use a 1"x5/2" x6"4 bridging plate for a WY or CI embedded strip plate, 1"x712"x64 bridging plate for a W1 or C1 embedded strip plate if the minimum distance between the adjoining plates is 14, of an inch, and a maximum distance of one inch between the adjoining plates. A minimum of three inches of bridging plate shall be welled to each adjoining embed, and where necessary, the attaching members shall be shortened by one inch to, compensate for the one inch thick bridging plate.

A DON should be initiated to incorporate this Fort to

i drawing ONE-218-6-6091

	DATE	POWER PLANT CONSTRUCTION COMPUTATION SHEET	SHEET # OF # DEPT FOR-15-372 Kee
· <u></u>			
	1 /	Option = 2)	FORM NO. 1630
In a	Hermative to	of construction to op.	tion # with
The 5	ame confl	ict/ anditions as sta	ted above
15 10	replace In	ader to make up for	late to the
between	the adjo	ining embedded strip	of the Tar
examp	e it a 3/0	" gap exists between	adjoining
Strip	plates and	the disin drawings	require a
alate	long gussel	t plate, replace this	gusset.
is to	be used with	perger there is a ga	o between
adjam.	ing ombado	led strip plates of	"4" or more
up to	a maximum	of ane inch.	

Type of Request: Fermanent Waiver to "use-as-is" ASME Section Field Change Recommended Action Non-ASME ASME Section	AP-IX-05 Exhibit 1 Page 1 of 2  00 III Division 2 tion III Division 1
Identification of Area and Item:  All Mores loveling Sespic Conduit And Cable Tray Harges	Q Non-Q
Conflict/Condition	
Reference Documents or Attachment All Profess Sheet Seismin	Cardit And
Tray Harger Erection Durs - SNP 45, FOR E. 078	
On sect. A and sect. 8 of FCE E-078 there are symbols indicating the need for square welds for the remection of the 14" gusset plates to angle. The field is training difficulties in execut particular type of weld.	to be used the vertical
Recommended Action:   Please Investigate	
Please Resolve as	
Allow the field to use a single beneled full por weld in place of the square weld.	enetration
wold in place of the square weld. Doct	MENT CONTROL
Uncontrolled Copy FOR INFORMATION ONLY	JAN 23 1981 STSILUTED IN HARRIS N. P. P.
Justification: Wold change will not compronise the structual, of the wolded connections.	
Requested by:  Site Approval:  Site Approval:  Discipline Engineer  Date  Senior Resident Eng	Auc 12-18-80 ineer Date
(Copy) Resign Organization (Copy) Resign (Copy)	25/2/4/2,-
(Copy)	

	AP-IX-05 ARON HARRIS HUCLEAR POWER PLANT D CHANGE REQUEST/RERMANENT WALVER Page 1 of 23
	ement Waiver to "use-as-is" ASME Section III Division 2 Recommended Action Non-ASME ASME Section III Division 1
Identification of Area and	Item: Cable Tray, Conduit, And HVAC hanger Supports Q (Angle Iron Connections)
Reference Documents or Att	Conflict/Condition  achment Coc 2169-G-7000 Series (7001-7199)
two parallel sides and to "Parallel sides, and iside	nection details typically call for three sides to be welded us. Typically the drawings call for a 3/16" weld on the the and. (Scientiachment sheet 3 of 3 for definitions of end, opposite end") the field where the Constructor has welded the two side opposite the end. See typical case 1, 2, and 3 on
Recommended Action:	Please Investigate and Resolve
	Please Resolve as Follows
the weld on the end	And when the length of the well on the side opposite longer than the length (called for by the drawings) of Allow the field to accept for use as is.  TOOMTONE CONSTITUTE CODY  FOR INFORMATION AND
the weld on the end	Allow the field to accept for use as is.  INCONTROLLED CODY  FOR INFORMATION ONLY  SSCO]; RECOMMENDED ACTION WILL NOT  JEOPARDIZE THE INTEGRITY OF THE  STRUCTURE.
Justification: [By EBA	FOR INFORMATION ONLY  SCO]; RECOMMENDED ACTION WILL NOT  JEOPARDIZE THE INTEGRITY OF THE

SHEARON HARRIS N. P P. ....

PAGE 343

Designed_ Proposed. Definition: End, Parallel sides, & Side_
opposide of end. Note: Arrows indicate sides welded Attach ment shoot 3 of 3

DEC 1 7 1930	DEC.	1 7	1530
--------------	------	-----	------

FCR-A5-250

•	ч-	TY-	02.
E	xh	ibi	7.1


Design Organization Approval (AE) ⊠ (NSSS) □ (	
Organization Approval (AE) (NSSS) (NSSS) (NSSS)	N/A) [ (Other) [ Telephone Resolution
tx	Yes No
Approved as Recommended Rejec	
requires the following Desire	- Conditional Approval
to be changed <u>CHANGES TO BE SHOWN ON</u> Comments:	AS-BUILT DUIS
comments:	-
121	
1:00 -	10
Signature Title	Walth PE 2/16/21
Signature Title Date	
Date	Signature Title Date
P&L Harris Plant Engineering Approval Required	Yes Telephone Resolution
30 M (2011 10 M M 10 M M 10 M M M M M M M M M M	□No □Yes □No
Approved as Recommended	
	d Conditional Approval
11	
041 111	- 01.00
3/3/81	0-6/11/1/1/
Distipline Engineer Date	THPE or PPE 2/3/8
te Concurrence: Recommend Dimplementation	Date
HAlternate Resolut	. 10011.
cond Distribution:	Senior Resident P
riginal) Document Control	
opy)	(Copy)
opy)	(Copy)
	(Copy)
lementation Completed as Approved?	
ments:	rov.
meats:	DYes ONo
	$\sim$
	00171
_	railed & trench 5/8/81
1 Distribution:	Discipline Engineer Date
	24.0
ginal) File in Doc. Contro	(Copy)
	100017
DEU 1 & 1980	(Copy)
it home	(Copy)
EIVIE ENGINEERING BEFT:	
- Indifferent BEPT:	


Pg 3. 49 FIR 15- 34 350

Conflict / Condition

Frohim =1) The field is having difficulties installing two CSBI-7 conduit support hangers as per Den 500 083 to the correct elevation due to the diagonal bracing coming in centact with the bottom of the CLXID.5 x 9-10" long channel. Channel location is five feet from column line 13. See page 4, for hanger bocation and page 5, for hanger detail

Problem "2) The field is also having difficulties in creeting hanger (381-71 located 12 feet from column line 13 and 4-6" from column line 0, one to a HIMC hanger interference. The design location of the HIMC hanger, number F1891, is 13 feet north of column line 13 and 4'4" west of column line 0. See page 4 for condit hanger location, page 6 for (381-71 hanger detail, page 7 for HUMC support hanger location and page 8 for HUMC hanger detail.






Dwg CAR 2168-6-170506 Rev 4

- I522 - 2'z

## NOTES

DESIGN FABRICATION & ESTEEL SHALL BE IN ACCO
SPECIFICATION FOR DE
ERECTION OF STRUCTURA
(The EDITION) AND EBASCO
STRUCTURAL STEEL SHALL
ASTM SPECIFICATION A:
TUBULAR STEEL SHALL BE IN
A-500 GR B OR A-501
ALL AUGLES TO BE 'N'THICK A

CLEANING & PAINTING OF !



Recommended Action

Problem 1) Allow the field to cut and relecte the diagonal bracing to clear the interference problem.

Problem 2) Allow the field to remove the east dia.

gonal brace of the HURC support which interferes with the installation of the conduit support


thanger, and relocate the diagonal brace to the

north side of the vertical leg. See page & for

detail.


The west diagonal brace can not be relocated to the north side of the west vertical leg due to no embed being located at the point where the west diagonal brace would need to be fastened. It the design load conditions for the HUAC transfer requires the west diagonal brace to also be relocated to the north side of the west vertical ling, allow the field to bridge across the existing embedded plates using a Clocated cornel. Allow the channel to be fastened to the embeds as per Fire As-314 Rev 1. The 'e' distance for the HUAC transfer support will remain as per designed.

MAR 2 : 1931	15-349 Por.1	Page	of 1/4
sign Organization Approval (AE)	(NSSS)□ (N/A) □ (Other	Telephone Reso	ution No
sign Organization Approval		IX 1es	
	The leased	Conditional Approv	al
Yapproved as Recommended	☐ Rejected	on Drawing, SAR, etc.	)
Approved as Recommended s change requires the following Do	cument(s) (Specificati	ω6.	
be changed CHANGES TO BE SHO ments: PER TELEDIN BETWEEN I	OWN ON AS-1301ET	AMES NEULL ON 3-1	1-81.
PERTELEON BETWEEN	VICE INDICATION -	0 4/1.03/17	21
SEE EBASCO COMME	INTS ON EBASCO)	y refacts	
9. N. ATTACHMENT		11 (0) 1= 4	1/8/
cholas C. Tassoulas SAE 3/2	24/8 Wa		te
Da	te Signatur	9 / 11010	
Signature		Telephone Res	□No
&L Harris Plant Engineering Approv	al Required	□No □Yes	LINO
		Conditional Appro	val
Approved as Recommended	Rejected		
7000			
2 . 00		11.1111	
1 /// /	1 0=	1/1/1/1/3/1/8/	
0 Freel 3/17/	Para MHPE or	DEF DE	ate
Discipline Engineer	Date	1 - 201 0	
	plementation	Elexillet to	3-18-81
	ternate Resolution	enior Resident Enginee	r Date
	-	Copy)	
Second Distribution:			
(Original) Document Control		(Copy)	
(Copy)		(Copy)	
(Copy)			
Implementation Completed as Appro-	ved?	□Yes	
Implementation		Пио	
Comments:			
1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1			
		Discipline Engineer	Date
	RECEIVEL	)	in it be
Final Distribution:	KECEIVEL		
	W 0 0 4 4004	(Copy)	
(Original) File in Doc. Control	MAR 2 4 1981	(Copy)	
(Copy)	M. V/EBER	(Cany)	
(Copy)	CIVIL ENGINEERING DEPT	• 12 (12 m) - 12 m - 1 m - 1	




FCR- AS - 349 Km, ATTACHMENT II


Pg 40f4




DESIGNED



**FNSTALED** 



DESIGNED




INSTALLED


1	EBASCO SE	RVICES INCORPORATED	
BY OY	DATE 3-24-81	NEW YORK	SHEET _ OF _
CHKD BY AD	12 DATE 3-24-81	OFS NO.	DERT
CLIENT_C	AR		
PROJECT	SHUPP		
SOMEON	ATTACHMENT TO	FCR - 45 - 3	49 21
			-T   Pc
			+
			<del></del>
		27.1111	
			ACCEPTABLE NEAR SIDE
			THE SIDE OR BOTH SIDES!
			OU NOT KEND BY DESIGN
	/		
			ACCEPTABLE NS
	CASE :		
		· · · · · · · · · · · · · · · · · · ·	
		- 0	
		X /	
		/	
		1	
		* * 1 * *******************************	
		· · · · · · · · · · · · · · · · · ·	
		ACCEPTABLE	NS OR FS OR
- > !		1 BOTH SIDES	BUT HOT REW'S
		BY DESIGN ,	
	CASE	TI .	
FORM 581 REY 7-71	THE RESERVE OF THE PARTY OF THE		

PROJECT ENDITEDING PW-AS-347

Page 2 of 23

Design Organization Approval (AE)⊠ (NSSS)□ (N	1/1
Approved as Recommended Reject	ed Conditional Approval
This change requires the following Document(s) (	Specification, Drawing, SAR, etc.)
to be changed	SHOWN ON PAGE 3 OF 3 IS
	ECOMMENDED.
POLISIEM 2 6 3' SEE EBASCO	ATTACHMENT, PAGE 1 OF 1, FOR
J.W.	of non official
Vicholas C. Tassoulos 54E 3/5/81	Mario 5. Verdibello APE 3/6/81
Signature Title Date	Signature Title Date
CP&L Harris Plant Engineering Approval Required	Telephone Resolution  Yes No
NAPPTOVED AS RECOMMENDED TO BE ACCEPTED AS RECOMMENDED	S ALLXOS PROBLEMS #2 F#3
I folywell 4/23/21  Discipline Engineer Date	MHPE or PPE Date
Site Concurrence: Recommend DImplementation	11 0-11 1 1- 2016 4-23-21
Second Distribution: "	(Copy)
(Original) Document Control	(Copy)
(Copy)	
(Copy)	(Copy)
Implementation Completed as Approved?	MYes □No
	July Strench 5/8/81
	Discipline Engineer Date
Final Distribution:	
Final Distribution:	Discipline Engineer Date
Final Distribution:  (Original) File in Doc. Control	Discipline Engineer Date
	Discipline Engineer Date





AP-IX-C5 Exhibit 1

180 DEC 2 1630	Page 2 of 4
gn Organization Approval (AE) (NSSS) (N/A)	(Other) □ Telephone Resolution □ Yes ☑ No
Approved as Recommended  change requires the following Document(s) (Special Change of CHANGES TO BE SHOWN ON A changed CHANGES TO BE SHOWN ON A change of the change	Conditional Approval
Discipline Engineer Date MH  te Concurrence: Recommand Dimplementation  Cond Distribution:	ion Senior Resident Engineer D  (Copy)  (Copy)
mplementation Completed as Approved?	□Yes □No
	Discipline Engineer D
Final Distribution: (Original) File in Doc. Control	(Copy)

SUBJECT	FCR-F	15-334 Per. 1
		FORM NO. 1630
4.00000	0,000	i. No.
Designed		POPUSED
Descrip	3.0	Pariso
	0 0 00.00	To To
Designed		Former
Descues		Zarseo


AP-IX-05 CAROLINA POWER & LIGHT COMPANY Exhibit 1 Page 1 of 2 -001 FCR AS- 218 REV.Z FLELD CHANGE REQUEST/HERMANENT WATVE 16 8/80 Non-ASME □ ASME Section III Division 1 Type of Request: See Recommended Action E Field Change Identification of Area and Item: RAB I Common Best MQ □ Non-Q HUAC/CABLE TRAY RESTRAINT STRUCTURES Reference Documents or Attachment 2168-6-7021, REV.4, FCR-A5-218 REV 1. Conflict/Condition FCR-AS- ZIB, REV.I, CALLS FOR HANGER No. HC- Z308 TO BE INSTALLED USING A WT 6x 26.5 @ 10/2"LONG AS AN EXTENSION OF THE INSTALLED CZ EMBEDDED PLATE. THIS PARTICULAR SECTION OF STEEL IS NOT AVAILABLE IN THE FIELD. DPlease Investigate and Resolve Recommended Action: ⊠Please Resolve as Follows ALLOW THE FIELD TO USE A WIT 8x 25@101/2"LONG IN PLACE OF THE REQ'D WT 6x26.5. DOCUMENT CONTROL Uncontrolled Copy FOR INFORMATION ONLY SHEARON HARRIS N. P. P. CHANGE IN SIZE OF THE SECTIONS WILL NOT Justification: AFFECT THE DESIGN INTENT. Site Approval: Requested by: Senior Résident Engineer Date est O.E. 8/26/90 (Copy) First Distribution: (Copy) (Original) Ebasco (Copy) (COPY) ERNIE FELTON

APF-001 Rev. 17 11/6/80

APR 6 - 1981


AP-IX-05 Exhibit 1


PROJECT ENGINEERING PULL AS 15	o Reriz	Page 2 of 2-7
Design Organization Approval (AE) (NSSS) (N	(/A) (Other) Tel	ephone Resolution Yes No
Approved as Recommended Reject This change requires the following Document(s)		onal Approval
to be changed		
Comments:	,	
Lucholos C. Tassoulos SAE 4/20/81	Let & P	= 4/20/3)
Signature Title Date	Signatu Titl	e Date
CP&L Harris Plant Engineering Approval Required	Tes Te	lephone Resolution
Approved as Recommended Reject	ced Conditi	onal Approval
Discipline Engineer Date	MHPE OF PPE	1 9/22/21
Site Concurrence: Recommend Implementation	/2101	/ -
Alternate Resol	Senior Residen	for ANL 4-22-51 t Engineer Date
Second Distribution:	(Conv.)	
(Original) Document Control	(Copy)	
(Copy)	(Copy)	
(Copy)	(Copy)	
Implementation Completed as Approved?  Comments:	⊠Yes □No	
	$\sim$ $\sim$	
	Discipline Eng	5/8/8/ ineer Date
Final Distribution:	bracipitue Eng	Incer Date
(Original) File in Doc. Control	(Copy)	
(Copy)		
(Copy)	(Copy)	
(40)	(Copy)	



rooking up

Attachment =1





LOOKING up


Attachant 2

560-026

697501-12

O Pg 5. F7. #1 Pw-As-152 Rer. 2

HANGER TYPE B2-3




E ->
LOOKING UP

Attachment #3

Pg 6.17 Pw-115-152 Rer. 2

0



Attachment #4

697501-16

HANGER TIPE -82-3

PW-AS. 752

Ror 2

Location - 4'0" North of

Colline 20 \$'5"-0" Law of


Colline 12


Looking Up

12A10 TO a10 to 12A9


Hanger No. F-1105	
Hanger Ispection Report # 58	
Detail rework required listed below:	
A. Problem 173 - Pamk 34 P3 to gusset glate 13015- add The "fillet word to Fourth side	D. Min fred
all 3/16" filet waid to fourth side	A. The Track
13915 - ald The " filet well to forthe side	A. Mire Frank
eff weld spatter and are strikes.  US. Add weld model to correct underent	D. Market
6.	QA Accept
7.	QA Accept
8	QA Accept
R£rarklin 412181	QA Accept
Completed by  R. Rehittle 3 /24 /8  Issued To Date  Date	Moderated By Date


Reviewed ALS Accepted By OR. JAN 4/9/81






Hanger No. F - 1005	
Hanger Ispection Report # 69	
Detail rework required listed below:	
1. Anothern 218 - Pe Mx 2421 to gusset plate	
13914 - add 3/16" fillet weld to fourth side	N/A 2.7 4-10-81  QA Accept
2. Arablem 217 - PC MK 257 to gesset plate	N/A 857 4-1018
13916 - add weld to side shown on backlike	With Diene
3. VIN'CREASE wield to 5/6" on gusset to embed	WA Accept 43
	William Ters
4.	QA Accept
ON Proseem 217 - the weld allow the	
5. Backside of 267 to 13616/ well	QA Accept
is not completed 4.76%	
5.	QA Accept
ASCUE has been pecented full tox	7
	QA Accept
7.	
	QA Accept
	an necept
22 1	QA Accept
Atrablia \$ 124181	
Completed by Date	










Hanger No. F-1000	
Hanger Ispection Report # 77	
Detail rework required listed below:	
1. Problem 284 - Gusset Plate 13916 to embed -	1.11 1 1
injugar weld, improper fitup - cut quest	DA Accept
from embed and from at 2 and refit	1 1 2 -1
and reweld inaccordance with drawing	DA Accept L
fitte with in accordance with delait X comment	
4	· ·
5.	QA Accept
6.	QA Accept
7.	QA Accept
8	QA Accept
A Fraklin	QA Accept
Completed by  R. Kehletter  Issued To  Date  Date	Accepted By Date

Reviewed AND Accepted
By GA. Gon 4/9/81





	l rework req				veldar's sy	mso!	1/1/1/
. <u>//</u>	Toblem 24	13- ad	d 3/16"	fillet w	eld to 2 13915	- \ Ca	QA Accept
							QA Accept ,
							QA Accept
							QA Accept
							QA Accept
							QA Accept
							QA Accept
-							QA Accept





nger No. F-1099	
nger Ispection Report # OCI	
tail rework required listed below:	
Problem co1 - Remove are strikes by	D. Markont
grinding.	QA Mccept
Groblem 002 - Remove excessive converty	
Acres 3820 to K1a35	1 4th tol
Jerne Sike 45 Klazi	DA Accept
	QA Accept
	QA Accept
	OA Accept
	QA Accept
	CA Accept
	QA Accept
	QA Accept
07 11	QA Accept
tropla 41715	_
Rhohletten 4:1151	Thursd 4171
Issued To Date	Accepted By Date





K1035 38K6


R Mit. to A Mit. 136-15 EMBED 38K6 13615

## Huge Weld Inspersion From

Pe mie to Pe mie EMBUD Extra weld for FCR-AD- 349 R1 136-15 Clerrice per FCR-AS - 392.RI cincis.ty (002) 3819 3/8" 12


# Hugge Weld Inspersen Fern

Oversize per Fee-As-39281




(00)


78 K8 TE MIK to	15 WF
3819	3/8" A




3-20-2/



R1035 38KG




FCK-AS-349R1 FCK-AS-39ZR1



R MK. to A Mik.

13615 EMBED

13615 3816




Hanger No. <u>F-1696</u>	
Hanger Ispection Report # 17	
Detail rework required listed below:	
1. Panak 62N3 To Gosset Plate 13616 - welker	11. 1.
symbol unclean - re stemil	Christian QA Accept
2.	
	QA Accept
3.	
4.	QA Accept
5.	QA Accept
6.	QA Accept
7.	QA Accept
	QA Accept
8	
A Frankli- 3 125181	QA Accept
Completed by Date	1/1/1/3/2001
Issued To Date	Accepted by Date


# HANGER WELD INSPECTION FORM


	2168 - G17136 5 611 REV. EMDRAC DWG. NO. REV.
F 11.9%	2168 - G17150 REV.
F-1696 HANGER NUMBER 247	EMDRAC DIS. 2031
HANGER NUMBER  247  ELEVATION	INSPECTOR
BLDG ELEVATION	D sans about the sale to
BLDG	B
Carlotte Car	alhie molet
	16/08/23 2/11/00/ TI
	unchece L
4-11	1-1-11
البل	_ то
1341/5	PC. MK.
PC. MK. PC. MK.	PC. MIN
PC. MK.	
(see Reverse side)	
	D. ————————————————————————————————————
C	
C. (************************************	
	1 !! ]
7.10	
×	117-1-
	· _ TO
	PC. MK. PC. MK.
TO PC. MK.	PC. MIN.
PC. MK. PC. MK.	
	F T!
=	"
E. T.	
-+ 11 1 1	
	TO
	PC. MK. PC. MK.
PC. MK.	PO. MIL.
PC. MK. PC. MK.	Beviewes AND DOCEDIES OF GA
	BELLEWED PNS DUCEDTED OF
	3m 41.181

EAST DC. MK. GONS 10 p nit. 13616

West to MK 62NS to TX MIX 136-16







13016

extra weld per FER-AS-347RI

Pai-As-477


Pending on


fitup only

No.	HR-	011	


Hanger No F-1096	
Hanger Ispection Report # 28	
Detail rework required listed below:	
1. 060 - Are strikes & SPATTER ON P. MK 45KL TO  Klast - Grind & remove Are strikes & spatter (	HEXINIZECT OF ACCEPT
2. Poblem ose - inderent at 45K1 To KIA36 reweld to build weld & venove underent	Continues of the State of the S
3. Problem 055 - Piece mark 45k6 to Gussef - Grind	Mar Defel
4. Problem 054 - 60554 flate 13615 to embed - Gried clay and reweld. 8. 16 throat size on north rick	Med light
5.	WA Accept
6.	QA Accept
	QA Accept
7.	QA Accept
8	an necept
P7-60.	QA Accept
Completed by  Date  Date	World 3 100 181
Issued To Date QA Acc	cepted/By Date

# HANGER WELD INSPECTION FORM






P. MK. to P. MK. 45K6 Kla36




Po Mr. to Po MX. 45K6 Kla36



Pa. Mr. to R. MK.
45K5 Kla36

And the second or an in-




45K5 Kla36

F-1086

Huger Weld Insperson From


957 4-22-81


Freder PW-A5-510




(003

## Huge Weld Inspersion From






Hanger No. F-1/02	
Hanger Ispection Report # 30	
Detail rework required listed below:	
1. Adden 69 - remove are striker from fe. mk.	11111
K2a23 .	Citien & Moderal
	QA Accept
2. Problem 69 - remove spatter from 13616 at	Men Malus
at x 2 a 23 TO 13 916.	QA Accept
3.	
	QA Accept
4.	
	QA Accept
5.	
6.	QA Accept
	Of Assest
	QA Accept
7.	
	QA Accept
8	
0-7 11.	QA Accept
Street 5 3 126 181	711
1 1 Colors	Marland 312418
Issued To Date QA A	ccepted By Date



0	Han	ger No. F-1089	
	Han	ger Ispection Report # 33	
	Det	ail rework required listed below:	
	1.	Problem 001- PLMK 45K9 TO KZE35-	1.4/1
		add 3/6" .fillet to 4th side	D. Thatas
1	<	1 mx 45k4 to gusset 13915 - Add 916"	QA Viccept
N	2.		1 Harland
		fillet to forth side	A Accept
	3	Perik 45K5 to gosset - Add The fillet	
	_	to forthe side Not key'd 887	QA Accept
	4	fe mk 45kb to gussel - Add The" fillet	- An Accept
	-	to forthe side - not pagil Est	MR
,	5.	PC MK 45K6 to Kz=35 - Add 16" fillet	QA Accept
		to fourth side	D. The Sant
	6.	Problem co2 - Pc MK 45K5 to KZe35	A Accept
		Add 3/6" fillet to fourth side	D. Markart
		( )	OA Actept
	7.	fromk 45 k3 to 13 G15 (gusset) - add 3/10"  fillet to fourth like	1 Water
		+Illel 10 Fourth 1, de	QA Accept
	8		
			QA Accept
	-	Completed by Date	- 1 2 1
		R Rohletter 411181	Thatast 41 23 181
		Issued To Date OA	Accepted By Date

Hanger No. F-1089	
Hanger Ispection Report # 33	
Detail rework required listed below:	
1. Problem 77.74, 70 40 - PEMIK 45 K5 to KZE35 - ald	
The fillet weld to 2 sides - Weld all acount required. CANCCEPT	
Invifficient tierseef = add weld metal to correct	
2.3. Pc MK BG15 (Gusset state) to embed - increase	
fillet weld size to %.	
and reveld correct size.	
48. fr Mk 45 KL to 3/5" plate - add weld metal	
5 8. Problem 52-83-84 - Pc MK 45K5 to K2e35-	
grind or rewell area of lack of fusion to The Accept	
QA Accept	
7 ·	
R Franklis	
Completed by  Date  Men Making 3 1771 S	2/
Issued To Date QA Accepted By Date	

### HANGER WELD INSPECTION FORM




EAST DETAIL C POME to Po ME. Po. Mr to A.r TABU ALCANT
TAKOAT 45K5 KJe35 45K4V 13615 SIA9 15 KG KDe 35 A. Mr. to A. ME 45K5 3/8 PZ LUNDECCUT ×4 P P. Mr. to P. MK. 45 KG 3/8" A 001)

PAGE 3

33


## WEST DETAIL C



CASI PC.

WEST DC.


13616



WEST DIA BEACES

136-16

K2e35





Pe MK. to Pe MK Emass 13519


## Corrective Action & Disposition of Hanger Reinspection

Hanger No. $F-1930$	
Hanger Ispection Report # 82	
Detail rework required listed below:	
1. Medlem 249 - he MK 6 917 to 395 - correct  Moderant by adding weld metal D. Martine	1
2. Aroblem 250 - PeMK 6918 to 395 - add D. Mich Fred	1
3. Verblem 251 - for me 6918 to 395 - add A. Markate  The filet weld to forth side D. Markate	4
4. Accept	
5. QA Accept	
6. QA Accept	
7. QA Accept	
8 QA Accept	_
R Franklin 412181	
A hohletter 3 1 24 131 Date D. Har tar 1 410	# 19/ ate
Canadra	


Reviewed AND FROCEPTED By P.F. Sun 4/9/81








13615 EmBes





B F1931

5054 5/16 1/4 2622 To 13619 5/18 +3619 To

A B C

P

Type of Request: Dw. Libert Veiver to "use-	Page 1 of 2  Page 1 of 2  FOR / FAR - H - 863  as-is   DASME Section III Division 2
Identification of Area and Item: RAB    LOCATION CHANGE	PIPE HANGER DO
Conflict/Condition  Reference Documents of Attachment A - 1 - 216  INTERFERENCE BETWEEN MEMBE  LINE NECESSITATES RELOCATING  OF DESIGN — INCORRECT WELD	R (4) AND INSTALLED PD 6 HANGER 134" WEST
Recommended Action:	Please Investigate and Resolve  Delease Resolve as Follows
	SEP 2 : 1881  SHEARCH HADRIS N. P. P.
Justification: NECESSARY TO AVG	D INTERFERENCE WITH
Requested by:    Total Coble   24 Juvier     Discipline Engineer   Date     First Distribution:   Obtioinal Design Organization     Common   Design Organization	Site Approval:  SELECTION 5 7-28-61  Senior Resident Engineer Date  (Copy)  (Copy)

Design Organization Approval	(AE) (NSSS	)D (N/A) & (Other)	Telephone Resolution  Yes
Dapproved as Recommended This change requires the follow			Conditional Approval
to be changed			, 5151116, 571, 611.)
Comments:			
The same of the sa			
			- 17-65 176
Signature Title	Date	Signature	Title Date
			Talashana Basalustas
CP&L Harris Plant Engineering A	pproval Requ		TY.
	_	□ĸ	0
Approved as Recommended			MConditional Approval
See	ATTACHE	ed . Sketch.	
			and the second
CHK'D! JM 9-14-8		0.	
Pariale, 2.1142 8.31.8.		nd Karlan e	Sanfrin 9/19/81
Discipline Engineer	Date	MHPE or PPE	Date
Site Concurrence: Recommend )	Eimplements	tion	1-60
	Dalternate	Resolution Senio	r Resident Engineer Date
Second Distribution:	- Nakaraka	(Copy	***
(Criginal) Decement Control	TRIBING R		
(Copy) (Copy)		(Copy)	
(copy)		(Copy)	)
Implementation Completed as App			
Implementation Completed as App	rovedi	Ø	Yes
Comments:			No
			The state of the s
		Jany	Coble 71 SEPT BI
The second of the second			pline Engineer Date
Final Distribution:		Starto Properties	
(Ofiginal) File in Doc. Contro	1	(Copy	A Company of the Comp
(Copy) .	to the to		
(Copy)		(Copy	
600353	AND DESCRIPTION	(Copy	/)


CH	PES ATTACHMENT
7	FCR. H. 863 SHT. 1 of 3
	DOCUMENT CONTROL
	TOUR MERCHAN
	FEB 1 1 1930
	SHIADON HADDIS N. D. D.


DEZEK		ENGINEERINA
FOR	DISCIPLINE	FOR
FO COWN	5	INFO COME
	MECHANICAL	
	CIVIL	
	ARCH	
	ELECTRICAL	
	INSTRIK	
111	CONTROLS	
	PLUMETING !	
	HYAC	
	APPLIED PAT SICS	111
	PTR TREAT	
	RADEASTE I	
	SHIELDING	
	WATERIALS	
	5 TE ( 1 ) 5 / FF &	
	COMST	
	QAE	
	POAF	
	TAGILITIES	
	CPELEITE	XIII
	EXPEDITER	ZIII
		1
REPRODU	CIBLE ILLEGIBLE	
ADDRIES		
STANDARD	DISTRIBUTION	

	CARD	LINA POWER & LIGHT COUPANY	72	1.
1	4 CO95	RON HARRIS NUCLEAR POWER P (*(*) - UNITS 1-4 - 1984-1990		NT
1	0 5	SI 147 ITEL .		
	1	NO COMMENTS, PRINT TO VENDOR	1	1
	Evil 8	COMMENTS AS NOTED, PRINT TO VENDOR	2	
A	E SHIN	PRINT TO YENDOR	3	
	DAA	NO COMMENTS, NO MINET TO YENDOR		2
		FOR INFORMATION DELT	5	
	CEED	NO FRETHER REPRODUCIBLE REQUIRED	1	Z
Ł	PRCATI	SURWIT REVISES REPRODUCIELE	2	
-	E C	NO FURTHER REPRESACING REQUIRED	3	
	In F	SUSMIT PEVISES REPRODUCINE	4	
	4-	1- 5/6- 1- 57 - H-101	Z	
-		19:14 - 1-5/		
	ewer !	M M	A.	
# 1 E	0 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 -	THIS DOCUMENT NITH OF WITHOUT COMME ENCRA. CONFORMANCE WITH EBASCO PROP IONE AND FOR CONTRIMATION OF AVAILABLE ENG BHONE WITH PELATED STATEMENT, BUE IN SE MAT PELICY CONTRACTOR FROM E LITY FOR ESCINTERINE, DESIGN, NOTHING PERFORMANCE OF EQUIPMENT AND MATERI MET CLASSIFIT UNDORS THE CONTRACT	**	-
	State of the later	ALMAN THE SERIETE TO		

450 A/2-78

842/11





C.W. Dolors

Discipline Engineer

AP-IX-05 Exhibit 1

5-6-82

Date

Senior Resident Engineer

BER/PW - AS - +515- 1528

Page 1 of Z

Dien.		25-0
Type of Request:  Permanent Waiver to "use-as-	ORIGINAI	Non-ASME  ASME Section III Division 1  ASME Section III Division 2
		t No
Identification of Area and Item:	RAB EL. 236 UN AC HANGER F-1957	
(FIELD FITUP) - DESKNDIM	ENSIONS CANNOT BE MAI	NTAINED.
Reference Documents or Attachment	Conflict/Condition DCN-650-518	
	. **	
C82	36 HANGER	MEMBER AND CS WAS
CB 23 x 3/8	ncontroll	Od CODYCEIVED
L+ HG'R	FOR INFORMATI	ON ONLY JUN 0 9 1982
DESIGN CONDITION		
Recommended Action:		ease Investigate and Resolve ease Resolve as Follows
}		PT THE FITUP AS SHOWN THE LEFT.
1 4	234 ON WEST SIDE E	OTE: WELDING IS AS-DESIGNED XCEPT FOR VERTICAL LEGS OF THE 4 HANGER MEMBERS (DECREASED ENGTHS.).
EXISTING CONDITION		
Justification: RECOMMENDE	OF SUPPORT.	OVIDE ADEQUATE  000485
Requested by:	P 5/4/8Z S	ite Approval:

Date

1528 PER/PW-AS - +515- Fro 5/6/82

Page 2 of 2

Design Organization Approval	NSSS NPED Only C Other
Telephone Resolution Yes No Approved as Recommended This change requires the following Docuto be changed	Design Organization Attachments Yes No  Rejected Conditional Approval ment(s) (Specification, Drawing, SAR, etc.)
Comments:	
	FRED DEAN AND NICK TASSOULAS  Sphell 6/3/82  Mulso Signature Title Date
CP&L Harris	Plant Engineering Approval
HPES Atta	chments Tes No
Approved as Recommended	☐ Rejected ☐ Conditional Approval
	MHPF or PPE Date  mentation  mate Resolution Sid Hully for PMY 6/3/82
□ Rejec	ted Senior Resident Engineer Date
Distribution: (Original) Document Control	(Copy)
	(Copy)
(Copy)	(Copy)
Implementation Completed as Approved?	₽ Yes
Comments:	□ No
	C.W. Dolomon 10-29-82
	Discipline Engineer Date
Final Distribution:	
(Original) File in Doc. Control	(Copy)
(Copy)	(Copy)
(Copv)	(Copy)

## CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT FIELD CHANGE REQUEST/PERMANENT WAIVER

AP-IX-05 Exhibit 1

#192

FCR/# - 'AS - 1934

Page 1 of 5

Type of Request:  Permanent Waiver to "use-as-is" ORIGINAL ASME Sector Asme Sector See Recommended Action  Nonconformance No Yes Report No.	tion III Division 1 tion III Division 2
Identification of Area and Item: RAB EL. 305 UNIT *1	
HVAC HANGERS F-6470 + F-6841 (5-241)	
INTERFERENCE - DESIGN	
Conflict/Condition	50105
Reference Documents or Attachment 2163-6-818 R6, 2168-6-179	SUDKS
1) THE NORTH + SOUTH VERTICAL LEGS OF F-6470 MIS CENTER LINE OF THE EMBED. SEE PAGE 344 OF	
THE DIAGONAL BRACE ON F-6841 (SECT. AF 2168-6-17950) BE INSTALLED BECAUSE OF A CONFLICT WITH F-6461 RECEIVED CONTIONS  RECEIVED FOR INFORMATION  ON 19 1992 FOR INFORMATION	DOC MENT COINT 0CT 2 6 1982
Recommended Action:  PROJECT ENCINEERING  Please Resolve as	and Resolve
I) INSTALL A 10x7XI PLATE AS SHOWN ON PAGE 3 OF THE NORTH VERT. LEG. USE A 6X8X1/2 GUSSET PLATE THE SOUTH VERT. LEG AS SHOWN ON PAGE 4 OF 5.	e for
2) INSTALL TWO DIRGONAL BRACES INSIDE THE HANGER A ON PAGE 5 OF 5.	s shown
	<b>P</b>
Justification: RECOMMENDED ACTION PROVIDES CONSTRUCT AB	BILITY
WITHOUT ALTERING THE DESIGN INTENT	000487

Site Approval:

Senior Resident Engineer

Date

CAZ 9-14-82 JP 9/14/82

Discipling Engineer

9-14-82

Date

Final Distribution:

(Copy)

Cop"

(Original) File in Dog. Control

2/4/82 FCR/= - AS- 1924 Page 2 ch 5 Design Organization Approval R AE NSSS MPED Only Cother (IDAGE) Telephone Resolution Yes Design Organization Attachments Yes No ☐ No Tonditional Approval Rejected Approved as Recommended This change requires the following Document(s) (Specification, Drawing, SAR, etc.) to be changed CHANGES TO BE SHOWN ON AS-BUIL DWG. Comments: PER TELECOM BETWEEN FRED DEAN AND NICK TASSCULAS ucholos C. Tassoule ENGR 10/18/82 CP&L Harris Plant Engineering Approval HPES Attachments Tyes P Conditional Approval Rejected Approved as Recommended SEE EBASCO ATTACHMENT SHEET /05/ Z Implementation Site Concurrence: Recommend Alternate Resolution Refected Distribution: (Copy) (Original) Document Control (Copy) (Copy) (Copy) inclementation Completed as Approved? Yes Couments:

(Copy)


(Copy)

PURPOSE  SKETCH CALCULATION COMMENT DATA OTHER	Carolina Pow	PILE NO. / PM NO. WR & A NO. LCO NO	DATE  PAGE 3 OP 5  CS NO.  JR NO.  PT/MI NO.  LER NO.  OTHER
ORIGINATOR		CHECKED BY FCR	-AS- 1924
WORTH **	NAME 5	5" 11/2" = 10x7x1 R	
	PLAN VIEW PROPOSED SOL	41) (SECT 2 2168-6-	-17950G)  PERNAL ORIGINAL ORIGINAL
	SECT A-	A	

* FORM NO. 2001	Carolina Pow	P&L er & Light Company	PAGE 4 OF 5
PURPOSE  SKETCH CALCULATION COMMENT DATA OTHER	USER: PPPED  CNSS CONST MAINT PPED OTHER	PILE NO. PM NO. WR & A NO. LCO NO	CS NO. JR NO. PT/MI NO. LER NO. OTHER
ORIGINATOR	NAME	CHECKED BY FC	R-AS- 1924
	5 1	→ <del>  1</del> "	
1	*V	121/8	
		-	
	港	6x8x1/2 ft	
	VIEW LK	SOUTH_AT	
	PROPOSE	SOUTH AT ON SECT. 2. O SOLUTION (S-241)	
	3-9" F-6470	*	-10"
	E	ANE PA	No.
			.99
	CONFLICT WITH BEALE		
	WEST PERT A		
	F-6461 75	EXISTING C	
		F-6841 (	SECT. AF 2168-6-174500) SOUTH

ORM NO. 2001 /81	The state of the s	er & Light Company	PAGE S OF S
SKETCH CALCULATION COMMENT DATA OTHER	USER:   FPPED   CNSS   CONST   MAINT   PPED   OTHER	PILE NO. 1 PM NC. WR & A NO. LCO NO	CS NO.  JR NO.  PT/MI NO.  LER NO.  OTHER  - A S - 1924  NAME
EL 322'-0"	7/27	**V	
1,-10"		L3X3X1/4	76 3"MIN (TYP)
	Et 316-6"		

VIEW LK SOUTH



10	CAROLINA POWER & LIGHT COM HEARON HARRIS NUCLEAR POWER LD CHANGE PEQUEST PERMANENT	I AMAGE - OL 3
		SME ASME Section III Division 2
Identification of Area and I		6 50 fc ) Non-Q
Reference Documents or Attac	hment 2/66-6-69	19502 Rev 4
of the affact of support to	ment to allow Tee Gusseff D	complete welding late. DOCUMENT CONTROL  JUN 6 1980
gossett plate	-s as shown	
EBASCO ATTACHME	ON ABOVE IS NOT ACC ENT FOR CORRECTI	VE ACTION.
Justification:	SH. 10H	SCD RECOMMENDED ON, ERASCO ATTACHMENT OI, SATISFIES DESIGN REMENTS.
Requested by:  Discipline Engineer	4/28/80 CS	Approval:  Hinnally AML 4-29-80 for Resident Engineer Date
First Distribution: (Original) Ebasco (Copy)	000476	(Copy) (Copy)

Design Engineering Approval (AE) (NSSS)	Telephone Resolution
	□Yes □No
□Approved as Recommended □Reject	ted Conditional Approval
This change requires the following Document(s)	
to be changed CHANGES TO BE SHOWN ON	AS-BUILT DWG.
THE RECOMMENDED ACTION AS SO ACCEPTABLE.  Picholos C. Tonoula. Evar 5/30/80  Signature Title Date	
	Telephone Resolution
CP&L Harris Plant Engineering Approval Required	Yes No
CApproved as Recommended CReject	ted Conditional Approval
Discipline Engineer Date	MHPE or PPE Date
Site Concurrence: Recommend Implementation	Lution Am Luca 6-5-80 Senior Resident Engineer Date
Second Distribution:	
(Original)	
(Document Control)	
(Copy) Principal Q.A. Specialist	
Implementation Completed as Approved?	□ Yes
Comments:	
	Q. E. Bul 7-18-80
	Discipline Engineer Date
Final Distribution:	
(Original) File in Doc. Control	(Copy) Principal Q.A. Specialist
(Copy) Ebasco	(Copy)
(Copy) PPED	(Copy)

T				T	· · · · · · · · · · · · · · · · · · ·	A NO. 1630
				2	Pocker	
				/ Seam	rocher	
		_		7		
¢ —			5-A A	- 4		-
			L .	1-3-74		
				Los	1/- 7	
	+	6'-0		-		
			2/	View		
			1200	VIEW		
	28			1	SE SUSSETT	
			1 1	-	4 1	1 -7
			1	E AVENUE	1	1 0
		F.LE		weio		
	WEL	p P. 1262	لما	,	1	
				9.00		
				SECTION	A-A	
				The s		HEELE

## EBASCO SERVICES INCORPORATED SHEET / OF DATE 5-23-20 NEW YORK CHKO. BY SP DATE 5-28-80 OFS NO. CPEL SHNPP PW-A5-215 CSAI- 2 REVISED TEE GUSSET EBASCO ATTACHMENT 2168-6170506 (SUF 2166-6699502(ELE 28 2168-G155502 (EMA 6'-0 6 6 HGR OF CSAI- 2 CCI EMB PE WT4 GUSST 1B EMB PE WT4x9 (EXIST) FIELD TO CUT WT4 TO MAKE THE SHAPE AS SHOWN . FOR WELDING BET WT4 & 18 EMB & SEE TYP DET. DWG 2168-6170506. 13×3 (EXIST)

A (AS SHOWN)

B (OPP HAND)

SECT

SECT

CAROLINA POWER & LIGHT COMPAN  17 SHEARON HARRIS NUCLEAR POWER PL  FIELD CHANGE REQUEST/PERMANENT W  Type of Request/ Permanent Warver to 'use-as-as'	Page 1 of 74  Page 1 of 74  PAGE PW - 45 - 467
O TIE D O D D D D	SME ASME Section III Division 1
Conflict/Condition  Reference Documents or Attachment 2/68-6-17/502  1364-16318 Rev  1364-16294 Rev	2 Rev 7
- See also Page 4014 -	e 344 ~
VQOD bellous	FOR INFO
Recommended Action:	ease Investigate and Resolve ease Resolve as Follows
	MAY 6 1981 SHEARON HARRIS N. P. P.
Justification: will not just adize integrity of the	le structure
Quie Felton 3-12-80 42	Approval:  Electron 3-13-81  ior Resident Engineer Date
(Original) Design Organization (Copy) 000478	(Copy) (Copy)

PROJECT ENCINEERING

Page 2 of Z4 PW- AS- 467 Design Organization Approval (AE)□ (NSSS)□ (N/A) □ (Other)□ Telephone Resolution Yes No Conditional Approval Approved as Recommended Rejected This change requires the following Document(s) (Specification, Drawing, SAR, etc.) to be changed CHANGES TO BE SHOWN ON AS-BUILT DWG. Comments: RE \$ 28/31 cholos C. Tanoulos SAE 1/21/81. Signature Title Signature Telephone Resolution TYes CP&L Harris Plant Engineering Approval Required Yes □ No □ No Approved as Recommended Conditional Approval Rejected MHPE of PPE Biscipline Engineer Site Concurrence: Recommend Implementation Dalternate Resolution Senior Resident Engineer Second Distribution: (Copy) (Original) Document Control (Copy) (Copy) (Copy) (Copy) Implementation Completed as Approved? Pres ONo Comments: 5-7-81 Discipline Engineer Date Final Distribution: (Copy) (Original) File in Doc. Control (Copy) (Copy) (Copy) (Copy)

Continuation


Problem 017 - Gusset plate 13416 melded to embed


plate on 3 sides - 2 sides required only


Problem 018 - Gusset plate 13616 welfed all around to embed - 2 sides only required fiece mark. Kym18 improperly fit to Gusset plate 13416. 1344-16294 (c3986N SHTEZ3) gives typical connection defail for this hanger. The fitop war inaccordance with 2168-G-7047 CASE 1. This type connection (lane 1) is for hangers located in comment building.


Froblem 019 - Gusset Plate 13615 was welded all around to the sembed. Iside only required.

Problem 020 - Gusset. Plate 13515 was welked to
the embed plate on 3 sides. Z sides
enly required.










019

(20)

-00:		OWER & LIGHT COMPANY IS NUCLEAR POWER PLAN	т	AP-1X-05 Exhibit 1
6,80	1011011	REQUEST/ PERMANENT FAT	T TOP W ST	the same of the sa
Type of Request:		ver to "use-as-is"		
Identification of	Area and Item: 4/10	is and insuffice	ient weld deta	67 0 Non-0
		lict/Condition		
CHE 6166-668		DENS60-083, 2	CE-13-314	
2.1/2.1.12	to on pross	FOR-15-314 and	inspection De	sonne/are
211 5 1		I for attacking	tod Dreblans.	no detail
, ,	A ALL FIABRY	well annoction		
reattache	reas are design	inted by 800	on sheet 3	£5.
Recommended Acti	on: 171	IO MOLLING	se Investigate and	Resolve
	See attack	10 NOILYNAPHER	U) LA Jac	SIGH .
			MEDI	26 1981
			صعالا	IZII V IZIU
Justification:	Recommendal of	the design in	ton SUEABORS	HARRIS N. P. P.
Requested by: 1	7 /			
Discipline Eng		21-81 Alax	pproval:  Of For PHI  r Resident Enginee	4-22-8/ T Date
First Distributi			(Cop)	
(Original) Design	n Organization	000479	(Cop··)	

11/6/83		Exilisit.1
APR 2 9 1981	PW-A5-541	Page 2 of -2
Design Organization Approval	(AE) (NSSS) (N/A) (Oth	Telephone Resolution  ☐ Yes ☐ No
Approved as Recommended	☐ Rejected	Conditional Approval
his change requires the follow to be changed CHANGES TO B	ing Document(s) (Specifica	T DW6.
PEO TELECUL BET	WEELL NICK TASSOULAS	AND JAMES NEWHONARS/81
45-18-81		I faile 4toles
icholos C. Tassoulas		Title Date
Signature Title	Date Signatu	Telephore Resolution
P&L Harris Plant Engineering A	pproval Required	Yes Yes No
Approved as Recommended	Rejected	Conditional Approval
Discipline Engineer  Site Concurrence: Recommend  Second Distribution: (Original) Document Control (Copy) (Copy)	DAlternate Resolution	Date  Date  Date  Date  Copy)  (Copy)
Implementation Completed as Ap	proved?	Yes
Comments:		'No
	She	La S. French 5/8/8/ Discipline Engineer Date
Final Distribution:		
(Original) File in Doc. Contr	ro1	(Copy)
(Copy)		(Copy)
(Copy)		(Copv)



SUBJECTDATE	COMPUTATION SHEET	PW-AS-5
		FORM NO. 1630
Problem =1		
	?,,   , , ,   , , ,	
Kristing The	Id as built condition	to accessibility
	5/16 the 2	ack side of the
1 4 4	0 0 0 0 0	inspected.
(		
	Sect A-A	
Feramonded Action		
Secommended Action	2	
	II Propose	5.8 x 4x 4x6 Long
7		3
, ,	0 +0 +0 +0 +0 +0	
		<del></del>
	5111	
	Cope this area 1 316	
ashing	gusset plate to	
cubed o	citiz plate weld.	

. . .

	DATE POWER PLANT CONSTRUCTION TO DATE COMPUTATION SHEET		PW-AS-5	
			FORM NO. 1430	
Frablem	2			
N	despo	fall is given for the requ	wel type of	
braces ?	the very	the attachment of the	la for field	
as-buil	Condition			
		MI		
		Indicates	all sides welder	
		Minuman Coo Free	weld tenths a	
-				
0	Led Action			
Secommen				
	Allow H	to field to use as is.		
in a second				
Marian				
-				

1.

FLEED	ROLINA POVER & LICHT RON BARRIS NUGEEAR CHANGE REQUEST/PERU	MANENT WALVER	AP-IX-05 Exhibit 1 Page 1 of <u>+3</u> S-806 807 Ion III Division 2
Type of Request: Perma  Field Change See R  Identification of Area and  Conduit Support Han	ecommended Action	Non-ASME C ASME Se	ction III Division
Reference Documents or Atta	Conflict/Conditional CAR-3/6	100 8-6 720251 Rev	5-2824183
		Lod Conv	
Recommended Action:	FOR INFORM	Alled Copy	ate and Resolve
In place of the hanger to, sect shown below.	San T	Structural  -318 Stiffen	Beam
Justification:  The above recommendation of the structural integral	ended action the c	design intent.	promise the
Requested by:    Sales   Second     Discipline Engineer	7/10/81 vate	Site Approval:  Senior Resident	for AM 9/11/8 Engineer Date
First Distribution: (Original) Design Organiz (Copy)	1111	(Copy) (Copy)	000480

## NE CETTEU


OCT 0 1 1981

FCE. AS. 8

PROJECT ENGINEERING				Page Z ol ZJ
Design Organization Approval	(AE) (MSSS) [	(N/A) [ (Other) [	Telepho	qe Resolution Yes No
	T	1	Conditional	Approva1
Approved as Recommended	Reje			
his change requires the follow	wing Document(s)	(Specification	DWM.	A, ecc.,
o be changed CHANGES TO	DE SHOWN	ON HS DUICE		
omments Tex Texas Betw	need RKK BEHA	the AND LEC N	4/24	£1
DEE EBANC COMMENT	(Dade 1043) H	ew /	,	. ,
2 10000		West &	1=	10/7/31
Kickerd T. Bekak ASST. ENE	5 10/6/81	4		
Signature Title	Date	Signature	Title	Date
P&L Harris Plant Engineering	Approval Require	a 1911	•	Yes No No
Av	· · · · DReje	ected	Conditional	Approval
Approved as Recommended			, 1	
	31	,,,,,		
		er of the least of the		
		00		
400	9/14/4/	W/ala	Janhun-	- 9/24/8/
Discipline Engineer	Date	MHPE or PPE		Date
Site Concurrence: Recommend		on -	11	
Site Concuirence: Recommend	DAlternate Re	antueton Se	I fugler for	1 AMY 9/24-18
	marteria in	Seni	or Resident E	ngineer Date
Second Distribution:	10.00	(Cop	y)	
(Original) Document Control		(Cop	y)	*
(Copy) Chuck French		(Cop		
(Copy)		1000	-	
	442		_	
Implementation Completed as	Approved		Yes No	
Comments:			Juo	
		CV.	17	0 ,
		harles	A. Trines	1/28/82
		Disc	ipline Engine	er Date
Final Distributions				
		100	py)	and the state of
(Original) File in Doc. Con	itro1	-		
(Copy)		100	ру)	The state of the state of
		In.		

(Copy)

Hanger to, a type & conduit support hanger, requires the use of a sect. TX detail for the
attachment of diagonal braces going from the
vertical support member to beam stiffener plates.
The orientation of hanger to to a structural
beam is so located that the proper weld to be
used for the attachment of a stiffener plate
to the web of a structural beam should be a
partial penetration type weld in place of the
fillet weld as shown in sect TX. See shotch
below for field condition.



Bev. 6

### CAROLINA POWER AND LIGHT COMPANY SHEARON HARRIS BUCLEAR POWER PLANT

AP-IX-04 Exhibit 1

## REQUEST FOR CLARIFICATION OF INFORMATION (RCI)

Please Reply By: ASAP	201-85-166
Reference Documents: Attached FCR/PM-A	S-805 W/OUT ATTACHMENTS. :
Description: Unit *1 Cont. Blog. El. 136 - C Sect. TX - Weld Design C	Canduit Support Hanger #60
Inquiry:	
Can the field proceed with the reco preliminary FCR/PN-AS-807 pro	ommended action on the attached ior to engineering approval?
Fred Renegar I.W. G.F. 9/11/	la Chack French Const Sp. 9/11/81
Originator Title Dat	THE RESERVE OF THE PARTY OF THE
Response:	
Yes, with the following conditions	
1.) Preliminary FCR/PW can be wor	rked only with specific direction by
the Senior Resident Engineer. 2.) It is understood that if the	FCR/PW is not approved as recommended,
field rework may be required.	
Subs & French Coust Low 9/11	10 Oal n. D. Dava alular
Response Signature Title Date	te Approval Title Date
"Beed-to- Chuck French	
Inov"	

OCT 0 1 1981

# PROJECT ENGINEERING

FCR. AS. 80% Page 2 of 23 807

	A) [ (Other) [	Telephone Resoluti	No
Approved as Recommended  Rejects  is change requires the following Document(s) (s)  be changed CHANGES TO BE SHOWN ON	Specification, Dr. 45- Suil P		
be changed <u>CHANGES</u> JOBE SHOWN OF THE TELECON BETWEEN RKK BEHNKE DEE EBADO COMMENT (PAGE 100%) HKW	west &	- 15- 13/7/31	
School T. Beliefe ASST. ENG 10/6/31 -	Signature	Title Date	
Signature Title Date P&L Harris Plant Engineering Approval Required	75 Yes	Telephone Resolu	No
Approved as Recommended  SEE EBASCO CONNENT ( TOWN 1 OF A) HA	. ПС	onditional Approval	
	.00	1 : 21-20	,
A tulle Total	Wales 20	new - 9/24/8	
Discipline Engineer Date	MHPE OT PPE	CONTRACTOR OF THE PERSON NAMED IN COLUMN TWO IS NOT THE OWNER.	
99		1111	4.1
Site Concurrence: Recommend Implementation	lution - Rid -	July for AMI 9	124-/8/ Date
Site Concurrence: Recommend   Implementation   DAlternate Reso	Senior R	Suylu for AMI 9	Date
Site Concurrence: Recommend	lution Senior R  (Copy)  (Copy)	fugles for AMI 9	Date
Site Concurrence: Recommend	(Copy)	fugles for AMI 9 esident Engineer	Date
Site Concurrence: Recommend	(Copy) (Copy)	Suylu for AMI 9	Date
Site Concurrence: Recommend	(Copy) (Copy) (Copy)	esident Engineer	7/24/8) Date
Site Concurrence: Recommend Dimplementation  Calternate Reso  Coriginal) Document Control  Copy) Chuck French  Copy)	(Copy) (Copy) (Copy)	esident Engineer	Date
Site Concurrence: Recommend Dimplementation  Calternate Reso  Second Distribution: (Original) Document Control (Copy)  Chuck French (Copy)  Implementation Completed as Approved?	(Copy) (Copy) (Copy)	esident Engineer	Date
Site Concurrence: Recommend Dimplementation  Calternate Reso  Second Distribution: (Original) Document Control (Copy)  Chuck French (Copy)  Implementation Completed as Approved?	(Copy) (Copy) (Copy)	esident Engineer	Date
Site Concurrence: Recommend Dimplementation  Calternate Reso  Second Distribution:  (Original) Document Control  (Copy) Chuck French  (Copy)  Implementation Completed as Approved?	(Copy) (Copy) (Copy)	esident Engineer	Date
Site Concurrence: Recommend Dimplementation  Calternate Reso  Second Distribution:  (Original) Document Control  (Copy) Chuck French  (Copy)  Implementation Completed as Approved?	(Copy) (Copy) (Copy)	esident Engineer	Date
Site Concurrence: Recommend Dimplementation  Calternate Reso  Second Distribution:  (Original) Document Control  (Copy) Chuck French  (Copy)  Implementation Completed as Approved?	(Copy) (Copy) (Copy)	esident Engineer	Date Date
Site Concurrence: Recommend Dimplementation  Calternate Reso  Second Distribution:  (Original) Document Control  (Copy) Chuck French  (Copy)  Implementation Completed as Approved?	(Copy) (Copy) (Copy)	esident Engineer	Date
Site Concurrence: Recommend Implementation  Concurrence: Recommend Implementation  Second Distribution:  (Original) Document Control  (Copy)  (Copy)  Implementation Completed as Approved?  Comments:  Final Distribution:	(Copy) (Copy) (Copy)	ine Engineer	Date
Site Concurrence: Recommend	(Copy) (Copy) (Copy)  One	ine Engineer	Date

į.	APF-0	0.1	
	-e7.	17	
	11.76/	30	

# CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT

AP-IX-05 Exhibit 1

76/30 FIELD CHANGE	REQUEST/PERMANENT		Page 1 of 3 4 PW - AS- 1105
Type of Request: Permanent Wait			
Identification of Area and Item: AL SHOP WELDED CONNECTIONS WHOSE CON WELD IS APPROPRIATE (TUBE STEEL	NFIGURATION DIC	TATES THAT A	FLARE-BEVEL NON-
Reference Documents or Attachment L			EEL SHOP DRAWING
THE REFERENCED PW ADDRESSES CON FLARE BEVEL WELD IS APPROPR FOR A 3/6" FILLET WELD, THE IN: BEVEL WELD WITH A 3/6" FILL PROPER PROFILE FOR THIS WELL TION HAS BEEN MADE OF A REPRESSE WELDS FOR THESE TYPE CONNECTION THE WELD WAS NOT FLUSHED - OUT 'IN ALL CASES IT WAS NOTED THAT I'M SUCH THAT THE 3/16" (MINIMUM) FILL PROFILE OF THIS WELD CONDITION IS SHO	THE, BUT THE TENDED WELD A TENDED WELD REINFOLD AT THE SAMPLE ONS. IN ALL CATO THE FLAT SURTHE FLATE SEVENTER FRONTORIEMEN.	SHOP PRAWING PER EBASCO TORCEMENT (S. HE SKETCH ON ING OF THE PER ASES, THE FEM PER ASES, THE FEM IN WALL HAS B	KAS INDICATE ASYMBOLICATE ASYMBOLICATE A FLARE  PACE 3 TO AN INSPECTOR OF THE STATE  PER BEVEL PORTION OF  TUBE STEEL, HOWEN  S FLUSHED-OUT ENOUGH  SEN DEVEL OPED, A
Recommended Action:	THE RESERVE THE PERSON NAMED IN COLUMN 2 I	The state of the s	gate and Resolve
	B	Please Resolve	as Follows
ALOW THE SUBJECT SHOP			
Uncontro	lled.Go	FINTROL	KECEIVED
FOR INFORM.	ATION ONAR	1 3 1982	MAR 2 5 1982
		HARRIS N.P.P.	PROJECT ENGINEERING
Justification: ADEQUATE STREET			THESE WELDS
Requested by: OFT 1-8-82  John T. Poel 1/8/2  Discipline Engineer Dat	82 /	Approval:	Engineer / Date
First Distribution:		(Copy)	- Date
(Original) Design Organization		(6004)	

(Copy)

	1/A) [ (Other) [	Telephone Resolution  Resolution
Approved as Recommended Reject		itional Approval
This change requires the following Document(s)		ing, SAR, etc.)
to be changed CHAUGES TO BE SHOWN ON AS	- BUILT DWG	Cee Favor
ATTACHMENT. BOTHER B. STEPHENS	97/10	ul 3/22/22
D. Cacoclo/NCT SAE 4/2/82	wait of	- A= 4/2/4c
Signature Title Date	Signature T	itle Date
CP&L Harris Plant Engineering Approval Required	⊠Yes □ No	Telephone Resolution  Yes No
Approved as Recommended Rejec	ted Cond	itional Approval
SEE EBASCO ATTACHMENT. NOTE: EBASCO HAVE BEEN VERIFIED BASEDON SH 3 of 4 NO ATTACHMENT.	O COUDITIONS 142	E FUR APPROVAL ON SHEET E OF
Buelle Stephens 3/19/82	9 Lefter	1/3/22/82
Discipline Engineer Date	MHPE or PPE	Date
	water the same to	
Site Concurrence: Recommend Implementation	lution Bill of	,
Site Concurrence: Recommend ZImplementation	lution Rill Ma	In for AM 3/22/8
Site Concurrence: Recommend	lution Rie fu Senior Resi	In for AM 3/22/8
Site Concurrence: Recommend Implementation  Calternate Reso  Second Distribution: (Original) Document Control (Copy)	lution Rie factor Residence (Copy)	In for AM 3/22/8
Site Concurrence: Recommend	lution Rie fu Senior Resi	In for AM 3/22/8
Site Concurrence: Recommend Implementation  Calternate Reso  Second Distribution: (Original) Document Control (Copy)	(Copy) (Copy)	In for AM 3/22/8
Site Concurrence: Recommend MImplementation  Calternate Reso  Second Distribution: (Original) Document Control (Copy) (Copy)  Implementation Completed as Approved?	(Copy) (Copy) (Copy)	dent Engineer Date
Site Concurrence: Recommend Implementation  Calternate Reso  Second Distribution: (Original) Document Control (Copy) (Copy)  Implementation Completed as Approved?	Copy) (Copy) (Copy)	dent Engineer Date
Site Concurrence: Recommend MImplementation  Calternate Reso  Second Distribution: (Original) Document Control (Copy) (Copy)  Implementation Completed as Approved?	(Copy) (Copy) (Copy)	dent Engineer Date
Site Concurrence: Recommend Implementation  Calternate Reso  Second Distribution: (Original) Document Control (Copy) (Copy)  Implementation Completed as Approved?	(Copy) (Copy) (Copy)	dent Engineer Date
Site Concurrence: Recommend Almplementation  Calternate Reso  Second Distribution: (Original) Document Control (Copy) (Copy)  Implementation Completed as Approved?  Comments:	(Copy) (Copy) (Copy)  Discipline	dent Engineer Date

RENES	E (OF TURE	STEEL)	VI OF THE	E STEEL /STA	Kenny Tuent	
					FORM NO. 161	10
						11
_	-					
			_	ANGLE (S	C TUBE SIEE	)
			_			
			3/16			
2.50						
				INELD	TUBE	5-24
		1/2		/	/ 1	
		***	////	4	1	
11111111111			11/17	VIII		
			1////			
0.44	1 2 1		/////			
			1///			
			11			
			U			
			d	1/		
	ALC: YES		1	/		
						1000
	7 T T T					
		in				
			Marie 17			
	1.107			1		
	1 1 1 1 1 1					
	713.	-	ALE: 1	"- V."		
		~	11-6	- /4		

CHKD. BY	_DATE	- COMP	ANT CONSTRUCTION	PW- AS- 116 SHEET & OF & DEPT.
SUBJECT	-16 ROSE	DE PEDEN STE	EL SHOP WELDS MA	ERE APPROPRIATE
WELD S	27-2 1	FLAKE BETEL	WELD WATH A %.	
				FORM NO. 1630
+				
		~ -		
	1		ANGLE (DE TAES	====)
		1.5		
A Comment				
		3/16		
	-			TUBE ETEL
		T	NELD /	
		* 1	1	
		m //////		
		777		
14		1/1/		
		1		
4411		V		
				SCALE 1" = 14"
		~	~ ,	
			NOTES:	k = 1111
				15 Sm. W. 1 / Fr & 11
				אות בנונוב ביואר
Marine Land			ED, AND APPX 1/2 OF THE	ELDS WELL VISUALLY

PENGALLEMENTS ISLENTER THAN 3/1."

PEDEN SHOP WELDS INTENDED TO BE FLARE-BEVEL GRECKE WELDS, AS IDENTIFIED IN THIS PW, HAVE BEEN REVIEWED AND ARE CONSIDERED TO BE ACCEPTABLE, ARCUIDED THAT:

- THE FILLET WELD SIZE SHOWN ON DRAWINGS
- 2. WELD HAS A SMOOTH TRANSITION WITH BASE METAL,

  AS SHOWN ON SKETCH TRANSMITTED BY J. PEEL ON

  FEB 2,1922 (SEE EBASCO ATTACHMENT SHEET 2 OF 2).

	REFERE						T.				NO. 1630	
	(ADDITI	ONAL	INFOR,	MENT	_ TO	PW -	AS.	CP\$L)		<b>S</b> A	act t	•f
											A I	
-									-	-		-
												_
+									/	-		
								/	Am	MILE		
1	_							1	7	1	L	Just
					-		-		1	-	1	100
+		1			11						33%	-0
		1	4"								8	Moe
	-	1	</td <td>1/4</td> <td>+</td> <td></td> <td></td> <td>-</td> <td>$\vdash$</td> <td>7</td> <td>Anc</td> <td></td>	1/4	+			-	$\vdash$	7	Anc	
	Rik	1	12/4						1	186	38	Siery
	*	15	1	/					1	35.6	3	
-			74							133×3×14)	2 %	-
		W	ESTEEL							XXX	on	

AP-IX-05

Exhibit 1 FIELD CHANGE REQUEST/PERMANENT WAIVER Page 1 of 4 -AS - 1245 Type of Request: Non-ASME Permanent Waiver to "use-as-is" ASME Section III Division 1 ASME Section III Division 2 ☐ Field Change See Recommended Action Non-Q Nonconformance No Yes Report No Identification of Area and Item: RAB #1 ELEVATION 248' 14" GAP PREVENTS REQUIRED WELD BETWEEN RG. 4 ENGINEERED R & BEAM 7AI (CONTRACT 3836N) RECEIVED Conflict/Condition 1364-9858 Rev. 1 Reference Documents or Attachment AWS DI. 1 , Para , 3,3,1 SHEARON HARRIS N P D A 1/4" GAP EXISTS BETWEEN RG. 4 ENGINEERED P & END R ON BEAM 7AI. (SHOWN ON SHEET 3 of 4) AWS DI. I, PARAGRAPH 3.3.1 STATES THAT GAPS BETWEEN PARTS, SHALL NOT EXCEED 3/16". THIS CONDITION PROGNENTS US FROM MAKING THE REQUIRED WELDING FOR INFORMATION PARASE The Stigate and Resolve Recommended Action: Please Resolve as Follows LEAVE END PE "as is" & USE A SEAL WELD TO PREVENT MELT THROUGH AND INCREASE REQUIRED NELD FROM A 3/8 FILLET TO A 5/8" FILLET WELD. KECEIVED ( AS SHOWN ON SHEET 4 of 4)

MAR 03 1982

PROJECT ENGINFERING

Justification: RECOMMENDED ACTION WILL ENABLE CONNECTION TO MEET ITS DESIGN INTENT.

000483

Requested by: Discipline Engineer


Site Approval:

PW -AS	-124	5
--------	------	---

Page 2 of 4

Design Organization Approval	AE NSSS	□ NPED Only □ Other
Telephone Resolution Yes	□ No Design	Organization Attachments Yes No
This change requires the follow	wing Document(s) (Specific	ation, Drawing, SAR, etc.)
to be changed		
Comments:	DE SHOULD EN ASTRU	no and Lee Williams.
ree Tersion t	Between Dave Caco	no and Lee WILLIAMS
		Shull zister the
David H. Cacoll SI	AE 3/10/82	halthe n= >110/02
Signature Title	Date Signa	ture Title Date
CP6	L Harris Plant Engineering	Approval
	HPES Attachments	□ No
Approved as Recommended	☐ Rejected	Conditional Approval
- inprinted as incommended	,	<u> </u>
		111
.1 0		0 1/1/11
AX William	2/25/02	1 mol /2/20/22
Discipline Engineer	Date MHPE o	TAPE/ Date
		7
Site Concurrence: Recommend	Implementation	
	Alternate Resolution	Bill Hugh, for And 2/25/02
	Rejected	Senior Resident Engineer Date
Distribution:		(Copy)
(Original) Document Control		The state of the s
(Copy) EDSON GLOVER	UNCONTROLLED)	(Copy)
(Copy)		(Copy)
Implementation Completed as Ap	proved?	
amplementation dompletes as my	,	Yes
Comments:		O No
		1
	£.	41 11.1-
	_ca	son Bour 4/14/92
Mark Toleran Control of the Control	Disc	ipline Engineer Date
Final Distribution:	A THE STREET STREET STREET	
(Original) File in Dog Comm	-1	(6000)
(Original) File in Doc. Contr	01	(Copv)
(Original) File in Doc. Contr (Copy) (Copy)	01	(Copy) (Copy)

PW-AS - 1245 FORM NO. 2001 7/41 -Carolina Power & Light Company PAGE FILE NO. CS NO. PPPED PURPOSE USER: JR NO. PM NO. CNSS SKETCH PT/MI NO WR & A NO CONST CALCULATION LER NO. LCO NO MAINT COMMENT OTHER PPED O DATA OTHER OTHER SHEET 30 ORIGINATOR CONFLICT CONDITION BEAM 7AI-1/4" GAP AT TOP TAPERING TO X" GAP -O"GAP AT BOTTOM ENTIRE LENGTH OF SIDE R4.4 EMBED R



Sype of Request:	FIELD CHANCE REQUEST/PERMANE  Permanent Waiver to Tust ast  See Recommended Action	NT WAIVER		記述 東海
dentification of Are	a and Item: PIPE HANG	6ER	⊠ Q □ Non-Q	1
eference Documents o	Conflict/Condition  Attachment A-Z-236  PHP-124Z	-1-CC-H-483	3/6	*
177	My Consider the Constitution of the Constituti	Contraction of the Contraction o	750	大海
A CONTRACTOR OF THE PROPERTY O	FILLET WAS . W			4
FILLET	WELD WAS ALSO	APPLIED B	POTTOM	· 报为
	F B TO B.	ERIFIED.	100	72
		Please Investigati	e and Resolve	1000
commended Action:		Please Investigate		
ACCEP	THAS BE RESO	Please Resolve as	Follows	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
ACCEP NEED	TO BE RESO	ERMANENT K	JAIVER JO/81	100 to 100
NEEP S	to Profit at a Warden has any or to have been	ERMANENT K	JAIVER JO/81	
NEEDS NOTE 4/2/ Intifications HANG	THAT PHP-124  BI-  THAT PHP-124  BI-  THAT PHP-124  BI-  THAT PHP-124	Site Approval:	10/81 177EN	15 · 15 · 15 · 15 · 15 · 15 · 15 · 15 ·
NEEP S NOTE 4/2/ ustifications HANG	THAT PHP-124  BI-  SER IS BUILT.  16-7  4/5/8/  Vace DOCUMENTO	Site Approval:	10/81 177EN	15. 45. 15. 15. 15. 15. 15. 15. 15. 15. 15. 1

180 FIELD CHANGE REQUEST P	111 11 APW - H - 303
Type of Request: Permanent Walver to "	ISE-ASME DASME Section III Division 2  RNON-ASME DASME Section III Division 1
dentification of Area and Item: PIPE HAN	NGER W-6-236-1-4-WG-H-7/2 Q Rev 3/D Non-Q
Conflict/Cond	dition
eference Documents or Attachment	
HANGER WAS INSTALLED PE	R REV /B AND AS A
RESULT PIECE (S) IS AN I-	-BEAM (W4 x 13 x 4 '16).
Antonia Service	
Recommended Action:	Please Investigate and Resolve
LEAVE "AS BUILT" . CHA	TO LEAF TO SEE TO SEE
OF THE PARTY OF THE PROPERTY OF	
THE "AS-BUILT" CONZ	DOCUMENT CONTROL
A total and the control of the second	'ത്രമാവന്ത്രാ
Justification:	APR 1 3 1981
HANGER IS BUILT -	MRRISIA P
	SHEARON HARRIS N. P. P.
Plu Howard 2-19-81  Discipline Engineer Date	Site Approval:  EE/Allax for 2-24-81  Senior Resident Engineer Date
Discipline Engineer Date  First Distribution:	
Original) Design Organization (Copy) WAYNE HARRIS	(Copy) (Copy)
	000327

PF-001			Contract of the
ev. 17			P-IX-05
1/6/80			xhibit 1
	2.0		
PW-H-	303	Page	2 of 2
Design Organization Approval (NSS	S) 0 (N/A) 0 (Other) 0	Telephone Reso	lution 7
		Yes	DE No
Approved as Recommended	Rejected Co	enditional Approv	ral
his change requires the following Docume	nt(s) (Specification, D:	awing, SAR, etc.	)
be changed W-6-236-1-4-WG		_	
omments: HANGER SKETCH R	evised recle	CTING 45	34167
GONDITIONS. SEE. W-6	5-236-1-4-WE	-H-7/2R.	5/5
Veller Lead Tris Ing	3-3/-P/ 1: (1)	/	/-
A. folly mowing Roth for ".	sies lintix	- 1E 41	2
Signature Title Date	Signature	Title Da	te Tan
Signayore breie batte	CONTRACTOR AND	Telephone Res	1 2 3 7 1 1 1 1 2 1 1 1 1 1 1 1 1 1 1 1 1 1 1
P&L Harris Plant Engineering Approval Re	quired Yes		
and the state of t	□ No	Yes	□No ·
		onditional Approv	The state of the s
Mapproved as Recommended	Rejected LC	mercroner white	
			180.576.5
		A Francisco	
			* 17 17
11/36/			- 3
Nahart S. Zand 18 4/8/8/	W. Parker 20.	-him \$110	181
Report S. Zunk Gord 10/8/8/8/	MHPE or PPE	Dat	
Site Concurrence: Recommend Almplemen	(4////	luce 4	13/1/
L'Alternat	e Resolution Senior Re	sident Engineer	
econd Distribution:		Carried Street	Carrier 12
Original) Document Control	THE PLANT OF THE PARTY OF THE P	- AND AND THE PARTY OF THE PART	AS A NAME OF STREET
Copy)	(Copy)	Mark Aller	
(Copy)	(Copy)	CONTRACTOR OF THE	COMPANY TO SERVICE STREET
(000)	(CODY)	- 1 March 1	mako sam
mplementation Completed as Approved?	COLUMN DESCRIPTION OF THE PROPERTY OF THE PROP		The state of the s
molementation Completed as Annroyed?			THE PROPERTY OF THE PARTY OF
L whitered we whitered	Tyes		- The Contract of the Contract
	□Yes □No		
Comments: 7 1 85;	□Yes □No		
coments: 7 1 85;			
Doments: 7   95;			
omments: 7 1 85;			
Comments: 7 1 85;			
Doments: 7   95;			
Comments: 7 1 85;	□No		
District Delli	□No	e Engineer	Date
Comments: 7 1 PS;	□No		Date
inal Distribution:	Disciplin		Date
District Delling Delling	Discipling (Copy)		Date
inal Distribution:	Disciplin		Date
inal Distribution: Original) File in Doc. Control	Discipling (Copy)		Date

OO1 CAROLINA POWER &	LIGHT COSPANY
17 5/80 SEPARON HARRIS FOCI FIELD CHANGE REQUEST	TON= - H- 28%
	"usens-iet       MAME   Section   III Division 2
Field Change See Recommended Acti	on Mon-ASME DASME Section III Division 1
Identification of Area and Item: PIPE HANGER V	VELDING D'NOD-Q
Reference Documents or Attachment	SOLF FOR-258 (INCLUDING DRAFT:
RI), FCR-H-280, FCR-H-281, AUF F	CR-H-282, AND HANGER DRAWINGS
	ALED: I. WELD SIZES LARGER
	E.G. DWG CALLS FOR WELDING
	ELDED FOUR SIDES.
The second secon	DOCUMENT CONTROL
The state of the s	העבפרות ורכה
	DEC 181980
	DEC 18 1881
Recommended Action:	Please Investigate ash Barowwarkis N. P. P.
T THE TOP VOICE TOP II O	Please Resolve as Follows
I. THIS FOR VOIDS FOR-H-Z	CONNECTION IDENTIFICATION
- IS UNDER SEPARATE DIRE	CTIVE . LET
I. ADD A NOTE (OR NOTES	The state of the s
ACCOMPLISHES THE FOLL	OWING FOR FILLET WELDS
FILLET WELD REINFORCET	PING: (CONTO ON PAGE 3)
· · · · · · · · · · · · · · · · · · ·	-200 h 70
Justification: CODE ONLY ADDRESS	
	PERMIT PROMPT CORRECTIVE
ACTION TO RESOLVE OPEN	
Requested by:	Site Approval:
1 bum 12-16-80	
Discipline Engineer Date	Senior Resident Engineer Date
First Distribution:	(CODY) R.HANFORD
Original) Design Organization	(Copy)
(COOV) WAYNE THARRY	(Copy)
	03032

FCR-H-286	Page 2	of &
Design Organization Approval (AE) (NSSS	) (N/A) (Other) (Telephone Resolut	-
Mapproved as Recommended		wed a
This change requires the following Down	Rejected Conditional Approval	
This change requires the following Document to be changed	(s) (Specification, Drawing, SAR, etc.)	
The state of the s		****
comments: Per telecon among Fiala, on 12-18-80 MB	G. White, W. Tomlinson, and E. Willett	
Signature Title Date		40%
- TE A MAN (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1 (1995) 1	A STATE OF THE PARTY OF THE PAR	
CPGL Harris Plant Engineering Approval Requi	ired Yes Telephone Resolut	Landar .
Dapproved as Recommended	and the second second the second seco	PARTICIPATED
	ejected	
		165.0
d A.V.		874 £
Temas () White 12/18/80	MG6 21.	Lham
Discipline Engineer Date	MHPE or PPE Date	2
Site Concurrence: Recommend Elmplementat	DECE -	
П.,.	(4/11)	( )
The state of the s	Senior Resident Engineer De	20
(Original) Document Control	(Copy)	
(Copy) R. HANFORD	(Copy)	
(COPY) V. SAFARIAN	10 - Water Committee of the Committee of	- HOS
THE THE PERSON NAMED IN THE PERSON OF THE PE	The state of the s	1
Implementation Completed as Approved?	THE PROPERTY OF THE PARTY OF TH	- TOP
Comments:	□Yes □No	-
	Lino	7.37
레이지 않아지는 내고 있었다는데 그는 것 같다.		
- American Company		A
		<b>4</b>
		146
		Jan -
inal Distribution:	Discipline Engineer Date	- At 1
Original) File in Doc. Control	(Coov)	
Copy)	(Copy)	_
Copy)		-
	(Copv)	

#### NOTES:

- 1. Weld sizes indicated on hanger drawings are nominal sizes. ~
- 2. A fillet weld in any single continuous weld shall be permitted to underrun the nominal fillet weld size provided that the requirements of AWS Dl.1, Paragraph 9.25.1.6 (1979 Edition) are satisfied.
- -3. Flare bevel or groove bevel welds may finish with a fillet weld reinforcement.
  - 4. Welds in excess of that called for on the hanger details are acceptable (excluding the flexible connection joints) from the standpoint of the overall integrity of the structure and they do not require Ebasco's approval. Any detrimental effect on the weld or base material (revealed from the field visual inspection) that may be caused by overwelding is within CP&L scope of responsibility. All fillet welds on flexible connection joints are-permitted to be oversized by 1/8".
  - 5. Extra welds are permitted except on joints designed for flexibility. X
  - 6. Flexible connection joints are indicated by notation in the weld symbol such as:

1/2" return, flexible joint

The requested notation for flexible connection joints will be included on all 43 hanger details identified by Bergen-Paterson (itemized list attached) from CP&L "Isometric Report" (status as of September 12, 1980). CP&L is to provide further directives regarding the review of flexible connection joints on remaining Bergen-Paterson hanger designs (installed after September 12, 1980, and also all "un-installed" but designed or fabricated devices).

# PAGE 4 of 4

## FLEXIBLE CONNECTIONS

TURBINE BUILDING		40
	REACTOR AUXILIARY BUILDING	(Cont'd)
T-2-240-1-SW-H-292	A-3-236-1-CC-H-378 .	The second second
293 294	348	
295	, <b>22</b>	
296		
297.	FUEL HANDLING BUILDING	Total State
298-	the state of the s	
299 A 300	F-1-236-1-4-SF-H-902	
331	The state of the s	
332		
333		The second section
335	The same of the sa	<b>国工业公司</b>
336		-
337		1
338		
801		<b>一种</b>
815-	사기가 되는 사람이 나는 사람들이	Water to the state of
	네트 발표 기계	The same of the sa
ACTOR AUXILIARY BUILDING		
A-2-236-1-CC-H-891	보고 있는 사람들이 되었다. 그리고 남자 생각이다.	
893		The state of the second
952	Serious to the seriou	- 2-5
There is a second secon	THE REPORT OF THE PERSON OF TH	THE STATE OF THE S
A-3-236-1-CC-E-386	MANUAL STREET, WALLES	
The state of the s		
A-5-236-1-5W-H-1425		
the same and the s		
A-1-190-1-CC-H-636		The same of the sa
1284		
1286.		
76.	맞으면 되고 있는 그 뭐라면 그리고 생겨왔다.	
75.		48
46		100
47		THE RESERVE
49.		
51 54	The state of the s	The same of the sa
59		The same water

065.002

# CAROLINA POWER & LIGHT COMPANY

PHP TRANSMITAL SHEE	T	
	PRIORITY 21	
ATTENTION: CEORCE WHITE	PHP NO. 17./12	10
ATTENTION : GEORGE WHITE	PHP NU.LIZIZIA	
HANGER NO. A- 2-2.6.1-1-A.F-	H - 2,2,2,	]
SEISMIC NON-SEISMIC	REV. 3,C,	$\overline{}$
PROBLEM TYPE WELD SYMBOLS & SIZE	S REV. 19191	
PROBLEM DESCRIPTION PLEASE CLARIFY TH	HE FOLLOWING	
WELD SYMBOLS & SIZES.		ALL ST D
		*
		The state of the s
1. ITEM = 2 TO ITEM = (1)		
2- ITEM " @ TO EMBED TE		
3- ITEM # (2) TO ITEM (4)		
3- 1/EM (2) 10 1/EM		
4- ITEM # 3 TO ITEM @ NO SY	neal Stiewn	
	And the second	and the second
		***
		Sign :
26 분호 19 18 18 18 18 18 18 18 18 18 18 18 18 18		
		•
	000434	

PROBLEM REPORTED BY:

DATE 2/30/83

### CARCLINA FOWER & LIGHT CONTANY SHEARON HARRIS NUCLEAR POWER PLANT PIPE HANGER PROBLEM TRANSMITTAL SHEET

PHP # 1644 PAGE 1 OF 1



LANGER VENDER: BERGEN-PATERSON LANGER DRAWING NO. & REV. A-3-236-1-PD-H-1298 1/B UILDING: REACTOR AUXILIARY BUILDING

SEISMIC NON-SEISMIC

R

BASCO DRAWING NO. & REV.

E E. HILLETT

2 C. C. 4:- ITE

TOM TA 1108

ROBLEM DESCRIPTION: MISSING EMBED

- THE EMBED SHOWN ON THE HANGER SKETCH AT 8-4" NORTH OF BB MES NOT EXIST. DRAWING # 21686-155-502 SHOWS NO EMBED AT THIS LOCATION EITHER.

THERE IS AN EMBED LOCATED 7-4" NORTH OF GO WHICH THE HANGER MAY BE ATTACHED TO. IF THE HANGER ATTACHES TO THE EMBED 7-4" NORTH OF GO.

I WILL HAVE TO BE RELOCATED 4" WEST TO AVOID NIERFERENCE WITH PIPE HANGER A-3-236-1-CC-H-464.

I SHOULD ALSO BE NOTED THAT PIPE HANGER A-3-236-1-CC-H-368 EXTENDS 7-2" EAST OF (D).

- WELD FOR 1 TO EMBED IS CONFUSING.

EMG 3-9-82

600110

AG

DELEM REPORTED BY: PAT CHRISCOE

DATE 9-24-81

REV. 2 7/82  CAROLINA PO PHP TI	WER & LIGH	HEET PRIORITY		EXHIBIT-I
ATTENTION : GEORGE WHITE		PHP NO.	5824	
HANGER NO. A- 7- 20	€1/-/-C	Х-н-	1.8.0.7	
SEISMIC   NON-SEISMI	C	REV	LIB	
PROBLEM TYPE WELD SYM				Name .
PROBLEM DESCRIPTION -MEMBE				
BOTH SHOWN IN "SECTION.	A-A" WITH !	4" FILLET	SHOP WELL	D, 4
HOWEVER THESE WELDS AR	E TIL" UNDE	E SIZED. THE	HEY ARE W	leuser
REFLECT THE AS-WELDER	CONDITION	IS.	LO STIMES	2 70
				· ·
ZESOLVED				5752
· (PHP 5824)				n.
RE 6/03/83)				
. (151)				
				-
			- The	
				,
				,100 dec.

Patales

000453

DATE 5-9-83

To: E.E. Willett  CC: G.O. White CAROLINA POWER & LIGHT COMPANY  CC: G.O. White CAROLINA POWER & LIGHT COMPANY  CC: G.O. White CAROLINA POWER & LIGHT COMPANY  FANGER/SUPPORT PROBLEM  TRANSMITTAL SHEET  Attention: George White	1 of
Hanger/Support Vendor Bargel-Paterson  Vendor Drawing No. 6 Rev. F-2-286-1-4-5E-H-8402/C  Endrac Drawing No. 6 Rev. Ebasco Drawing No. 6 Rev. Euilding:  Elevation  Well Symbols	Seistic Non-Seistic
Problem Description:	F
(1) - WELDS CAN NOT BE MADE INSIDE "ROX" OF HANGER AT (1) TO (2). Also well and at 2 to 3 is incorrect	4
	700
DESOLVED DEN 251	
	000473
Problem reported by: Chace 5. Thomas	Date 8-3-8/

	SHEARON HARRIS NUCLEAR POWER PLANT	2
A grant of the same of	24 P. L. P. J. B.	PWP 0 2389
foc to the state of	PIPE HANGER PROBLEM TRANSMITTAL SHEET	PHP 0 2389 PAGE _ OF _
70.45	INANOMITIAD DEEDI	
1, 15, 140		
1		
ATTENTION:	GEORGE WHITE	
1		
HANGER VENDER: BERGE	N-PATERSON	%
HANGER DRAWING NO. &	REV. A-2-261-1-SW-H- 2350	SEISMIC 📉
BUILDING: _RAB	Life the control of the property of the control of	NON-SEISHIC
T F" TTON: 7-61		
EBASCO DRAWING NO. &	REV. 2168-6-156 SOZ REV. 12	
FROBLEM DESCRIPTION:	MISSING EMBED	
THE RESIDENCE SERVICES		
THERE IT NO	EMBED AT 8-0" EAST OF C	ON EMBED
	- G-156 502 AND NO EMBER	LAISTALLED IN THE
DRAWING ZIGE	6-756 302 AND NO EMBE	- '- "
FIELD THERE	THERE IS AN EMBED	INSTALLED AT 9-6
== C	O DELETE BOTH TEM (O)	· AND MOUT HANGER
EAST OF	J. VECETE BOTA	
INCATION TO	9-6" EAST OF (E), THE	WELD STMBOL BETWEEN
14.00	NECRRECT. THE FLARE BEVEL	WELD BETWEEN (B)
AND (D) CAN	NOT HAVE A FILLET REINFORCEM	FNT
		*** *** ***
Carried Company of the Company		T. VY
		6 1 6 001
	Resolved	ser Site Rev. Ost
	### [16] - 15 - 15 - 15 - 15 - 15 - 15 - 15 - 1	RHC 2/19/82
		RHC 3/5/82

000361

DATE Z-15-82

+6+

PROPLEM FERCETED BY: Dellancghatty

CAROLINA POWER & LIGHT COMPANY. 1-4005.009 5/25/83 PHP TRANSMITAL SHEET PRIORITY ATTENTION : GEORGE WHITE PHP NO. 16,0:15 HANGER NO. Y.P - 12 - 2611-11-514-H- 1310,4,4 TH SEISMIC NON-SEISMIC 10/15 PROBLEM TYPE __ BOO LLED SUMME PROBLEM DESCRIPTION Was Symbol From # 5 TO HER # SW-H- 8042 15 BOD PLEASE COZDECT exception of TS THICKNESS CHANGE - 3/6"-RESOLVED PER FLD REV OS JCD 6.9-83

630450

PROB THE REPORTED BY: Pur Ulusus AB) 6/6 DATE 6/6/83

CAROLINA POWER & LIGHT COMPANY  SHEARON HARRIS NUCLEAR POWER PLANT  PIPE HANGER PROBLEM  TOW TAYLOF  (EBASCO)  TRANSMITTAL SHEET	PHP # 44/3 PAGE 1 OF 1
ATTENTION GEORGE WHITE	
HANGER VENDER: BERGEN-PATERSON HANGER DRAWING NO. & REV. F-Z-Z36-1-4-MO-H-434 & BUILDING: FHB ELEVATION: 23C EBASCO DRAWING NO. & REV.	SEISMIC X
PROPLEM DESCRIPTION: Was Sunson	
MELT SYMBOL @ # 5 TO # 7 SHOULD B  PLEMENT CHANCE  WHELD @ 1145,DES OF BOTH # 7'S TO EMBED  MADE OUR TO LICE & ACCESS, PLEMEN (MANIC  LICENT IF PRESIDE.  HOLD @ # 5 TO CHIEST IN SECTION A.A. SHOULD	CAN NOT 134
	RESOLUTION PER SITE REV 052
MOTE: ITEM ABOVE REQUESTING  CHANGE TO 3 SIDED WELD REQUIRE  RE-ANAMYSIS OF FRAME-TO-EMBERS JO  AND COULD HAVE BEEN AUDIDED RE  WORK (A LITTLE FORESIGHT!) THE  COSTING CPEL MONEY. GOW	C. H. DELL  II/17/BZ  OTAT,  CAREFUL
1/7 1/8	

PPEBLEM PEPOPTED BY: PHIL WILLIAMS

DATE 11/8/62

		,				
k	e	V			1	
1	0	1	8	1		

### CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT PIPE HANGER PROBLEM TRANSMITTAL SHEET

WP-110 PHP # 3069 PAGE / OF /

Exhibit 1

1- 67.64

ATTENTION: GEORGE WHITE

HANGER VENDER: BERGEN-PATERSON

HANGER DRAWING NO. & REV. _A-1-236-1-CT-4-522/B

BUILDING: RAS

ELEVATION: 236


SHITE

EBASCO DRAWING NO. & REV. _

SEISMIC NON-SEISMIC

PROPLEM DESCRIPTION: 17EM (7) SKEWED DIMENSION CHANGE AND INCORRECT WELD STABOL.

IN THE VIEW LOOKING EAST ADD THE 3-9 DIMENSION, TAKE TYPICAL OFF THE FLARE BEUFL WELD STAROL AND CHANGE ITEM () TO EMBED WELD SYMBOL AS SHOWN BELOW, IN THE VIEW LKG. NORTH ADD A FILLET STABOL BETWEEN ITEM ( AND () I -EM (7) 'S SKEWED 7'2" TO THE WORTH DUE TO HUAC INTERFERENCE, SHOW A SECTION OR ADD A NOTE FOR THIS.



TOM TAYLOR

### CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT PIPE HANGER PROBLEM TRANSMITTAL SHEET

WP-110 PHP # 3392 PAGE OF

Exhibit 1

- ASSENTION - OFORGE WHITE

	- /
HANGER VENDER: BERGEN-PATERSON HANGER DRAWING NO. & REV. C-1-221-1-FP-H-1307 Rev 3/D S	EISMIC L
BUILDING:	ON-SEISMIC
ELEVATION:	
EBASCO DRAWING NO. & REV.	
	100
PROPLEM DESCRIPTION: GEOMETRY	AS COMPANY
WELD SYMBOL.	
FROM \$ # 3 @ BEAM TO \$ #Z @ BEAM 5	HOULD BE
2'-0" BUT 15 2'-33"	
. , , , , , , , , , , , , , , , , , , ,	
E NORTHERN # 3 SHOULD INTERSECT W/ \$#6	E # # 1 BUT
15 &" HIGH.	
15 g HIGH.	
4. SOUTHERN # 3 SHOULD INTERSECT W/ & # 2	É & #   BUT
15 / to " HIGH.	1 = 11,001
13 116 HIGH.	
PLEASE ACCEPT AS SUILT.	A STATE OF THE PARTY OF THE PAR
DOES #3 TO #7 CONNECT LIKE DETAIL A; IF	NOT WELD
CYMROL IS INCORPECT	
INCORRECT WELD SYMBOLS @ # 3 TO #	2,#1 TO
	A STATE OF THE STA
#6, \$ #4 TO #5.	
#9 TO BEAM, REMOVE "TYP."	
MISSING WELD SYMBOL @# 4 TO #1.	ę,
WELDS INSIDE WINDOW CANNOT BE MADE.	
4 OF WINDOW IS @ 231.955 € SHOULD E	€ @ 232.00.
Kesolved	in field
A00 35)	in field 1-82 000110
	000113
FROFLEM REPORTED BY: 9. E Bulland Hor Wire	
4 16 K 00 0 NO	
PROPER PERCETED BY: //. C / Succase	DATE 17 June 82

ev. 1 . 10/81 TOM TAYLOR (EBASOC)

# CAROLINA POWER & LIGHT COMPANY SHEAPON HARRIS NUCLEAR POWER PLANT PIPE HANGER PROBLEM TRANSMITTAL SHEET

PHP # 4041
PAGE 1 OF 1

ATTENTION: GEORGE WHITE

A		
HANGER VENDER: BERGEN HANGER DRAWING NO. & BUILDING: RAB ELEVATION: 236' EBASCO DRAWING NO. &	PEV. A5-236-1-5A-H-169	SEISMIC NON-SEISMIC
PROBLEM DESCRIPTION:	WELD SYMBOL CHANGE	
RELAUSE OF THE	T BE WELDED ON THE EAS SMALL WORKING AREA. CHAN H SIDES OF ITEM Q. HANGER C	GE THE WELD TO THE
		- en e entre
		resourd the site rev 252
		C. H. DELL
		4/23/82

600413

DATE 5/21/82

PROBLEM REPORTED BY:

ELEV. LKG. SOUTH

1/8-1	TOM TALLOR	OLINA POWER & LIGHT OF THE POWER OF THE POWER PROBLEM TRANSMITTAL SHEET	ER PLANT	PHP # 43/2 PAGE OF
	ATTENTION: GEORG	E WHITE		3
HANGER DRA BUILDING: ELEVATION		C-1-236-1-RC-H-	459 Rev 1/8	SEISMIC NON-SEISMIC
PROPLEM DI		EUD SYMBOL		
HANG	FER IS BUIL	T AS SHOWN B	SELOW. ACCEPTION	ON PRINT.
	GE #8's \$  D BE MADE		NGTH TO EN	ABLE WELD
DARKE	N WELD S	YMBOL LINE \$	ARROW @ #5 TO	0 W24
	182		Reso	DLVED & SITE
	1/61		SECTION A-	A 600391
PROBLEM	REPORTED BY:	& Bullard	PWH driler	DATE 28 Oct 82

0/84 .

cc: 6. 0. arr 12
TOM TAILCA
(EBASCO)

# CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT PIPE HANGER PROBLEM TRANSMITTAL SHEET



PHP # 3985
PAGE / OF /

ATTENTION: GEOF JE WHITE

HANGER VENDER: BERGEN-PATERSON HANGER DRAWING NO. & REV. A-G-361-1-CH-H-1196(C) BUILDING: REACTOR AUXILIARY PLOS ELEVATION: 261 EBASCO DRAWING NO. & REV.	SEISMIC NON-SEISMIC
PROPLEM DESCRIPTION: KIELD SYMBOL	
- MEMBER (3) PLATE WAS CUT & INST THE BILL OF MATERIAL SHOWS MEMBER CHANGE THE WELD SYMBOL FROM 1/4" TO READ 3/16" LILLET ALL AROUND F THIS HANGER IS WELDED OUT & THE	FILLET ALL AROUND.
	nakina in 14
	RESOLUED AEL SITE REV 052
	C. H. DELL 9/15/82

000410

DATE 9-1-82

Hirty Post 10 5/10

10/81				
10	E E.	V.ILL	ETT	

### CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS MUCLEAR POWER PLANT PIPE HANGER PROBLEM TRANSMITTAL SHEET

	Exhibit 1 WP-110	2
PHP #	3464	
AGE /	OF /	

CO S O. WHAT 7041 704107 250

HANGER VEHANGER DEBUILDING	ENDER: BERAWING NO. RAB	RGEN-PATER:	A-7-236	-1-BR-H-	12.53 		IC SISMIC
PROPLEM I	DESCRIPTION	ON:	ASE	PLATE.	DESIGN		
						REMOVE THE (MIN	
				57M BO			

contains 2 pats

JCD 7-16-82

RESOLVED PEZ FLD REV 451

600169

PROBLEM REPORTED BY: William counting #67 6/28

DATE 6-28-82

A POWER & LIGHT COMPANY
APPIS NUCLEAR POWER PLANT
APPIS NUCLEAR POWER PLANT
THE HANGER PROBLEM
TRANSMITTAL SHEET

CC: 6.0. Taylor
Tomebasco

PHP # 1966 PAGE 1 OF 1

HANGER VENDER: BERGEN-PATERSON AND PATERSON AND PATERSON AND PET. A-3-236-1-CC-14-1309-3/0 SEIS BUILDING: REACTOR AUXILIARY BUILDING NON-ELEVATION: 236  EBASCO DRAWING NO. & REV.	MIC SEISMIC
PROBLEM DESCRIPTION: WELD SYMBOLS	46
- WELD SYMBOL FOR (1) TO (3) IS INCORRECT.  MAKE FILLET REINFORCEMENT WELD.  - WELD SYMBOL FOR (3) TO (4) IS INCORRECT.  WHICH ATTACHES TO (3) FROM (4) IS 3"X5  HORIZONTAL DIRECTION, AND 5" IN VERTICAL  MEMBER (3) IS 3"X 3".  - PART NO. 96003 IS NOT LISTED IN BEI	T. STEEL
PATERSON CATALOGO.  PRESON CATALOGO.  Resolved per site Rev 35	-200 AT 17808

000422

PAT CHRISCOE

DATE 11-9-81

5. VIAS

Elecon.	REINSPECTION		TO. PHY- 1306
GENT	EARTHAN PONTE & 11CH SHLARON HARRIS MUCIELE PO EARCIR/SYPPORT PROD TRANSMITTAL SHIP	TO N	3-3794 1.J. NICOUCH
HAMI PETE !	FIALA	· Feory, 3	TOE CAFFERTY
			Y .
to Drawing No. & Kay.	A-2-236-1-EF-H.	888 7/2	Seienic D Kon-Seienic
ler Description:			
4	3/. //	-	A STATE OF THE STA
REF	N APPLIED AT	(FILLET)	HAS
	ESTIGATE AND		PLEASE
			175
	,		
·			***************************************
			7
KESOLUTION.	SEE HANGER S	KETCH A-1-720	-1-FP-H-888 R 3
			1
		A. Foi	19novia 04-21-8
			/
	•		
-			000471
773			.000411
. (		· · · · · ·	

DE SOPOSED DE JW HOURS

Date 4/17/3)

HOLD . 3	REINSPECTION	KO. PHY- 1246
EO 3	CAROLINA POWER & LIGHT COMPANY SHEARON MARRIS MUCLEAR POWER PLANT	FR-3-2017
met 5	BANGER/SUPPORT PROBLEM	TO, NJ NICOLICH
05	TRANSHITTAL SHEET	B-P
sen: PEIE	FIALA	FRM. J LAFFERTY
	• •	
/Support Vendor Drawing No. & R	BORGEN - PATERSON 4.	/=
Drawing No. 6 R	ev.	Seiseie
TANK	Elevation 2%	Non-Seismic
m Description:		
IN RE	EFERENCE TO PHRA95 AN	UP PHP-1146,
PUT -	THE FLARE BEVEL	DN THE
EAST	# WEST SIDES OF (	(3) +0 (4)
PUT .	THE FILLETS ON THE	-TOO 410
30770M	OF (3) TO (4)	TO MAD
A 5/1	IL" FILLET WELD HAS.	BEEN APPLIED
ALL A	KOUND PAT (4) TO EMB	
Note:	HANGER IS BUILT.	
10012 -	simples is porci.	
RESOLUTION	SEE HONGE INTERNAL	225 1 212 1/ 22 - 0 5
	SEE HANGER SKETCH TK.1.	-236-1-PM -H-300 K. 3/
		1
		A. Follynowin 04-08-6
-		
		630469
		000403
	11 AKT	
	PW-Howal	
teported by:	1 10 TIOWant	Date 4-3-81

	7	.0.5	The same		113	2	
age	1	of.		1			

### CAROLINA POWER & LIGHT COMPANY SHEARON MARRIS MUCLEAR POWER PLANT MANGER/SUPPORT PROBLEM TRANSMITTAL SHEET

r/Support Vendor	BORGEN-PATERSON	
Draving No. &	Rev. A-2-236-1-5W-H-365 R4	Seismi:
Draving No. 4	Rev.	
Est PAF	lievation 236	Kon-Seiszic
er Description:	WELD SYMBOLS AT. (3)	TO AND @ TO ARE
e Description.	UNCLEAR . OUR INTERPR	PETATION FROM AWS
	WELD SYMBOL GUIDE O	
	TO THE 1/4" SIZE INCL	DED IN THE SYMBOL.
	WE INTERPRET A SIZE I	UCLUDED WITH A
	CONVEX TYPE SYMBOL AS	BEFERING TO SURFACE
	WELDING INDICATING A E	BUILT UP SURFACE
	RATHER THAN THE HEIG	HT OF A CONVEX CAP.
	THE SYMBOL SHOWS A S	TRAIGHT LINE OVER TH
	FLARE BEVEL AND A CO	NUEX CAP. IS THIS
	WELD TO BE A FLARE.	BEVEL WELDED FLUSH
	WITH AN ADDED CONVE	X CAP ? PLEASE
	ADVISE.	
	ADVISE.	
RESOLUTION		***
RESOLUTIO	NI VEE HANGER SKETC	H A. 2.236-1-SW-H-355
RESOLUTIO		H A. 2.236-1-SW-H-355
RESOLUTIO		
e e solutio		
RESOLUTIO		H. Folly nown 04-
RESOLUTIO		
RESOLUTIO		
RESOLUTIO		A. Folly nowh 04-
RESOLUTIO		
RESOLUTIO		A. Folly nowh 04-
RESOLUTIO		A. Folly nowh 04-
RESOLUTIO		A. Folly nowh 04.
		A. Folly nowh 04-

# CAROLINA POUTR & LIGHT COMPARY SHLANON BARRIS RUCLEAR POUTR PLANT BANGER/SUPPORT PROBLEM: TRANSMITTAL SHEET

To.PHP- 110+

nger/Support Vendor nder Drawing No. & R frac Drawing No. & R asco Drawing No. & R ilding:	ev. <u>A- 2-236-</u>	-1-5W-H-34	71/3	Seismin  Kon-Seismin
ebler Description:				
	D SYMBOLS			THIS DRAWING.
RESOLUTION:	SEE HANGER	SKETCH A	-2-236-1-3	SW-H-347 P Z/
PESOLUTION:	HEC HANGER	SKETCH A.		SW-H-347 R. 2/6
PESOLUTION:	SEE HANGER	SKETCH A.		

### CAROLINA POWER & LIGHT COMPANY SHEARON HAPRIS NUCLEAR POWER PLANT FARE HANGER PROBLEM TRANSMITTAL SHEET

GHORGE WHITE

PHP 0 2050 PAGE / OF /

HANGER VENDER: BERGEN-PATERSON HANGER DRAWING NO. & REV. SF- BUILDING: ELEVATION: EBASCO DRAWING NO. & REV.	H-659	· C (F-7	-236-1-1)	SEISMIC NON-SEISMI	
PROPLEM DESCRIPTION: WELD SYM	1806				2.4.
(1.) THE EMBED SHOULD ONLY. ALSO, MAKE	MAVE S	TYP"	MORE LE	THE STA	1302
(2.) INDICATE THE OVERLAP	" שלשא	9) AND	(ii).		
(3.) CLARIFY WELD SYMBOL ARE TYPICAL)	- FOR (	7) 70	EMBED.	(WHICH	G SIDES
(4.) INDICATE ORIENTATION	0= (7)				and the second

RESOLVED BY FIELD DRAWING REV. 251.

SW Starling
12/9/81

AG) 372-

000448

DATE 11-19-8/

FROBLEM REPORTED BY:

CAROLINA FOWER & LIGHT CONTAINY
TOM TAYLOR
(EBASOC)

CAROLINA FOWER & LIGHT CONTAINY
SHEARON HARRIS NUCLEAR FOWER FLANT
HANDER/SUFFORT FROELEN
TRANSMITTAL SHEET

PHP # /40/ Page 1 of ____

GEORGE WATTE	
rest/Suffers Vender Borgol-Proceson  der Fra ing No. 6 Rev. A-3-236-1-CS-H-302/C  rac Fra ing No. 6 Rev.  rac Francing No. 6 Rev.  RAB Elevation 236	Seismic Non-Seismic
MISLOCATED EMBEDS	Non-Seismic
I - THE HANGER SKETCH SHOW	JS.
FMBEDS LOCATED AT 5'0" WES	TOFO,
NO 6-6" WEST OF (D) AT AN ELEVATION	OF 248-3."
HERE IS AN EMBED 5-0" WEST OF O BU	R" EMBET
-0" LONG. THERE IS AN EMBED 6-6" WES	STOFO
IT ITS TOP ELEVATION IS 244'-9" THERE I	
EVATION OF 249-7" IT IS 3-0" LONG AN	A TOP
NEW SYMBOL FOR (2) TO (6) IS NOT CL	EARIN
TS MEANING.	
	a Hagy
RESOLVED PER S	W. 3 W
W. a	3/3/82
	2 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
	000147
AGA.	THE HARDS
the reported by: PAT CHRISCOE	Date 8-7-81

E. W. Nett

Con Taylor

Ton EDPSIO)

ATTENTION:

#### CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT PIPE HANGER PROBLEM TRANSMITTAL SHEET

PHP # 1515 PAGE ____ OF ___

VENDER: BERGEN-PATERSON

HANGER VENDER: BERGEN-PATERSON
HANGER DRAWING NO. & REV. A-6-236-1-CS-H-264 R %
BUILDING: RAB
ELEVATION: 236
EBASCO DRAWING NO. & REV.

SEISMIC NON-SEISMIC

HANGER	SKETZ	H LOCATE	S EMBE	D 1-	1 1/2" SOUT	TH OF A
EMBED	IS IN	STALLED WG 86-	2'-3"	SOUTH	OF (AIV)	AS SHOW
ON EMB	'D R D	W6 86-	163501			
Also in	buber o	vell symbol	from (2)	400,		
		ORDER TO THE OWNER OF THE OWNER OF THE OWNER, THE OWNER	CONTRACT AND ADDRESS OF THE PARTY OF THE PAR			

Resolved per site 100.051


000443

DATE 8-25-81

PROBLEM REPORTED BY:

Hary Colland 407

CARCLINA FOWER & LIGHT COMFAMY SHEARON HARRIS NUCLEAR POWER PLANT PIPE HANGER PROBLEM TRANSMITTAL SHEET



HANGER VENDER: BERGEN-PATERSON
HANGER DRAWING NO. & REV. A-3-236-1-PD-H-1298 1/B
BUILDING: REACTOR AUXILIARY BUILDING


ELEVATION: 236

C. E. E. WELLETT

CO: C. C. AILLITE

TOM TO CLORE

EBASCO DRAWING NO. & REV.



PROBLEM DESCRIPTION: MISSING EMBED

THE EMBED SHOWN ON THE HANGER SKETCH AT NORTH OF BO MES NOT EXIST. DRAWING # 21686-155-SOZ SHOWS NO EMBED

WHICH THE HANGER MAY BE STTACHED HAVE TO BE RELOCATED HANGER KUTH PIPE IT SHOULD ALSO BE NOTED THAT PIPE HAN CC-H - 368 EXTENDS 7-2"

- WELD FOR O TO EMBED IS CONFUSING.

RESOLVED) EMG 3-9-82

600110

DATE 9-24-81

### REINSPECTION

xo. PHP- 1004

CAROLINA POWER & LIGHT COMPANY SHEARCH HARRIS NUCLEAR POWER PLANT BANGER/SUPPORT PROBLEM TRANSMITTAL SHEET

Support Vendor A Drawing No. 6 Re Drawing No. 6 Re	ROGEN-PATER SON. A-2-236-1-CX-  NO. Elevation		Seismin Non-Seismin
	© TO ⊕. ALSO	THERE IS A D	The second secon
	FLARE - BEVEL	AT 3 TO EMBED	AND O TOO.
		`	
_		(KETCH A-2.23)	6-1-CX-H-391 REV.
S DEUTION .	FEE HANGER.		
SOLUTION	FEE HANGER.		Folknown 02-25
ES DEUTION.	HEE HANGER		
SOLUTION	HEE HANGER		

### REINSPECTION

CAROLINA POWER & LIGHT COMPANY SREARON HARRIS MUCLEAR POWER PLANT BANGER/SUPPORT PROBLEM TRANSMITTAL SHEET

	10				_
	,	Co.	PHP-	1004	
286			1		

ten: PETE FIALA.			
Drawing No. 6 Rev. A-2-236 CX.  Drawing No. 6 Rev.  Drawing No. 6 Rev.  Drawing No. 6 Rev.  Rev.		3/0	X Seismin
NO WELD SYMP	O THERE	S A DIMENS	
	1		18,
ESOLUTION SEE HANGER	SKETCH H	1-2-236-1-C	K-H-391 REV.
		A. F. 15	nowin 02-25-
			000453
= reported by: Lary afela	rd	A 1,29,81	Date 1-26-51

### · KEINSPECTION

Eo. PHP- 1055 Page 1 of 1

CAROLINA POWER & LIGHT COMPANY SHEARON MARRIS MUCLEUR POWER PLANT EANGER/SUPPORT PROFILES TRANSMITTAL SHEET

Support Vendor Based-Patenson  Drawing No. & Rev. T-2-240-1-5W-H-292 9/K  Drawing No. & Rev.  Drawing No. & Rev.  Drawing No. & Rev.  Elevation 240	Seismin  Kom-Seismin
Description:  (4) to (1) NEEDS A WELD SYMBOL	
	RE
NOTÉ: THIS HANGER TO RELVILES !  PLEASE EXTENTE.	REWOLK.
PLEASE EXPEDITE.	REWOLK.
PLEASE EXPEDITE.	REWOLK.
PLEASE EXPEDITE.	REWOLK.

CC: 6.0. White Ton Taylox (Ebasco)

### CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT PIPE HANGER PROBLEM TRANSMITTAL SHEET

PHP # 1548 PAGE 1 OF 1

ATTENTION: GRORGE WHITE

HANGER VENDER: BERGEN-PATERSON HANGER DRAWING NO. & REV. A-4-23C-1-PD-H-18 BUILDING: RAB ELEVATION: 254' EBASCO DRAWING NO. & REV.	SEISMIC NON-SEISMIC
PROPLEM DESCRIPTION: MISSING WELD  WELD SYMBOLS NEED TO	
AND (2) TO (G)	
Q111 0 AG7	Revenued per site  Rev. 051  Rev. 051  Deviewed per site  COU:42
PW-HOWN AG7	DATE 8-31-81

CAROLINA P
SHEARON HARR
PIPE
TRAN

TOT ED PSO

ATTENTION: - GEORGE WHITE

#### CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT PIPE HANGER PROBLEM TRANSMITTAL SHEET

PHP # 1515 PAGE 1 OF 1

HANGER VENDER: BERGEN-PATERSON HANGER DRAWING NO. & REV. A-6-236-1-CS-H-264 R% BUILDING: RAB	SEISMIC	$\boxtimes$
ELEVATION: 236 EBASCO DRAWING NO. & REV.	NON-SEISMIC	

PROPLEM DESCRIPTION: _	NO BUBED AT L	OCATION SHOW	N ON
HANGER SKI	ETCH.		
			~
HANGER SKE	ETCH LOCATES BY	BED 1-7/2 SC	NITH OF (414).
EMBED IS	INSTALLED 2'-3	" SOUTH OF (41	I AS SHOWN
ON EMB'D R	NSTALLED 2'-3 DWG 86-163501		
Also improper	well symbol from (	260,	
	7		
			100

Resolved per site 100.051

000448

DATE 8-25-81

PUBLEM REPORTED BY:

Harry Pollard Att

CC. GO WA: **

CAROLINA POWER & LIGHT COMPANY

TO TRY SHEARON HARRIS NUCLEAR POWER PLANT

(EXECUTED SHEAR PROBLEM

TRANSMITTAL SHEET

PHP # 1484 PAGE 1 OF 1

### ATTENTION: GRORGE WHITE

BLEM DESC	CRIPTION:	WEL	D SYMB	04			
					AND T	HE EMBEL	) /5
NLY (	0.0	ONE	SIDE.				
							· minite
				OLVED - 1			* 4

630444

PROBLEM PERCETED BY: William Hartly Aby

DATE 8-24-81

CC: G.O. White SHEARON RAFFIS MUCLEAR FOWER FLANT PHP # 1461 Tom Taylor HANGER/SUFFICET TROPLEM Page 1 of TRANSMITTAL SHEET WHITE EET/Suffert Vender Borged-Branson for Ira ing No. & Rev. A-1-216-1-PD-H-9/3 REVYB X Seistia rat Dra fing No. & Rev. see Praving No. 6 Rev. Non-Seismic Iding: _ RAB Elevation JELD STMBOL DIMENSIONS THE WELD SYMBOL BETWEEN MEMBER ( blem Description: NO THE EMBED SHOULD SO THE WELDS CANNOT BE MADE INSIDE THE BOX UD THE DIMENSIONS BETWEEN THE TWO MEMBER DE AND (3) - ARE NEEDED. NO MEMBER PESOLVED REV 151 SKETCH REV 151 CCU #40 Da: e 8-19-81 itter regarted by: _

CAROLINA FOUTE & LIGHT CONTANY

" E. E. Willer

TON: TAYLOR

### CAROLINA FOWER & LIGHT CONTANY SHEARON HARRIS NUCLEAR FOWER FLANT HANGER/SUFFORT FROELEM TRANSMITTAL SHEET

PHP # /40/ Page 1 of ____

				Ι		
er/Suffert Ventor Barea	1-77-50N	-H-30 2	Tr.			
at Tra ing No. & hev.	2-636 / 23		_	X	Seismit	
to Drawing No. 6 Rev.	Elevation _ Z	36	_	Nam-	Seismic	45
MISLOCATE	E HANGEL	2 6 6 15	TCH S	HOUS		
ler Description: - THO	DS LOCAT	DO AT	5LOT	15CT	OFID	
ID 6-6" WEST	DE DA	EANIF	FELATI	IN OF	248-3"	1
ERE IS AN EN	1BED 5-0	II WIFE	OF	BUT	ITS	
TTOM ELEVATION					" EMBE	D.
O" LONG. THERE						
T ITS TOP ELEV					ALSO	
EMBED LOCAT	BD 2'-4"	NEST	OF (D)	WITH	A TOP	
FUATION OF 24	9-71 17	15 3-0	" LONG	AND	8" WIDE	-
IED SYMBOL	FOR (2)	TO (6)	15 NO	I CLIS	AR IN	
S MEANING.						_
				$\sim$		7
		. ( -	RESOLVED 7	PER SITE	PEV 251.	-7.
			1)0	e.	3/5/82	1
		(-	W. U	Thus	7-50-	1
			$\overline{}$			
						- 1
					Professional Communication of the Personal Communication of the Communic	- 1
					TO THE PARTY OF TH	
2		4		1795		
					600147	
	*			78	OCCET	
	AG					
Les reportes by: PAT		25			<u>8-7-8</u>	1
· Co reported by: Ph	CHRISCE	JE		p	1.60 0	4

### CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR FOWER PLANT FARE HANGER PROBLEM TRANSMITTAL SHEET

PHP 0 2050 PAGE / OF /

T.FVATIO	ENDER: BERGEN-PATERSON SF-H-659 26 (F-2-236-1-4) RAVING NO. & REV. SF-H-659 36 (F-2-236-1-4) RAWING NO. & REV.	SEISMIC NON-SEISMIC	
PROPLEM (//)	DESCRIPTION: WELD SYMBOL  THE EMBED SHOULD HAVE SHE ARROW ON	THE SIM	30=
	INDICATE THE OVERLAP BOWN (1) AND (11).	6-8cE -	COAS
	CLARIFY WELD SYMBOL FOR (7) TO EMBED.  ARE TYPICAL)  INDICATE ORIENTATION OF (7).	( WHICH	- 3/pes
=			.4.4

RESOLVED BY FIELD DRAWING REV. 251.

SW Starling
12/9/81

ACT -

600443

DATE //- 27-9/

PROBLEM REPORTED BY: .

SHEARON HARRIS NUCLEAR POWER PLANT PIPE HANGER PROBLEM TRANSMITTAL SHEET  ATTENTION: GEORGE WHITE	PHP # 2005 PAGE OF
NGER VENDER: BERGEN-PATERSON NGER DRAWING NO. & REV. A-1-216-1-SW-H-1716 (FCE-16 ILDING: EVATION: ASCO DRAWING NO. & REV.	SEISMIC NON-SEISMIC
SEE & DIMENSIONS OF EXISTING	
COLUMN (20) BELOW - CHANGE DI	MENSIONS AS
REQUIRED -	
NEED DETAIL INDICATING WHERE (5	ATTACHES TO
1 AND TO WHICH 1 -	
NEED TO TRIM I" OFF NORTH SI	
MOST (8) TO ALLOW BETTER ALLE	SS FOR WELDING -
NEED MINIMUM WELD LENGTH FOR	(E) TO EMBED -
MEDAIL CLARITY OF DRWG IS PO	OR - HOW ABOUT
A NEW DRWG -	SOLVED PER SITE REV 251.
	~ () () - 1 11-23-81
20	w.ce.
11'-24'6"  10'-24'6"  10'-24'6"	· ·
5	
6-93/6"	5'-84"
	- 30 - 57
	( 38 110 ) - 5
PLAN N ->	Just 110 Jours
	Tool Survey Sources
	2 2 1 10/0/
	.57
	630140
707	
PIELE: PEPOPEE BY: Sany Coble	DATE 12 NOV'EL

CAROLINA POWER & LIGHT COMPANY EXHIBIT-I PHP TRANSMITAL SHEET RET.# PRIORITY PHP NO. 15,415,3 ATTENTION : GEORGE WHITE A- 15-2,3,6-2-5,W-H- 117,5,6 X SEISMIC NON-SEISMIC REV. . . OA PROBLEM TYPE WELD SYMBOL PROBLEM DESCRIPTION PLEASE CLARIFY THE WELD'S SYMBOLS PIECE (A) TO THE EMBED AND FOR THE CLIP TO PIECE 3. Also change the weld symbol for piece 3 to piece 1 to a flare bevel and make it typ.

4/14/83 (05)

600401

Married Anna Control Science Special S
IT TO S S S S S FTT !
110 = - 11
IREV.2 A WALTE
14705
7/82
1
-
The state of the s

### CAROLINA POWER & LIGHT COMPANY

EXHIBIT-I

PHP TRANSMITAL SHEE	T
	PRIORITY /
ATTENTION : GEORGE WHITE	PHP NO. 15,5,6,2
HANGER NO	H - 1,6,
SEISMIC NON-SEISMIC	REV. 8.5.3.
PROBLEM TYPE WELD SYMBOLS	NEV. LETETET
PROBLEM DESCRIPTION ON SHEET 7 OF 14, ITEM	(31) REQUIRES A 58" FILLE
ALLAROND WELD WHICH CANNOT BE MADE BUT	ON THREE SIDES DUETO
ITEM (10) ONLY HAVING A "E" GAP TO THE STRUCT	WEAL MEMBER. CHANGE TO
A THREE SIDED WELD, ALSO ON SHEET 7 OF 19	+ , SECTION C-C, GIVE THE
TORQUE REQUIREMENTS FOR THE BOLTS SHOW	WN ITEM (32).

RESOLVED AT SITE PRI 5-3.83

me 215 all por you PROBLEM REPORTED BY:

TO E E WILLS | FEE . B. 191 TAN DO | 131,500 |

### CAROLINA POWER & LIGHT COMPANY

PHP TRANSMITAL SHEET  RFT. # 1-4080.001 PRI	
	NO. 5.6.7.7
HANGER NO. A- 3- 236- 1- CC- H-	- [15,7,9]
SEISMIC NON-SEISMIC	REV. 152
PROBLEM TYPE Missing Weld Symbol  PROBLEM DESCRIPTION The weld symbol for piece  missing. On rev 151 it was a 3/16 fillet on tw	(3) to piece (4) is
- Also clans legiblity on skettl of dimons.	ins and BOM

THIS PHP HAT REEN RENTITIES FER

600157

PROBLEM REPORTED BY: Rodney Turner

DATE 5/2/83

RFT=1-4085-003

K 1 1 = 1 - 400	33-003
REV. 2 TO E E. WILLETT	WP-110
7/82 CAROLINA POWER 8	LIGHT COMPANY EXHIBIT-I
(SEASON PHP TRANSMI	
14	PRIORITY [/]
71	
ATTENTION - GEORGE WHITE	PHP NO. 15.1.96
HANGER NO. 4 0,2 - 2,6,1 -	1-C,K-H- 1,5,9,9
SEISMIC NON-SEISMIC	REV. 1.0.4
PROBLEM TYPE Missing W	eld symbol REV. 1.0.4
PROBLEM DESCRIPTION	majories .
TROBLEM DESCRIPTION	The same of the same
The weld symbol	between item # (4) and
m	o show w on sheet 2 of
3 of this hanger	7
Please correct and	cerde 125 5
맞지 기계에 있는 것이 되어 그 생기에 되었다.	
계계 보기 그는 학생이 되었다. 그 같은 네이트 나를 다 했다.	( PHP RESOLVED )
	BY M. F 340/83 (
경기들은 병에 대한 경험이 없는 나무를 다 했다.	
	A STATE OF THE STA
하는 사람들은 사람들은 사람이 되었다면 하는 것이 없다면 없었다.	
하는 사람들은 아내가 얼마나 하는 것이 없는 사람들이 되었다.	
선생님 [16] 이번 시간	
	633360
	630460 .
1	547 3/4/
101	11- N.
PROBLEM REPORTED BY:	DATE 3/4/83

RFT = N/A

TA CAROLINA POWER & LIGHT TOWN TA CAROLINA PHP TRANSMITAL S	HT COMPANY EXHI	P-110 BIT-1
ATTENTION - GEORGE WHITE	PHP NO. 15.2.7.9	
HANGER NO. 4 2-2.6.1-1-P	D-H- 4252	
SEISMIC NON-SEISMIC	REV O.A	
PROBLEM TYPE Weld Symbol		ã
The weld sembol be	tween welded	-
attachement of item #	+3 and #2 como	
item # 2 13 6x6x,5	and wilded abode	
of item # 3 is 55"		
. Please correll and re	vide as shown	
. below to agree with	as beilt audition	_:
		•
	EV V	).
	- DILO PREDIVE	7
	STAL POSE.	1
	( BY FIELD	);
	> = 115 (A) 05	14.
: (	REVISION -	1):
· - 1	JM 3.18.83	/ :
		•
	630461	:
1 0 \$6	7 3/15	
/ D/ 10-	-1.:1-	

O: E E.WILLETT TO CO WHITE (EBASCO)

RFT 1.4085.002

### CAROLINA POWER & LIGHT COMPANY

WP-110 EXHIBIT-I

TEA	PHP TRANSMITAL SH	HEET
		PRIORITY /
ATTENTION : GEORGE WH	ITE	PHP NO. 149,5,8
HANGER NO. A-	2-261-1-61	H-H- 1,7,7,1,
PROBLEM TYPE WELL	1-SEISMIC DOE#	754 REV. 1.5.4.
PROBLEM DESCRIPTION	CONCECT THE FOLL	LOWING WELD SYMBOLS!
	PL#1 TO EMB	ED SHOULD BE TYPICAL
THE RESERVE OF THE PARTY OF		SHOULD BE TYPICAL
	PC# 3 TO PC# (	6 SHOULD BE FILLET 251055
		FLARE BEVEL ZSIDE
	SLEAN UP SOME OF T	THE REVISION CLOUDS SO THE
	PRINT IS WASHILE	

RESOLVE AT SITE PER FIELD REV. 155. 8/24/83

600462

PROBLEM REPORTED BY: MORGA

DATE 8/14/03

### REINSPECTION

CAROLINA POWER & LIGHT COMPANY SHEARON MARRIS NUCLEAR POWER PLANT HANGER/SUPPORT PROBLEM TRANSMITTAL SHEET No. PHP- 977

er/Support Vendor Bor Drawing No. & Rev. ac Drawing No. & Rev. co Drawing No. & Rev.	A-3-23/2-1-0X-H-3	78 R 4/E	Seiszi:
dang:RAG	0 WELD SYMBOL W	IN CIVEL TOP	Non-Seistic
Te: Description.	O FUBED OR (D)	. TO (6) - NOTE	: MEMBER
Name and Address of the Owner, when the Owner, where the Owner, which is the Owner, where the Owner, which is the Owner,	AS ATTACHED TO	@ USING A	3/16" FILLET.
DF 9 TO (	DES AND A 3	FLARE-BEVEL	WAS INSTALLED
ON POTH 3	IDES AND A S	MA FILLET O	N TOP AND
BOTTOM.	PLEASE RESCUE		
BOTTOM.	PLEASE RESOUVÉ		
BOTTOM.	PLEASE RESOLUTE		
BOTTOM.	PLEASE RESOLUTE		
			CX-H-378 R. 6
	PLEASE RESOLUTE	A A-3-236-1-0	EX-H-378 R. 9
		A A-3-236-1-0	-X-H-378 R. 6
		A A-3-236-1-0	EX-H-378 R. 9
		A A-3-236-1-0	EX-H-378 R. 9
		A A-3-236-1-0	EX-14-378 R. 6
		A A-3-236-1-0	EX-H-378 R. 9

### CAROLINA POUTA & LIGHT COMPANY SALARON BARRIS KUCLEAR POUTA PLANT BANGER/SUPPORT PROBLES

1	60.	PHP-	11	0	4	-
 1	of		_			

ot con

er Drawin	Ko. & Rev.		ол 1- SW- H- 34	71/3	Seismin  Kon-Seismin	
e Descr	iptien:					
					PAND P FO	
		-				
?ES 0 4.	ITION: SE	C HANGER.	SKETCH A	-2-236-/	-SW-H-347 R.	2/0
?ES 044	TION: SE	C HANGER.	SKETCH A		-SW-H-347 R.	
2504	ITION: SE	C HANGER.	SKETCH A			
2504	ITION: SE	C HANGER.	SKETCH A			

CAROLINA POLER & LIGHT CONTAIN  SREARON MARRIS HUCLEAR POLATE FLATE  HANGER/SUPPORT PROBLEM  TRANSMITTAL SHIFT  TO NOT NICOLICH  REP  SEIDLE  TO DESCRIPTION  TO DESCRIPTION  TO DESCRIPTION  TO DESCRIPTION  THE FLATE BEVEL ON THE  FRATE FILLETS ON THE TOP AND  TOTTOM OF (3) TO (4)  A SILL FILLET NELS HAS BEEN APPLIED  ALL HROUND SAT (4) TO EMBED  NOTE: HANGER SEIDLET.  RESCRIPTION  RESCRIPTION  RESCRIPTION  RESCRIPTION  RESCRIPTION  RESCRIPTION  RESCRIPTION  RESCRIPTION  RESCRIPTION  REP  RESCRIPTION  RE
THE FIRE TO THE PARTY ON THE TOP AND THE POTTOM OF CASE OF CAS
THE RESERVENCE TO PHERRYS AND PHY-1146, PUT THE FLATE BEVEL ON THE EAST & WEST SIDES OF (3) TO PHOR BOTTOM OF (3) TO PHERRY BEEN APPLIED  A S/IC" FILLET NELB HAS BEEN APPLIED  ALL BROWND DAT (4) TO EMBED.  RESOLUTION: SEE HANGER SKETCH TK-1-23G-1-PM-H-300 R, 5/A
IN REFERENCE TO THERS AND PHY-1146,  PUT THE FLAVE BEVEL ON THE  EAST & WEST SIDES OF (3) to (4)  PUT THE FILLETS ON THE TOP AND  BOTTOM OF (3) TO (4)  A S/IL" FILLET NELB HAS. BEEN APPLIED  ALL AROUND DAT (4) TO EMBED  NOTE: HANGER SKETCH TK.1-236.1-PM-H.300 R.5/A
PUT THE FLATE BEVEL ON THE EAST & WEST SIDES OF (3) to (9)  PUT THE FILLETS ON THE TOP AND BOTTOM OF (3) TO (4)  A S/IC" FILLET NELB HAS BEEN APPLIED ALL AKOUND DAT (4) TO EMBED.  NOTE: HANGER IN BUILT.  RESOLUTION: SEE HANGER SKRTCH TK.1-236.1-PM-H:300 R. 5/A
PUT THE FILLETS ON THE TOP AND BOTTOM OF (3) TO (4)  A S/IL" FILLET NELB HAS BEEN APPLIED ALL AKOUND PAT (4) TO EMBED  NOTE: HANGER IS BUILT.  RESOLUTION: SEE HANGER SKETCH TK.1-236.1-PM-H.300 R.5/A
ROTTOM OF (3) TO (4)  A S/IL" FILLET NELB HAS BEEN APPLIED  ALL AROUND PAT (4) TO EMBED.  NOTE: HANGER IS BUILT.  RESOLUTION: SEE HANGER SKETCH TK.1-236-1-PM-H-300 R.5/A
NOTE: HANGER IS BUILT.  RESOLUTION: SEE HANGER SKETCH TK.1-236-1-PM-H-300 R. 5/A
RESOLUTION: SEE HANGER SKETCH TK.1-236.1-PM-H.300 R. 5/A
A. Folknowin 04.08.E.
630469
1 ar reported by: PN +Howal Date 4-3-81

	EARDINA PONTR & 1: ARON EARRIS KUCLEAU EARCIR/SVPPORT I TRANSMITTAL SI	PROBLEM	EB-B-	NICOURH	
PETE FIAL	A . •		eon, DE	CAFFER	79
				Y '.	
Draving Ko. & Rev. A Draving Ko. & Rev. A Draving Ko. & Rev. A				<b>∑</b>	
- Description:		-:			
A 3/10	" 5HOP. W	IELD (FIL	LAT.	HAS	
REEN	APPLIED AT	(3) to	(2)	PLEAR	=
INVEST	164 TE AND	RESOLVE			
ESOLUTION: 3	EE HANGER	SKETCH A	1.7.720.	1- 50 H-	980 P
ESOLUTION: 3	EE HANGER	SKETCH A	1-2-236-	1-FP-H-8	888 R.
ESOLUTION: S	EE HANGER	SKETCH A	1-2-236-	1-FP-H-8	888 R.
ESOLUTION: S	EE HANGER			1-FP-H-8	888 R.
ESOLUTION: 3	EE HANGER			1-FP-H-8	888 R.
ESOLUTION: S	EE HANGER			1-FP-H-8	888 R.
ESOLUTION: S	EE HANGER			1-FP-H-8	888 R.
ESOLUTION. S.	EE HANGER			1-FP-H-8	888 R.
ESOLUTION. S.	EE HANGER			1-FP-H-8	888 R.
ESOLUTION. S.	EE HANGER			1-FP-H-8	888 R.
ESOLUTION: S	EE HANGER			1-FP-H-8	888 R.
	W HANGER			1-FP-H-8	888 R.

### REINSPECTION

No. PHP- 636
Page 1 of 1

CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT HANGER/SUPPORT PROBLEM TRANSMITTAL SHEET

nder Drawing No.		6-1- CC-H-100		Na Na	Seismic
	PARTS & THE FIELD I BESCRIBED I	INSTALLED US	DAEE	FOR THE MOSED PLEASE	INVESTIGATE
RESOLUTION:	SEE HANGER	SKETCH !		1-CC-H-102	
					030473
	by: Churtofur	0 01	700,2	1,30	

ATTENTION: GEORGE-WHITE

HANGER VENDER: BERGEN-PATERSON HANGER DRAWING NO. & REV. A-6-236-1-38-4-1506


BUILDING: _ RAR

ELEVATION: 236

EBASCO DRAWING NO. & REV. _

SEISMIC NON-SEISMI

PROBLEM DESCRIPTION: ORIENTATION. 15 INCORRECT, INCORRECT WELD SYMBOL AND CANNOT MAKE WELDS INSIDE OF WINDOW HANGER WILL WORK IF DRAWN AS SHOWN BELOW, THE WELD STMBOL BETWEEN () AND EMBED IS INCORPER, WELDS CONNET BE MADE NIDE WINDOW.



HANGER VENDER: BERGEN-PATERSON

HANGER DRAWING NO. & REV. A-1-236-1-WL-H-4451

BUILDING: _ RAB


ELEVATION: 236

EBASCO DRAWING NO. & REV.

SEISMIC NON-SEISMI

FROELEM DESCRIPTION: NO STRIP PLATE, WELD STABOL AND COLATION CONFLICT THERE IS NO 8" STRIP PLATE FOR ITEM (2) AT ELFU Z51-0." BELOW

MATCH DINFINSUME SHOWN BELOW.



Nev. 1 10/81

## CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT PIPE HANGER PROBLEM TRANSMITTAL SHEET

Exhibit 1 WP-110

PHP # 3025 PAGE _ OF _

ATTENTION: GEORGE WHITE	
HANGER VENDER: BERGEN-PATERSON HANGER DRAWING NO. & REV. A-5-236-/-IA-H- BUILDING: ELEVATION: 236'-0' EBASCO DRAWING NO. & REV.	SEISMIC NON-SEISMIC
PROPLEM DESCRIPTION: Weld symbols.	
Welds can not be made ins Symbol given for end caps to 25 Shown in Sketch below. Add	ide Window. No Weld  #3. Change Weld symbols  symbol for end caps.
3. CONP.	Resource An Sme Rev 352 PLB 6/1/82

000363

467

DATE 5-11-82

## CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT PIPE HANGER PROBLEM TRANSMITTAL SHEET

PHP # 2989 PAGE _/ OF _/

ATTENTION: GEORGE WHITE

HANGER VENDER: BERGEN-PATERSON HANGER DRAWING NO. & REV. A-1-216-1-51-M-403 - 4/E BUILDING: ELEVATION: EBASCO DRAWING NO. & REV.	SEISMIC NON-SEISMIC
PROPLEM DESCRIPTION: WELD SYMBOL S	
DEND ATTACHMENT MEMBER #3 TO MEMBE BE A FILLET WELD ALL MESUND (RED of END ATTACHMENT)	ASON NEW REUSION
3) Member # 5 To EMBOD INCORRECT 3) Member # 5 To # 4 NO Symbol	
0 K: 5.21-82 MJI 5.21-82	

RESOLVED By FIELD DRAWING REV. 451.

JU Starling
5/11/82

000364

This Athers ACT

DATE 5-6-82

### CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT PIPE HANGER PROBLEM TRANSMITTAL SHEET

PHP # 3953 PAGE ___ OF ___

ATTENTION: GEORGE WHITE

HANGER VENDER: BERGEN-PATERSON HANGER DRAWING NO. & REV. A-1-216-1-CH-H-633-6 BUILDING:	SEISMIC NON-SEISMIC
EBASCO DRAWING NO. & REV.	
PROPLEM DESCRIPTION: NEW SYMBOL	
NEED FLARE BEVER WEND SYN	1BIL FOR # 2 TO#1
3" T.S TO 3" T.S.	
	mg012 - 12 M

ng 5.14.82

000365

Mukel Hunt + 16?

DATE 4.30.82

## CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT PIPE HANGER PROBLEM TRANSMITTAL SHEET

PHP # 2272 PAGE / OF /

ATTENTION: GEORGE WHETE

HANGER VENDER: BERGEN-PATERSON HANGER DRAWING NO. & REV. A-4- BUILDING: RAB ELEVATION: 236 EBASCO DRAWING NO. & REV.	236-1-8D-H-190 1/4	SEISMIC NON-SEISMIC
PROPLEM DESCRIPTION: M/55/~	6 DIMENSIONS AND	WELD SYMBOL
THIS HANGER IS TACKE AND CHANGE WELD	57MAGE AT (3). 70 (	D. ADD DIMENSON
PABC-40	2'-51/6"	A
3/6	Z-1"	
icsolved pur site Revost		2:178"
	ELEN LAG WEST	600369
***** ******* *** ********************	Mo 3 to	DATE 4-13-82

To	E E .WILLET
CC	G. C. WHITE
	(EBASCO)
'	(EBASCO)
1	-

EBASCO DRAWING NO. & REV.

#### CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT PIPE HANGER PROBLEM TRANSMITTAL SHEET

		_	
	1	7	
	Ł	٩	1
	١	ď	1

PHP # 1932 PAGE 1 OF 1

ATTENTION. GROSSE WALLE		
HANGER VENDER: BERGEN-PATERSON HANGER DRAWING NO. & REV. A-6-236-1-CS-H-2452 9/A BUILDING: RAB	SEISMIC	
ELEVATION: 236	NON-SEISMIC	

WITH CLARAL

OBLEM DESCRIPTION: WAD SYNLOC.	
1	- **
INCORRECT WELD SYMBOL AT (2) TO(3). SHOULD	BE A
INCORPECT WELD SYMBOL AT @ TO 3. SHOULD FLARE - BEVEL PIPE OR HANGER NOT INSTAL	LED.
ALSO, PLEASE CLARIFY DIMENSION LINES LOCATI	NG (3)
)	
	lacente
	11 11 11 11 11 11 11 11

Kesolved persire new ost

000370

EATE 2 NOV 81

Sary Pollard med

#### CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT PIPE HANGER PROBLEM TRANSMITTAL SHEET

PHP 0	1871
PAGE _	OF

ATTENTION: GEORGE WHITE

HANGER VENDER: BEI HANGER DRAWING NO BUILDING: ELEVATION: EBASCO DRAWING NO	. & REV	1-1-216-1-		95 3/D	SEIS NON-	MIC SEISMIC	
PROBLEM DESCRIPTI	ON: WEL	D SYMI	301				. 11
ADD WE DELETE	LD SYM	BOL A	T JOIN	TS OF	MEMBERS	2	3
NOTE:	FLOOR	PENET 1'-10"	TRATION E of	LOCAT (FX)	ED 1'-8	″ ມ 。	13
							THE STATE OF THE S

PER CONVERSATION WITH EUGENE MONROE

OF CONSTRUCTION, PIPE WILL BE KEPT AT

PRESENT DESIGN LOCATION FOR THIS HGR

AND ANGLED OVER TO PENETRATION BELOW

ELEV. 218'-0".

RESOLVED PER SITE REV 35!

JMM 3:26-82

01/2/8

600012

FROBLEM REPORTED BY: .

Jany Coste

DATE 29 OCT 81

0.K1 (2)

To: E.E.W: lett

CC: 6.0.White CAROLINA POWER & LIGHT COMPANY

CC: 6.0.White SHEARON HARRIS NUCLEAR POWER PLANT

PIPE HANGER PROBLEM

TRANSMITTAL SHEET

PHP # 1824 PAGE 1 OF 1

ATTENTION: GRORGE WHITE

EBASCO DRAWING NO. & REV.

HANGER	VENDER:	BERGE	-PATE	RSON _					. 21.
HANGER	VENDER: DRAWING NG: REA ION: 2	NO. &	REV. I	A-2-23	36-1	-2	W-t	1-51	74C
BUILDI	IG: REA	CTOR	AUX	LIARY	BI	JILL	ING		
ELEVAT:	ION: 2	36							

SEISMIC NON-SEISMIC

PROBLEM DESCRIPTION: MISLOCATED EMBED

THE EMBED TO WHICH MEMBER (1) ATTACHES IS
LOCATED 4" EAST OF (1) IN THE FIELD. THE
BERGEN-PATERSON HANGER SKETCH SHOWS THE EMBED
LOCATED ON THE & OF (1) AS DOES G DRAWING
21686-156501.

-WELD SYMBOL FOR (3) TO (6) IS CONFUSING. SOUTH (3) TO (6)
HAS AN ALL AROUND FILLET SYMBOL TYPICAL AND NORTH
(3) TO (6) HAS A FILLET ON TWO SIDES.

-INTERSECTING POINT OF (8) TO (6) IS UNCLEAR.

- INCORRECT WELD SYMBOL FOR (2) TO(4).

-WELD FOR (7) TO (6) IS NOT TYPICAL

Resolved per SITE REU 251 5.VIAS

000373

A67

PROBLEM REPORTED BY: PAT CHRISCOE

DATE 10-23-81

# CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT PIPE HANGER PROBLEM TRANSMITTAL SHEET

PHP 0 2325 PAGE / OF /

ATTENTION: GEORGE WHITE

ANGER VENDER: BERGEN-PATERSON

ANGER DRAVING NO. & REV. A-1-236-1-PF-A-477  UILDING: RAS  LEVATION: 236  BASCO DRAWING NO. & REV. Z168-G-158 SOI R 9	NON-S	EISMIC E	j
			45
ROBLEM DESCRIPTION: NO EMBED .			o y and
			ings.
2168-(-158 SOI SHOWS NO EMBED AT HANGER	LOCATIO	on. no	
EMBED IS INSTACLED AT HANGER LOCATION ALSO	THERE	ARE NO	
WELD SYMBOLS BETTEEN DS AND D=			
	1		11000
		1.84.14.11	***
			1.64
HANGER VOID PER REV. 2/C		(# - Ye : )	
MHIVELE VOID PER 12EV. 2/2 JSH Z/11/87			-

To: 2. 2. 3 SHEARON HARRIS NUCLEAR POWER PLANT PHP 0 2293 PIPE HANGER PROBLEM TRANSMITTAL SHEET (3075.0) -ATTENTION: CHORGE WHITE HANGER VENDER: BERGEN-PATERSON HANGER DRAWING NO. & REV. _FW-H-61'4 (7-1-261-1) SEISMIC NON-SEISMIC BUILDING: ____ ELEVATION: _ EBASCO DRAWING NO. & REV. _ PROBLEM DESCRIPTION: WELD SYMBOL , MATERIAL 1.) ITEM () WILL HAVE TO BE REPLACED ON SITE. BECAUSE WE DO NOT HAVE ANY WBX 21 ON SITE PLEASE ALLOW W8x24 TO BE SUBSTITUTED. 2.) PLEASE CORRECT WELD SYMBOLS (Q) -SOUTH CLIPS IN ACCORDANCE W/ FCR-H-1006 SEE FW-H-61 REV. ISI JSH 1/29/82

9/5//

600373

DATE _/-29-82

2

TOPE E SELECT CE SON TAYLOR CESTON

## CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT PIPE HANGER PROBLEM TRANSMITTAL SHEET

PHP # 2198 PAGE / OF /

ATTENTION: GROEF WHITE		
HANGER VENDER: BERGEN-PATERSON HANGER DRAWING NO. & REV.	TW-H-318 9/A	SEISMIC X
WILDING:		NON-3513:410

ELEVATION: ______

ROBLEM D	ESCRIPTION: WELD SYMBOL MISSING - MATE LIST TOCORRECT.
1	WELD SUMBOL MISSING @ (9) TO (1)
2	BILL OF MATE CALLS FOR FOUR OF ITEM (6) - 8 ARE
	RECOURED.
(	( IF ,T IS FERSIBLE TO HAVE ONE AT EACH JUINT, THEN
	WEAVE AS IS.)
(3.7)	SECT F-D SHOULD BE THE CAL
(47)	IF TWO ITEMS (6) PRE REQUIRED ( EACH JOINT, THEN THE
3/	WELD SYMBOL FOR @ TO EXISTING STL. SHOULD BE TYPICAL.
1	THERE SHOULD BE A WELD SYMBOL SHOWING AN END
	RETURN FOR 6 TO EXISTING STL.
6	ANGLE AND SLOPE OF ITEM (D) DO NOT AGREE.
7	

fesolved per sine New as 1 5.Vits 1.20.82

ev.	1
10/81	THE WILLETT
	TOURS WELLE
	TOUTS (LOF)
	1 (SE 1800) 1
	ATTENTION

## CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT PIPE HANGER PROBLEM TRANSMITTAL SHEET

2

PHP # 3801 PAGE _ OF _

Exhibit 1

(55 /600)		
_ATTENTION:	GEORGE	WHITE

L-A-STITUTE OF WILLIE				
HANGER VENDER: BERGEN-PATERSON HANGER DRAWING NO. & REV. F-Z-ZG BUILDING: FOGE HANDLAG ELEVATION: ZGI EBASCO DRAWING NO. & REV.	1-1-4-CE-H-1167	<u>≈/∠</u>	SEISMIC NON-SEISMIC	
PROPLEM DESCRIPTION: BASE	PLATE DETAILS !	Nissing	the second	e dy
	•			20011
PILLISE PRUVIDE DETAILS FOR	BASE PLATE , SE	EE SHEET T	or 2.	7
(IS IT NOT MISSIBLE TO USE				1000
FOR POSSIBLE INTERFERENCES,				24:000 20 prom
PLENSE DELETE "MIN" com				The second
PLANE DELETE COUNCIL'S TO		IN THE FICE	D ( NOTE )	
Comercial and land route	Emach (2)			
	1			Als:
7	2011 11.23		18 st 1950	TOTALTY
TESOLIED PER SITE REL 251	5'-0" (TYP)			
				-
9%		6"		10/6-4
		12"	PLAN VIEW	<u>~</u>
g"		6"		41
				1
(764)		1'-	61/2"	N
		8/16	© 6003	62
	AST P	i.k		182

### KELIVOIELIVIV

CAROLINA POLER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT HANGER/SUPPORT PROBLEM TRANSMITTAL SHEET

	No. YH	H- 600	
Page 1		1	
			-605
			CHO 11-25-80

Attention: PETE	FIALA.				
Manger/Support Vendor Vendor Drawing No. & Endrac Drawing No. & Ebasco Drawing No. & Suilding: RAB	Rev. A-3-216-1	- PD-H-69 / K	¥=	Seismic  Non-Seismic	
Problem Description: WELD THE TOP JOINTS OF PA	JOINTS OF	5 UNCLEAR . D	OR WEL	PARTS () AND AL DETAIL MEAN D THE ROTTOM DDITION WELD	_ _ _ _
· RESOLUTION	: SEE HANSE	ie skutch' h	7-3-2/6-/- 7	D-11'-697 BEV.	
				12-17	•
				6000	38
	Marth	9. A. M	1.2°	5t ⁰	

Probler reported by:

CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT HANGER/SUPPORT PROBLEM

	1	No.	PHP- 582	
Page	1	of	1	

Date 11-21-80

		IKANSATITAL	SHLLI			
Attention: PET	E FIALK	1				
REINSPECT	ON					
Hanger/Support Vend Vendor Drawing No. Endrac Drawing No. Ebasco Drawing No. Euclding: RAI	6 Rev. A-1 6 Rev. 6	-PATERSON -190-1-RH-H		(D		eismic eismic
Problem Description	MEMBE	R 4. IT H	AS BEEN	WELDED A	LL THE	WAY
MEMBER @ AN	D MEMBE	ET. THERE	ASE ADD	CORPETT	WELD SU	RETWEEN
IT HAS BEEN	WELDED	ALL THE WA	T AROUND	WITH A 1/	"FILLET.	ALSO
MEMBER 6	AS BEEN	INSTALLED	ACCORS	DING TO	SECTION	AA SO
ITS POSITION	IN THE	ELEV. LY	SG WEST	NEEDS T	O BE C	ORRECTED
	14-165					
<del></del>						1000
RESOLUTION	: 486	HANGER	IKETCH A	1-1-190-1	RH-H-	64 R. 8/F
			A. K	: 1 moni-	12-	24-20
						600365

Problem reported by: William Hartle

No. PHP- 56a

CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT HANGER/SUPPORT PROBLEM TRANSMITTAL SHEET

Accention: PET	E FIALA .		
Hanger/Support Vend Vendor Drawing No. Endrac Drawing No. Ebasco Drawing No. Ebasco Drawing No.	& Rev.	R W	Seismic Non-Seismic
Problem Description	NEED WELD SYMBOL PLEASE REVISE.	- FOR JOINT OF	manners (3) 's (7).
255060710	W: SEE HAHGER SKEI		
		9. Felgorenta	
			630363
Problem reported by	· Miniacles of AN	14.19.	Date 11-19-60

	No. Ph	H-540
Page	1 of	1

CAROLINA POWER & LIGHT COMPANY
SHEARON HARRIS NUCLEAR POWER PLANT
HANGER/SUPPORT PROBLEM
TRANSMITTAL SHEET

Attention: TED FEIGENBAUM	
Hanger/Support Vendor Bossel-Parenton Vendor Drawing No. & Rev. A-1-190-1-CT-H-797 REV Endrac Drawing No. & Rev. Ebasco Drawing No. & Rev.	Seiszic Seiszic
Puilding: RAB Elevation 190	Non-Seismic
Problem Description: MEMBER 3 15 A 2000 -1.	
PART THAT ATTACHES TO T	HE 4 SIDE OF THE TUBE
STEEL IS 3 3/4" WIDE SO WHERE MEMBE (2) ON THE NORTH AND SOUTH SIDE IT N	
ON THE EAST AND WEST SIDE IT NEE	FIRS A FILLET WELD AND
FIELD HAS WELDED MEMBER 3 WITH A	" EVET - THE
AND SOUTH SIDE AND A FLARE BEVEL OF	AL THE EAST AND WEST
DE. IF ACCEPTABLE PLEASE CHANGE	
RESOLUTION: SEE HANGER SKETCH A-1-	190-1-CT-H-797 R. 1/8
	A. Follymonia 12-08-80
- 10 10 10 10 10 10 10 10 10 10 10 10 10	
	600367
	1
Problem reported by: William Heatte	Date //-/8-80 .

### FFT 0000.000

WP-HC

### CAROLINA POWER & LIGHT COMPANY.

	PRIORITY 12
ATTENTION : GEORGE WHITE	PHP NO. 4319
HANGER NO. A- 5- 2.3.6- 1- P.D-	H- [13,3,8]
SEISMIC NON-SEISMIC	REV. 10,5,2
PROBLEM TYPE WELDING	
PROBLEM DESCRIPTION RECOURCES WELD	SIZE CANNOT
BE MADE AT (2) TO (1) ON THE	The state of the s
AT THE EAST END OF THE HAN	
NOW UNDERSIZE AND CANNOT	
DUE TO MATTRIAL SIZE ACA	
WELD SIZE OR ENLARGE DATE	ENEMBER (1) (W
THIS END	

000354

PROBLEM REPORTED BY: 4 Mind Mond DATE 2737 13.

CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT PIPE HANGER PROBLEM TRANSMITTAL SHEET  ATTENTION: GEORGE WHITE	BHP # 3449 PAGE TOF T
HANGER VENDER: BERGEN-PATERSON HANGER DRAWING NO. & REV. A-3-236-1-MS-H-7611B BUILDING: REACTOR AUXILIARY BUILDING ELEVATION: 236 EBASCO DRAWING NO. & REV.	SEISMIC NON-SEISMIC
PROPLEM DESCRIPTION: WELD SYMBOL	
- WELD LAP IS NOT DIMENSIONED IN EMBED AND 60 TO EMBED. LAP ON I FOR (3) IS 27/8". LAP ON SOUTH EMBE 6 IS 4".	NORTH EMBED
	atto come questa establica
ESOLVED BY  ITE REV 151  DUW 07/28/82  P.CHRISCOE 8-5-82	
	680358
PROBLEM PEROPTED BY: PAT CHRISCOE #67 6/18	DATE 6-25-82

Ko.PHP- 903

CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT HANGER/SUPPORT PROBLEM TRANSMITTAL SHEET

tion: PETE FIALA.	
r/Support Vendor Based-Paterson  r Drawing No. 6 Rev. A-3-236-1-DW-H-84 O/A  e Drawing No. 6 Rev.  c Drawing No. 6 Rev.  Elevation 236	Seismin Non-Seismin
er Description:	
Please provide a weld symbol - + (7) +o (1). Member (7) was instead  A 1/4" fillet 'all around" at b	
Please clarify "Typ" at (4) to (	7
	.381.7
RESULUTION ; SER HAMMER SKETCH A-3-236-1-2	
A. Follyno.	win 02-05-81
	600161
les reported by: Pw Howal	5.61 Date 1-15-

18/0	0: E		1 5 7	7	
0/81	o: E.		1111	E	
			AYL		
	(2	3.5	(0)	1	
1				_	
				1	
			AMA		ION:
			-		
				-	ERGE

## CAROLINA POWER & LIGHT COMPANY SHEAPON HARRIS NUCLEAR POWER PLANT PIPE HANGEP PROBLEM TRANSMITTAL SHEET

PHP # 3179 - PAGE 1 OF 1

ATTENTION: GEORGE WHITE

HANGER VENDER: BERGEN-PATERSON
HANGER DRAWING NO. & REV. 9-7-236-1-BR-H-1645
BUILDING: RAB
ELEVATION: 236'

SEISMIC NON-SEISMIC X

PROPLEM DESCRIPTION: Can not weld item (2)

Hanger is designed to install in trench and can not be welded as desighed. Hanger can be welded as shown below by cutting @ & making @ longer as shown below. Weld @ after pipe is installed.

Ref. PHBC# 123


EBASCO DRAWING NO. & REV.

ENG TIME 2485 50

SECRETA SERCATED BY: dolman

RESOLVED PERFLD REV 151

JCD 6-8-82



630465

E-E LOCKING SOUT -

achien

DATE 5-27-92

Kev. 1 10/81

## CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT PIPE HANGER PROBLEM TRANSMITTAL SHEET

Exhibit 1 (3)
PHP # 3134
PAGE 1 OF 1

ATTENTION:	GEORGE WHITE		
HANGER VENDER: BERGEN HANGER DRAWING NO. & BUILDING: RA ELEVATION: 236-0 EBASCO DRAWING NO. &	REV. A-4-236-1-FP-	052 H-981	SEISMIC NON-SEISMIC
PROPLEM DESCRIPTION:	Weld cha	ng.e	
Item ( is Fillet weld Change we	shop welded to can not be ld symbols a	made inside is senown in ske	nstalled. Vindowr tch helow.
			- Kguni
		TYP	
	3/1. 10°	ELEVILOOKING WE	SI 000163
PROBLEM REPORTED BY:	Johnny docks	*67	DATE 5-24-82

kev. 1 * 10/81

## CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT PIPE HANGER PROBLEM TRANSMITTAL SHEET

	Exhibit
0	WP-110
PHP #	3543
PAGE	I OF f

ATTENTION: GEORGE WHITE	
HANGER VENDER: BERGEN-PATERSON HANGER DRAWING NO. & REV. A-1-216-1-2x-H-729-15/ BUILDING: ELEVATION: EBASCO DRAWING NO. & REV.	SEISMIC NON-SEISMIC
PROPLEM DESCRIPTION: WELD SYMBOL.	
CHANGE WELD SYMBOL FOR # 1 TO ZSIDE AS SHOWN BELOW.	EMBED TO 14 FILLET
	p de mar est
140 129.8°V	
RESO	LVED PERSONE

RESOLVED PERSONE REV 152 PLB 7/20/82

pwhácz

000403

DATE 7-15-82

PROBLEM REPORTED BY

Kev.	**
10/8	

170:	2 G O G		- 1
(cc:	G. 0	3100	1 0
1	1000	mari	
1	(221		
1			
1			

#### CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT PIPE HANGER PROBLEM TRANSMITTAL SHEET

1		
1		
12)		
61		
		2111
	- 1	-
	- 3	

Exhibit 1 WP-110 PHP # 3946 PAGE | OF 1

ATTENTION: GEORGE WHITE

HANGER VENDER: BERGEN-PATERSON HANGER DRAWING NO. & REV. A-1-216-1-5W-H-110-7/= BUILDING: ELEVATION: EBASCO DRAWING NO. & REV.	SEISMIC NON-SEISMIC
PROPLEM DESCRIPTION: GEOMETRY DISCREPANCIES	
D DIMENSION FROM THE & OF #3 TO THE  B DIMENSION FROM & OF PIN TO THE	HE & of #9 6#6
3) DINIENSION FROM & OF PIN TO THE	TOE of #4 15
Q CLARITY WELD LEDOTH FOR #3 TO # WELD WILL BE FLARE BEVEZ.	6 AS PART of
	70 <b>2</b> PH

RESOLVED AT SITE
REV 751

MB 9-9-82

OK
MST
0.16-82

Michael Stages + Ker 5/7

000411 DATE 8.30-82 v. *: 1/81

#### CAROLINA POWER & LIGHT COMPANY SHEAPON HARRIS NUCLEAR POWER PLANT PIPE HANGER PROBLEM TRAMSMITTAL SHEET

Exhibit 1 WP-110 PHP # 4184 PAGE _ ( OF 1

ATTENTION: GEORGE WHITE

RESOLVED AT SITE

MB 10/25/82.

Rev 152

MANGER VENDER: HANGER DRAWING BUILDING: ELEVATION: EBASCO DRAWING	NO. & REV.	_A-3-Z	6-Z -SW- H-	768 15	H		SEISMIC NON-SEISM	ده <u>ا</u>
PROPLEM DESCRI	PTION:	Mensel	Oz. cutati	or 4	Fine T	PLATE		
BOTHICA		LOHCE *	2 Pure					
			SECTION A-A					
Engineer	ed plubes	are:	5 6.1	-	@ + @ West @			
			59.5		eut (		2	- sweety-

600417

· 604 A67 10/11

DATE MILEZ.

REINSPECTION

CAROLINA POWER & LIGHT COMPANY

SHEARON HARRIS NUCLEAR POWER PLANT

HANGER/SUPPORT PROBLEM

TRANSMITTAL SHEET

	,	· 0 .	-	175	
Page	1	of			

Tital 1-2-81 Date 1/2:81

ger/Support Vendor Bogged-Parenson  for Drawing No. & Rev. A-2-336-1-CC rac Drawing No. & Rev. sco Drawing No. & Rev.  Iding:  Elevation	Seismic Non-Seismic
eler Destription:	
	NEORCEMENT? PLEASE ADVISE.
ESOLUTION: HEE HANGER SKE	A. Follynowin 01-24-
ESOLUTION: HEE HANGER SKE	TCH A-2-236-1-CC-H-1254 REV.

Phase Thomas

Problem reported by:

Page 1 of CARDLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR PUWER PLANT HANGER/SUPPORT PROBLEM TRANSMITTAL SHEET PETE FIALA . -tien: er/Support Vendor BORGEN - PATERSON
or Drawing No. 6 Rev. A-4-216-1-FD-H-301 3 D Seismis at Drawing No. & Rev. to Drawing No. 6 Rev. Elevation Non-Seismic lem Description: WELD SYMBOLS THAT SHOULD JOIN ITEMS (3) TO (4); @ TO O; AND @ TO (F) ARE MISSING . PLEASE REVISE THIS DRAWING RESOLUTION : SER HANGER SKETCH 1-4-216-1-PD-H-301 R. 4/E A. Follynowth 02-05-81 630120 Plan Thomas FIT 1-2-81 Date 1/2/81

CAROLINA POLITE & LIGHT COMPANY Page 1 of

-815

CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT HANGER/SUPPORT PROBLEY TRANSMITTAL SHEET

terrioni PETE F	-IALA - ·	and the second second	
nger/Support Vendor Bondor Drawing No. & Rev. drac Drawing No. & Rev. asco Drawing No. & Rev. diding:	A-3-236-1-DW-	4-87 1/B	Seismic Non-Seismic
oblem Description:			
	DIN SECTION A-A BECAUSE OF TH		
PESOTUEIN	LEE HANGER SKET	CH A-3-236-/- DH	1-H-87 2. 2/c
, , , , , , , , , , , , , , , , , , , ,		A. Folly~in	
-			
			000450

robler reported by:

E.E. W. Hether (D) (E) Jan (E) PSCO)

#### GARCLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT PIPE HANGER PROBLEM TRANSMITTAL SHEET

PHP • 1778 PAGE __ OF __.

ATTENTION: GEORGE WHITE

HANGER	VENDER:	BERGEN	-PATERSON
*******			

HANGER DRAWING NO. & REV. A-1-236-1-CX -H-648
BUILDING: RAS

SEISMIC NON-SEISMIC

ELEVATION: 236
EBASCO DRAWING NO. & REV.

PROBLEM DESCRIPTION:	WELD	PROBLEM			
					e de la company
MEMBER D	CANNOT	BE WELDED	ON BOTH S	DES DU	E
TO LACK OF	ROOM C	HANGE OUFL	D TO PARTIAL	L PEN.	1,378,0
					Kultifati er
THE PROPERTY OF					
				naga, nikia	· Marionse
				<u> Laurente</u>	

RESOLUED PER SITE REU. OSI. FOR WELD CALC, SEE PHP- 1727. JAM 10-21-81

000374

PROBLEM REPORTED BY:

William c siantle

18-03-01 STAD