

WOLF CREEK

NUCLEAR OPERATING CORPORATION

Otto L. Maynard
Vice President Plant Operations

January 11, 1996

WO 96-0004


U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-137
Washington, D. C. 20555

Subject: Docket No. 50-482: December, 1995, Monthly
Operating Report

Gentlemen:

Attached is the December, 1995, Monthly Operating Report for Wolf Creek
Generating Station. This submittal is being made in accordance with the
requirements of Technical Specification 6.9.1.8.

Very truly yours,



Otto L. Maynard

OLM/jad

Attachment

cc: L. J. Callan (NRC), w/a
W. D. Johnson (NRC), w/a
J. F. Ringwald (NRC), w/a
J. C. Stone (NRC), w/a

170039

9601170009 951231
PDR ADDCK 05000482
R PDR

P.O. Box 411 / Burlington, KS 66839 / Phone: (316) 364-8831

An Equal Opportunity Employer M/F/HC/VET

IF29
11

WOLF CREEK NUCLEAR OPERATING CORPORATION

WOLF CREEK GENERATING STATION

MONTHLY OPERATING REPORT

MONTH: December YEAR: 1995

Docket No.: 50-482

Facility Operating License No.: NPF-42

Report No. 130

SUMMARY

The following report highlights the operating experience of Wolf Creek Generating Station for the month of December, 1995. This report is being provided pursuant to Technical Specification 6.9.1.8.

I. SUMMARY OF OPERATING EXPERIENCE

The unit operated at or near 100% power, Mode 1, through the month of December, 1995.

II. MAJOR SAFETY RELATED MAINTENANCE ACTIVITIES

NONE

OPERATING STATUS

1. Reporting Period: December, 1995 Gross Hours in Reporting Period: 744
2. Currently Authorized Power Level (Mwt): 3565 Max. Depend. Capacity (MWe-Net): 1167
 Design Electrical Rating (MWe-Net): 1170
3. Power Level to Which Restricted (If Any) (MWe-Net): N/A
4. Reasons for Restriction (If Any): N/A
- | | This Month | Yr. to Date | Cumulative |
|---|------------------|-------------------|--------------------|
| 5. Number of Hours Reactor was Critical | <u>744</u> | <u>8,648.7</u> | <u>74,616.8</u> |
| 6. Reactor Reserve Shutdown Hours | <u>0.0</u> | <u>0.0</u> | <u>339.8</u> |
| 7. Hours Generator on Line | <u>744</u> | <u>8,625.1</u> | <u>73,779.7</u> |
| 8. Unit Reserve Shutdown Hours | <u>0.0</u> | <u>0.0</u> | <u>0.0</u> |
| 9. Gross Thermal Energy Generated (MWh) | <u>2,639,730</u> | <u>30,308,867</u> | <u>245,341,185</u> |
| 10. Gross Electrical Energy Generated (MWh) | <u>918,312</u> | <u>10,494,705</u> | <u>85,258,920</u> |
| 11. Net Electrical Energy Generated (MWh) | <u>883,988</u> | <u>10,062,177</u> | <u>81,436,851</u> |
| 12. Reactor Service Factor | <u>100.0%</u> | <u>98.7%</u> | <u>82.4%</u> |
| 13. Reactor Availability Factor | <u>100.0%</u> | <u>98.7%</u> | <u>82.8%</u> |
| 14. Unit Service Factor | <u>100.0%</u> | <u>98.5%</u> | <u>81.5%</u> |
| 15. Unit Availability Factor | <u>100.0%</u> | <u>98.5%</u> | <u>81.5%</u> |
| 16. Unit Capacity Factor (Using MDC) | <u>101.8%</u> | <u>98.7%</u> | <u>79.2%</u> |
| 17. Unit Capacity Factor (Using Design MWe) | <u>101.6%</u> | <u>98.2%</u> | <u>76.9%</u> |
| 18. Unit Forced Outage Rate | <u>0.0%</u> | <u>1.5%</u> | <u>4.7%</u> |
19. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of each):
Refuel VIII outage is scheduled to begin approximately March 1, 1996.
20. If Shut Down at End of Report Period, Estimate Date of Startup: N/A

AVERAGE DAILY UNIT POWER LEVEL
DOCKET NO. 50-482
WOLF CREEK GENERATING STATION
WOLF CREEK NUCLEAR OPERATING CORPORATION
DATE 1-9-96
TELEPHONE 316-364-8831

MONTH December, 1995DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1	1189
2	1188
3	1189
4	1189
5	1189
6	1189
7	1184
8	1184
9	1188
10	1188
11	1191
12	1190
13	1190
14	1182
15	1188
16	1191

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17	1191
18	1190
19	1189
20	1189
21	1181
22	1189
23	1189
24	1190
25	1190
26	1190
27	1189
28	1179
29	1188
30	1190
31	1191

WOLF CREEK NUCLEAR OPERATING CORPORATION

WOLF CREEK GENERATING STATION

UNIT NO. 1

MONTH December, 1995

SUMMARY OPERATING EXPERIENCE

Listed below in chronological sequence is a summary of operating experiences for this month which required load reduction or resulted in significant non-load related incidents.

<u>DATE</u>	<u>TIME</u>	<u>EVENT</u>
N/A	N/A	N/A