

CP&L

Carolina Power & Light Company

Brunswick Steam Electric Plant
P. O. Box 10429
Southport, NC 28461-0429
November 21, 1984

FILE: B09-13510C
SERIAL: BSEP/84-2609


NRC Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555

BRUNSWICK STEAM ELECTRIC PLANT UNIT 2
DOCKET NO. 50-324
LICENSE NO. DPR-62
LICENSEE EVENT REPORT 2-84-12

Gentlemen:

At 1345 on October 24, 1984, an automatic Reactor Protection System high pressure scram occurred on Unit 2 when the MSIVs closed on a Group 1 isolation signal. The investigation and review of this event is still in progress, therefore, the Licensee Event Report required for this event will be delayed until on or before December 14, 1984.

Very truly yours,



C. R. Dietz, General Manager
Brunswick Steam Electric Plant

MJP/sdl/LETSDL

Enclosure

cc: Mr. R. C. DeYoung
Mr. J. P. O'Reilly

112030519 841121
PDR ADOCK 05000324
S PDR

NOTE: NO ENCL
Rec'd

IE22
1/0