




KANSAS GAS AND ELECTRIC COMPANY

GLENN L. KOESTER
VICE PRESIDENT - NUCLEAR

December 5, 1984

Mr. R.P. Denise, Director
Wolf Creek Task Force
U.S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011



KMLNRC 84-212
Re: Docket No. STN 50-482
Ref: Interim Report KMLNRC 63-161 dated 12/07/83
from GLKoester, KG&E, to JEGagliardo, NRC
Subj: Interim Status Report for Wolf Creek
Generating Station 10CFR50.55(e) Items

Dear Mr. Denise:

Attached is a copy of Kansas Gas and Electric Company's
Status Report for October and November, 1984, on 10CFR50.55(e)
items. The format and purpose of this report were described
in the Reference.

If you have any questions concerning this subject, please
contact me or Mr. Otto Maynard of my staff.

Yours very truly,

Glenn L. Koester

GLK:bb
Attach
xc: RCDeYoung, w/a
PO'Connor, w/a
HBundy, w/a

84122/0013 841205
PDR ADOCK 05000482
S PDR

IF-27
11

Status Report

On

10CFR50.55(e)/Part 21 Open Items

December 5, 1984

I. LEGEND

- File: QA Record File Number
- Title: Title or Subject Matter
- Reported: When Deficiency Was Initially Reported to NRC
- Status: Status
- RPT: NRC Inspection Report Reference
- OPEN - Concern has not been resolved.
- FINAL - Final report has been submitted but corrective action has not been completed or closure documentation has not been through final review.
- REVIEW - Ready for NRC review. All corrective actions completed or evaluation has determined that this item is not reportable pursuant to 50.55(e)/ Part 21.
- *CLOSE - Has been reviewed and recommended for closure by the NRC. No inspection report has been received.
- CLOSED - The NRC has reviewed and closed this item.

- I. Legend
- II. Status of KG&E Reported Items
- III. Status of SNUPPS Reported Items

II. Status of Significant Deficiencies Report by KG&E

10CFR50.55(e) / PART 21 ITEMS

FILE	TITLE	REPORTED STATUS	RPT.	REFERENCES	REMARKS
53564-K005	ESWS DAMAGED VALVE OPERATOR	79/02/15	*CLOSE 84-44	KMLNRC XX-XXX,79/03/14	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-44.
53564-K026	MASONRY WALLS - MISALIGNED REBAR	79/12/19	*CLOSE 84-44	KMLNRC XX-XXX,80/01/24 KMLNRC XX-XXX,80/04/30 KMLNRC 80-009,80/06/27 KMLNRC 80-030,80/09/30 KMLNRC 80-042,80/11/28 KMLNRC 81-092,81/06/29 KMLNRC 81-139,81/11/24 KMLNRC 82-180,82/03/25	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-44.
53564-K052	GENERAL ELECTRIC AKR 30 AND 50 BREAKERS	81/04/02	REVIEW	KMLNRC 81-074,81/04/30	THIS ITEM IS PRESENTLY READY FOR REVIEW BY THE NRC.
53564-K065	WESTINGHOUSE POST ACCIDENT INSTRUMENTATION ERRORS	82/04/08	*CLOSE 84-44	KMLNRC 82-196,82/05/04 KMLNRC 82-211,82/06/09 KMLNRC 82-250,82/11/03 KMLNRC 83-018,83/03/01 KMLNRC 83-084,83/07/01	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-44.
53564-K068	DANIELS TEST FOR WELDING INSPECTORS	82/07/12	*CLOSE 84-23	KMLNRC 82-234,82/08/11 KMLNRC 82-247,82/10/20 KMLNRC 83-013,83/01/31 KMLNRC 83-049,83/04/25 KMLNRC 83-114,83/08/26 KMLNRC 83-157,83/11/28 KMLNRC 84-134,84/08/06	REVIEWED AND RECOMMENDED FOR CLOSURE. NO KNOWN INSPECTION REPORT REFERENCE. AWAITING NRC ACTION.
53564-K101	VULKENE SUPREME CABLE	83/06/20	*CLOSE UNKWN	KMLNRC 83-095,83/07/20 KMLNRC 83-125,83/09/28 KMLNRC 83-151,83/11/23 KMLNRC 84-185,84/10/17	REVIEWED AND RECOMMENDED FOR CLOSURE. NO KNOWN INSPECTION REPORT REFERENCE. AWAITING NRC ACTION.
53564-K103	SWAY STRUT WASHERS	83/07/15	*CLOSE UNKWN	KMLNRC 83-104,83/08/12 KMLNRC 83-143,83/11/03 KMLNRC 84-165,84/09/21	REVIEWED AND RECOMMENDED FOR CLOSURE. NO KNOWN INSPECTION REPORT REFERENCE. AWAITING NRC ACTION.
53564-K106	GOULD - RUNDALL HANDSWITCHES	83/08/24	*CLOSE UNKWN	SLNRC 84-028,84/02/09 SLNRC 84-067,84/04/13 SLNRC 84-103,84/07/20	REVIEWED AND RECOMMENDED FOR CLOSURE. NO KNOWN INSPECTION REPORT REFERENCE. AWAITING NRC ACTION.
53564-K112	POLAR CRANE TESTING	83/11/18	REVIEW	KMLNRC 83-165,83/12/16 KMLNRC 84-164,84/09/21	AWAITING COMPLETION OF NRC REVIEW.
53564-K113	CABLE TERMINATION LUGS	83/11/18	*CLOSE 84-44	KMLNRC 83-164,83/12/16 KMLNRC 84-090,84/06/15	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-44.
53564-K114	I - BEAMS	83/12/01	*CLOSE UNKWN	KMLNRC 83-170,83/12/30 KMLNRC 84-184,84/10/17	REVIEWED AND RECOMMENDED FOR CLOSURE. NO KNOWN INSPECTION REPORT REFERENCE. AWAITING NRC ACTION.
53564-K116	PIPE SCHEDULE	83/12/13	REVIEW	KMLNRC 84-005,84/01/12	AWAITING COMPLETION OF NRC REVIEW.

10CFR50.55(a) / PART 21 ITEMS

FILE	TITLE	REPORTED STATUS	RPT.	REFERENCES	REMARKS
53564-K118	FIELD PROCUREMENT	84/01/03	REVIEW	KMLNRC 84-011,84/02/02	AWAITING COMPLETION OF NRC REVIEW.
53564-K120	FUSION WELDED PIPE	84/01/20	*CLOSE UNKWN	KMLNRC 84-018,84/02/17 KMLNRC 84-163,84/09/21	REVIEWED AND RECOMMENDED FOR CLOSURE. NO KNOWN INSPECTION REPORT REFERENCE. AWAITING NRC ACTION.
53564-K121	LIMITORQUE OPERATORS	84/02/03	OPEN	KMLNRC 84-024,84/03/01	FINAL REPORT IN DECEMBER.
53564-K122	CHECK VALVES	84/02/06	*CLOSE UNKWN	KMLNRC 84-027,84/03/07 KMLNRC 84-166,84/09/21	REVIEWED AND RECOMMENDED FOR CLOSURE. NO KNOWN INSPECTION REPORT REFERENCE. AWAITING NRC ACTION.
53564-K126	DIESEL GENERATOR LUBE OIL KEEP WARM PUMP	84/03/09	OPEN	KMLNRC 84-056,84/04/05	FINAL REPORT IN DECEMBER.
53564-K127	VALCOR WIRING	84/03/15	REVIEW	SLNRC 84-065,84/04/13 SLNRC 84-079,84/05/10	AWAITING COMPLETION OF NRC REVIEW.
53564-K128	FAN MECHANICAL INTERLOCKS	84/03/16	OPEN	KMLNRC 84-061,84/04/11	FINAL REPORT IN DECEMBER.
53564-K132	SEISMIC POSITIONER PLATES ON DS-416 REACTOR TRIP BREAKERS	84/03/27	*CLOSE 84-44	KMLNRC 84-071,84/04/26 KMLNRC 84-160,84/09/21	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-44.
53564-K133	CONTAINMENT SPRAY PUMP ROOM FLOODING	84/03/27	*CLOSE 84-44	KMLNRC 84-072,84/04/26 KMLNRC 84-178,84/10/08	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-44.
53564-K135	BARTON 752 TRANSMITTERS	84/04/24	FINAL	KMLNRC 84-078,84/05/23 KMLNRC 84-177,84/10/08	COMPLETION OF THIS ITEM IN DECEMBER.
53564-K138	DIESEL GENERATOR TURBOCHARGER	84/05/04	OPEN	KMLNRC 84-083,84/06/01	FINAL REPORT IN DECEMBER.
53564-K139	TMI LEAD AUDITOR	84/05/24	OPEN	KMLNRC 84-098,84/06/21	FINAL REPORT IN DECEMBER.
53564-K140	THREE HOUR FIRE DOORS	84/05/24	FINAL	KMLNRC 84-097,84/06/21	SUPPLEMENTAL FINAL REPORT IN DECEMBER.
53564-K141	MICROBIOLOGICALLY INDUCED CORROSION	84/06/01	OPEN	KMLNRC 84-106,84/06/29	FINAL REPORT IN DECEMBER.
53564-K143	ASME COMPONENT REMOVAL	84/06/13	OPEN	KMLNRC 84-115,84/07/11	FINAL REPORT IN DECEMBER.
53564-K146	LIMITORQUE SB-2-80 ACTUATOR GEAR DAMAGE	84/04/19	FINAL	SLNRC 84-090,84/06/01 SLNRC 84-106,84/07/20 SLNRC 84-126,84/11/15	COMPLETION OF THIS ITEM IN DECEMBER.
53564-K147	LUBE OIL PIPING SYSTEM	84/07/17	OPEN	KMLNRC 84-147,84/08/17	FINAL REPORT IN DECEMBER.
53564-K148	RCS RTD CALIBRATION DATA	84/08/01	OPEN	KMLNRC 84-158,84/08/31	FINAL REPORT IN DECEMBER.
53564-K149	INCORE THERMOCOUPLE ADAPTOR CABLES	84/08/06	FINAL	KMLNRC 84-159,84/09/05	COMPLETION OF WORK ON THIS ITEM IN DECEMBER.
53564-K150	TC/CCM ALARM AND CAUTION RELAYS	84/08/21	OPEN	KMLNRC 84-162,84/09/20	FINAL REPORT IN DECEMBER.

10CFR50.55(e) / PART 21 ITEMS

FILE	TITLE	REPORTED STATUS	RPT.	REFERENCES	REMARKS
53564-K151	MECHANICAL SHOCK ARRESTORS	84/08/23	REVIEW	KMLNRC 84-168,84/09/21	THIS ITEM IS PRESENTLY READY FOR REVIEW BY THE NRC.
53564-K152	INSPECTION OF WELDS	84/09/18	OPEN	KMLNRC 84-187,84/10/17 KMLNRC 84-191,84/10/29	COMPLETION OF WORK AND FINAL REPORT ON THIS ITEM IN DECEMBER.
53564-K153	TURBINE DRIVEN AUXILIARY FEEDWATER PUMP TERMINAL STRIP	84/07/17	*CLOSE	84-44 KMLNRC 84-188,84/10/22	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-44.
53564-K154	EXCORE NEUTRON DETECTORS	84/10/09	FINAL	KMLNRC 84-195,84/11/09	COMPLETION OF WORK FOR THIS ITEM IN DECEMBER.
53564-K155	PRESSURIZER POWER OPERATED RELIEF VALVES	84/10/11	REVIEW	KMLNRC 84-196,84/11/13	THIS ITEM IS READY FOR NRC REVIEW.
53564-K156	TURBINE DRIVEN AUXILIARY FEEDWATER PUMP GUIDE STEM BUSHING	84/10/17	*CLOSE	UNKWN KMLNRC 84-192,84/11/16	REVIEWED AND RECOMMENDED FOR CLOSURE. NO KNOWN INSPECTION REPORT REFERENCE. AWAITING NRC ACTION.

III. Status of SNUPPS Reported Items

10CFR50.55(e) / PART 21 ITEMS

FILE	TITLE	REPORTED STATUS	RPT.	REFERENCES	REMARKS
55780-K007	RUSKIN FIRE DAMPERS	80/01/18 *CLOSE	UNKWN	SLNRC 80-008,80/02/15 SLNRC 80-016,80/04/03 SLNRC 80-024,80/05/16	REVIEWED AND RECOMMENDED FOR CLOSURE. NO KNOWN INSPECTION REPORT REFERENCE. AWAITING NRC ACTION.
55780-K024	WESTINGHOUSE EMD GATE VALVES	80/10/30 *CLOSE	84-44	SLNRC 80-054,80/11/26 SLNRC 81-022,31/04/01 SLNRC 82-038,82/09/03	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-44.
55780-K026	PIPE WHIP RESTRAINTS (FOUR INCHES AND UNDER)	80/12/24	REVIEW	SLNRC 81-043,81/06/05	THIS ITEM IS READY FOR REVIEW BY THE NRC.
55780-K033	REACTOR TRIP SWITCHGEAR	83/04/21 *CLOSE	84-44	SLNRC 83-028,83/05/23	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-44.
55780-K034	WESTINGHOUSE 7300 PROCESS SYSTEM	83/06/02	FINAL	SLNRC 83-039,83/07/21 SLNRC 84-007,84/01/24	COMPLETION OF WORK FOR THIS ITEM IN DECEMBER.
55780-K035	YARWAY VALVES	83/06/17 *CLOSE	UNKWN	SLNRC 83-037,83/07/18 SLNRC 83-043,83/07/29	REVIEWED AND RECOMMENDED FOR CLOSURE. NO KNOWN INSPECTION REPORT REFERENCE. AWAITING NRC ACTION.
55780-K036	EXCESSIVE VOLTAGE DROP IN CONTROL CABLES	83/06/23 *CLOSE	UNKWN	SLNRC 83-040,83/07/22	REVIEWED AND RECOMMENDED FOR CLOSURE. NO KNOWN INSPECTION REPORT REFERENCE. AWAITING NRC ACTION.
55780-K037	HANGER CLASSIFICATION	83/10/23 *CLOSE	84-44	SLNRC 83-060,83/11/22 SLNRC 84-006,84/01/20	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-44.