

# CP&L

PRP  
OFFICIAL COPY

Carolina Power & Light Company

34 NOV 6 AIO: 24

Brunswick Steam Electric Plant

P. O. Box 10429

Southport, NC 28461-0429

October 31, 1984

FILE: B09-13510C

SERIAL: BSEP/84-2282

Mr. James P. O'Reilly, Administrator  
U.S. Nuclear Regulatory Commission  
Region II, Suite 3100  
101 Marietta Street N.W.  
Atlanta, GA 30323

BRUNSWICK STEAM ELECTRIC PLANT UNIT 1

DOCKET NO. 50-325/

LICENSE NO. DPR-71


SPECIAL REPORT PER TECHNICAL SPECIFICATION 3.7.8 AND  
PURSUANT TO TECHNICAL SPECIFICATION 6.9.2 (1-SR-84-7)

Dear Mr. O'Reilly:

During Unit 1 power operation, concurrent with Unit 2 preoperational testing following a unit refueling/maintenance outage, a Unit 1 fire barrier LCO was initiated on September 24, 1984, for a fire door in the units' common Emergency AC Diesel Generator Building.

The subject fire door, No. 214, is located at fire barrier penetration seal No. DG-3-400 on the 50-foot north elevation of the building. Door No. 214 provides personnel access to the elevation from the northern stairwell of the building. The involved LCO was initiated due to the inability of the door to properly open and close as a result of excessive differential pressure conditions at the door. On October 1, 1984, the specified seven-day time frame of the LCO was exceeded. Until resolution of the excessive differential pressure condition affecting fire door No. 214, the involved LCO and appropriately stationed fire watches will remain in effect.

Very truly yours,



C. R. Dietz, General Manager  
Brunswick Steam Electric Plant

MJP/mcg/LETG2

cc: Mr. R. C. DeYoung  
NRC Document Control Desk

8411160144 841031  
PDR ADOCK 05000325  
S PDR

OFFICIAL COPY

IE 22

1/0