

Enclosure 3

Revised Page E1-4
for
Monthly Operating Report - Unit 1
April 1996

9606190181 960612
PDR ADOCK 05000321
R PDR

UNIT SHUTDOWNS AND POWER REDUCTIONS

UNIT NAME: E. I. HATCH - UNIT ONE

DOCKET NO.: 50-321

DATE: MAY 3, 1996

COMPLETED BY: S. B. ROGERS

TELEPHONE: (912) 367-7781 x2878

REPORT MONTH: APRIL 1996

NO.	DATE	T Y P E	DURATION (HOURS)	R E A S O N	M E T H O D	LICENSEE EVENT REPORT NUMBER	S Y S T E M	COMPONENT CODE (SUBCODE)	CAUSE & CORRECTIVE ACTION TO PREVENT RECURRENCE
96-003	960323	S	702.7	C	4	N/A	RC	FUELXX	Activities associated with the 16th Refueling Outage continued.
96-004	960430	F	16.3	F	4	96-008	HB	PIPEXX (A)	<p>During startup, the unit experienced hydraulic fluid leaks on a Main Turbine Control Valve and Turbine Stop Valve. Measures taken to isolate the leaks resulted in a partial loss of hydraulic fluid flow to the Main Turbine Bypass Valves, causing the valves to close. An automatic reactor scram occurred on high reactor pressure.</p> <p>The fluid leaks were repaired, and the hydraulic system was restored to normal configuration. Shift resumed startup activities.</p>

TYPE:

F-FORCED
S-SCHEDULED

REASON:

A-EQUIPMENT FAILURE (EXPLAIN)
 B-MAINTENANCE OR TEST
 C-REFUELING
 D-REGULATORY RESTRICTION
 E-OPERATOR TRAINING & LICENSE
 F-ADMINISTRATIVE
 G-OPERATIONAL ERROR (EXPLAIN)
 H-OTHER (EXPLAIN)

METHOD:

1-MANUAL
 2-MANUAL SCRAM
 3-AUTOMATIC SCRAM
 4-CONTINUATIONS
 5-LOAD REDUCTION
 9-OTHER (EXPLAIN)

EVENTS REPORTED INVOLVE
 A GREATER THAN 20%
 REDUCTION IN AVERAGE
 DAILY POWER LEVEL FOR
 THE PRECEDING 24 HOURS.