



Boston Edison

Pilgrim Nuclear Power Station
Rocky Hill Road
Plymouth, Massachusetts 02360

E. T. Boulette, PhD

Senior Vice President - Nuclear

June 27, 1996
BECo Ltr. No. 2.96.060

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Docket No. 50-293
License No. DPR-35

Reporting of Compliance with Pilgrim Nuclear Power Plant
Technical Specification 4.6.G "Structural Integrity" for Second Ten-Year Inservice Inspection (ISI)
Program Requirements

This letter documents our compliance with Pilgrim Nuclear Power Plant Operating License Technical Specification 3/4.6.G "Structural Integrity" surveillance requirements.

Technical Specification 4.6.G requires the results obtained from compliance with the Second Ten-Year ISI Program be evaluated at the completion of the interval and the conclusions of the evaluation be reviewed with the NRC. Accordingly, an assessment was completed of the Second Ten-Year ISI Program that ended on June 30, 1995. The following two items were identified for resolution:

1. Examination of residual heat removal/fuel pool cooling intertie piping welds and supports: The relief request and resolutions are discussed in BECo letter #96-034, dated May 30, 1996. NRC review and approval of the relief request is pending.
2. Unavailability of documentation related to surface examination of core spray system weld # 14-A-10A: The surface examination documentation could not be located, but the weld underwent VT-2 and UT examinations as required by the ASME code. Since the integrity of the weld was established by volumetric examinations, the unavailability of the documentation was resolved by rescheduling the weld for surface examination during RFO#11.

9607020041 960627
PDR ADOCK 05000293
P PDR

1047
1/0

DCC Desk

Page 2.

Upon completion of the above items, the Second Ten-Year ISI Program will be complete. This closes the Technical Specification requirement to review with the NRC conclusions of the Second Ten-Year ISI Program evaluation.

If you have any questions regarding the information contained in this letter, please contact Walter Lobo at (508) 830-7940.



E. T. Boulette, PhD

p/ts46G.doc

cc: Mr. A. Wang, Project Manager
Division of Reactor Projects - I/II
Mail Stop: 14D1
U. S. Nuclear Regulatory Commission
1 White Flint North
11555 Rockville Pike
Rockville, MD 20852

U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

Senior Resident Inspector
Pilgrim Nuclear Power Station