Attachment 1 to CO 96-0058 page 1 of 6

WOLF CREEK NUCLEAR OPERATING CORPORATION

WOLF CREEK GENERATING STATION

MONTHLY OPERATING REPORT

MONTH: June YEAR: 1996

Docket No.: 50-482

Facility Operating License No.: NPF-42

Report No. 136

9607170097 960712 PDR ADOCK 05000482

SUMMARY

The following report highlights the operating experience of Wolf Creek Generating Station for the month of June, 1996. This report is being provided pursuant to Technical Specification 6.9.1.8.

I. SUMMARY OF OPERATING EXPERIENCE

The unit operated at or near 100% power, Mode 1, June 1, 1996, until 1320, June 6, 1996, when the Unit experienced a reactor trip caused by a "lo-lo" level in Steam Generator "C" which resulted from the failure of a 3/16" roll pin in the "C" Steam Generator Main Feedwater Regulating Valve (FRV) which allowed the valve plug to separate from the valve stem. After the pin was replaced in the "C" FRV and pins were replaced in two other FRVs, the unit reached criticality at 0435, June 8, 1996, and the main generator output breakers were closed at 1421, June 8, 1996. The unit remained at or near 100% power, Mode 1, throughout the remainder of June, 1996.

II. MAJOR SAFETY RELATED MAINTENANCE ACTIVITIES

Replacement of roll pins with solid pins in three of the four Main Feedwater Regulating Valves (FRV). The fourth FRV already had a solid pin installed. (Reference LER 96-006-00).

Wolf Creek Generating Station Monthly Operating Report June, 1996 Page 2 of 6

OPERATING DATA REPORT
DOCKET NO. 50-482
WOLF CREEK GENERATING STATION
WOLF CREEK NUCLEAR OPERATING CORPORATION
DATE 7-8-96
TELEPHONE 316-364-8831

OPERATING STATUS

1.	Reporting Period: June, 1996	Gross Hours in	n Reporting Peri	od: 720	
2.	. Currently Authorized Power Level(MWt): 3565 Max. Depend.Capacity(MWe-Net):				
	Design Electrical Rating (MWe-Net): 11	70			
3.	Power Level to Which Restricted (If Any)	(MWe-Net): N	/A		
4.	Reasons for Restriction (If Any): N/A				
5.	Number of Hours Reactor was Critical	This Month 680.7	Yr. to Date 2,718.2	Cumulative 77,334.9	
6.	Reactor Reserve Shutdown Hours	0.0	0.0	339.8	
7.	Hours Generator on Line	671.0	2,663.3	76,443.0	
8.	Unit Reserve Shutdown Hours	0.0	0.0	0.0	
9.	Gross Thermal Energy Generated (MWh)	2,349,911	9,237,833	254,579,503	
0.	Gross Electrical Energy Generated (MWh)	804,513.0	3,191,319	88,450,239	
1.	Net Electrical Energy Generated (MWh)	769,603.0	3,022,669	84,459,520	
2.	Reactor Service Factor	94.5%	62.2%	81.5%	
3.	Reactor Availability Factor	94.5%	62.2%	81.9%	
4.	Unit Service Factor	93.2%	61.0%	80.6%	
5.	Unit Availability Factor	93.2%	61.0% 80.6%		
6.	Unit Capacity Factor (Using MDC)	91.6%	59.3% 78.2%		
7.	Unit Capacity Factor (Using Design MWe)	91.4%	59.2% 76.1%		
18.	Unit Forced Outage Rate	6.8% 5.6%		4.8%	
9.	Shutdowns Scheduled Over Next 6 Months (Type, Date, an	d Duration of ea	ach):	

Wolf Creek Generating Station Monthly Operating Report June, 1996 Page 3 of 6

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-482

WOLF CREEK GENERATING STATION

WOLF CREEK NUCLEAR OPERATING CORPORATION

DATE 7-8-96

TELEPHONE 316-364-8831

MONTH June, 1996

DAY	A A	VERAGE	DAILY	POWER	LEVEL
		(1)	We-Net	-)	

1	1176	
2	1176	
3	1176	
4	1175	
5	1174	
6	630	
7	0	
8	73	
9	1032	
10	1179	
11	1178	
12	1153	
13	1168	
14	1145	
15	1171	
16	1171	

DAY AVERAGE DAILY POWER LEVEL (MWe-Net)

17	1173
18	1172
19	1170
20	1166
21	1161
22	1168
23	1168
24	1162
25	1161
26	1168
27	1168
28	1163
29	1168
30	1166
31	N/A

Wolf Creek Generating Station Monthly Operating Report June, 1996 Page 4 of 6

UNIT SHUTDOWN AND POWER REDUCTIONS

DOCKET NO. 50-482 WOLF CREEK GENERATING STATION WOLF CREEK NUCLEAR OPERATING CORPORATION DATE -7-8-96

TELEPHONE 316-364-8831

No	Date	Type F: FORCED S: SCHEDULED	DURATION (Hours)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR OR REDUCING POWER(2)	CORRECTIVE ACTIONS/COMMENTS
1	6/6/96	F	49	A	3	Replacement of failed pins in Main Feedwater Regulating Valves

SUMMARY: The unit operated at or near 100% power, Mode 1, June 1, 1996, until 1320, June 6, 1996, when the Unit experienced a reactor trip caused by a "lo-lo" level in Steam Generator "C" which resulted from the failure of a 3/16" roll pin in the "C" Steam Generator Main Feedwater Regulating Valve (FRV) which allowed the valve plug to separate from the valve stem. After the pin was replaced in the "C" FRV and pins were replaced in two other FRVs, the unit reached criticality at 0435, June 8, 1996, and the main generator output breakers were closed at 1421, June 8, 1996. The unit remained at or near 100% power, Mode 1, throughout the remainder of June, 1996.

1) REASON: A: EQUIPMENT FAILURE (EXPLAIN) E: OPERATOR TRAINING AND LICENSE EXAMINATION (2) METHOD: 1. MANUAL

2. MANUAL SCRAM

B: MAINTENANCE OR TEST

F: ADMINISTRATIVE

C: REFUELING

G: OPERATIONAL ERROR (EXPLAIN)

3. AUTOMATIC SCRAM

D: REGULATORY RESTRICTION H: OTHER (EXPLAIN)

4. CONTINUED 5. REDUCED LOAD

9. OTHER

Wolf Creek Generating Station Monthly Operating Report June, 1996 Page 5 of 6

WOLF CREEK NUCLEAR OPERATING CORPORATION

WOLF CREEK GENERATING STATION

UNIT NO. 1

MONTH June, 1996

SUMMARY OF OPERATING EXPERIENCE

Listed below in chronological sequence is a summary of operating experiences for this month which required load reduction or resulted in significant non-load related incidents.

DATE 6/6/96 TIME

EVENT

1320 Reactor trip