



Carolina Power & Light Company

Brunswick Nuclear Project
P. O. Box 10429
Southport, N.C. 28461-0429
OCT 21 1992

FILE: B09-13510C
SERIAL: BSEP-92-0026

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555

BRUNSWICK STEAM ELECTRIC PLANT UNIT 1
DOCKET NO. 50-325
LICENSE NO. DPR-71
SPECIAL REPORT PER TECHNICAL SPECIFICATION 6.7.8A AND
PURSUANT TO TECHNICAL SPECIFICATION 6.9.2 (1 SR-92-007)

Gentlemen:

The following summarizes fire protection Limiting Conditions for Operation (LCO) A1-92-F0677, that was initiated to support a major outage project being performed in the Augmented Off-Gas Building:

A1-92-F0677

At 1000 on September 19, 1992, a conduit leading to seal AO-3-014 on the Augmented Off-Gas 50' elevation was declared inoperable due to corrosion at the floor penetration. A fire watch was stationed and remained in place until restoration of the fire seal. Due to the work scope and staging required to replace the conduit, the fire barrier could not be repaired within the 7 days required by the LCO and required this Special Report. The conduit repair was completed and the barrier seal restored at 0700 on September 27, 1992.

Very truly yours,

R. E. Morgan, Plant Manager Unit 1
Brunswick Nuclear Project

260042

cc: Mr. S. D. Ebnetter
Mr. R. H. Lo
BSEP NRC Resident Office

0210260352 921021
R ADDCK 05000325
PDR

IF 22
1/0