

May 15, 1996

U. S. Nuclear Regulatory Commission Attention: Document Control Desk Washington, D. C. 20555

Gentlemen:

- Subject: Docket Nos. 50-361 and 50-362 Monthly Operating Reports for April 1996 San Onofre Nuclear Generating Station, Units 2 and 3
- Reference: Letter, Walter C. Marsh (Edison) to Document Control Desk, "Annual Radioactive Effluent Release Report - 1995" dated April 29, 1996

Technical Specification 6.9.1.10 of Facility Operating Licenses NPF-10 and NPF-15 for the San Onofre Nuclear Generating Station, Units 2 and 3 respectively, requires Edison to provide a Monthly Operating Report for each Unit, which includes: routine operating statistics and shutdown experience; all challenges to safety valves; any changes to the Offsite Dose Calculation Manual (ODCM); and any major changes to the radioactive waste treatment system. All covered activities are reported monthly, except for ODCM changes, which are reported within 90 days from the time the changes are effective.

This letter transmits the April 1996 Monthly Operating Reports for Units 2 and 3. There were no challenges to safety values and no changes to the ODCM during the reporting period. A permanent mixed waste processing unit was installed to treat contaminated oil with radioactivity concentrations less than or equal to 4.1E-2  $\mu$ Ci/ml. A complete description and safety evaluation of this major change to the Units 2 and 3 radioactive waste treatment systems was provided by the referenced letter.

If you require any additional information, please let me know.

Sincerely,

A Silisan for

Walter C. Marsh Manager of Nuclear Regulatory Affairs

Enclosures

cc: L. J. Callan, Regional Administrator, NRC Region IV J. E. Dyer, Director, Division of Reactor Projects, NRC Region IV K. E. Perkins, Jr., Director, Walnut Creek Field Office, NRC Region IV M. B. Fields, NRC Project Manager, Units 2 and 3 J. A. Sloan, Senior NRC Resident Inspector, San Onofre Units 2 & 3 9605210011 960515 PDR ADOCK 05000361 R PDR

P. O. Box 128 San Clemente, CA 92674-0128 200129