

Duke Power Company
McGuire Nuclear Station
12700 Hagers Ferry Road
Huntersville, NC 28078



DUKE POWER

August 27, 1996

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20666

Subject: McGuire Nuclear Station
Docket Nos. 50-369, 50-370
License Nos. NPF-9, NPF-17
Emergency Plan Change

Ref.: Respiratory Qualification Submittal
Rev. 95-2

Revision 95-2 to the McGuire Emergency Plan revised Section J.6 in accordance with 10CFR50.54(q). In this submittal there were areas of NRC concern related to the requirements for members of the emergency response organization to be respirator qualified and to the intended use of respirators during an actual emergency.

The purpose of this letter is to return Section J.6 back as originally approved by the NRC.

By copy of this letter, two copies are being provided to NRC Region II, Regional Administrator.

Yours Truly,

A handwritten signature in cursive script, appearing to read 'T.C. McMeekin'.

T.C. McMeekin

TCM/tsb

Attachment

9609050236 960827
PDR ADOCK 05000369
F PDR

AD45
11

U.S. Nuclear Regulatory Commission

August 27, 1996

Page 2

xc: w/two copies of attachments
S.D. Ebnetter
Regional Administrator
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

w/o attachment
Victor Nerses
U.S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Washington, D.C. 20555

NRC Site Resident
McGuire Nuclear Site

E.M. Kuhr (EC050)
Electronic Licensing Library (EC050)
E.P. File 1502

August 27, 1996

MEMORANDUM

To: All Holders of the McGuire Emergency Plan

Subject: McGuire Emergency Plan


Revision 95-2 to the McGuire Emergency Plan revised Section J.6 in accordance with 10CFR50.54(q). In this submittal there were areas of NRC concern related to the requirements for members of the emergency response organization to be respirator qualified and to the intended use of respirators during an actual emergency.

The purpose of this letter is to return Section J.6 back as originally approved by the NRC.

Please update your Emergency Plan manual as instructed on Attachment 1.

If there are any questions, please call me at 704/875-4662.

Sincerely,



Becky Hasty
Emergency Planning Manager
McGuire Nuclear Station

RLH/tsb

Attachment: Emergency Plan Revision

cc: EP File 1502

<u>SECTION</u>	<u>REMOVE PAGES</u>	<u>INSERT PAGES</u>
Table of Contents	4	4
Section J	J-2	J-2

Table of Contents

		<u>Page #</u>
I.2.b	Radiation and Effluent Monitors	I-1
I.2.c	In-plant Iodine Instrumentation	I-1
I.3.a/	Method for Determining Release Source Term	I-2
I.3.b		
I.4	Effluent Monitor Readings Vs On-site/Off-site Exposure	I-2
I.5	Meteorological Information Availability	I-2
I.6	Release Rates/Projected Doses for Offscale Instrumentation	I-2
I.7/	Field Monitoring Within EPZ	I-2
I.8		
I.9	Detect and Measure Radioiodine Concentration in the EPZ	I-3
I.10	Relationship Between Contamination Levels and Integrated Dose/Dose Rates	I-3
I.11	Plume Tracking	I-3
J.	Protective Response	
J.1.a	Onsite Alerting and Notification	J-1
thru		
J.1.d		
J.2	Evacuation Routes and Transportation	J-1
J.3	Personnel Monitoring	J-1
J.4	Site Evacuation Procedures - Decontamination	J-1
J.5	Personnel Accountability	J-2
J.6	Protective Equipment Breathing Apparatus, Protective Clothing, KI	J-2
J.7	Protective Action Recommendations	J-3
J.8	Evacuation Time Estimates	J-3
J.9	Implementing Protective Measures	J-4
J.10	Implementation of Protective Measures for Plume Exposure Pathway	J-4
J.10.a	EPZ Maps	J-4
J.10.b	EPZ Population Distribution Map	J-4
J.10.c	EPZ Population Alerting and Notification	J-5
J.10.d	EPZ Protecting Immobile Persons	J-5
J.10.e	Use of Radioprotective Drugs for Persons in EPZ	J-5
J.10.f	Conditions for Use of Radioprotective Drugs	J-5
J.10.g	State/County Relocation Plans	J-5
J.10.h	Relocation Center Locations	J-5
J.10.i	Evacuation Route - Traffic Capacities	J-5
J.10.j	Evacuated Area Access Control	J-5
J.10.k	Planning for Contingencies in Evacuation	J-5
J.10.l	State/County Evacuation Time Estimates	J-6

J.5 Personnel Accountability

Within thirty minutes of a Site Assembly, all persons within the Protected Area at the McGuire Nuclear Site can be accounted for and any person(s) determined to be missing, will be identified by name. RP/O/A/5700/11, Conducting a Site Assembly or Evacuation, provides for the accounting of personnel (on site) continuously thereafter.

J.6 Protective Equipment - Breathing Apparatus, Protective Clothes, KI

Protective equipment and supplies will be distributed to and used by personnel remaining on site or arriving on site during the emergency to minimize the effects of radiological exposures or contamination. Protective measures to be utilized are as follows:

Individual Respiratory Protection - Respiratory protective equipment will be used when airborne radioactivity levels exceed the appropriate limits specified in 10CFR20, Appendix B.

Self-contained breathing apparatus will also be used in areas that are deficient in oxygen or when fighting fires. Respiratory protective equipment will be issued by Radiation Protection or Safety and Health Services. Self-contained breathing apparatus are available with other fire fighting equipment for use by the site fire brigade.

Individual Thyroid Protection - All efforts should be made to utilize respiratory protective equipment to minimize ingestion and/or inhalation of radionuclides and to maintain internal exposure below the limits specified in 10CFR20, Appendix B. However, if an unplanned incident involves the accidental or potential ingestion or inhalation of radioactive iodine, Potassium Iodide Tablets (KI) are available to distribution by HP/O/B/1009/16, Distribution of Potassium Iodide Tablets in the Event of a Radioiodine Release.

Use of Protective Clothing - Protective clothing will be issued when contamination levels exceed 1000 dpm/100 cm² beta-gamma and 20 dpm/100 cm² alpha of smearable contamination. Protective clothing items are located in the Change Rooms inside the Radiation Control Area, available for emergency use. Special fire-fighting protective clothing and equipment is available in designated site supply storage areas for use by fire brigade personnel.