

November 7, 1996

Georgia Power Company  
ATTN: Mr. C. K. McCoy  
Vice President  
Vogtle Electric Generating Plant  
P. O. Box 1295  
Birmingham, AL 35201

SUBJECT: PLANT PERFORMANCE REVIEW (PPR) - VOGTLE

On October 1, 1996, the regional staff completed the semiannual Plant Performance Review (PPR) of Vogtle. The staff conducts these reviews for all operating nuclear power plants to develop an integrated understanding of safety performance. The results are used by regional management to facilitate planning and allocation of inspection resources. The PPR for Vogtle involved the participation of all technical divisions in evaluating inspection results and safety performance information for the period from March 1996 through August 1996. PPRs provide regional management with a current summary of licensee performance and serve as inputs to the NRC Systematic Assessment of Licensee Performance (SALP) and senior management meeting (SMM) reviews.

This letter advises you of our planned inspection effort resulting from the Vogtle PPR review. It is provided in an attempt to minimize the resource impact on your staff and to allow for scheduling conflicts to be resolved in advance of inspection dates. The enclosure presents our inspection plan for the next six months. Specific dates are included for near term inspections. Long term inspection dates will be announced prior to the inspections and any scheduling conflicts will be resolved with your staff. The rationale or basis for each inspection outside the core inspection program is provided so that you are aware of the reasons for emphasis in these program areas. Resident inspections are not listed due to their ongoing and continuous nature, nor are Region based inspections which accomplish Resident Core Modules to compensate for Resident Inspector absences due to training.

During each NRC inspection planned during this period, specific attention will continue to be given to the verification of selected Updated Final Safety Analysis Report (UFSAR) commitments. Applicable portion(s) of the UFSAR that relate to the inspection activities will be reviewed and verification made that the UFSAR commitments have been properly implemented into plant practices, procedures and/or parameters.

150071

9611180083 961107  
PDR ADOCK 05000424  
G PDR

111  
1001

We will inform you of any changes to the inspection plan. If you have any questions, please contact P. H. Skinner at (404) 331-6299.

Sincerely,

(Original signed by Pierce H. Skinner)

Pierce H. Skinner, Chief  
Reactor Projects Branch 2  
Division of Reactor Projects

Docket Nos. 50-424, 50-425  
License Nos. NPF-68, NPF-81

Enclosure: Inspection Plan

cc w/encl:

J. D. Woodard  
Senior Vice President  
Georgia Power Company  
P. O. Box 1295  
Birmingham, AL 35201

J. B. Beasley  
General Manager, Plant Vogtle  
Georgia Power Company  
P. O. Box 1600  
Waynesboro, GA 30830

J. A. Bailey  
Manager-Licensing  
Georgia Power Company  
P. O. Box 1295  
Birmingham, AL 35201

Jim Hurt, Director  
Consumers' Utility Counsel Division  
Governor's Office of Consumer Affairs  
2 M. L. King, Jr. Drive  
Plaza Level - East; Suite 356  
Atlanta, GA 30334-4600

Office of Planning and Budget  
Room 615B  
270 Washington Street, SW  
Atlanta, GA 30334

cc w/encls cont'd: (See page 3)

cc w/encls: Cont'd  
Office of the County Commissioner  
Burke County Commission  
Waynesboro, GA 30830

Harold Reheis, Director  
Department of Natural Resources  
205 Butler Street, SE, Suite 1252  
Atlanta, GA 30334

Thomas Hill, Manager  
Radioactive Materials Program  
Department of Natural Resources  
4244 International Parkway  
Suite 114  
Atlanta, GA 30354

Attorney General  
Law Department  
132 Judicial Building  
Atlanta, GA 30334

Thomas P. Mozingo  
Manager of Nuclear Operations  
Oglethorpe Power Corporation  
2100 E. Exchange Place  
Tucker, GA 30085-1349

Charles A. Patrizia, Esq.  
Paul, Hastings, Janofsky & Walker  
10th Floor  
1299 Pennsylvania Avenue  
Washington, D. C. 20004-9500

Steven M. Jackson  
Senior Engineer - Power Supply  
Municipal Electric Authority  
of Georgia  
1470 Riveredge Parkway NW  
Atlanta, GA 30328-4684

Distribution w/encl:

P. Skinner, RII  
R. Wright, RII  
W. P. Kleinsorge, RII  
M. E. Ernstes, RII  
G. Hallstrom, RII  
L. Wheeler, NRR  
PUBLIC

Distribution w/encls cont'd: (See Page 4)

Distribution w/encls: Cont'd  
 NRC Senior Resident Inspector  
 U.S. Nuclear Regulatory Commission  
 8805 River Road  
 Waynesboro, GA 30830

SEND TO PUBLIC DOCUMENT ROOM?							YES	NO
OFFICE	RII:DRP	RII:DRP	RII:DRS:EB	RII:DRS:MB	RII:DRS:SIB	RII:DRS:PSB		
SIGNATURE	<i>RWright</i>	<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>		
NAME	RWright.dka	PSkinner	CCasto	HChristensen	PFredrickson	[Name]		
DATE	10 / 30 / 96	10 / 6 / 96	10 / 31 / 96	10 / 30 / 96	10 / 31 / 96	10 / 30 / 96		
COPY?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO		

SEND TO PUBLIC DOCUMENT ROOM?							YES	NO
OFFICE	RII:DRS:DLHP	RII:DRP						
SIGNATURE	<i>[Signature]</i>	<i>[Signature]</i>						
NAME	TPeebles	EWerschhoff						
DATE	10 / 30 / 96	10 / / 96	10 / / 96	10 / / 96	10 / / 96	10 / / 96		
COPY?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	<input type="checkbox"/> YES <input type="checkbox"/> NO	<input type="checkbox"/> YES <input type="checkbox"/> NO	<input type="checkbox"/> YES <input type="checkbox"/> NO	<input type="checkbox"/> YES <input type="checkbox"/> NO	<input type="checkbox"/> YES <input type="checkbox"/> NO		

OFFICIAL RECORD COPY

DOCUMENT NAME: A:LV-LETTER.PPR

VOGTLE INSPECTION PLAN

INSPECTION PROCEDURE / TEMPORARY INSTRUCTION	TITLE/PROGRAM AREA	NUMBER OF INSPECTORS	PLANNED INSPECTION DATES	TYPE OF INSPECTION - BASIS
IP 57080	NDE Procedure UT Examination [MAINTENANCE - SI]	1	10/03/96	Regional Initiative - Reactor Vessel Upper Internal Split Pin Failure
IP 82301 IP 82302	Evaluation of Exercises for Power Reactors Exercise Objectives & Scenarios [PLANT SUPPORT - PS]	1 1	11/20/96 11/20/96	Core Inspection Core Inspection
IP 62700	Maintenance Implementation [MAINTENANCE - MNT]	1	12/16/96	Regional Initiative - Maintenance and Testing of Safe Shutdown Panel
IP 52002	Digital Retrofits Not Receiving Prior Approval [NRR - TWO I&C Personnel]	2	01/13/97	NRR Initiative - Digital Modification Inspection
IP 62700	Maintenance Implementation [MAINTENANCE - MNT]	1	12/09/96	Regional Initiative - Debris in NSCW System. NSCW flow measurements. FME
IP 84750 IP 86750 TI 133	Rad Waste Systems, Water Chemistry, & Envir. Monitoring Rad Waste Management & Transp. Rad Waste [PLANT SUPPORT - PS]	1	02/10/97	Core Inspection  Combine with 86750
IP 82701	Op. Status of EP Program [PLANT SUPPORT - PS]	1	02/10/97	Core Inspection

VOGTLE INSPECTION PLAN

IP 64704	Fire Protection Program [PLANT SUPPORT - SI]	1	02/10/97	Core Inspection
IP 81700	Security Program for RXs [PLANT SUPPORT - SI]	1	03/03/97	Core Inspection