

Duke Power Company
McGuire Nuclear Generation Department
12700 Hagers Ferry Road (MG01VP)
Huntersville, NC 28078-8985

T. C. McMEEKIN
Vice President
(704)875-4800
(704)875-4809 Fax



DUKE POWER

DATE: November 7, 1996


U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Subject: McGuire Nuclear Station, Unit 1
Docket No. 50-369
Licensee Event Report 369/96-03, Revision 1
Problem Investigation Process No.: 0-M96-1753

Gentlemen:

Pursuant to 10 CFR 50.73 Sections (a) (1) and (d), attached is Licensee Event Report 369/96-03, Revision 1, concerning concurrent inoperability of both Unit 1 Emergency Diesel Generators. This report is being submitted in accordance with 10 CFR 50.73 (a) (2) (v). This report also satisfies the Special Reporting requirements of Technical Specification 3.8.1.1. This revision is being submitted to provide additional information with regard to troubleshooting of the components removed from Emergency Diesel Generator 1A. Also, it has now been determined that the failure of components associated with Emergency Diesel Generator 1A in this event is not Nuclear Plant Reliability Data System (NPRDS) reportable. This event is considered to be of no significance with respect to the health and safety of the public.

Very truly yours,


T.C. McMeekin

JWP/bcb

JE221

Attachment

cc: Mr. S.D. Ebnetter
Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta St., NW, Suite 2900
Atlanta, GA 30323

INPO Records Center
Suite 1500
1100 Circle 75 Parkway
Atlanta, GA 30339

Mr. Victor Nerses
U.S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Washington, D.C. 20555

Mr. Scott Schaeffer
NRC Resident Inspector
McGuire Nuclear Station

9611190261 961107
PDR ADOCK 05000369
S PDR

bxc: B. L. Walsh (EC11C)
Z. L. Taylor (CNS)
G. A. Copp (EC050)
J. I. Glenn (MG02ME)
P. R. Herran (MG01VP)
C. B. Davis (MG01CP)
J. E. Burchfield (ONS Reg Compliance)
G. H. Savage (EC06E)
G. B. Swindlehurst (EC11-0842)
C. M. Misenheimer (EC08I)
R. F. Cole (EC05N)
J. M. Frye (EC05N)
T. G. Becker (PB02L)
P. M. Abraham (EC08I)
R. B. White (MG01VP)
L. V. Wilkie (ON03SR)
D. P. Kimball (CN05SR)
K. L. Crane (MG01RC)
R. N. Casler (EC05N)
NSRB Support Staff (EC05N)