



**Northeast
Utilities System**

Millstone Offices • Rope Ferry Rd., Waterford, CT

P.O. Box 128
Waterford, CT 06385-0128
(203) 447-1791

February 11, 1997

Docket No. 50-423
B16163

Re:10CFR50.73(a)(2)(ii)(B)

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Millstone Nuclear Power Station Unit 3
Licensee Event Report 97-003-00
Submitted Pursuant to 10CFR50.73(a)(2)(ii)

This letter forwards Licensee Event Report 97-003-00, documenting a condition that was determined at Millstone Unit No. 3 on January 13, 1997. This LER is submitted pursuant to 10CFR50.73(a)(2)(ii)(B). NNECO's commitments in response to this event are contained within Attachment 1 and the LER is contained in Attachment 2 to this letter.

Should you have any questions regarding this submittal, please contact Mr. James M. Peschel at (860) 437-5840.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

G. D. Hicks
Unit Director, Millstone Unit No. 3

250053

Handwritten initials: JED

9702260032 970211
PDR ADOCK 05000423
S PDR

Attachment: 1) NNECO's commitments in response to LER 97-003-00
2) LER 97-003-00

cc: H. J. Miller, Region I Administrator
A. C. Cerne, Senior Resident Inspector, Millstone Unit No. 3
J. W. Andersen, NRC Project Manager, Millstone Unit No. 3
W. D. Travers, Dr., Director, Special Projects

Docket No. 50-423
B16163

Attachment 1

Millstone Nuclear Power Station, Unit No. 3
NNECO's Commitments
In Response To
(LER 97-003-00)

February 1997

Enclosure
List of Regulatory Commitments

The following table identifies those actions committed to by NNECO in this document. Any other actions discussed in the submittal represent intended or planned actions by NNECO. They are described to the NRC for the NRC's information and are not regulatory commitments. Please notify the Manager - Nuclear Licensing at the Millstone Nuclear Power Station Unit No. 3 of any questions regarding this document or any associated regulatory commitments.

Number	Commitment	Due
B16163-01	An evaluation of the RSS water column separation issue will be performed to determine if transient piping and equipment loads are acceptable or require design modification.	Prior to Unit Startup

Docket No. 50-423
B16163

Attachment 2

Millstone Nuclear Power Station, Unit No. 3
NNECO's Submittal of
(LER 97-003-00)

February 1997