

TABLE 1

U S NUCLEAR REGULATORY COMMISSION
 OFFICE OF INSPECTION AND ENFORCEMENT
 CONFIRMATORY MEASUREMENTS PROGRAM
 FACILITY: QUAD CITIES
 FOR THE 3 QUARTER OF 1985

SAMPLE	ISOTOPE	-----NRC-----		----LICENSEE----		---LICENSEE:NRC---		
		RESULT	ERROR	RESULT	ERROR	RATIO	RES	T
L WASTE	H-3	1.2E-03	2.0E-05	1.0E-03	0.0E-01	8.6E-01	6.1E 01	A
	SR-89	1.8E-08	1.2E-09	6.7E-08	0.0E-01	3.7E 00	1.5E 00	N
	SR-90	7.9E-08	7.0E-09	6.1E-08	0.0E-01	7.7E-01	1.1E 01	A
	FE-55	8.9E-07	7.0E-09	<0.8E-09	0.0E-01	9.9E-02	1.3E 01	D
	GROSS B	5.8E-06	2.0E-07	2.7E-06	0.0E-01	4.7E-01	2.9E 01	D

T TEST RESULTS:
 A=AGREEMENT
 D=DISAGREEMENT
 *=CRITERIA RELAXED
 N=NO COMPARISON

8601130334 860107
 PDR ADOCK 05000254
 Q PDR