



**DUKE POWER**

March 26, 1997

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, DC 20555

Subject: Oconee Nuclear Site  
Docket No. 50-269, -270, -287  
Technical Specification 3.1.6 Bases Revision

Please find attached a revision to the Technical Specification 3.1.6 Bases. This revision deletes the detection time of the reactor building air particulate monitor for a RCS leak of 1 gpm.

Attachment 1 contains the new Technical Specification Bases page. Attachment 2 contains a marked up version of the Bases.

Very truly yours,

A handwritten signature in dark ink, appearing to read "J. W. Hampton", with the word "for" written below it.

J. W. Hampton  
Oconee Site Vice President

cc: Mr. L. A. Reyes, Regional Administrator  
U. S. Nuclear Regulatory Commission, Region II

Mr. D. E. LaBarge, Project Manager  
Offices of Nuclear Reactor Regulation

Mr. M. A. Scott  
Senior Resident Inspector  
Oconee Nuclear Site

Mr. M. Batavia  
DHEC

9704080227 970326  
PDR ADOCK 05000269  
P PDR



Attachment # 1

Revised Technical Specification Bases