

UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D.C. 20655-0001

April 10, 1997

Mr. E. Thomas Boulette, Ph.D Senior Vice President - Nuclear Boston Edison Company Pilgrim Nuclear Power Station RFD #1 Rocky Hill Road Plymouth, MA 02360

SUBJECT: ASSESSMENT OF CORE SPRAY SYSTEM PIPING INSPECTION AND FLAW EVALUATIONS AT PILGRIM NUCLEAR POWER STATION (TAC NO. M93398)

Dear Mr. Boulette:

During Pilgrim Nuclear Power Station's (PNPS) Refueling Outage No. 11, Boston Edison Company (BECo) identified crack-like indications (or flaws) in collarto-shroud and pipe sleeve welds on core spray system downcomer piping internal to the reactor pressure vessel. On February 21, 1997, BECo notified the NRC of the core spray piping inspection findings pursuant to NRC Bulletin 80-13 requirements. In a telephone conference call on March 3, 1997, BECo updated information on the inspection findings, discussed the results of inspections and agreed to submit the inspection results and flaw evaluations for NRC review. On March 18, 1997, BECo submitted a description of flaws identified during core spray piping inspections and evaluation of flaws for NRC review prior to restart of PNPS. Further, on April 2, 1997, BECo submitted additional information in response to staff's telephone request on March 20, 1997.

BECo's evaluation of flaw indications included in the March 18, 1997, submittal concluded that the core spray system integrity and performance will not be compromised during the operation of PNPS for the next fuel cycle (12). BECo provided commitments to submit its plans to the NRC for reinspection and repair of the core spray piping internal to the reactor vessel 3 months prior to the start of refueling outage No. 12. BECo should work with Boiling-Water Reactor Vessel and Internal Project Committee to develop a reinspection plan and repair criteria to ensure piping structural integrity consistent with the commitments made in your March 18, 1997 letter.

Based on the NRC staff's initial review of these submittals, the staff has concluded that the flaw indications in the core spray piping are not a restart issue for PNPS. The results of the staff's detailed evaluation will be provided to you at a later date. Any concerns that arise during staff review will be promptly communicated to BECo. If the staff subsequently determines that the flaw and the piping integrity evaluations are unacceptable, BECo will be expected to take prompt action to place the facility in a safe configuration,

NRC FILE CENTER COPY

140052

9704140242 970410 PDR ADOCK 05000220 P PDR E. Thomas Boulette

*

consistent with the requirements of NRC regulations and Pilgrim technical specifications.

If you have any questions in this matter, please contact Mr. Alan Wang at (301) 415-1445.

Sincerely,

151

Patrick D. Milano, Acting Director Project Directorate I-3 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Docket No. 50-220

cc: See next page

Distribution Docket File AWang PUBLIC OGC PDI-3 RF ACRS SVarga GCarpenter JZwelinski WKOO **PMilano** JRajan

DWessman KWichman JLyons **CBerlinger** RConte, RI

DOCUMENT NAME: G:\PILGRIM\FLAW.LET To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with dischment/enclosure "N" = No copy

OFFICE	PM:PDI-3	LA: PDI-hQ	EMEB	EMCB	(A)D:PD4-3
NAME	AWang Agio	SLittle	DWessman	JStrosnider	PMiland
DATE	04/9/97	04/10/97	04/10/97	04/10/97	04//0/97

OFFICIAL RECORD COPY

E. Thomas Boulette

.

1

consistent with the requirements of NRC regulations and Pilgrim technical specifications.

If you have any questions in this matter, please contact Mr. Alan Wang at (301) 415-1445.

Sincerely, 1 0 t

Patrick D. Milano, Acting Director Project Directorate I-3 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Docket No. 50-220

cc: See next page

E. Thomas Boulette

cc:

Mr. Leon J. Olivier Vice President of Nuclear Operations & Station Director Pilgrim Nuclear Power Station 1FD #1 Rocky Hill Road Plymouth, MA 02360

Resident Inspector U. S. Nuclear Regulatory Commission Pilgrim Nuclear Power Station Post Office Box 867 Plymouth, MA 02360

Chairman, Board of Selectmen 11 Lincoln Street Plymouth, MA 02360

Chairman, Duxbury Board of Selectmen Town Hall 878 Tremont Street Duxbury, MA 02332

Office of the Commissioner Massachusetts Department of Environmental Protection One Winter Street Boston, MA 02108

Office of the Attorney General One Ashburton Place 20th Floor Boston, MA 02108

Mr. Robert M. Hallisey, Director Radiation Control Program Massachusetts Department of Public Health 305 South Street Boston, MA 02130

Regional Administrator, Region I U. S. Nuclear Regulatory Commission 475 Allendale Road King of Prussia, PA 19406

Ms. Jane Fleming 8 Oceanwood Drive Duxbury, MA 0233 Pilgrim Muclear Power Station

Mr. Jeffery Keene Licensing Division Manager Boston Edison Company 600 Rocky Hill Road Plymouth, MA 02360-5599

Ms. Nancy Desmond Manager, Reg. Affairs Dept. Pilgrim Nuclear Power Station RFD #1 Rocky Hill Road Plymouth, MA 02360

Mr. David F. Tarantino Nuclear Information Manager Pilgrim Nuclear Power Station RFD #1, Rocky Hill Road Plymouth, MA 02360

Ms. Kathleen M. O'Toole Secretary of Public Safety Executive Office of Public Safety One Ashburton Place Boston, MA 02108

Mr. Peter LaPorte, Director
Attn: James Muckerheide
Massachusetts Emergency Management
Agency
400 Worcester Road
P.O. Box 1496
Framingham, MA 01701-0317

Chairman, Citizens Urging Responsible Energy P.O. Box 2621 Duxbury, MA 02331

Citizens at Risk P.O. Box 3803 Plymouth, MA 02361

W.S. Stowe, Esquire Boston Edison Company 800 Boylston St., 36th Floor Boston, MA 02199 cc: (cont.)

.

٩

Chairman Nuclear Matters Committee Town Hall 11 Lincoln Street Plymouth, MA 02360

Mr. William D. Meinert Nuclear Engineer Massachusetts Municipal Wholesale Electric Company P.O. Box 426 Ludlow, MA 01056-0426