

February 12, 1986

Docket No. 50-293

DISTRIBUTION

Mr. William D. Harrington  
Senior Vice President, Nuclear  
Boston Edison Company  
800 Boylston Street  
Boston, Massachusetts 02199

Docket	PLeech	WKoo
NRC PDR	CJamerson	TBarnhart (4)
Local PDR	JZwolinski	RDiggs
PD #1 RDG	ACRS (10)	GLainas
RBernero	OELD	JPKnight
EJordan	BGrimes	DCrutchfield
JPartlow	RHouston	GHolahan
DEisenhut	HDenton	OPA

Dear Mr. Harrington:

SUBJECT: PARTIAL RELIEF FROM VISUAL EXAMINATION GUIDANCE IN GENERIC LETTER 84-11

Re: Pilgrim Nuclear Power Station

Our letter to you dated December 4, 1984, included a statement that the guidance in Attachment 1 to Generic Letter 84-11 (GL 84-11) should be followed at Pilgrim Nuclear Power Station until the plant technical specifications were changed relative to the reactor coolant system leak detection and leakage limits.

Pending completion of our review of the proposed technical specification changes, the Boston Edison Company requested, in a letter dated November 25, 1985, relief from Section E of GL 84-11 which states, in part, that "a visual examination shall be performed during each plant outage in which the containment is de-inerted." In lieu of this, you proposed that "a visual examination for leakage of the reactor coolant piping be performed during each plant outage in which the containment is de-inerted, unless such an inspection has been performed during the previous 92 days." Your letter indicates the reason for requesting this change is that personnel radiation exposures to perform these examinations have become a matter of concern because the Pilgrim Station has been shutting down more frequently than anticipated.

We have considered your request and we have concluded that visual inspection at intervals less than 92 days of operation should not be required. Therefore, the relief you requested is hereby granted. My decision is based on the staff review described in the enclosed Safety Evaluation.

Sincerely,

Original Signed by  
H. R. Denton

Harold R. Denton, Director  
Office of Nuclear Reactor Regulation

B602190703 860212  
PDR ADOCK 05000293  
P PDR

Enclosure:  
As stated

DBL:PD#1  
CJamerson  
1/24/86

DBL:PD#1  
PLeech:jg  
01/24/86

OELD  
M. Kauffman  
1/29/86

DBL:PD#1  
JZwolinski  
2/6/86

DBL:DD  
RWHouston  
2/7/86

DBL:DIR  
RBernero  
2/8/86

NRR:DD  
DEisenhut  
2/10/86

NRR:DIR  
HDenton  
2/11/86

Mr. William D. Harrington  
Boston Edison Company

Pilgrim Nuclear Power Station

cc:

Mr. Charles J. Mathis, Station Mgr.  
Boston Edison Company  
RFD #1, Rocky Hill Road  
Plymouth, Massachusetts 02360

Resident Inspector's Office  
U. S. Nuclear Regulatory Commission  
Post Office Box 867  
Plymouth, Massachusetts 02360

Mr. David F. Tarantino  
Chairman, Board of Selectman  
11 Lincoln Street  
Plymouth, Massachusetts 02360

Office of the Commissioner  
Massachusetts Department of  
Environmental Quality Engineering  
One Winter Street  
Boston, Massachusetts 02108

Office of the Attorney General  
1 Ashburton Place  
19th Floor  
Boston, Massachusetts 02108

Mr. Robert M. Hallisey, Director  
Radiation Control Program  
Massachusetts Department of  
Public Health  
150 Tremont Street  
Boston, Massachusetts 02111

Regional Administrator, Region I  
U. S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

Mr. A. Victor Morisi  
Boston Edison Company  
25 Braintree Hill Park  
Rockdale Street  
Braintree, Massachusetts 02184

-