



**CENTERIOR
ENERGY**

Power Generation Group

Perry Nuclear Power Plant
10 Center Road
Perry, Ohio 44081

Mail Address:
P.O. Box 97
Perry, OH 44081

216-280-5915
FAX: 216-280-8029

Lew W. Myers
Vice President

April 11, 1997
PY-CEI/OEPA-0265L

Ohio Environmental Protection Agency
Division of Surface Water
Enforcement Section, ES/MOR
P.O. Box 1049
Columbus, Ohio 43266-0149

Gentlemen:

Enclosed are the National Pollutant Discharge Elimination System (NPDES) monthly report forms for the month of March, 1997.

No violations occurred during this time period.

If you have questions or require additional information, please contact Ms. Donna Tizzano at (216) 280-5514.

Very truly yours,

DGT:sc

Enclosure

cc: NRC Region III
NRC Resident Inspector
NRC Project Manager
NRC Document Control Desk (Docket No. 50-440)

IR25/11

9704170417 970331
PDR ADOCK 05000440
R PDR



Perry Nuclear Power Plant

31B00016800 MAR 1997

1 1 04/07/97 00634

10 Center Rd.

800 INTAKE WATER TO PLANT FROM LAKE ERIE

Perry

14081 Lake

FORM

Perry-E240

D. G. Tizzano

1
999

WATER
TEMP.
F

00011

01	38								
02	40								
03	40								
04	39								
05	40								
06	40								
07	39								
08	39								
09	38								
10	38								
11	39								
12	39								
13	39								
14	38								
15	39								
16	37								
17	37								
18	37								
19	37								
20	38								
21	38								
22	39								
23	39								
24	38								
25	38								
26	39								
27	39								
28	41								
29	42								
30	42								
31	42								

1208.0
38.968
42.000
37.000

NONE

REPORTER

4-11-97

Worley for

VP-Nuclear

Perry Nuclear Power Plant

31B00016004 MAR 1997

1 1 04/07 '97 0063

10 Center Rd.
Perry

44081 Lake

004 POINT REP OF DISCHARGE PRIOR TO TUNNEL ENTRY
FORM

Perry-E240

D. G. Tizzano

	1 999	1 999	3 001	3 001	3 001		
	WATER TEMP. F	CONDUIT FLOW MGD	CHLORINE FREE A MG/L	PH S.U.	PHOS-T P-WET MG/L		
	00011	50050	50061	00400	00665		
01	52	70.1	0				
02	52	71.0	0				
03	53	71.3	0		.06		
04	53	64.8	0	8.2			
05	53	70.1	0				
06	52	76.2	0				
07	50	73.7	0	8.1			
08	51	72.3	0				
09	49	79.0	0				
10	50	80.1	0		.28		
11	51	72.8	0	8.1			
12	51	76.9	0				
13	51	76.7	0				
14	51	80.1	0	8.1			
15	51	78.6	0				
16	50	80.1	0				
17	49	83.3	0		.15		
18	50	79.3	0	8.1			
19	49	74.7	0				
20	49	68.8	0				
21	51	69.3	0	8.0			
22	50	80.1	0				
23	49	80.5	0				
24	50	80.2	0		.10		
25	51	99.5	0	8.1			
26	50	85.2	0				
27	51	79.4	0				
28	52	80.7	0	8.2			
29	53	78.7	0				
30	53	81.0	0				
31	53	83.1	0		.20		
	1580.0	2397.6	0.0000	64.900	0.7700		
	50.968	77.342	0.0000	8.1125	0.1540		
	53.000	99.500	0.0000	8.2000	0.2600		
	49.000	64.800	0.0000	8.0000	0.0600		

NONE

REPORTER

4-11-97

S. W. W. for VP-Nuclear

Perry Nuclear Power Plant

31B00016001 MAR 1997

1 1 04/09 97 0023

10 Center Rd
Perry 44081 Lake

001 DISCHARGE FROM REGENERATE NEUTRALIZATION PITS

FORM

Perry-E240

D. G. Tizzano

1 999	1 999	1 999	2 096	3 001				
CONDUIT FLOW MGD	PH (MAX) S.U.	PH (MIN) S.U.	RESIDU TOT NF MG/L	OIL GR TOTAL MG/L				
50050	00401	00402	00530	00550				
01 AH	AH	AH						
02 AH	AH	AH						
03 AH	AH	AH						
04 AH	AH	AH						
05 .016	7.6	7.6	13	AA				
06 AH	AH	AH						
07 AH	AH	AH						
08 AH	AH	AH						
09 AH	AH	AH						
10 .016	7.5	7.4	10	AA				
11 AH	AH	AH						
12 AH	AH	AH						
13 AH	AH	AH						
14 AH	AH	AH						
15 AH	AH	AH						
16 AH	AH	AH						
17 AH	AH	AH						
18 .013	8.6	8.0	14	AA				
19 AH	AH	AH						
20 AH	AH	AH						
21 AH	AH	AH						
22 AH	AH	AH						
23 AH	AH	AH						
24 .016	7.6	7.4	17	AA				
25 AH	AH	AH						
26 .018	7.9	7.6						
27 AH	AH	AH						
28 AH	AH	AH						
29 .014	7.3	7.3						
30 AH	AH	AH						
31 AH	AH	AH						
0.0930	46.500	45.300	54.000	AA				
0.0155	7.7500	7.5500	13.500	AA				
0.0180	8.6000	8.0000	17.000	AA				
0.0130	7.3000	7.3000	10.000	AA				

AA-BELOW DETECTABLE LIMIT (5MG/L FOR O&G, 2.5 MG/L FOR RESID)
 AH-SAMPLE NOT TAKEN. NO DISCHARGE PERFORMED THIS DATE.
 31B00016001 IS 31B0016601. MORMENU SOFTWARE TO BE CHANGED

REPORTER

4-11-97

Worley for VP-Nuclear

