

Commonwealth Edison Company
Quad Cities Generating Station
22710 206th Avenue North
Cordova, IL 61242-9740
Tel 309-654-2241

ComEd

LWP-97-044

April 29, 1997

United States Nuclear Regulatory Commission
Washington, DC 20555

Attention: Document Control Desk

Reference: Quad Cities Nuclear Power Station
Docket Number 50-254, DPR-29, Unit One

Enclosed is Licensee Event Report (LER) 97-008, Revision 00, for Quad Cities Nuclear Power Station.

This report is submitted in accordance with the requirements of the Code of Federal Regulations, Title 10, Part 50.73(a)(2)(v)(D). The licensee shall report any event or condition that alone could have prevented the fulfillment of the safety function of structures or systems that are needed to mitigate the consequences of an accident.

The following commitments are being made by this letter:

1. Revise QCOP 2300-13 to include steps to fully disengage the turning gear if necessary for testing purposes. This will be completed by 060197.
2. System Engineer to review with General Electric available information on this type of turning gear to ensure that correct repair instructions are included in the vendor manual and are available for future repairs. This will be completed by 090197.

9705070294 970429
PDR ADOCK 05000254
S PDR



STMGR\04497.LWP

A Unicom Company


IR22/1

April 29, 1997

If there are any questions or comments concerning this letter, please refer them to Charles Peterson, Regulatory Affairs Manager at 309-654-2241, ext. 3609.

Respectfully,

COMMONWEALTH EDISON COMPANY
QUAD CITIES NUCLEAR POWER STATION



L. W. Pearce
Station Manager

LWP/CP/plm
Enclosure

cc: A. B. Beach, Regional Administrator, Region III
R. M. Pulsifer, Project Manager, NRR
C. G. Miller, Senior Resident Inspector, Quad Cities
W. D. Leech, MidAmerican Energy Company
D. C. Tubbs, MidAmerican Energy Company
P. L. Piet, Licensing, ComEd
F. A. Spangenberg, Regulatory Affairs Manager, Dresden
INPO Records Center