

December 17, 1985

Dockets Nos. 50-313
50-368

DISTRIBUTION

Docket File

NRC PDR
L PDR
PBD-6 Rdg
FMiraglia
OELD
EJordan
BGrimes
JPartlow
GVissing

RLee
GKnighton
RIngram
ACRS-10
Gray File
EBrach
Hornstein

Mr. John M. Griffin
Senior Vice President
of Energy Supply
Arkansas Power and Light Company
P. O. Box 551
Little Rock, Arkansas 72203

Dear Mr. Griffin:

We have completed our review of your responses to Item 4.2.1 and 4.2.2 of Generic Letter 83-28 for Arkansas Nuclear One, Units 1 & 2. Our Safety Evaluation is enclosed. We have determined that your position on these issues is acceptable provided you confirm that the Undervoltage Trip Device (UVT) roller rivet-armature clearance is measured with the UVT armature down in the energized position, as recommended in IE Notice No. 85-58. We request you make this confirmation in writing within 30 days from receipt of this letter.

The reporting and/or recordkeeping requirements of this letter affect fewer than ten respondents; therefore, OMB clearance is not required under P.L. 96-511.

*ORIGINAL SIGNED BY
JOHN F. STOLZ*

John F. Stolz, Director
PWR Project Directorate #6
Division of PWR Licensing-B

Original signed by

George W. Knighton, Director
PWR Project Directorate #7
Division of PWR Licensing-B

Enclosure:
Safety Evaluation

cc w/enclosure:
see next page

*See previous white for concurrences:

PBD-6	PBD-7	PBD-6
GVissing;cr*	RLee*	CMcCracken*
12/6/85	12/6/85	12/9/85

PBD-6
JStolz
12/12/85

PBD-7
GKnighton
12/13/85

Dockets Nos. 50-313
50-368

Mr. John M. Griffin
Senior Vice President
of Energy Supply
Arkansas Power and Light Company
P. O. Box 551
Little Rock, Arkansas 72203

DISTRIBUTION

Docket File	RLee
NRC PDR	GKnighton
L PDR	RIngram
PBD-6 Rdg	ACRS-10
FMiraglia	Gray File
OELD	EBrach
EJordan	Hornstein
BGrimes	
JPartlow	
GVising	

Dear Mr. Griffin:

We have completed our review of your responses to Item 4.2.1 and 4.2.2 of Generic Letter 83-28 for Arkansas Nuclear One, Units 1 & 2. Our Safety Evaluation is enclosed. We have determined that your position on these issues are acceptable provided you confirm that the Undervoltage Trip Device (UVT) roller armature clearance is measured with the UVT armature down in the energized position, as recommended in IE Notice No. 85-58. We request you make this confirmation in writing within 30 days from receipt of this letter.

The reporting and/or recordkeeping requirements of this letter affect fewer than ten respondents; therefore, OMB clearance is not required under P.L. 96-511.

John F. Stolz, Director
PWR Project Directorate #6
Division of PWR Licensing-B

George W. Knighton, Director
PWR Project Directorate #7
Division of PWR Licensing-B

Enclosure:
Safety Evaluation

cc w/enclosure:
See next page

PBD-8
GV [signature]; cr
12/1/85

PBD-7
RLee [signature]
12/6/85

C.A.
PBD-6
CMcCracken
12/9/85

PBD-6
JStolz
12/ /85

PBD-6
GKnighton
12/ /85

Mr. J. M. Griffin
Arkansas Power & Light Company

Arkansas Nuclear One, Unit 1

cc:
Mr. J. Ted Enos, Manager
Licensing
Arkansas Power & Light Company
P. O. Box 551
Little Rock, Arkansas 72203

Mr. James M. Levine, General Manager
Arkansas Nuclear One
P. O. Box 608
Russellville, Arkansas 72801

Mr. Nicholas S. Reynolds
Bishop, Liberman, Cook, Purcell & Reynolds
1200 Seventeenth Street, NW
Washington, D.C. 20036

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
Suite 220, 7910 Woodmont Avenue
Bethesda, Maryland 20814

Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 2090
Russellville, Arkansas 72801

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
Office of Executive Director
for Operations
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Mr. Frank Wilson, Director
Division of Environmental Health
Protection
Department of Health
Arkansas Department of Health
4815 West Markham Street
Little Rock, Arkansas 72201

Honorable Ermil Grant
Acting County Judge of Pope County
Pope County Courthouse
Russellville, Arkansas 72801