



LWP-97-038

April 15, 1997

United States Nuclear Regulatory Commission  
Washington, DC 20555

Attention: Document Control Desk

Reference: Quad Cities Nuclear Power Station  
Docket Number 50-254, DPR-29, Unit One

Enclosed is Licensee Event Report (LER) 97-005, Revision 00, for Quad Cities Nuclear Power Station.

This report is submitted in accordance with the requirements of the Code of Federal Regulations, Title 10, Part 50.73(a)(2)(v)(D). The licensee shall report any event or condition that alone could have prevented the fulfillment of the safety function of structures or systems that are needed to mitigate the consequences of an accident.

The following commitments are being made by this letter:


1. Update the plant design documents to reflect the status of this abandoned cable. This will be completed by 080197.
2. Label this cable as abandoned at all accessible locations along its route. This will be completed by 081597.
3. QCAP 0460-06, Abandoned Equipment Procedure, will be reviewed to ensure that the proper requirements are in place to ensure drawing updates, cable numbering updates and labeling of abandoned cables. This will be completed by 080197.

If there are any questions or comments concerning this letter, please refer them to Charles Peterson, Regulatory Affairs Manager at 309-654-2241, ext. 3609.

9704220062 970415  
PDR ADOCK 05000254  
S PDR

220020


IE221



April 15, 1997

Respectfully,

COMMONWEALTH EDISON COMPANY  
QUAD CITIES NUCLEAR POWER STATION



L. W. Pearce  
Station Manager

LWP/CP/plm

Enclosure

cc: A. B. Beach, Regional Administrator, Region III  
R. M. Pulsifer, Project Manager, NRR  
C. G. Miller, Senior Resident Inspector, Quad Cities  
W. D. Leech, MidAmerican Energy Company  
D. C. Tubbs, MidAmerican Energy Company  
P. L. Piet, Licensing, ComEd  
F. A. Spangenberg, Regulatory Affairs Manager, Dresden  
INPO Records Center