VERMONT YANKEE NUCLEAR POWER CORPORATION



.

P.O. Box 157, Governor Hunt Road Vernon, Vermont 05354-0157 (802) 257-7711

> June, 10 1997 BVY-97-074

United States Nuclear Regulatory Commission ATTN: Document Control Desk Washington, D.C. 20555

Reference: (a) License No. DPR-28 (Docket No. 50-271)

In accordance with section 6.7.A.3 of the Vermont Yankee Technical Specifications, submitted herewith is the Monthly Statistical Report for the Vermont Yankee Nuclear Power Station for the month of May, 1997.

Sincerely,

VERMONT YANKEE NUCLEAR POWER CORPORATION Gregory A. Maret Plant Manager

224

cc: USNRC Region I Administrator USNRC Resident Inspector - VYNPS USNRC Project Manager - VYNPS

> 9706180171 970531 PDR ADOCK 03000271 R PDR

VERMONT YANKEE NUCLEAR POWER STATION

MONTHLY STATISTICAL REPORT 97-05

FOR THE MONTH OF MAY 1997

DP 0411 Rev. 6 Page 1 of 1

OPERATING DATA REPORT

DOCKET NO.<u>50-271</u> DATE <u>970610</u> COMPLETED BY <u>G.A. WALLIN</u> TELEPHONE (802)258-5414

| 12 | 10 | 121 | TO 3 | n. 1 | 71 | ÷. | 6.7 | 101 | (3) | CP1 | 75.1 | TTT | 707 |
|----|----|-----|-----------------------|------|----|----|-----|-----|-----|-----|------|-----|-----|
| 9 | Ľ. | Γ. | \mathbb{K}^{\prime} | ÷. | Ε. | à. | DI. | G | 122 | 1. | Α. | 11 | 10 |

- 1. Unit Name: Vermont Yankee
- 2. Reporting Period: May

3. Licensed Thermal Power(MWt): 1593

4. Nameplate Rating (Gross MWe): 540

5. Design Electrical Rating (Net MWe): 522

6. Maximum Dependable Capacity(Gross MWe): 535

7. Maximum Dependable Capacity(Net MWe): 510

 If changes, occur in capacity ratings(Items Number 3 through 7) since last report, give reasons:

9. Power level to which restricted, if any (Net MWe) : _ N/A

10. Reasons for restrictions, if any: N/A

| | | This Month | Yr-to-Date | Cumulative |
|-----|--|---------------|--------------|--------------|
| 11. | Hours in Reporting Period | 744.00 | 3623.00 | 214751.00 |
| 12. | Number Of Hours Reactor was Critical | 597.37 | 3317.54 | 178284.20 |
| 13. | Reactor Reserve Shutdown Hours | 0.00 | 0.00 | 0.00 |
| 14. | Hours Generator On-Line | 565.87 | 3286.04 | 174959.94 |
| 15. | Unit Reserve Shutdown Hours | 0.00 | (.00 | 0.00 |
| 16. | Gross Thermal Energy Generated (MWH) | 889693.40 | 5213848.80 | 262860982.20 |
| 17. | Gross Electrical Energy Generated | 304949.00 | 1797381.00 | 87848803.00 |
| 18. | Net Electrical Energy Generated (MWH) | 292454.00 | 1728035.00 | 83543924.00 |
| 19. | Unit Service Factor | 76.00 | 90.70 | 80.80 |
| 20. | Unit Availability Factor | 76.00 | 90.70 | 80.80 |
| 21. | Unit Capacity Factor (Using MDC Net) | | | 76.50 |
| 22. | Unit Capacity Factor (Using DER Net) | 75.30 | 91.40 | 75.00 |
| 23. | Unit Forced Outage Rate | 20.58 | 7.10 | 4.65 |
| 24. | Shutdowns scheduled over next 6 month Each: N/A | hs(Type, Date | e, and Durat | ion of |

25. If shut down at end of report period, estimated date of startup: N/A 26. Units In Test Status(prior to commercial operation): N/A Forecast Achieved

> INITIAL CRITICALITY INITIAL ELECTRICITY COMMERCIAL OPERATION

VYDPF 0411.01 DP 0411 Rev. 6 Page 1 of 1 RT No. 13.F01.19F

AVERAGE DAILY UNIT POWER LEVEL

| DOCKET NO. | 50-271 |
|-------------|----------------|
| UNIT | Vermont Yankee |
| DATE | 970610 |
| OMPLETED BY | G.A. WALLIN |
| TELEPHONE | (802)258-5414 |

C

| MONTH | May | | |
|-------|--|-----|-------------------------------------|
| DAY | AVERAGE DAILY POWER LEVEL (MWe-Net) | DAY | AVERAGE DAILY POWER LEVEL (MWe-Net) |
| 1. | 0 | 17. | 524 |
| 2. | 0 | 18. | 526 |
| з. | 0 | 19. | 527 |
| 4. | 0 | 20. | 527 |
| 5. | 0 | 21. | 527 |
| 6. | 0 | 22. | 526 |
| 7. | 0 | 23. | 522 |
| 8. | 142 | 24. | 526 |
| 9. | 491 | 25. | 527 |
| 10. | 515 | 26. | 526 |
| 11. | 528 | 27. | 52 |
| 12. | 518 | 28. | 524 |
| 13. | 528 | 29. | 524 |
| 14. | 528 | 30. | 524 |
| 15. | 527 | 31. | 526 |
| 16. | 527 | | |

INSTRUCTIONS:

On this format, list the average daily unit power level in MWE-Net for each day in the reporting month. Compute to the nearest whole megawatt.

VYDPF 0411.02 DP 0411 Rev. 6 Page 1 of 1 RT No. 13.F01.18V

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH MAY

DOCKET NO 50-271 UNIT NAME Vermont Yankee DATE 970610 COMPLETED BY G.A. Wallin TELEPHONE (802)258-5414

| No. | Date | 1 Type | Duration (hours) | 2 Reason | 3 Method of Shutting Down Reactor | License Event Report # | 4 System Code | 5 Component Code | Cause and Corrective Action to Prevent Recurrence |
|-----------------|--------|-----------|---------------------|-------------|---|------------------------------|---------------------|------------------------|---|
| 97-04 (cont) | 970501 | F | 146.63 | В | 3 | N/A | EB | TRANSF | Mini-Outage Repairs |
| 97-04 (cont) | 970501 | S | 31.50 | В | 3 | N/A | EB | TRANSF | Mini-Outage Repairs |

1 F: Forced 2 Reason: S: Scheduled A-Equipment Failure (Explain) B-Maintenance or Test C-Refueling D-Regulatory Restriction E-Operator Training and License Examination VYDPF 0411.03 F-Administrative DP 0411 Rev. 6 G-Operational Error (Explain)

H-Explain

Page 1 of 1

- 3 Method:
- 1 Manual
 - 2 Manual Scram

 - 4 Other (Explain)

4 Exhibit G- Instructions for Preparation of Data Entry Sheets for License 3 - Automatic Scram Event Report (LER) File (NUREG 0161)

5 Exhibit I - Same Source

| DOCKET NO. | 50-271 |
|--------------|---------------|
| DATE | 970610 |
| COMPLETED BY | G.A. WALLIN |
| TELEPHONE | (802)258-5414 |

REPORT MONTH May

SUMMARY OF OPERATING EXPERIENCES

Highlights

8 4 4 4

Verwont Yankee operated at 75.1% of rated thermal power for the month. Gross electrical generation was 304,949 MWHe or 75.1% design electrical capacity.

Operating Summary

The following is a chronological description of plant operations including other pertinent items of interest for the month:

At the beginning of the reporting period the plant was operating at 00.0% of rated thermal power.

- 970507 At 0238 hours, the reactor was critical following completion of the mini-outage. (See Unit Shutdowns and Power Reductions)
- 970508 At 1008 hours, the turbine-generator was phased to the grid, and a return to full power was initiated.
- 970516 At 0001 hours, began complying with stricter thermal discharge requirements as delineated by our NPDES permit. These requirements, based on upstream river temperature, define operation of the Circulation Water system in open, hybrid or closed cycle.

At the end of the reporting period the plant was operating at <u>99.9%</u> of rated thermal power.

VYDPF 0411.04 DP 0411 Rev. 6 Page 1 of 1 RT No. 13.F01.18X