

DOCKET
FILE
50-266



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

May 13, 1997

Mr. Richard R. Grigg
Chief Nuclear Officer
Wisconsin Electric Power Company
231 West Michigan Street, Room P379
Milwaukee, WI 53201

SUBJECT: COMPLETION OF LICENSING ACTION FOR GENERIC LETTER 95-03,
"CIRCUMFERENTIAL CRACKING OF STEAM GENERATOR TUBES," DATED APRIL 28,
1995, FOR POINT BEACH NUCLEAR PLANT, UNIT NOS. 1 AND 2
(TAC NOS. M92264 AND M92265)

Dear Mr. Grigg:

On April 28, 1995, the U.S. Nuclear Regulatory Commission (NRC) issued Generic Letter (GL) 95-03, "Circumferential Cracking of Steam Generator Tubes," to all holders of operating licenses or construction permits for pressurized-water reactors. The NRC issued GL 95-03 for three principal reasons:

- (1) Notify addressees about the safety significance of the recent steam generator tube inspection findings at Maine Yankee Atomic Power Station.
- (2) Request that all addressees implement the actions described within the generic letter.
- (3) Require that all addressees submit to the NRC a written response regarding implementation of the requested actions.

In addition, GL 95-03 alerted addressees to the importance of performing comprehensive examinations of steam generator tubes using techniques and equipment capable of reliably detecting the types of degradation to which the steam generator tubes may be susceptible. The staff also noted that the performance of steam generator tube examinations is controlled, in part, by Appendix B to Title 10, Part 50, of the *Code of Federal Regulations* (10 CFR Part 50).

In GL 95-03, the NRC staff also requested that licensees take the following actions:

- (1) Evaluate recent operating experience with respect to the detection and sizing of circumferential indications to determine the applicability to their plants.
- (2) On the basis of the evaluation in Item (1) above, as well as past inspection scope and results, susceptibility to circumferential cracking, threshold of detection, expected or inferred crack growth rates, and other relevant factors, develop a safety assessment justifying continued operation until the next scheduled steam generator tube inspections.

NRC FILE CENTER COPY

9705190269 970513
PDR ADOCK 05000266
P PDR

DV01
1/0

- (3) Develop plans for the next steam generator tube inspections as they pertain to the detection of circumferential cracking. The inspection plans should address, but not be limited to, scope (including sample expansion criteria, if applicable), methods, equipment, and criteria (including personnel training and qualification).

To document the outcome of these actions, the NRC staff requested that addressees prepare and submit the following:

- (1) A safety assessment justifying continued operation, predicated on the evaluation performed in accordance with requested actions 1 and 2 (above).
- (2) A summary of the inspection plans developed in accordance with requested action 3 (above) and a schedule for the next planned inspection.

In response to GL 95-03, you provided letters dated June 26, 1995, and October 6, 1995, for Point Beach Nuclear Plant. These submittals provided the information requested by GL 95-03; therefore TAC Nos. M92264 AND M92265 are closed. For your information, the staff's findings regarding this issue are contained in NUREG-1604, "Circumferential Cracking of Steam Generator Tubes."

If you have any questions regarding this matter, please contact Linda L. Gundrum at (301) 415-1380.

Sincerely,

ORIGINAL SIGNED BY
 Linda L. Gundrum, Project Manager
 Project Directorate III-1
 Division of Reactor Projects - III/IV
 Office of Nuclear Reactor Regulation

Docket Nos. 50-266
 and 50-301

cc: See next page

DISTRIBUTION:

- Docket File
- PUBLIC
- PDIII-1 Reading
- J. Roe
- C. Jamerson
- L. Gundrum
- K. Karwoski, EMCB
- S. Dembek, SPO-L
- OGC
- ACRS
- J. McCormick-Barger, RIII

DOCUMENT NAME: G:\WPDOCS\PTBEACH\PTB92264.LTR

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PM:PD31	E	LA:PD31	E	D:PD31	
NAME	L.Gundrum: <i>LLG</i>		C.Jamerson <i>CJ</i>		J.Hannon <i>JH</i>	
DATE	5/13/97		5/13/97		5/13/97	

OFFICIAL RECORD COPY

Mr. Richard R. Grigg
Wisconsin Electric Power Company

Point Beach Nuclear Plant
Unit Nos. 1 and 2

cc:

Ernest L. Blake, Jr.
Shaw, Pittman, Potts & Trowbridge
2300 N Street, N.W.
Washington, DC 20037

Mr. Scott A. Patulski
Vice President
Point Beach Nuclear Plant
Wisconsin Electric Power Company
6610 Nuclear Road
Two Rivers, Wisconsin 54241

Mr. Ken Duveneck
Town Chairman
Town of Two Creeks
13017 State Highway 42
Mishicot, Wisconsin 54228

Chairman
Public Service Commission
of Wisconsin
P.O. Box 7854
Madison, Wisconsin 53707-7854

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, Illinois 60532-4351

Resident Inspector's Office
U.S. Nuclear Regulatory Commission
6612 Nuclear Road
Two Rivers, Wisconsin 54241

Ms. Sarah Jenkins
Electric Division
Public Service Commission of Wisconsin
P.O. Box 7854
Madison, Wisconsin 53707-7854