

APR 2 1986

Docket No. 50-254  
Docket No. 50-265

Commonwealth Edison Company  
ATTN: Mr. Cordell Reed  
Vice President  
Post Office Box 767  
Chicago, IL 60690

Gentlemen:

Attached is an addendum consisting of a Confirmatory Measurement data sheet (Table III) for Inspection Reports No. 50-254/85023; 50-265/85026 transmitted by our letter dated August 14, 1985, and our letter dated January 7, 1986. Results show agreement for Fe-55. This closes out Open Items No. 50-254/85023-01; 50-265/85026-01.

Please attach this addendum to your copy of our inspection report.

We will gladly discuss any question you have concerning this addendum.

Sincerely,

*for W.D. Shafer*  
W. D. Shafer, Chief  
Emergency Preparedness and  
Radiological Protection Branch

Enclosure: As stated

cc w/enclosure:  
D. L. Farrar, Director  
of Nuclear Licensing  
N. Kalivianakis, Plant Manager  
DCS/RSB (RIDS)  
Licensing Fee Management Branch  
Resident Inspector, RIII  
Phyllis Dunton, Attorney  
General's Office, Environmental  
Control Division

JE06  
//

RIII  
*TTT*  
Oestmann/lt

RIII  
*RBH*  
Holtzman

RIII  
*SH*  
Schumacher

RIII  
*W*  
Wright

RIII  
*W*  
Shafer  
4/2/86

8604080272 860402  
PDR ADOCK 05000254  
G PDR

TABLE III

U S NUCLEAR REGULATORY COMMISSION  
 OFFICE OF INSPECTION AND ENFORCEMENT  
 CONFIRMATORY MEASUREMENTS PROGRAM  
 FACILITY: QUAD CITIES  
 FOR THE 1 QUARTER OF 1986

SAMPLE	ISOTOPE	-----NRC-----		----LICENSEE----		---LICENSEE:NRC----		
		RESULT	ERROR	RESULT	ERROR	RATIO	RES	T
L SPIKED	FE-55	6.7E-05	1.3E-06	5.7E-05	0.0E-01	8.6E-01	5.1E 01	A

T TEST RESULTS:  
 A=AGREEMENT  
 D=DISAGREEMENT  
 \*=CRITERIA RELAXED  
 N=NO COMPARISON

86011-30334