## Sargent & Lundy "

Don K. Schopfer Vice President 312-269-6078

> July 7, 1997 Project No. 9583-100

Document No. 50-423

Northeast Nuclear Energy Company Millstone Nuclear Power Station, Unit No. 3 Independent Corrective Action Verification Program

United States Nuclear Regulatory Commission Attention: Document Control Desk Washington, D.C. 20555

I have enclosed the following two (2) discrepancy reports (DRs) identified during our Programmatic Review activities for the ICAVP. These DRs are being distributed in accordance with the Communications Protocol, PI-MP3-01.

DR No. DR-MP3-0007 DR No. DR-MP3-0008

Please direct any questions to me at (312) 269-6078.

Yours very truly,

D. K. Schopfer

Vice President and ICAVP Manager

DKS:pah Enclosures Copies:

E. Imbro (1/1) Deputy Director, ICAVP Oversight T. Concannon (1/1) Nuclear Energy Advisory Council

J. Fougere (1/1) NU

9707100164 970707 PDR ADOCK 05000423 PDR

Northeast Utilities Millstone Unit 3

## ICAVP Discrepancy Report

DR No. DR-MP3-0007

Review Group: Programmatic DR VALID Review Element: Change Process Potential Operability Issue Discipline: Other Yes No. Discrepancy Type: Design Control Procedure Date FAXed to NU: System/Process: N/A Date Published: Discrepancy: Use of Unverified Information Description: We have reviewed Millstone Station Procedure DC 2, Rev. 1, Change 3 (effective 3/3/97), titled "Developing and Revising Millstone Procedures and Forms". Based on this review, we have noted the following discrepancy. When, while revising a procedure, reference information is not available. paragraph 1.2.8.b and Attachment 2 of DC 2 require the Procedure Writer to place an empty basis box in the appropriate location (of the procedure) with the following content: "Reference information not currently available." During the procedure verification and validation process, the Independent Reviewer, with the Department Head's concurrence, determines whether the document can be approved without verifying reference information. Thus, a procedure can be revised with unavailable reference information. There is no review by the PORC/SORC or a subcommittee to evaluate the risk of implementing the procedure with this missing information, and no requirement is imposed to try to recreate the reference material later. This is a discrepancy because unverified information could be used as the basis for a procedure. Review Valid Invalid Needed Date Initiator: Sheppard, R. P. 7/7/97 VT Lead: Ryan, Thomas J 7/7/97 VT Mgr: Schopfer, Don K 7/7/97 IRC Chmn: Singh, Anand K 7/7/97 Date: INVALID: Date: RESOLUTION: Review Accept Reject Needed Date Initiator: Sheppard, R. P. VT Lead: Ryan, Thomas J VT Mgr: Schopfer, Don K IRC Chrnn: Singh, Anand K Date: REJECTION:

Northeast Utilities Millstone Unit 3

## **ICAVP Discrepancy Report**

DR No. DR-MP3-0008

Review Group: Programmatic

Review Element: Change Process

Discipline: Other

Discrepancy Type: Design Control Procedure

System/Process: N/A

DR VALID

Potential Operability Issue

Yes Yes

No.

Date FAXed to NU: Date Published:

Discrepancy: Procedure Step Sequence

Description: We have reviewed Millstone Station Procedure DC 4, Rev. 3 (effective 1/17/97), titled "Procedural Compliance". Based on this review, we have noted the following discrepancy.

> Paragraph 1.4.1 of procedure DC 4 allows, for continuous or general level of use procedures, unless otherwise stated in the procedure, a First Line Supervisor or, in the case of operations procedures, the Shift Manager or Unit Supervisor to authorize deviation from the specified step sequence, as long as the intent of the procedure is neither changed nor compromised. This is not consistent with the standard industry approach for continuous use procedures, especially for operations procedures.

> Continuous level of use procedures as defined in Attachment 1 to DC 4 are procedures which "... require step-by-step use to prevent immediate effects on nuclear or personnel safety ...".

The continuous use procedure steps should be performed in the sequence stated in the procedure. See, for example, XVI.C.2.o of INPO Guideline 85-017, Rev. 2, titled "Guidelines for the Conduct of Operations at Nuclear Power Stations", which states in part: 'Training on this sequence, reinforced with procedures that show the same sequence, will serve to improve operator performance by development of patterns of action that are more easily remembered. If a procedure step must be performed out of the sequence specified, a procedure change should be completed prior to performing the step unless the procedure specifically states that the step may be performed in any order."

In addition, paragraph 5.2.3 of INPO Preliminary Good Practice OA-106 titled "Technical Procedure Use and Adherence", which is referenced in DC 4, states: "The policy (on procedure use and adherence) provides direction for performing some technical procedures in other than the normal step-bystep manner and identifies conditions requiring procedure changes. For example, procedures that allow limited portions to be performed or the sequence of steps to be changed will include specific instructions on the conditions under which this use is appropriate. Otherwise, procedure changes are required to be initiated and approved prior to performance of the limited portions of the procedure or changing the sequence of steps."

		Valid	Invalid	Review	Date
Initiator:	Sheppard, R. P.				7/7/97
VT Lead:	Ryan, Thomas J				7/7/97
VT Mgr:	Schopfer, Don K				7/7/97
IRC Chmn:	Singh, Anand K				7/7/97

Date:

INVALID:

Northeast Utilities Millstone Unit 3

## ICAVP Discrepancy Report

DR No. DR-MP3-0008

and opening the port								
Date: RESOLUTION:		manifest years and management for company to the company of the co			COMMUNICATION CONTINUES			
VT Lead: VT Mgr:	Sheppard, R. P. Ryan, Thomas J Schopfer, Don K Singh, Anand K	Accept	Reject	Review Needed	Date			
REJECTION:								