



Illinois Power Company  
Clinton Power Station  
P.O. Box 678  
Clinton, IL 61727  
Tel 217 935-6220  
Fax 217 935-4632

Wayne D. Romberg  
Assistant Vice President - Nuclear

U-602788  
2C.220

August 6, 1997

Docket No. 50-461

10CFR50.73

Document Control Desk  
Nuclear Regulatory Commission  
Washington, D.C. 20555

Subject: Clinton Power Station - Unit 1  
Licensee Event Report No. 97-006-01

Dear Madam or Sir:

Enclosed is Licensee Event Report (LER) No. 97-006-01: Lack of Coordination of 120 Volt Non-Safe Shutdown Circuit Breakers in Distribution Panels with Safe Shutdown Circuit Breakers Causes Plant to be Outside Its Design Basis. The enclosed report has been revised to include the cause of the event, corrective action, analysis of event, and a discussion of previous similar events. This report is being submitted in accordance with the requirements of 10CFR50.73.

Sincerely yours,

Wayne D. Romberg  
Assistant Vice President

MRS/krk

Enclosure

cc: NRC Clinton Licensing Project Manager  
NRC Resident Office, V-690  
Regional Administrator, Region III, USNRC  
Illinois Department of Nuclear Safety  
INPO Records Center

*JE221*



9708200083 970806  
PDR ADOCK 05000461  
S PDR