

Davis-Besse Nuclear Power Station
5501 North State Route 2
Oak Harbor, OH 43449-9760

NP-33-97-009-1

Docket No. 50-346

License No. NPF-3

July 24, 1997


United States Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Ladies and Gentlemen:

LER 97-009, Revision 1
Davis-Besse Nuclear Power Station, Unit No. 1
Date of Occurrence - March 31, 1997

Enclosed please find Revision 1 to Licensee Event Report 97-009, which is being submitted to provide a revised date of completion for the corrective action to implement a new functional test surveillance procedure for testing of essential electrical bus undervoltage relays. The changes are marked with a revision bar in the margin. Please destroy or mark superceded, the previous copies of the LER. This LER is being submitted in accordance with 10CFR50.73(a)(2)(i)(B).

Very truly yours,



James H. Lash
Plant Manager
Davis-Besse Nuclear Power Station

DLM/dlc


Enclosure

cc: Mr. A. B. Beach
Regional Administrator
USNRC Region III

Mr. Stan Stasek
DB-1 NRC Sr. Resident Inspector

Utility Radiological Safety Board

9708040035 970724
PDR ADOCK 05000346
S PDR



TE 22
||

010075